Rexroth IndraDrive Drive System

R911309636 Edition 04

Project Planning Manual



Title Rexroth IndraDrive

Drive System

Type of Documentation Project Planning Manual

Document Typecode DOK-INDRV*-SYSTEM*****-PR04-EN-P

Internal File Reference RS-133519800a6846ac00a015a26f840210-1-en-US-3

Record of Revision

Edition	Release Date	Notes
120-2400-B321-04/EN	2007/08	Changes: see chapter "Introducing the System" → "Documentation" → "About This Documentation" → "Changes in Comparison to Previous Edition"

Copyright © 2007 Bosch Rexroth AG

Copying this document, giving it to others and the use or communication of the contents thereof without express authority, are forbidden. Offenders are liable for the payment of damages. All rights are reserved in the event of the grant of a patent or the registration of a utility model or design (DIN 34-1).

Validity The specified data is for product description purposes only and may not be

deemed to be guaranteed unless expressly confirmed in the contract. All rights are reserved with respect to the content of this documentation and the availa-

bility of the product.

Published by Bosch Rexroth AG

Bgm.-Dr.-Nebel-Str. 2 ■ D-97816 Lohr a. Main

Telephone +49 (0)93 52/ 40-0 ■ Fax +49 (0)93 52/ 40-48 85

http://www.boschrexroth.com/

Dept. BRC/EDY1

Note This document has been printed on chlorine-free bleached paper.

						Page
1.8	Introducing the Sys	stem				1
1.1	System Platform	<i>V</i>	<u></u>		······································	1
1.2	Drive System Rexrot	h IndraDrive C -	Compact Conv	verters		
1.3	Drive System Rexrot	h IndraDrive M -	Modular Syste	em		3
1.4	Drive System Rexrot					
1.5	Combinations of Rex					
1.6	Basic Design of the I	Devices				8
1.6.1	_					
1.6.2	Power Section		<u></u>		To.,	ε
1.6.3	Control Section					g
1.7	Overview of Type Cu	irrents and Type	Performances			s
1.7.1						
1.7.2					''' ₁₂₂	
1.7.3	Supply Units and C	Converters				10
1.8	Overview of Function					
1.8.1					······································	
1.8.2	1000					
1.9	Documentation					
1.9.1						
1.9.2					- 1 ₁₂₀ .	
		•				
					The.	
1.9.3						
	W.Q.,					
2	Important Direction	o for Lloo				11 ¹¹ 15
2	•					
2.1	Appropriate Use					
2.1.1						
2.1.2						
2.2	Inappropriate Use					16
3	Safety Instructions	for Electric D	rives and Co	ontrols		17
3.1	Safety Instructions -	General Informa	tion			17
3.1.1	Using the Safety Ir	structions and P	assing them of	n to Others		17
3.1.2	How to Employ the	Safety Instruction	ons			17
3.1.3	Explanation of War	ning Symbols ar	nd Degrees of	Hazard Serious	ness	18
3.1.4	Hazards by Improp	er Use		<u> </u>		19
3.2	Instructions with Reg	ard to Specific D	angers			20
3.2.1	Protection Against	Contact with Ele	ctrical Parts ar	nd Housings	*1212.	20
3.2.2	Protection Against	Electric Shock b	y Protective Ex	xtra-Low Voltage	e	21
3.2.3						
3.2.4	Protection Against	Magnetic and El	ectromagnetic	Fields During C	peration and Mount	ing 24

					D
					Page
3.2.5	Protection Against Contac	t with Hot Parts		627	24
3.2.6	Protection During Handling	g and Mounting			24
3.2.7	Battery Safety				<u></u> 25
3.2.8	Protection Against Pressu	rized Systems			25
4 0 V	Brief Description, Usage.				27
4.1	General Information				
4.2	Applications of the Drive Sys				
4.3	Mains Transformers DST an				
4.4	Mains Filters HNF, HNK, NF				
4.5	Mains Chokes HNL01 and H				
5 4.6 ⊗	Supply Units HMV01 / HMV0				
4.7	Drive Controllers HMS01, H				
4.8	Control Sections CSH01, CS				
4.9	Drive Controllers HCS02				
4.10	Drive Controllers HCS03				
4.11	DC Bus Resistor Unit HLB0				
4.12	Braking Resistor HLR01				
4.13 S	DC Bus Capacitor Unit HLC				
4.14	Blower Unit HAB01				
4.15	Motor Filters HMF01				
4.16	Accessories HAS				
4.10 4.17	Housing HAC01 for Control				
4.17 4.18	Hall Sensor Box SHL01 (in F				
4.10	Tiali Selisoi Box Si ILOT (III i	-reparation)		-92/	32
- 89					
5	General Specifications of				
5.1	Certifications				
5.2	Transport and Storage				
5.2.1	Transport of the Compone				
5.2.2	Storage of the Component				
5.3	Installation Conditions				
5.3.1	Ambient and Operating Co				
5.3.2	Mounting Position				
5.3.3	Compatibility with Foreign				
5.4	Capacity Utilization				
5.5	High-Voltage Test				
5.6	Control Voltage Specification	n (24V Supply)			40
6 🔇	Project Planning of Contr	ol Voltage (24V Su	pply)		43
6.1	General Information				
6.2	Selection of 24V Supply				
6.2.1	General Information				
6.2.2	Electrical Requirements				
6.3	Installation of 24V Supply				
6.4	Looping Through the Contro				

		Page
7	Project Planning of Mains Connection	49
7.1	General Information	
7.2	Power Voltage Supply	49
7.3	Mains Types	51
7.3.1	TN-S Mains Type	51
7.3.2	TN-C Mains Type	52
7.3.3	IT Mains Type	52
7.3.4	TT System	54
7.3.5	Mains with Grounded Outer Conductor (Corner-Grounded Delta Mains)	54
7.4	Mains Short-Circuit Power and Mains Connected Load	55
7.4.1	General Information	55
7.4.2	Mains Short-Circuit Power	55
7.4.3	Mains Connected Load	57
7.5	Protection Systems at the Mains Connection	60
7.5.1	General Information	60
7.5.2	Protective Grounding	60
	General Information	60
	Fusing by Protective Grounding in TN-S Mains	61
	Fusing by Protective Grounding in TN-C Mains	62
	Fusing by Protective Grounding in IT Mains (Ungrounded Mains)	64
	Rating of Mains Circuit Breaker	65
7.5.3	Connecting Equipment Grounding Conductor	66
	General Information	66
	Equipment Grounding Connection Between the Components	66
	Connecting Equipment Grounding Conductor to Mains	66
7.5.4	Residual-Current-Operated Circuit Breakers (RCD, RCCB) as Additional Fusing	67
	General Information	67
	Cause of Leakage Currents	67
	Possibilities of Use	68
	Using Residual-Current-Operated Circuit Breakers at HCS Drive Controllers	69
	Using Residual-Current-Operated Circuit Breakers at HMV Supply Units	69
7.5.5	Insulation Monitoring Devices	
8	Configuration of the Drive System	71
8.1	General Information	
8.2	Kind of Supply for Power Sections	
8.2.1	General Information	
8.2.2	HMV Supply Units for HMS/HMD Power Sections	
0.2.2	Central Supply HMV	
	Parallel Operation HMV - Group Supply With DC Bus Connection HMV01, HMV02	
8.2.3	Converter HCS as Supply Unit for Power Sections	
0.2.3		
	General Information Central Supply - HCS Supply HCS or HMS/HMD Drive Controllers	
	Parallel Operation HCS - Group Supply With DC Bus Connection of the Groups	
8.2.4	Third-Party Supply Units for Power Sections	
0.2.4	General Information	
	General Inionnation	ರು

				Page
8.3	Mains Connection Supply U	nits and Converters		85
8.3.1				
8.3.2				
0.0.2		1.10		
		AV 1.1	700	
8.3.3		. (%)		
0.5.5				
			<i>\delta</i>	
8.4	Additional Components			
8.4.1				
0.4.1			700	
			sistors	
8.4.2	•	•		
0.4.2				
0.5				
8.5	Control Section and Firmwai			
8.5.1			C	
8.5.2	Required Equipment of Co	introl Sections With Op	tional Modules for Evaluati	ng Encoder Systems 103
8.6	Combination with Other Rex	roth Components		
8.6.1			nge Rexroth IndraControl V	
0.0.1				
8.6.2	20			
0.0.2	· · · · · · · · · · · · · · · · · · ·			
8.7	Connection Cables to Motor			
8.7.1				
8.7.2	Motor Cables	9		107
0.1.2			N.	
	.00			
	- 13	F)	Brake	
	•			
070				
8.7.3				
8.8	Using Rexroth IndraDyn Mot			
8.8.1	Rexroth IndraDyn H – Fran	neless Synchronous S	pindle Motors	109
9	Control Circuits for the M	ains Connection	····· ⁶ 8 _A	111
9.1	General Information	4	4, 4	111
9.2	Mains Contactor, Bb Contac	t,,,,,		111
9.3	Control Circuits for Mains Co	onnection of Rexroth Ir	ndraDrive C Drive Controlle	rs 115
9.3.1	General Information			115

V/XI

					Page
9.3.2	Control via Exter	rnal Maine Contactor -	HCS03 and HCS03		47.7
J.J.Z					
				ated 24V Control Voltag	
	Boolgirioi ilo	302 dila 110000 Billy	Controller with integre	atou 217 Control Voltag	116
	Design for HC	S02 and HCS03 Drive	Controllers with Integra	ated 24V Control Voltag	ge Supply and
9.3.3				it HLB01.1C or HLB01.	
9.4				Supply Units	
9.4.1					
9.4.2					
9.4.3				rive (DC Bus Short Circ	120
9.4.4	Deceleration in t	he Case of Emergency	Stop or Mains Failure		128
				ol Unit" Without DC Bus	
	100				
		- 500	659	rt Circuit (ZKS)	
9.4.5		. ()		DFF	
	.(4)				
	Switching Off				135
10	Electromagnetic	Compatibility (EMC	;)		137
10.1	EMC Requirement	ts			137
10.1.1	General Informa	tion			137
10.1.2	Noise Immunity	in the Drive System			137
	Basic Structure	e for Noise Immunity			137
	Noise Immunit	y Limit Values			138
10.1.3					
	Causes of Noi	se Emission			138
	Limit Values for	or Line-Based Disturbar	nces		139
10.2	Ensuring the EMC	Requirements			141
10.3	Measures to Redu	ce Noise Emission			143
10.3.1	General Informa	tion			143
10.3.2	Shielding				143
10.3.3	Grounding				143
10.3.4	Filtering				143
11	Arranging the Co	mponents in the C	ontrol Cabinet		145
11.1					
11.1.1				40.	
		•			
11.1.2	2-7/-				

General Information Distance Between the Devices Distance to the Bottom of the Devices Distance to the Top of the Devices	146
Distance Between the Devices. Distance to the Bottom of the Devices.	146
Distance to the Bottom of the Devices.	
Distance to the Top of the Devices	
Lateral Distance at Drive System	
11.1.3 Boring Dimensions for the Mounting Plate	
Individually Arranged Devices	
Combination of Devices of the Rexroth IndraDrive M Product Range	
Combination of Drive Controllers of the Rexroth IndraDrive C Product Range	
Combination of Drive Controllers of the Rexroth IndraDrive C Product Range Combination of Drive Controllers of the Rexroth IndraDrive C and IndraDrive M Product Range	
Combination of Drive Controllers of the Reviour Indiablive C and Indiablive W Frodu	156
11.2 Arranging Components From Electrical Point of View	
11.2.1 General Information	
11.2.2 Performance-Dependent Arrangement	
11.2.3 EMC Measures for Design and Installation	
Rules for Design of Installations With Drive Controllers in Compliance with EMC	
11.2.4 EMC-Optimal Installation in Facility and Control Cabinet	
General Information	
Division Into Areas (Zones)	
Control Cabinet Mounting According to Interference Areas - Exemplary Arrangements	
Design and Installation in Area A - Interference-Free Area of Control Cabinet	
Design and Installation in Area B - Interference-Susceptible Area of Control Cabinet	
Design and Installation in Area C - Strongly Interference-Susceptible Area of Control C	
	à 166
11.2.5 Ground Connections	167
11.2.6 Installing Signal Lines and Signal Cables	168
11.2.7 General Measures of Radio Interference Suppression for Relays, Contactors, Switches,	Chokes, In-
ductive Loads	169
12 Control Cabinet Cooling	171
12.1 General Information	
12.2 Passive Control Cabinet Cooling	
12.2.1 Cooling via the Surface of the Control Cabinet	
12.3 Active Control Cabinet Cooling	
12.3.1 Ventilation of the Control Cabinet	
12.4 Arrangement of Cooling Units	
12.5 Multiple-Line Design of the Control Cabinet	
	2
42. Connections of the Common ante in the Drive Creaters	404
Connections of the Components in the Drive System	181
13.1 System Connections of the Components	
4014.4 O	181
13.1.1 General Information	
13.1.2 Position of System Connections	181
13.1.2 Position of System Connections	181 182
13.1.2 Position of System Connections	181 182

					Page
	Fauinment Gro	ounding Connections Be	tween Devices	Calify,	184
		Equipment Grounding S			
13.1.5		lains Choke and Mains F	•		
13.1.6		e DC Bus Connections			
,,00		nation			
		wed Line Length at DC E			
		uirements to the Connec			
	(4)	to the Left			
	_	to the Right			
13.1.7	\-	e Control Voltage Conne			
10.1.7		nation			
		to the Left			
	- C	to the Right			
13.1.8	.677	nection X1			
13.1.9		lotor to Drive Controller			
13.1.9		nation	•		
		ction with Accessory HAS			
		ction Without Accessory			
13.2		n Diagrams of the Syste			
13.2	Overall Confidence	II Diagrams of the System			200
	(190°)	(4 <u>0</u> 0	1/90,		(400)
14		ne Drive System Rex			
14.1		essories			
14.1.1	(O)				
14.1.2	10-2	1			
14.1.3					
14.1.4	7)				
14.1.5	Scope of Supply	·			203
14.1.6	10), "	irts "Bar" and "End Piece			
14.2		nnection			
14.2.1	General Informa	tion			228
14.2.2	Type Code				229
14.2.3	Usage				229
14.2.4	Assignment of A	ccessory HAS02			229
14.2.5	Scope of Supply	/			230
14.2.6	Mounting the Ac	cessory HAS02			245
		nation			
	HAS02.1-001	at HMS01.1N-W0054			246
	HAS02.1-002	at HCS02.1E-W0054			247
	HAS02.1-003	at HMS01.1N-W0210			248
	HAS02.1-004	at HCS03.1E-W0070			249
	HAS02.1-005	at HCS03.1E-W0100 / 1	50		250
	HAS02.1-008	at HCS03.1E-W0210	''''''	- 1 ₂₁	251
		at HMS02.1N-W0028 / 5			
	HAS02.1-014	at HMS01.1N-W0350			252
14.2.7	Shield Connection	on of the Motor Cable via	a Mains Filter	16.	252
	General Inform	nation			252

				Page
	HAS02.1-006 With Motor Cable and	Mains Filter		253
	HAS02.1-007 With Power Supply Ca			
	HAS02.1-009 With Power Supply Ca			
14.3	HAS03 - Control Cabinet Adapter			
14.3.1	Type Code			
14.3.2	Usage			
14.3.3	Assignment HAS03 Accessories			
14.3.4	Scope of Supply			
14.4	Capacitor HAS04			
14.4.1	General Information			
14.4.2	Type Code			
14.4.3	Usage			
14.4.4	Assignment			
14.4.5	Scope of Supply	······································		261
14.4.6	Capacitor			
14.4.7	Mounting Dimensions			
14.4.8	Mounting the HAS04.1-001 Accessorie	es		265
14.4.9	Mounting the HAS04.1-002 Accessorie			
14.5	Accessories HAS05			268
14.5.1	Overview of Types) ·	2,	268
14.5.2	Type Code	70.	70.	269
14.5.3	HAS05.1-001, Adapter for Mains and	Motor Connection		270
	Brief Description and Usage			270
	Technical Data			271
14.5.4	HAS05.1-002, Extension			272
	Brief Description and Usage	.00		272
14.5.5	HAS05.1-003, Signal Level Converter	Encoder Emulation	2	273
	Usage			273
	Scope of Supply			273
	Dimensions			273
	Parts			274
14.5.6	HAS05.1-004, Adapter DC Bus Conne	ction (Preliminary)		276
	Brief Description and Usage			276
	Technical Data		······································	280
	How to Mount HAS05.1-004			281
14.5.7	HAS05.1-005, Signal Level Converter	RS232/RS485 (Prelim	inary)	285
	Usage			285
	Scope of Supply			285
	Technical Data			286
	Installation	<u>;0``</u>	30	288
14.5.8	HAS05.1-006, Adapter for Controlling	Motor Holding Brake (F	Preliminary)	290
	Usage			290
	Technical Data			
	Usage			
	Mounting			
14.5.9	HAS05.1-007, Adapter From D-Sub to	Terminal Connector (F	Preliminary)	295

		Page
	Usage	295
	Technical Data	
14.5.10		
	Usage	
	Mounting	
14.6	Fiber Optic Cable Connections	
14.6.1	Overview of Types	
14.6.2	Interconnection of Drive Controllers	
	General Information	306
	Combination of HCS02 and HCS02	306
	Combination of HCS02 to the Right of HMS or HMD	307
	Combination of HCS02 to the Left of HMS or HMD	
	Combination of HCS03 to the Right of HMS or HMD	308
	Combination of HCS03 to the Left of HMS or HMD	
14.7	RKB0001, Extension for Module Bus Connections	
14.7.1	Usage	309
14.7.2	Mounting	
	The The Sales of t	
15	Third-Party Motors at IndraDrive Controllers	317
15.1	General Information on Third-Party Motors	
15.1.1	Why Use Third-Party Motors at IndraDrive?	
15.1.2	Which are the Important Directives?	
15.1.2	Third-Party Motors to be Controlled	
15.1.5	Requirements on Third-Party Motors	
15.2.1	General Information	
15.2.2	Voltage Load of the Third-Party Motor	
15.2.3	Minimum Inductance of Third-Party Motor	
15.2.4	Temperature Evaluation of Third-Party Motor	
15.3	Requirements on the Encoder of the Third-Party Motor	
15.3.1	Motor Encoder of Asynchronous Third-Party Motor	
15.3.2	Motor Encoder of Synchronous Third-Party Motor	
15.3.3	Motor Encoder Resolver - Notes on Selection	
15.4	Notes on Selection and Commissioning	
15.4.1	Selecting the Controller as Regards Continuous Current	
15.4.2	Selecting the Connection Technique	
15.4.3	Notes on Commissioning	
A	à à à	
16	Calculations	319
16		
16.1	Determining the Appropriate Drive Controller	
16.1.1	Introduction	
16.1.2	DC Bus Peak PowerDC Bus Peak Power	
16.1.3 16.1.4	Regenerative Power	
16.1.4		
16.1.5	Reduction of Generated Power Dissipation - Additional External Capacitors at DC Bus	324 326

				Page
16.1.7	Peak Regenerative P	ower		329
16.1.8				329
16.2	Calculations for the Ma	ins Connection	<u> </u>	330
16.2.1	Calculating the Mains	s-Side Phase Current		
16.2.2	Calculating the Inrush	n Current		331
16.2.3	Mains Contactor and	Fusing		332
16.2.4	Calculations for the M	lains Harmonics		332
	Harmonic Load TH	D		332
	Harmonic Content /	Distortion Factor k		332
	Power Factor cosφ	1 or DPF for Calculating th	ne Wattless Power Load	of the Mains 332
	Power Factor cosq	or TPF (λ)		333
16.2.5	Mains Voltage Unbala	ance		333
16.2.6	Calculating the Allow	ed Continuous Power in th	e Common DC Bus	333
16.3	Determining Componer	nts in the Mains Connectio	n	334
16.3.1	Determining Mains C	hoke HNL		334
16.3.2	Determining Mains Fi	Iter HNF		
16.3.3	Determining the Leak	age Capacitance	<u> </u>	335
16.3.4	V.V	TO		336
	V0 - V0			re Rise Due to Harmonics
				336
		-64		337
16.4				338
16.4.1	Charging the DC Bus			338
17	Appendix	<u> </u>		341
17.1	System Elements - Pro	duct Overview, Short Desi	gnations	341
17.2	Capacitances Against (Ground		342
17.2.1	General Information			342
17.2.2	Capacitance Data for	Motors		342
17.2.3				344
17.3	Emitted Harmonics on	Mains Current and Mains \	Voltage	344
17.3.1	General Information			344
17.3.2	Harmonics of Mains (Current		345
17.3.3	Harmonics on Mains	Voltage		349
17.4	Voltage Pulse for Test	According to EN61000		349
17.5	Discharging of Capacite	ors		351
17.5.1	Discharging of DC Bu	ıs Capacitors	ų	351
17.5.2	Discharging Device	(O)		351
18	Disposal and Enviror	nmental Protection		353
18.1	-			353
18.1.1	College Colleg			353
18.1.2	Packaging Materials.			353
18.2	, ,			353
18.2.1	No Release of Hazar	dous Substances		353

					Page
18.2.2					
	Electronic Devices				353
	Motors				353
18.2.3	Recycling				354
	#Office,				
19	Service and Support.	,55			355
19.1	Helpdesk				355
19.2	Service Hotline		144.	- 1 ₁₀ .	355
19.3	Internet				355
19.4	Helpful Information				355
	The state of the s				
	Index	76,	7/0,	770	357

1 Introducing the System

1.1 System Platform

The following products are part of the Rexroth IndraDrive system platform:

Control	sections	Power s	sections	Supply	HOL.	Additional compo- nents	Motors	Firmware
double-axis		double-axis	8	M.	>	HLC HLR		E. C.
single-axis/	single-axis	single-axis/	single-axis	7410		HLB		24/10
C*B	C*H	HM*	HC*	E 20	E/R	HNL	KSM	109/11
Basic	Advanced	modular	compact	HMV-E	HMV-R	HNF	MS*	M**

Fig.1-1: Rexroth IndraDrive system platform

Hierarchical Levels of Rexroth IndraDrive The assignment of the fundamental components to the hierarchical levels system platform, type, range, line and component is illustrated in the figure below.

System plat- form				Rexroth I	ndraDrive			
Туре	NO.	Rexroth Indr	aDrive powe	er sections	43.P	Rexroth Inc	IraDrive con	trol sections
Range	Rexroth Ir	ndraDrive C	Rex	xroth IndraDri	ve M	Bas	sic	Advanced
Line	HCS02	HCS03	HMV01 HMV02	HMS01 HMS02	HMD01	CSB	CDB	CSH
Component	W001270	W0070210	W0018	W0020	W0012	01, 02, 03, 04, 05	02, 03	01

Fig.1-2: Hierarchical levels Rexroth IndraDrive C and M

Component	different sizes, lengths and designs	KCU01.2N-SE-SE*-025-NN-S	different lengths and codings
Line	KSM01	KCU01	RKHxxxx
Range	Rexroth Inc	hybrid cable	
Туре	Rexroth IndraDrive distributed servo drives	Rexroth IndraDrive electronic control system	Rexroth cable
System plat- form	Rextotin indiaprive		NAMA CO,

Fig. 1-3: Hierarchical levels Rexroth IndraDrive Mi

Short Designations

For an overview of the short designations, such as HMV, HCS, CSH, KCU, see Appendix of this documentation, chapter 17.1 , System Elements - Product Overview, Short Designations, page 341.

1.2 Drive System Rexroth IndraDrive C - Compact Converters


Rexroth IndraDrive C is the form of compact converters of the Rexroth Indra-Drive product range.

Basic features of the product range Rexroth IndraDrive C:

integrated power supply

- integrated braking resistor (as an option, external for HCS03)
- integrated inverters
- integrated 24V control voltage supply (optional for HCS02)
- additional components:
 - DC bus resistor units
 - DC bus capacitor units
 - braking resistors

The figure below illustrates the system structure of the drive system Rexroth IndraDrive C. For the allowed combinations of components, see chapter "Configuration of the Drive System".



you can do without 24V power supply unit when using devices with integrated 24V power supply (HCS02.1E- or HCS03.1E-...-NNNV with control section CSB01.1N-FU)

Fig.1-4: Drive system Rexroth IndraDrive C



If you use an HNK mains filter at HCS03 devices, connect the mains contactor between mains supply and mains filter.

1.3 Drive System Rexroth IndraDrive M - Modular System


Rexroth IndraDrive M is the form of a modular system of the Rexroth IndraDrive product range.

The combination of an HMV supply unit and HMS and HMD drive controllers to form a modular drive system allows operating several motors.

Basic features of the product range Rexroth IndraDrive M:

- scaleable power supply
- integrated mains contactor (except for HMV01.1R-W0120)
- modular extension of number of axis is possible
- two lines (mounting depths) of HMV and HMS available
- additional components:
 - DC bus resistor units
 - DC bus capacitor units

The figure below illustrates the system structure of the drive system Rexroth IndraDrive M. For the allowed combinations of components, see chapter "Configuration of the Drive System".



external mains contactor K1 only required for HMV01.1R-W0120 optional mains choke (HNL) for HMV01.1E, required for HMV01.1R optional mains filter (HNF); depends on EMC requirements *Drive system Rexroth IndraDrive M (line 01)*

Fig.1-5:





Fig. 1-6: Drive system Rexroth IndraDrive M (line 02)

1.4 Drive System Rexroth IndraDrive Mi

The figure below illustrates the system structure of the drive system Rexroth IndraDrive Mi with HMV supply unit. For the allowed combinations of components, see chapter "Configuration of the Drive System".



external mains contactor K1 only required for HMV01.1R-W0120

Fig.1-7: System structure Rexroth IndraDrive Mi with HMV

The figure below illustrates the system structure of the drive system Rexroth IndraDrive Mi with supply by an HCS converter. For the allowed combinations of components, see chapter "Configuration of the Drive System".




Fig. 1-8: System structure Rexroth IndraDrive Mi with HCS

1.5 Combinations of Rexroth IndraDrive C With Rexroth IndraDrive M and Rexroth IndraDrive Mi

On the common platform Rexroth IndraDrive, it is possible to combine the components of the product ranges IndraDrive C, Rexroth IndraDrive M and Rexroth IndraDrive Mi to form drive systems of optimum costs and performance.


To supply the product range Rexroth IndraDrive Mi (KCU01 with KSM), you can use:

- modular HMV01 and HMV02 supply units
- HCS02 and HCS03 converters

For the allowed combinations of components, see chapter "Configuration of the Drive System".

1.6 Basic Design of the Devices

1.6.1 General Information



power sectioncontrol section

Fig. 1-9: Basic design of a drive controller

A drive controller consists of two essential parts:

- power section
- control section

1.6.2 Power Section

The power section incorporates the control section and has the following connections:

- mains voltage connection (at supply units and HCS devices)
- motor connection (with optional motor holding brake and motor temperature monitor)
- 24 V control voltage
- DC bus connection

- module bus connection for cross communication in the case of DC bus connection with other devices
- connection for external braking resistor (at HCS devices)

For detailed information on the power sections, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections".

1.6.3 Control Section

The control section is a separate component which is plugged into the power section. The control section consists of

- basic control section circuit board with interfaces
- optional modules (only for configurable control sections)

The drive controller is supplied complete with factory-installed (possibly configured) control section.



Only especially trained staff are allowed to replace control sections.

For detailed information on the control sections, see Project Planning Manual "Rexroth IndraDrive Drive Controllers Control Sections".

1.7 Overview of Type Currents and Type Performances

1.7.1 General Information

To allow you selecting appropriate drive controllers for a multitude of applications, the Rexroth IndraDrive product range includes a wide range of type currents and performances. The table below shows the fundamental data of drive controllers and supply units.

For detailed technical data, see Project Planning Manual "Rexroth Indra-Drive Supply Units and Power Sections".

1.7.2 Drive Controllers

The order of the following table lines conforms with the peak currents of the devices.

Compact converters	Modular inverters	Type current	Contin. current I _{out_cont_4k} [A] ¹⁾	Peak current I _{out_max_4k} [A] 1)	Nominal motor power [kW] ²⁾
HCS02	12	17.	4	12	1,5
9 -	HMD01	W0012	6,9	12	-
<u>-</u>	HMS01	1410000	12,1	20	-
- 10 ¹¹	HMD01	W0020	12,1	20	- 110
HCS02	- ,35°	M0000	11	28	4,0
Phylip.	HMS02	W0028	13	28	no.
-	HMS01	14/0000	21,3	36	-
*5, -	HMD01	W0036	20	36	-

ninal motor ver [kW] ²⁾
7,5
13. S
-
11
18,5
- 3
30
<u> -</u>
45
-
75
-
13.Z
1

- at fs = 4 kHz; without overload
- 1) 2) for standard motor 3 AC 400 V; use of mains choke HNL01; variable torque

Fig.1-10: Type current and type performances

1.7.3 **Supply Units and Converters**

The order of the following table lines conforms with the continuous power of the devices.

Compact convert- ers	Modular mains supply	Type current or power	Contin. power "ON" P _{DC_cont} [kW] ¹⁾	Peak power "ON" P _{DC_peak} [kW] ¹⁾	Contin. braking power [kW]	Max. braking power [kW]
HCS02	Wales.	E-W0028	4,2	10	0,15	10
HCS02	-	E-W0054	9,1	16	0,35	18
HCS02	- 7KB.	E-W0070	13,3	19	0,5	25
	HMV01	R-W0018	18	45	0,4	36
HCS03	17.517	E-W0070	25	40	opt.	opt.
<u>-</u>	HMV01	E-W0030	30	45	1,5	36
HCS03	-	E-W0100	43	59	opt.	opt.
HCS03	- 3	E-W0150	56	89	opt.	opt.
"ight	HMV02	R-W0015	15	37,5	0,3	33
Tigg	HMV01	R-W0045	45	112	0,4	90
<u> </u>	HMV01	R-W0065	65	162	0,4	130
-	HMV01	E-W0075	75	112	2	90
HCS03	-	E-W0210	85	124	opt.	opt.

Compact convert- ers	Modular mains supply	Type current or power	Contin. power "ON" P _{DC_cont} [kW] ¹⁾	Peak power "ON" P _{DC_peak} [kW] ¹⁾	Contin. braking power [kW]	Max. braking power [kW]
<u> 3</u>	HMV01	E-W0120	120	180	2,5	130
-	HMV01	R-W0120	120	180	0	0

opt. equipment to be optionally ordered

1) with use of mains choke HNL01; at 3 AC 400 V

Fig.1-11: Performance data of mains supply units

The data of peak power and continuous power show the maximum possible limit values.

For the actually available performance profiles, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective component → "Technical Data" → "Exemplary Data for Applications" → "Performance Profiles".

1.8 Overview of Functions

1.8.1 Supply Units and Power Sections

For an overview of the functions of supply units and power sections, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections"

"Functions and Electrical Connection Points"

"Overview of Functions, Power Sections and Supply Units".

1.8.2 Control Sections

For an overview of the functions of control sections, see Project Planning Manual "Rexroth IndraDrive Drive Controllers Control Sections" → "Rexroth IndraDrive Control Sections" → "Overview of Functions and Interfaces".

1.9 Documentation

1.9.1 About This Documentation



Personal injury and property damage caused by incorrect project planning for applications, machines and installations!

Observe the contents of the reference documentations relevant to your drive system (see chapter 1.9.2 Reference Documentations, page 12).

Purpose of Documentation

This documentation provides information on

- the drive system Rexroth IndraDrive
- the allowed combinations of Rexroth IndraDrive system components
- the selection of system components of the drive system Rexroth Indra-Drive
- the specification applying to all components (ambient and operating conditions)
- the application description of system characteristics

For detailed technical data of the individual components, see the respective Project Planning Manual. See chapter 1.9.2 Reference Documentations, page 12.

Changes in Comparison to Previous Edition

Chapter	Changes				
Introducing the System	drive system Rexroth IndraDrive Mi included				
Project Planning of Control Voltage	selection of 24V supply revised				
Configuration of the	configuration of drive system restructured				
Drive System	drive system Rexroth IndraDrive Mi included				
	operation of HMS02 at HCS02 included				
	requirements of third-party supply unit included				
	power supply for IndraDrive Mi (KCU01 and KSM) integrated				
	encoder systems ServoDyn D (SR, SF) included				
	assignment Hall sensor box to optional module encoder evaluation included				
Control Circuits for the Mains Connection	control circuits for mains connection expanded and restructured				
	use without mains contactor specified				
	HMV without integrated mains contactor included				
	control circuits with HLB adjusted				
	time behaviors when switching supply units ON and OFF included				
Arranging the Compo-	chapter "control cabinet mounting" revised				
nents in the Control Cab- inet	lateral minimum distances HCS02 corrected				
Control Cabinet Cooling	project planning of control cabinet cooling included				
Connections of the Components in the Drive	equipment grounding conductor design, cross section data and cross section reduction included				
System	fusing of branches included				
,or ⁰ 70	HMV example removed				
Accessories in the Drive	complete accessories included				
System	new: HAS05.1-004, -006, -007, -008				
Calculations	data for harmonics and power factors added				

Fig.1-12: Changes

1.9.2 Reference Documentations

Drive Systems, System Components

Title Rexroth IndraDrive	Kind of documentation	Document typecode ¹⁾ DOK-INDRV*	Part no. R911
Drive System	Project Planning Manual	SYSTEM****-PRxx-EN-P	309636
Mi Drive Systems	Project Planning Manual	KCU+KSM****-PRxx-EN-P	320924

Title	Kind of documentation	Document typecode ¹⁾	Part no. R911	
Supply Units and Power Sections	Project Planning Manual	DOK-INDRV* HMV-S-D+HCS-PRxx-EN-P	318790	
Drive Controllers Control Sections	Project Planning Manual	CSH******-PRxx-EN-P	295012	
Additional Components	Project Planning Manual	ADDCOMP****-PRxx-EN-P	306140	

1)

In the document typecodes, "xx" is a wild card for the current edition of the documentation (example: PR01 is the first edition of a Project Plan-

ng Manual)

Fig. 1-13: Documentations – drive systems, system components

Motors

Title Rexroth IndraDyn	Kind of documentation	Document typecode ¹⁾ DOK-MOTOR*	Part no. R911
A Series Asynchronous Motors MAD/ MAF	Project Planning Manual	MAD/MAF***-PRxx-EN-P	295781
H Frameless Synchronous Spindle Motors	Project Planning Manual	MBS-H*****-PRxx-EN-P	297895
L Synchronous Linear Motors	Project Planning Manual	MLF******-PRxx-EN-P	293635
S MSK Synchronous Motors	Project Planning Manual	MSK******-PRxx-EN-P	296289
T Synchronous Torque Motors	Project Planning Manual	MBT******-PRxx-EN-P	298798

1)

In the document typecodes, "xx" is a wild card for the current edition of the documentation (example: PR01 is the first edition of a Project Plan-

ning Manual)

Fig. 1-14: Documentations – motors

Cables

Title	Kind of documentation	Document typecode ¹⁾ DOK	Part no. R911
Rexroth Connection Cables	Selection Data	CONNEC-CABLE*STAND-AUxx- EN-P	282688

1)

In the document typecodes, "xx" is a wild card for the current edition of the documentation (example: AU03 is the third edition of the documen-

tation "Selection Data")

Fig. 1-15: Documentations – cables

Firmware

(0)		(8)	(0)	
Title	Kind of documentation	Document typecode ¹⁾	Part no.	
Rexroth IndraDrive		DOK-INDRV*	R911	
Firmware for Drive Controllers	Functional Description	MP*-02VRS**-FKxx-EN-P	299223	
Firmware for Drive Controllers	Functional Description	MP*-03VRS**-FKxx-EN-P	308329	
Firmware for Drive Controllers	Functional Description	MP*-04VRS**-FKxx-EN-P	315485	
Firmware for Drive Controllers	Parameter Description	GEN-**VRS**-PAxx-EN-P	297317	
Firmware for Drive Controllers	Troubleshooting Guide	GEN-**VRS**-WAxx-EN-P	297319	
Integrated Safety Technology	Functional and Application Description	SI*-**VRS**-FKxx-EN-P	297838	

Title Rexroth IndraDrive	Kind of documentation	Document typecode ¹⁾ DOK-INDRV*	Part no. R911
Rexroth IndraMotion MLD	Application Manual	MLD-**VRS**-AWxx-EN-P	306084
Rexroth IndraMotion MLD Library	Library Description	MLD-SYSLIB*-FKxx-EN-P	309224

In the document typecodes, "xx" is a wild card for the current edition of the documentation (example: PA02 is the second edition of a Parameter 1)

Description)

Fig. 1-16: Documentations - firmware

Your Feedback 1.9.3

图 Your experience is important for our improvement processes of products and documentations.

Inform us about mistakes you discovered in this documentation and changes you suggest; we would be grateful for your feedback.

Please send your remarks to:

Address for Your Feedback Bosch Rexroth AG

Dept. BRC/EDY1

Bürgermeister-Dr.-Nebel-Str. 2

D-97816 Lohr

e-mail: brcedy1-dokusupport-drives@boschrexroth.de

Important Directions for Use

2 Important Directions for Use

2.1 Appropriate Use

2.1.1 Introduction

Rexroth products represent state-of-the-art developments and manufacturing. They are tested prior to delivery to ensure operating safety and reliability.



Personal injury and property damage caused by incorrect use of the products!

The products have been designed for use in the industrial environment and may only be used in the appropriate way. If they are not used in the appropriate way, situations resulting in property damage and personal injury can occur.



Rexroth as manufacturer is not liable for any damages resulting from inappropriate use. In such cases, the guarantee and the right to payment of damages resulting from inappropriate use are forfeited. The user alone carries all responsibility of the risks.

Before using Rexroth products, make sure that all the pre-requisites for an appropriate use of the products are satisfied:

- Personnel that in any way, shape or form uses our products must first read and understand the relevant safety instructions and be familiar with appropriate use.
- If the products take the form of hardware, then they must remain in their original state, in other words, no structural changes are permitted. It is not permitted to decompile software products or alter source codes.
- Do not mount damaged or faulty products or use them in operation.
- Make sure that the products have been installed in the manner described in the relevant documentation.

2.1.2 Areas of Use and Application

Drive controllers made by Rexroth are designed to control electrical motors and monitor their operation.

Control and monitoring of the Drive controllers may require additional sensors and actors.



The drive controllers may only used with the accessories and parts specified in this documentation. If a component has not been specifically named, then it may neither be mounted nor connected. The same applies to cables and lines.

Operation is only permitted in the specified configurations and combinations of components using the software and firmware as specified in the relevant Functional Descriptions.

Drive controllers have to be programmed before commissioning, making it possible for the motor to execute the specific functions of an application.

Drive controllers of the Rexroth IndraDrive line have been developed for use in single- and multi-axis drive and control tasks.

To ensure application-specific use of Drive controllers, device types of different drive power and different interfaces are available.

Typical applications include:

Important Directions for Use

- handling and mounting systems,
- packaging and food machines,
- printing and paper processing machines and
- machine tools.

Drive controllers may only be operated under the assembly and installation conditions described in this documentation, in the specified position of normal use and under the ambient conditions as described (temperature, degree of protection, humidity, EMC, etc.).

2.2 Inappropriate Use

Using the Drive controllers outside of the operating conditions described in this documentation and outside of the indicated technical data and specifications is defined as "inappropriate use".

Drive controllers must not be used, if ...

- they are subject to operating conditions that do not meet the specified ambient conditions. This includes, for example, operation under water, under extreme temperature fluctuations or extremely high maximum temperatures.
- Furthermore, Drive controllers must not be used in applications which have not been expressly authorized by Rexroth. Please carefully follow the specifications outlined in the general Safety Instructions!

3 Safety Instructions for Electric Drives and Controls

3.1 Safety Instructions - General Information

3.1.1 Using the Safety Instructions and Passing them on to Others

Do not attempt to install or commission this device without first reading all documentation provided with the product. Read and understand these safety instructions and all user documentation prior to working with the device. If you do not have the user documentation for the device, contact your responsible Bosch Rexroth sales representative. Ask for these documents to be sent immediately to the person or persons responsible for the safe operation of the device.

If the device is resold, rented and/or passed on to others in any other form, these safety instructions must be delivered with the device in the official language of the user's country.



Improper use of these devices, failure to follow the safety instructions in this document or tampering with the product, including disabling of safety devices, may result in material damage, bodily harm, electric shock or even death!

Observe the safety instructions!

3.1.2 How to Employ the Safety Instructions

Read these instructions before initial commissioning of the equipment in order to eliminate the risk of bodily harm and/or material damage. Follow these safety instructions at all times.

- Bosch Rexroth AG is not liable for damages resulting from failure to observe the warnings provided in this documentation.
- Read the operating, maintenance and safety instructions in your language before commissioning the machine. If you find that you cannot completely understand the documentation for your product, please ask your supplier to clarify.
- Proper and correct transport, storage, assembly and installation, as well as care in operation and maintenance, are prerequisites for optimal and safe operation of this device.
- Only assign trained and qualified persons to work with electrical installations:
 - Only persons who are trained and qualified for the use and operation of the device may work on this device or within its proximity. The persons are qualified if they have sufficient knowledge of the assembly, installation and operation of the product, as well as an understanding of all warnings and precautionary measures noted in these instructions.
 - Furthermore, they must be trained, instructed and qualified to switch electrical circuits and devices on and off in accordance with technical safety regulations, to ground them and to mark them according to the requirements of safe work practices. They must have adequate safety equipment and be trained in first aid.
- Only use spare parts and accessories approved by the manufacturer.

- Follow all safety regulations and requirements for the specific application as practiced in the country of use.
- The devices have been designed for installation in industrial machinery.
- The ambient conditions given in the product documentation must be observed.
- Only use safety-relevant applications that are clearly and explicitly approved in the Project Planning Manual. If this is not the case, they are excluded. Safety-relevant are all such applications which can cause danger to persons and material damage.
- The information given in the documentation of the product with regard to the use of the delivered components contains only examples of applications and suggestions.

The machine and installation manufacturer must

- make sure that the delivered components are suited for his individual application and check the information given in this documentation with regard to the use of the components,
- make sure that his application complies with the applicable safety regulations and standards and carry out the required measures, modifications and complements.
- Commissioning of the delivered components is only permitted once it is sure that the machine or installation in which they are installed complies with the national regulations, safety specifications and standards of the application.
- Operation is only permitted if the national EMC regulations for the application are met.
- The instructions for installation in accordance with EMC requirements can be found in the section on EMC in the respective documentation (Project Planning Manuals of components and system).
 - The machine or installation manufacturer is responsible for compliance with the limiting values as prescribed in the national regulations.
- Technical data, connection and installation conditions are specified in the product documentation and must be followed at all times.

National regulations which the user must take into account

- European countries: according to European EN standards
- United States of America (USA):
 - National Electrical Code (NEC)
 - National Electrical Manufacturers Association (NEMA), as well as local engineering regulations
 - regulations of the National Fire Protection Association (NFPA)
- Canada: Canadian Standards Association (CSA)
- Other countries:
 - International Organization for Standardization (ISO)
 - International Electrotechnical Commission (IEC)

3.1.3 Explanation of Warning Symbols and Degrees of Hazard Seriousness

The safety instructions describe the following degrees of hazard seriousness. The degree of hazard seriousness informs about the consequences resulting from non-compliance with the safety instructions:

Warning symbol	Signal word	Degree of hazard serious- ness acc. to ANSI Z 535.4-2002		
	Danger	Death or severe bodily harm will occur.		
	Warning [r			
<u> </u>	Caution	Minor or moderate bodily harm or material damage may occur.		

Fig.3-1: Hazard classification (according to ANSI Z 535)

3.1.4 Hazar	ds by Improper Use					
		High electric voltage and high working current! Risk of death or bodily injury by electric shock!				
	Observe the sa	afety instructions!				
DANGER	16. The.	- Aron		»··		
*01/1/10	*OLU	*O(U)	*Ollio	70%		
W. P. California	Dangerous m damage by u	novements! Danger to nintentional motor mo	life, severe bodily evements!	harm or material		
	Observe the sa	afety instructions!				
DANGER	9	2		2		
A zadachi		voltage because of in	correct connection	! Risk of death or		
	Observe the sa	afety instructions!				
WARNING	14.	1/2	1,	- House		
A		d for persons with hea		etal implants and		
WARNING	Observe the sa	afety instructions!				
M	New Trans	V ₂	N.	No.		
. À A	Hot surfaces	on device housing! D	anger of injury! Da	nger of burns!		
N /!\	Observe the sa	afety instructions!				
CAUTION						
(3)	(1)	(4)	(10)	(4)		



Risk of injury by improper handling! Risk of bodily injury by bruising, shearing, cutting, hitting or improper handling of pressurized lines!

Observe the safety instructions!



Risk of injury by improper handling of batteries!

Observe the safety instructions!

3.2 Instructions with Regard to Specific Dangers

3.2.1 Protection Against Contact with Electrical Parts and Housings



This section concerns devices and drive components with voltages of more than 50 Volt.

Contact with parts conducting voltages above 50 Volts can cause personal danger and electric shock. When operating electrical equipment, it is unavoidable that some parts of the devices conduct dangerous voltage.



High electrical voltage! Danger to life, electric shock and severe bodily injury!

- Only those trained and qualified to work with or on electrical equipment are permitted to operate, maintain and repair this equipment.
- Follow general construction and safety regulations when working on power installations.
- Before switching on the device, the equipment grounding conductor must have been non-detachably connected to all electrical equipment in accordance with the connection diagram.
- Do not operate electrical equipment at any time, even for brief measurements or tests, if the equipment grounding conductor is not permanently connected to the mounting points of the components provided for this purpose.
- Before working with electrical parts with voltage potentials higher than 50 V, the device must be disconnected from the mains voltage or power supply unit. Provide a safeguard to prevent reconnection.
- With electrical drive and filter components, observe the following:
 - Wait **30 minutes** after switching off power to allow capacitors to discharge before beginning to work. Measure the electric voltage on the capacitors before beginning to work to make sure that the equipment is safe to touch.
- Never touch the electrical connection points of a component while power is turned on. Do not remove or plug in connectors when the component has been powered.
- Install the covers and guards provided with the equipment properly before switching the device on. Before switching the equipment on, cover and safeguard live parts safely to prevent contact with those parts.
- A residual-current-operated circuit-breaker or r.c.d. cannot be used for electric drives! Indirect contact must be prevented by other means, for example, by an overcurrent protective device according to the relevant standards.
- Secure built-in devices from direct touching of electrical parts by providing an external housing, for example a control cabinet.



For electrical drive and filter components with voltages of **more than 50 volts**, observe the following additional safety instructions.



High housing voltage and high leakage current! Risk of death or bodily injury by electric shock!

- Before switching on, the housings of all electrical equipment and motors must be connected or grounded with the equipment grounding conductor to the grounding points. This is also applicable before short tests.
- The equipment grounding conductor of the electrical equipment and the devices must be non-detachably and permanently connected to the power supply unit at all times. The leakage current is greater than 3.5 mA.
- Over the total length, use copper wire of a cross section of a minimum of 10 mm² for this equipment grounding connection!
- Before commissioning, also in trial runs, always attach the equipment grounding conductor or connect to the ground wire. Otherwise, high voltages may occur at the housing causing electric shock.

3.2.2 Protection Against Electric Shock by Protective Extra-Low Voltage

Protective extra-low voltage is used to allow connecting devices with basic insulation to extra-low voltage circuits.

All connections and terminals with voltages between 5 and 50 volts at Rexroth products are PELV systems. ¹⁾ It is therefore allowed to connect devices equipped with basic insulation (such as programming devices, PCs, notebooks, display units) to these connections and terminals.



High electric voltage by incorrect connection! Risk of death or bodily injury by electric shock!

If extra-low voltage circuits of devices containing voltages and circuits of more than 50 volts (e.g. the mains connection) are connected to Rexroth products, the connected extra-low voltage circuits must comply with the requirements for PELV. 2

3.2.3 Protection Against Dangerous Movements

Dangerous movements can be caused by faulty control of connected motors. Some common examples are:

- improper or wrong wiring of cable connections
- incorrect operation of the equipment components
- wrong input of parameters before operation
- malfunction of sensors, encoders and monitoring devices
- defective components
- software or firmware errors

Dangerous movements can occur immediately after equipment is switched on or even after an unspecified time of trouble-free operation.

- 1) "Protective Extra-Low Voltage"
- 2) "Protective Extra-Low Voltage"

22/363

Safety Instructions for Electric Drives and Controls

The monitoring in the drive components will normally be sufficient to avoid faulty operation in the connected drives. Regarding personal safety, especially the danger of bodily harm and material damage, this alone cannot be relied upon to ensure complete safety. Until the integrated monitoring functions become effective, it must be assumed in any case that faulty drive movements will occur. The extent of faulty drive movements depends upon the type of control and the state of operation.



Dangerous movements! Danger to life, risk of injury, severe bodily harm or material damage!

 Ensure personal safety by means of qualified and tested higher-level monitoring devices or measures integrated in the installation.

These measures have to be provided for by the user according to the specific conditions within the installation and a hazard and fault analysis. The safety regulations applicable for the installation have to be taken into consideration. Unintended machine motion or other malfunction is possible if safety devices are disabled, bypassed or not activated.

To avoid accidents, bodily harm and/or material damage:

- Keep free and clear of the machine's range of motion and moving parts.
 Possible measures to prevent people from accidentally entering the machine's range of motion:
 - use safety fences
 - use safety guards
 - use protective coverings
 - install light curtains or light barriers
- Fences and coverings must be strong enough to resist maximum possible momentum.
- Mount the emergency stop switch in the immediate reach of the operator.
 Verify that the emergency stop works before startup. Don't operate the device if the emergency stop is not working.
- Isolate the drive power connection by means of an emergency stop circuit or use a safety related starting lockout to prevent unintentional start.
- Make sure that the drives are brought to a safe standstill before accessing or entering the danger zone.
- Additionally secure vertical axes against falling or dropping after switching off the motor power by, for example:
 - mechanically securing the vertical axes,
 - adding an external braking/ arrester/ clamping mechanism or
 - ensuring sufficient equilibration of the vertical axes.
- The standard equipment motor brake or an external brake controlled directly by the drive controller are not sufficient to guarantee personal safety!
- Disconnect electrical power to the equipment using a master switch and secure the switch against reconnection for:
 - maintenance and repair work
 - cleaning of equipment
 - long periods of discontinued equipment use
- Prevent the operation of high-frequency, remote control and radio equipment near electronics circuits and supply leads. If the use of such devices cannot be avoided, verify the system and the installation for possible malfunctions in all possible positions of normal use before initial startup. If necessary, perform a special electromagnetic compatibility (EMC) test on the installation.

3.2.4 Protection Against Magnetic and Electromagnetic Fields During Operation and Mounting

Magnetic and electromagnetic fields generated by current-carrying conductors and permanent magnets in motors represent a serious personal danger to those with heart pacemakers, metal implants and hearing aids.



Health hazard for persons with heart pacemakers, metal implants and hearing aids in proximity to electrical equipment!

- Persons with heart pacemakers and metal implants are not permitted to enter following areas:
 - Areas in which electrical equipment and parts are mounted, being operated or commissioned.
 - Areas in which parts of motors with permanent magnets are being stored, repaired or mounted.
- If it is necessary for somebody with a pacemaker to enter such an area, a doctor must be consulted prior to doing so. The noise immunity of present or future implanted heart pacemakers differs greatly so that no general rules can be given.
- Those with metal implants or metal pieces, as well as with hearing aids, must consult a doctor before they enter the areas described above. Otherwise health hazards may occur.

3.2.5 Protection Against Contact with Hot Parts



Hot surfaces at motor housings, on drive controllers or chokes! Danger of injury! Danger of burns!

- Do not touch surfaces of device housings and chokes in the proximity of heat sources! Danger of burns!
- Do not touch housing surfaces of motors! Danger of burns!
- According to the operating conditions, temperatures can be **higher than 60 °C**, 140°F during or after operation.
- Before accessing motors after having switched them off, let them cool
 down for a sufficiently long time. Cooling down can require up to 140 minutes! Roughly estimated, the time required for cooling down is five times
 the thermal time constant specified in the Technical Data.
- After switching drive controllers or chokes off, wait 15 minutes to allow them to cool down before touching them.
- Wear safety gloves or do not work at hot surfaces.
- For certain applications, the manufacturer of the end product, machine or installation, according to the respective safety regulations, has to take measures to avoid injuries caused by burns in the end application. These measures can be, for example: warnings, guards (shielding or barrier), technical documentation.

3.2.6 Protection During Handling and Mounting

In unfavorable conditions, handling and mounting certain parts and components in an improper way can cause injuries.



Risk of injury by improper handling! Bodily injury by bruising, shearing, cutting, hitting!

- Observe the general construction and safety regulations on handling and mounting.
- Use suitable devices for mounting and transport.
- Avoid jamming and bruising by appropriate measures.
- Always use suitable tools. Use special tools if specified.
- Use lifting equipment and tools in the correct manner.
- If necessary, use suitable protective equipment (for example safety goggles, safety shoes, safety gloves).
- Do not stand under hanging loads.
- Immediately clean up any spilled liquids because of the danger of skidding.

3.2.7 Battery Safety

Batteries consist of active chemicals enclosed in a solid housing. Therefore, improper handling can cause injury or material damage.



Risk of injury by improper handling!

- Do not attempt to reactivate low batteries by heating or other methods (risk of explosion and cauterization).
- Do not recharge the batteries as this may cause leakage or explosion.
- Do not throw batteries into open flames.
- Do not dismantle batteries.
- When replacing the battery/batteries do not damage electrical parts installed in the devices.
- Only use the battery types specified by the manufacturer.



Environmental protection and disposal! The batteries contained in the product are considered dangerous goods during land, air, and sea transport (risk of explosion) in the sense of the legal regulations. Dispose of used batteries separate from other waste. Observe the local regulations in the country of assembly.

3.2.8 Protection Against Pressurized Systems

According to the information given in the Project Planning Manuals, motors cooled with liquid and compressed air, as well as drive controllers, can be partially supplied with externally fed, pressurized media, such as compressed air, hydraulics oil, cooling liquids and cooling lubricating agents. Improper handling of the connected supply systems, supply lines or connections can cause injuries or material damage.



Risk of injury by improper handling of pressurized lines!

- Do not attempt to disconnect, open or cut pressurized lines (risk of explosion).
- Observe the respective manufacturer's operating instructions.
- Before dismounting lines, relieve pressure and empty medium.
- Use suitable protective equipment (for example safety goggles, safety shoes, safety gloves).
- Immediately clean up any spilled liquids from the floor.



Environmental protection and disposal! The agents used to operate the product might not be economically friendly. Dispose of ecologically harmful agents separately from other waste. Observe the local regulations in the country of assembly.

27/363

Brief Description, Usage

Brief Description, Usage

General Information

In terms of "Appropriate Use", cases of operation and applications not mentioned in this chapter are not allowed.



In this context, observe the chapter "Configuration of the Drive Sys-

Applications of the Drive System Rexroth IndraDrive

The digital, intelligent drive system Rexroth IndraDrive is the cost-efficient solution with a high degree of functionality for single-axis and multi-axis drive and control tasks.

The drive system Rexroth IndraDrive fulfills a large number of drive tasks in the most varied applications.

Typical applications are the industrial sectors:

- printing and paper converting
- packaging and food
- mounting and handling
- wood machining
- machine tools
- metal forming
- general automation

For these applications there are different device types of graduated perform-

4.3 Mains Transformers DST and DLT

DST und DLT transformers are used to transform mains voltages to the allowed nominal voltage of the device.

DLT transformers are used to

- prevent overvoltage between outer conductor and ground
- protect other loads against leakage currents

Туре	Usage	
DST autotransformer	adjusting voltage range in grounded mains	
DLT isolating transformer	adjusting voltage range in ungrounded mains	

Fig.4-1: Usage of transformers

B

As a matter of principle, use DLT isolating transformers at ungroun-

Mains Filters HNF, HNK, NFE, HNS02 and NFD

Mains filters reduce radio interference and mains pollution.



When using HNF01, NFD03, HNS02 and HNK01 mains filters at mains grounded via outer conductor, use an isolating transformer between mains and mains filter.

Туре	Usage		
NFE01.1	interference suppression of supply units up to 230 V		
NFE02.1	interference suppression of single-phase drive controllers up to 230 V		
NFD03.1	interference suppression of three-phase drive controllers up to 480 V for 1–6 axes and motor cable lengths up to max. 75 m single-axis / 120 m multi-axis (HCS02.1E)		
HNF01.1	interference suppression of three-phase drive controllers up to 480 V for drive systems with a high number of axes and long motor cables		
HNK01.1	interference suppression of three-phase drive controllers HCS03.1E u to 500 V		
HNS02	interference suppression of three-phase drive controllers up to 480 V for drive systems with a maximum of 12 axes and motor cable lengths up to a maximum of 200 m		
<i>'</i> 5,	integrated switch-disconnector		

Fig.4-2: Usage of mains filters



Only operate expressly allowed components at the mentioned mains filters. Operating, for example, blowers, pumps etc. at HNF mains filters is not allowed.

4.5 Mains Chokes HNL01 and HNL02

(Standard) mains chokes HNL01.1E, HNL01.1R and HNL02.1R

- reduce harmonics in the mains current
- increase the allowed DC bus continuous power of certain converters
- allow operating regenerative supply units at the mains

Current-compensated mains chokes HNL01.1E-****-S and HNL01.1R-****-S

• reduce asymmetric currents (leakage currents) in the mains connection phase of the drive system.

The different types may be used **exclusively** as follows:

Туре	Usage	
HNL01.1R	for connection to components with regeneration to the supply mains (HMV01.1R)	
HNL01.1E	for connection to components without regeneration to the supply mains (HMV01.1E, HCS02.1E; HCS03.1E)	
HNL01.1*-****-S	current-compensated chokes for use with HNL01.1 mains chokes to reduce asymmetric currents (leakage currents) in the mains connection phase of the drive system (HMV01.1E, HMV01.1R; HCS02.1E; HCS03.1E)	
HNL02.1R	mains chokes in housing for control cabinet mounting for connection to components with regeneration to the supply mains (HMV02.1R)	

Fig.4-3: Usage of mains chokes

4.6 Supply Units HMV01 / HMV02

HMV supply units supply modular HMS and HMD drive controllers.

Туре	Usage
HMV01.1E	infeeding supplies HMS01 and HMD01 drive controllers
HMV01.1R regenerative supplies HMS01 and HMD01 drive controllers	
HMV02.1R	regenerative supplies HMS01, HMS02 and HMD01 drive controllers

Fig.4-4: Usage of supply units

4.7 Drive Controllers HMS01, HMS02 and HMD01

In the modular drive system, HMS and HMD drive controllers control single and double axes.

Туре	Usage
HMD01.1	have two power outputs to operate two motors independently of each other
	are operated at HMV supply units and HCS drive controllers
HMS01.1	have a power output to operate a motor
	are operated at HMV01 supply units and HCS02 and HCS03 drive controllers
HMS02.1	have a power output to operate a motor
	are operated at HMV02 supply units and HCS02 drive controllers

Fig.4-5: Usage of HM* drive controllers

4.8 Control Sections CSH01, CSB01, CDB01

CSH, CSB and CDB control sections

- allow operating HMS, HMD and HCS drive controllers
- fulfill open-loop and closed-loop control tasks with analog command value input

Туре	Usage		
CSH01	Advanced in HMS01, HMS02, HCS02 and HCS03 drive controllers		
CSB01	BASIC - single-axis in HMS01, HMS02, HCS02 and HCS03 drive controllers		
CDB01	BASIC - double-axis in HMD01 drive controllers in HAC01 control section housings for SERCOS analog converter		

Fig.4-6: Usage of control sections

4.9 Drive Controllers HCS02

HCS02 drive controllers control single axes.

Туре	Usage	6.
HCS02	have a power output to operate a motor	"The
	power range: 1.5 kW to 11 kW	


Fig.4-7: Usage of HCS02 drive controllers

4.10 Drive Controllers HCS03

HCS03 drive controllers control single axes.

Туре	Usage	
HCCO3	have a power output to operate a motor	
HCS03	power range: 18.5 kW to 75 kW	

Fig.4-8: Usage of HCS03 drive controllers



For applications where regenerative power is generated, use HCS03.1 of the -NNBV design and HLR braking resistors.

4.11 DC Bus Resistor Unit HLB01

DC bus resistor units HLB01

- convert generated kinetic energy into thermal energy
- increase the continuous regenerative power in the drive system
- increase the peak regenerative power in the drive system
- allow the DC bus short circuit function ("ZKS") in the drive system

Туре	Usage
HLB01.1C	in drive systems of the Rexroth IndraDrive C product range with a device mounting depth of 265 mm
	see also chapter "Additional Components at the DC Bus - Allowed Combinations" in the Project Planning Manual "Rexroth IndraDrive Drive System".
HLB01.1D	in drive systems of the Rexroth IndraDrive M product range with a device mounting depth of 322 mm
	see also chapter "Additional Components at the DC Bus - Allowed Combinations" in the Project Planning Manual "Rexroth IndraDrive Drive System".

Fig.4-9: Usage of DC bus resistor units HLB

4.12 Braking Resistor HLR01

HLR01.1N-xxxx-Nxxx-A-007-NNNN braking resistors convert generated kinetic energy into thermal energy. For this purpose, the line covers a wide range of continuous power and energy absorption capacity.

Туре	Usage		
HLR01.1 A	Type of construction A (version for device mounting): To be mounted drive controllers of the Rexroth IndraDrive C product range. For this pose, the drive controllers must be equipped with a brake chopper.		
HLR01.1 N	Type of construction N (version for free assembly): For free assembly in the installation, operated by drive controller of the Rexroth IndraDrive C product range. For this purpose, the drive controllers must be equipped with a brake chopper.		

Fig.4-10: Usage of DC bus resistor units HLR

Versions of type of construction N:

- fixed resistor IP 20 type A
 cement-coated, wire-wound, tube-type fixed resistors; screwed on side
 walls; perforated cover; connections in terminal box with PG gland
- steel-grid fixed resistor IP 20 type B
 fixed resistor in steel-grid design; connection depending on type
- steel-grid fixed resistor IP 20 type C
 fixed resistor in steel-grid design; connection depending on type

4.13 DC Bus Capacitor Unit HLC01

DC bus capacitor units HLC01 store energy in the DC bus of the drive system.

Туре	Usage
HLC01.1C	in drive systems of the product ranges Rexroth IndraDrive C and Rexroth IndraDrive M
HLC01.1D	in drive systems of the product ranges Rexroth IndraDrive C and Rexroth IndraDrive M

Fig.4-11: Usage of DC bus capacitor units HLC

4.14 Blower Unit HAB01

HAB01 blower units cool certain HMV01 and HMS01.

Туре	Usage	20/42.X	
HAB01.1	at HMS01.1N-W0350 drive controllers	"Ollio	1010
	at HMV01.1R-W0120 supply units		

Fig.4-12: Usage of HAB01 blower unit

4.15 Motor Filters HMF01

HMF01 motor filters

- reduce the rise of the output voltage of drive controllers
- reduce the leakage currents of the motor lines
- reduce interference voltage on the motor lines

Туре	Usage
HMF01.1	at the motor output of HCS03 drive controllers

Fig.4-13: Usage of HMF01 motor filters

4.16 Accessories HAS

The HAS accessories support the operation and combination of components in the Rexroth IndraDrive system.

Description of the accessories and their usage: see chapter "14 Accessories in the Drive System Rexroth IndraDrive page 201".

4.17 Housing HAC01 for Control Sections

The additional component HAC01 is used to

- insert control sections in it
- supply control sections with 24V control voltage

Туре	Usage	29/4°
HAC01.1-002-NNN-NN	to insert CDB01 control sections in it	6.

Fig.4-14: HAC01 type

4.18 Hall Sensor Box SHL01 (in Preparation)

The additional component SHL01 is used when the commutation setting of linear motors (e.g. IndraDyn L and LSF) is to be carried out, mechanical movement mustn't take place and the automatic commutation methods of the drive firmware cannot be used.

The drive firmware provides automatic commutation methods which can be used for sophisticated motion tasks.

See also Functional Description of firmware, chapter "Saturation Method" (requires I_{out_max}) and "Sine-Wave Method" (requires freedom of motion)

5 General Specifications of the Components

5.1 Certifications

Declaration of Conformity

For components there are declarations of conformity which confirm that the components comply with valid EN standards and EC directives. If required, ask our sales representative for these declarations.

	Designation	Standard
100	CE conformity regarding Low-Voltage Directive	EN61800-5-1 (IEC 61800-5-1:2003)
	CE conformity regarding EMC product standard	EN61800-3 (IEC 61800-3:2004)

Fig.5-1: Applied standards

CE Label




Fig.5-2: CE label

C-UL-US Listing

The components are labeled:




Fig.5-3: C-UL-US label

Designation	Standard	20 ² 110
listing according to UL standard (UL)	UL 508 C	And the state of t
listing according to CSA standard	See docume	entation of the respective component.

Fig.5-4: Applied standards

B

UL ratings

For using the component in the scope of UL, take the UL ratings of the individual components into account.



See documentation of the respective component.

In the scope of UL, it is exclusively the following components which have been approved for supplying IndraDrive components:

- HMV01.1E
- HMV01.1R
- HMV02.1R
- HCS02.1E
- HCS03.1E



Wiring material

In the scope of UL, use Class 1 copper wire only (or equivalent) with a minimum allowed conductor temperature of 75 $^{\circ}$ C for wiring the components.



Allowed degree of dirt contamination

Observe the allowed degree of dirt contamination of the components. Only use the components in environments with a maximum degree of dirt contamination 2 (see Ambient and Operating Conditions).



The components are listed by **UL** ("Underwriters Laboratories Inc.®"). You can find the evidence of certification on the internet under http://www.ul.com under "Certifications" by entering the file number or the "Company name: Rexroth".



See documentation of the respective component.

The control sections are part of the listed components.

CCC (China Compulsory Certification)

The CCC test symbol comprises a compulsory certification of safety and quality for certain products mentioned in the product catalog "First Catalogue of Products Subject to Compulsory Certification" and in the CNCA document "Application Scope for Compulsory Certification of Products acc. first Catalogue" and put in circulation in China. This compulsory certification has been existing since 2003.

CNCA is the Chinese authority responsible for certification directives. When a product is imported in China, the certification will be checked at the customs by means of entries in a database. For the requirement of certification three criteria are normally relevant:

- 1. Customs tariff number (HS code) according to CNCA document "Application Scope for Compulsory Certification of Products acc. first Catalogue".
- 2. Scope of application according to CNCA document "Application Scope for Compulsory Certification of Products acc. first Catalogue".
- For the IEC product standard used, the corresponding Chinese GB standard must exist.

For the Rexroth drive components described in this documentation, **certification** is **not required at present**, thus they are not CCC certified. Negative certifications will not be issued.

5.2 Transport and Storage

5.2.1 Transport of the Components

Ambient and operating conditions - Transport

Description	Symbol	Unit	Va	lue	
temperature range	T _{a_tran}	°C	-25 .	70	N ₁ N ₁ N ₁
relative humidity		%	5	. 95	
absolute humidity		g/m³	₩ [®] 1	. 60	
climatic category (IEC721)	3	Car.	21	< 3	č
moisture condensation	108/150		not al	lowed	108/10
icing	410		not al	lowed	11/0

Fig.5-5: Ambient and operating conditions - Transport

5.2.2 Storage of the Components



Damage to the component caused by long storage periods!

Some components contain electrolytic capacitors which may deteriorate during storage.

When storing these components for a longer period of time, operate them **once** a year for at least 1 hour with power on:

- HCS and HMV with mains voltage U_{LN}
- HMS, HMD, HLC with DC bus voltage U_{DC}

Ambient and operating conditions - Storage

Description	Symbol	Unit	Value	" " (Q)
temperature range	T _{a_store}	°C	-25 55	224
relative humidity		%	5 95	
absolute humidity		g/m³	1 29	
climatic category (IEC721)	, 3 <u>7</u> 0		1K3	"Tiol
moisture condensation	7900		not allowed	77/2/20
icing	Total.		not allowed	The state of the s

Fig.5-6: Ambient and operating conditions - Storage

5.3 Installation Conditions

5.3.1 Ambient and Operating Conditions

The supply units and drive controllers, as well as their additional components, are designed for control cabinet mounting!



Check that the ambient conditions, in particular the control cabinet temperature, are complied with by calculating the heat levels in the control cabinet. Afterwards, make the corresponding measurements to find out that the ambient conditions have actually been complied with.

In the technical data of the individual components, the power dissipation is indicated as an important input value for calculating the heat levels

Ambient and operating conditions

Description	Symbol	Unit	Value
degree of protection (IEC529)			IP20
temperature during storage	N	9. ⁽²⁾	see chapter "Storage of the Components"
temperature during transport	Clife)		see chapter "Transport of the Components"
allowed mounting position definition of mounting positions: see chapter 5.3.2 Mounting Position, page 37	¹ (1) ₀ (1) ₀	n ^a	See documentation of the respective component.
allowed ambient temperature range	T _{a_work}	°C	0 40
allowed ambient temperature range during operation with reduced nominal data ¹⁾	T _{a_work_red}	°° °C	0 55 see figure "Capacity utilization at higher ambient temperature" in chapter "Capacity Utilization"
derating at $T_{a_work} < T_a < T_{a_work_red}^{2}$	f _{Ta}	%/K	see technical data of the individual components
nominal data up to installation altitude	h _{nenn}	m 👊	1000
maximum installation altitude without additional overvoltage limiter	h _{max_ohne}	m m	2000
maximum installation altitude ³⁾	h _{max}	m	4000 see figure "Capacity utilization at higher installation altitude" in chapter "Capacity Utilization"
reduced performance data above installation altitude at $T_a < T_{a_work_red}^{4}$	h _{red}	m 📈	1000
relative humidity	N	%	5 95
absolute humidity	Clife)	g/m³	1 29
climatic category (IEC721)	1311C		3K4
allowed degree of dirt contamination (EN50178)	⁷ ;O,	.5	2
allowed dust, steam		7/2	EN50178 tab. A.2
vibration sine: amplitude (peak-peak value) at 10 57 Hz ⁵⁾	-31	mm	0,15 ±15 %

Description	Symbol	Unit	Value	
vibration sine: acceleration at 57 150 Hz ⁵⁾	A.	g	1 ±15 %	The state of the s
vibration noise (random) frequency ⁵⁾	2	Hz	20 150	
vibration noise (random) spectral acceleration density, amplitude ⁵⁾	i Na. X	g²/Hz	0.005 ±3 dB	
vibration noise (random) rms value of the total acceleration ⁵⁾		g	1 July Paris	(Ilp _{blito}
shock test out of operation (EN60068-2-27), 11 ms	- 25	g	10	Wall.


- observe reduced performance data
- 2) data to be derated: PDC_cont; PBD; lout_cont
- Install overvoltage limiter for transient overvoltage in the installation to limit the voltage to 1 kV between the outer conductors and to 2.5 kV between conductor-ground.
- 4) see characteristic below; observe reduced performance data
- 5) 6) according to EN 60068-2-36
- Fig.5-7: Ambient and operating conditions Operation

5.3.2 Mounting Position

Only operate the components in allowed mounting positions.

For the **allowed mounting positions**, see documentation of the respective component.

Definition of Mounting Positions



- mounting surface
- g direction of gravitational force
- G1 Normal mounting position. The natural convection supports the forced cooling air current. This avoids the generation of pockets of heat in the
 - component.
- G2 180° to normal mounting position
- G3 turned by 90° from vertical to horizontal mounting position
 G4 bottom mounting; mounting surface on bottom of control cabinet
- G5 top mounting; mounting surface at top of control cabinet
- Fig.5-8: Definition of mounting positions

5.3.3 Compatibility with Foreign Matters

All Rexroth controls and drives have been developed and tested according to state-of-the-art technology.

As it is impossible to follow the continuing development of all materials (e.g. lubricants in machine tools) which may interact with our controls and drives, it cannot be completely ruled out that any reactions with the materials used by Bosch Rexroth might occur.

For this reason, before using the respective material you have to carry out a compatibility test for new lubricants, cleaning agents etc. and our housing/our materials.

5.4 Capacity Utilization

Where installation conditions differ, the following performance data are reduced in accordance with the diagrams:

Drive controller:

- allowed DC bus continuous power P_{DC cont}
- braking resistor continuous power P_{BD}
- continuous current l_{out cont}

Motor:


- power
- continuous torque at standstill
- S1 continuous torques
- short-time service torque MKB

If differing ambient temperatures and higher installation altitudes occur simultaneously, both capacity utilization factors must be multiplied. The installation altitude must only be taken into account once, deviating ambient temperatures must be taken into account separately for motor and drive controller.



Use outside of the indicated installation conditions is not allowed, even if the performance data are additionally reduced.

Capacity Utilization vs. Ambient Temperature As the ambient temperature increases, the capacity utilization of the devices is reduced according to the figure below.




f_{Ta} load factor

T_{a work} ambient temperature range for operation with nominal data
 T_{a work red} ambient temperature range for operation with reduced nominal data

Fig.5-9: Capacity utilization at higher ambient temperature

Capacity Utilization vs. Installation Altitude

As the installation altitude increases, the capacity utilization of the devices is reduced according to the figure below.



f load factor

 h_{nenn} maximum installation altitude for operation with nominal data

h_{max_ohne} maximum installation altitude for operation with reduced nominal data

without using an overvoltage limiter

 h_{max} maximum installation altitude for operation with reduced nominal data

when using an overvoltage limiter

Fig.5-10: Capacity utilization at higher installation altitude

5.5 High-Voltage Test

According to standard, the components of the Rexroth IndraDrive range are tested with high voltage.

Test	Test rate
high-voltage test	100% (EN61800-5-1)
high-voltage and insulation test	100% (EN61800-5-1)

Fig.5-11: Applied standards

B

Before making a high-voltage test for the installation in which the components are used, disconnect all connections to the components or disconnect the plug-in connections to protect the electronic components.

5.6 Control Voltage Specification (24V Supply)

The data in the table below generally apply to the 24V supply of the devices of the Rexroth IndraDrive range. For other data, such as power consumption and inrush currents, see the technical data of the respective device.

Description	Symbol	Unit	Value
control voltage for drive systems without operation of motor holding brakes in Rexroth motors	U _{N3}	V V	19,2 28,8 (24 ±20%) When using supply units HMV01.1E, HMV01.1R, HMV02.1R, HLB01.1D: 22,8 27,3 (24 -5%, 26 +5%)
control voltage for drive systems with operation of motor holding brakes in Rexroth motors	U _{N3}	V	Depending on the motor cable length, the control voltage must be within the following voltage ranges: motor cable length < 50 m: 22,8 25,2 (24 ±5%) motor cable length > 50 m: 24,7 27,3 (26 ±5%) Take the data of the corresponding motor holding brake into account.
external control voltage at devices of design "NNNV" (see type code HCS02, HCS03; other design: DC 24 V power supply from the DC bus or external)	U _{N3}	V V	26 28,8 The output voltage of the internal switching power supply unit is 24 ±10% (see control voltage block diagram "int. SMPS").
max. ripple content	w	OLUSION.	The amplitudes of the alternating component on $U_{\rm N3}$ must be within the specified voltage range.
maximum allowed overvoltage	U _{N3max}	V	33 (max. 1 ms)

Fig.5-12: Control voltage

B

Overvoltage

Overvoltage greater than 33 V has to be discharged by means of the appropriate electrical equipment of the machine or installation.

This includes:

- 24V power supply units that reduce incoming overvoltage to the allowed value.
- Overvoltage limiters at the control cabinet input that limit existing overvoltage to the allowed value. This, too, applies to long 24V lines that have been run in parallel to power cables and mains cables and can absorb overvoltage by inductive or capacitive coupling.



Power supply units with buffer (UPS)

For HMV supply units, use 24 V supplies with buffer times of at least 100 ms (e.g. UPS), if commutation drops and short-time interruptions in the application exceed the specified values.

For the 24V supply, also take the following chapter into account: "Dimensioning the Mains Connection" in the Project Planning Manual "Rexroth IndraDrive - Drive System".


B

Insulation monitoring impossible

The input 0 V is connected in conductive form with the housing potential. Insulation monitoring at +24V and 0V against housing is therefore impossible.

Control Voltage Block Diagram

The control voltage, which is supplied via the connection for 24V supply, takes effect according to the following block diagram.



BR circuit for brake control LT power section, e.g. HCS02 ST control section, e.g CSB01

ZK DC bus

int. SMPS internal switching power supply unit, for types HCS0x.1E-Wxxxx-NxxV Fig.5-13: Block diagram of internal control voltage

6 Project Planning of Control Voltage (24V Supply)

6.1 General Information

To operate the drive system, supply the devices with control voltage. For the project planning of the 24V supply of the drive system, take the requirements of the devices used into account:

- voltage with tolerance zone position depending on line lengths and use of holding brake (see chapter "General Specifications of the Components" → "Control Voltage Specification (24V Supply)")
- power consumption of the drive controllers with control section and power section
- power consumption of other components, e.g. holding brakes
- current carrying capacity of the connections for "looping through"

For the requirements of the supply units and converters, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for control voltage supply".

6.2 Selection of 24V Supply

6.2.1 General Information

At components of the Rexroth IndraDrive range, the external 24V supply takes place via the connection X13 or via the connections 24V and 0V at the terminal block.


Via these connections, the components are supplied with 24V for

- the power section of the drive controller or supply unit
- brake control via X6
- the control section of the drive controller



The inputs/outputs of the I/O extensions MA1, MD1 and MD2 are not supplied with voltage via the control section, but have their own connections.

Take the additional power required for these connections into account.



D1, D2 diodes, internal

D3 protective diode, external

LT power section

BR circuit motor holding brake

ST control section OM1 optional modules

OM2 optional modules with supply voltage connection, e.g MA1, MD2

Fig.6-1: Block diagram of 24V supply

6.2.2 Electrical Requirements

The following parameters contain the essential electrical requirements on the power supply unit:

- output voltage or range of output voltage
- continuous power which the power supply unit must supply during operation
- ullet peak current which the power supply unit must supply when switching on The output voltage of the power supply unit must be within the allowed input voltage U_{N3} .

Which Output Voltage Must the Power Supply Unit Have?

See Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → "Data for control voltage supply".



Control voltage when using motor holding brakes!

Depending on the motor cable length, a higher output voltage of the power supply unit is required for operating the motor holding brakes. Observe the data for operating motors with holding brakes in chapter "General Specifications of the Components" → "Control Voltage Specification (24V Supply)".

Use power supply units with adjustable output voltage from 24 V to 26 V.

Which Continuous Power Must the Power Supply Unit Supply? The continuous power of the power supply unit must be greater than the sum of power consumptions P_{N3} of the components to be supplied.

For the power consumption P_{N3} , see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" \rightarrow Chapter of the respective device \rightarrow "Technical Data" \rightarrow "Basic Data" \rightarrow "Data for control voltage supply".

For the power consumption of the control sections (basic control section circuit board or optional modules), see Project Planning Manual "Rexroth IndraDrive Drive Controllers Control Sections"

"Other Technical Data"
"Power Consumption"

If required, determine the continuous current I_{N3} for selecting the power supply unit:

 $I_{N3} = P_{N3} / U_{N3}$

The power consumption is indicated as maximum value of the respective component and can occur at **individual components**.

In drive systems with **several components**, the occurring power consumption under statistical assumptions will be lower than the calculated one.

Experience has shown that the **typical power consumption** of drive systems is at only **approx. 70%** of the calculated maximum value.

Which Peak Current Must the Power Supply Unit Supply?

When switched on, the power supply unit must supply the sum of the occurring inrush currents I_{EIN3} or charges $I_{EIN3} \times t_{EIN3Lade}$.


When the power supply unit is switched on, the power supply unit is loaded with the charging current to the capacitors of the 24V supply input of the connected devices. An electronic circuit in each drive controller limits this charging current to the value I_{EIN3} .

For the data of the inrush current I_{EIN3} and its pulse width t_{EIN3Lade} for the individual devices, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → "Data for control voltage supply".

The occurring charging process $I_{\text{EIN3}} \times t_{\text{EIN3Lade}}$ is controlled by power supply units with **integrated dynamic current limitation**, if the power supply units allow the 1.2-fold continuous current for at least 1 second. Therefore, use power supply units with integrated dynamic current limitation the continuous power of which is at least 20% above the determined sum of power consumptions P_{N3} .

6.3 Installation of 24V Supply

As a matter of principle, the 24V supply of the devices of the drive system Rexroth IndraDrive has to be in star-shaped form, i.e. for each group of drive controllers or third-party components it is necessary to run separate supply lines. This, too, applies to multiple-line arrangement in the case of supply from a supply unit, for example.



- 1) third-party component (e.g. PLC, valve etc.)
- 2) connection to central ground point (e.g. earth-circuit connector) Fig.6-2: Installation of 24V supply

B

If you use several power supply units for 24 V supply:

- Interconnect the reference conductors 0 V of the individual power supply units with low impedance.
- The output voltages of the power supply units must be within the allowed voltage range.
- Switch the power supply units on and off synchronously.

Chronological Order of 24V Supply and Mains Voltage

Before mains voltage or DC bus voltage is applied to the devices, they have to be supplied by the 24V supply. Therefor, observe chapter 9 Control Circuits for the Mains Connection, page 111.

6.4 Looping Through the Control Voltage Supply



Property damage in case of error caused by too low line cross section!

Make use of the contact bars provided to loop-through and observe the current carrying capacity of the connections for 24V supply at the devices used (see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → "Terminal Block, 24 V - 0V (24V Supply)" and "X13, Control Voltage (24V, 0V)").

At the drive controllers, the 24V supply is looped through via contact bars from one device to the next (for HCS02, HLB01.1C and HLC01.1C via lines at X13, see figure "Looping through the control voltage, example HCS02.1E-W0012").




Fig.6-3: Looping through the control voltage, example HCS02.1E-W0012 Exemplary calculation for 3 drive controllers:

$$I_D = 3 \times \frac{P_{N3}}{U_{N3}}$$

Fig.6-4: Continuous current

The result I_D must be smaller than the specified current carrying capacity of the connection point.



Looping through at HCS02

The current carrying capacity of X13 at HCS02 is only suited for looping through low currents. Limit the looping through to loads with low power consumption, such as HCS02.1E-W0012 with CSB01.1N-FC and additional components HLB01.1C.



Inrush current I_{EIN}

When connecting the control voltage source to the connection point for 24V supply, a higher inrush current I_{EIN} will flow for the specified duration t_{EIN3Lade} .

The inrush current is increased with every additional drive controller.

7 Project Planning of Mains Connection

7.1 General Information

To supply the drive system with power, it is connected to the local supply mains via the mains connection. For the project planning of the mains connection, observe the requirements of the supply mains and of the devices used.

The essential requirements are:

- mains voltage U_{LN} (depending on mains type) with mains frequency f_{LN}, number of phases and rotary field
- mains connected load S_{LN}, mains short-circuit power S_{k_min} and system impedance
- short-circuit current I_{SCCR}, particularly when used in the scope of C-UL
- mains circuit breaker and mains contactor
- protection systems that can be used, such as residual-current-operated circuit-breakers and insulation monitoring devices

For the requirements of the supply units and converters to the mains connection, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

7.2 Power Voltage Supply

Permanent mains connection

A permanent connection to the supply mains is required for Rexroth IndraDrive controllers.




Make sure that **all** devices participating in the mains connection are operated at the corresponding mains type in the allowed voltage range.

Description	Symbol	Unit	Value
allowed mains input voltage in TN-S, TN-C, TT mains type ¹⁾	U _{LN}	V	and Project Planning Manual "Powerth In
allowed mains input voltage in IT mains type ¹⁾ for devices of which the minimum allowed mains input voltage includes this value	U _{LN}	N A	see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage and the second of the second
allowed mains input voltage in mains grounded via outer conductor ¹⁾²⁾ for devices of which the minimum allowed mains input voltage includes this value	U _{LN}	V	age supply"
In TN-S, TN-C, TT, IT mains type and mains grou	nded via ou	ter conduct	tor:
rotary field	29	£2.	no rotary field condition
allowed range of mains frequency	f_{LN}	Hz	(5060) ±2
maximum allowed mains frequency change	Δ f _{LN} /t	Hz/s	2% × f _{LN}

Description	Symbol	Unit	Value
maximum allowed voltage unbalance according to IEC 61000-2-4, class 3		25	3%
maximum allowed voltage drops on the mains voltage according to IEC 60146-1-1 - class 3	omairi	3. ²	depth 40% of mains amplitude, total surface 250% × degrees (see diagram " Maximum allowed voltage drops in % of the mains voltage")
maximum allowed THD according to IEC 61000-2-4, class 3	'iq _{banı}		10%
short-time interruptions		21/2	n.s., see section " Note on Project Planning Short-Time Interruptions"
maximum allowed overvoltages ³⁾ mains circuits against environment and ground	, gi	V	2000
maximum allowed overvoltages ³⁾ between the conductors of the mains connection; characteristic "Voltage Pulse" see chapter Calculations	'iq _{galique}	V	1000

- explanations see chapter Mains Types 1)
- 2) for higher voltages, use isolating transformers with grounded neutral
- 3) impulse withstand voltage 1,2/50 µs and 8/20 µs

Fig.7-1: Standard range of power voltage



Maximum allowed voltage drops in % of the mains voltage Fig.7-2:

Note on Project Planning "Short-Time Interruptions"

The drive system is used for energy conversion and a voltage drop is a loss of available energy.

The effect of the voltage drop (energy reduction) on the process cannot be determined without detailed knowledge of the respective process. The effect is a system and rating aspect and generally will be greatest when the power demand (including the losses) of the drive system is greater than the available power.

In the case of a voltage drop on the mains, the voltage in the DC bus can be reduced. This can cause the drive system to be cut off the mains when voltage falls below certain levels and certain times are exceeded. When voltage returns, the drive system has to be reactivated in order to continue operation.

Note on Project Planning "Overvol-

If higher overvoltage values can occur in the application, measures for limitation of the values have to be taken in the electrical equipment of the machine or installation.



Overvoltages at the devices can occur due to

- inductive or capacitive coupling on lines
- lightning strikes

Use overvoltage limiters at the machine or installation, when the overvoltages at the devices are greater than the maximum allowed overvoltages.


Use the overvoltage limiters at long lines run through the building in parallel with power and mains cables.

Electrically place the overvoltage limiter at the control cabinet input.

7.3 Mains Types

7.3.1 TN-S Mains Type

The TN-S mains type is the usual mains type in Europe.



T = direct grounding of a point (station ground)


N = exposed conductive parts directly connected to station ground

S = separate neutral conductor and equipment grounding conductor in en-

tirė mains

Fig.7-3: Mains type TN-S

7.3.2 TN-C Mains Type




T = direct grounding of a point (station ground)

N = exposed conductive parts directly connected to station ground

Neutral conductor and equipment grounding conductor functions in entire mains combined in a single conductor, the PEN conductor.

Fig.7-4: Mains type TN-C

7.3.3 IT Mains Type



isolation of all active parts from ground or connection of one point to ground via an impedance RE

T exposed conductive parts directly grounded, independent of grounding of current source (station ground)

Fig.7-5: Mains type IT

Notes on Project Planning



Damage to the devices by voltage arcing!

For applications with static charging (e.g. printing, packaging) and operation at IT mains type, use an isolating transformer with $U_K \le 2.5\%$.

B

Voltage increase in the case of ground fault!

In case of the error "ground fault" in the IT mains type, higher voltages against ground (device housing) than in error-free operation affect the device.

For operation at the IT mains type, the drive system including mains filter and mains choke should be galvanically decoupled from the mains via an **isolating transformer**.

In this was, the ground fault detection or monitoring can remain effective in the installation.

When operating IndraDrive C (HCS) drive systems in other applications **without isolating transformer** at the IT mains type,

- observe the allowed mains voltage U_{LN} at the IT mains type of the corresponding devices
- observe the allowed switching frequency f_s; see note below
- check whether the ground fault detection of the mains does not trigger accidentally
- check whether the interference suppression (that is only activated via the parasitic mains capacitances of the ungrounded mains) is still sufficient to comply with the required limit values

The EMC requirements are only complied with by further measures (special mains filters, among other things)!




Allowed switching frequency fs

Operating HCS03 converters at IT mains types without isolating transformer is only allowed with switching frequencies $f_s \le 8$ kHz.

See also Parameter Description "P-0-0001, Switching frequency of the power output stage".

7.3.4 TT System



T = direct grounding of a point (station ground)


T = exposed conductive parts directly grounded, independent of grounding

of current source (station ground)

Fig.7-6: Mains system TT

The EMC requirements are only complied with by specific measures (special mains filters, among other things).

7.3.5 Mains with Grounded Outer Conductor (Corner-Grounded Delta Mains)



I = isolation of all active parts from ground, connection of one phase - generally phase V - to ground or via an impedance

T = exposed conductive parts directly grounded, independent of grounding of current source (station ground)

Fig.7-7: Mains with grounded outer conductor

Notes on Project Planning

The EMC requirements are only complied with by specific measures (special mains filters, among other things).



Mains filters HNF01, NFD at mains grounded via outer conductor

HNF01.1 or NFD03.1 mains filters are not suited for operation on mains grounded via outer conductor. Use isolating transformers.

Allowed mains connection voltage: see technical data of the respective device

7.4 Mains Short-Circuit Power and Mains Connected Load

7.4.1 General Information

Apart from the mains connected load, observe the following corridor of the mains short-circuit power for the mains connection:

 Minimum required mains short-circuit power (mains connected load) for interference-free operation

The smaller the mains short-circuit power, the greater the mains pollution due to the load current with harmonics on the supply voltage of the device. This can disturb both the device and other devices at the same mains node.

Minimum mains short-circuit power is required to limit mains pollution and to have sufficiently high voltage for realizing the drive performance.

• Maximum allowed mains short-circuit power (for device protection)

The higher the mains short-circuit power, the greater the short-circuit currents occurring in the case of error.

Use mains chokes to limit the short-circuit currents in the case of high mains short-circuit power S_k . See also note on "UL requirement I_{SCCR} ."



For comments on the short designations used, see chapter 16.2 Calculations for the Mains Connection, page 330.

7.4.2 Mains Short-Circuit Power

Mains short-circuit power:

Power at nominal voltage U_N between the phases and the maximum mains short-circuit current I_K at the connection point:

$S_k = \sqrt{3} U_N \times I_k$
1,000

S_k short-circuit power of the mains

 I_k short-circuit current U_N mains voltage

Fig.7-8: Mains short-circuit power



For the mains short circuit power of the point of supply, ask your local power supply company.

 I_K results in the case of a short circuit at the point of power supply connection. It is calculated as follows:

$$I_{k} = \frac{U_{N}}{\sqrt{3} \times_{k}}$$

 X_K system impedance U_N mains voltage

Fig. 7-9: Mains short-circuit current

B

UL requirement I_{SCCR}

Devices with C-UL listing are operated at mains nodes with a symmetrical short-circuit current smaller than the indicated value $I_{\rm SSCR}$. If necessary, use mains chokes to increase the system impedance and reduce the short-circuit current.

 $I_{SSCR} = I_{K}$

Mains Classes According to Short-Circuit Power

We basically distinguish the following mains (graded according to mains short circuit power and system impedance):

	To.	U _N = 400 V		U _N = 480 V	
Classification	S _k	X _k	L _k	X _k	Lk
Ugich,	MVA	mOhm	μН	mOhm	μH
1 rigid mains	200	0,80	2,55	1,15	3,67
	150	1,07	3,40	1,54	4,89
	100	1,60	5,09	2,30	7,33
8	50	3,20	10,19	4,61	14,67
2 semi-rigid mains	40	4,00	12,73	5,76	18,33
	30	5,33	16,98	7,68	24,45
	20	8,00	25,46	11,52	36,67
	15	10,67	33,95	15,36	48,89
	10	16,00	50,93	23,04	73,34
	5	32,00	101,86	46,08	146,68
	4	40,00	127,32	57,60	183,35
3 non-rigid mains	3	53,33	169,77	76,80	244,46
	2	80,00	254,65	115,20	366,69
	1	160,00	509,30	230,40	733,39
6	0,6	266,67	848,83	384,00	1222,31

S_k short-circuit power of the mains

X_K system impedance

L_k inductance of mains phase

Fig.7-10: Mains classified according to mains short circuit power and mains in-

ternal resistance



Minimum inductance

The specified minimum inductances protect the drive controllers (especially the DC bus capacitances) during operation at mains with low impedance and high mains short-circuit power.

Use mains chokes at mains with $L_k < L_{min}$.

Example:

 $U_N = 400 \text{ V}; S_K > 20 \text{ MVA}; L_k = 25.46 \mu\text{H}$

Data L_{min} of drive controller in technical data: 40 µH

 $L_k < L_{min}$: use of assigned mains choke is required.

7.4.3 Mains Connected Load

The apparent power with which the mains is loaded by the drive system is significantly determined by the power factor ($\cos \varphi$ with sinusoidal mains current or TPF with non-sinusoidal mains current). The load of the mains with harmonics is taken into account.

The mains connected load is calculated as follows from the projected power in the DC bus:

$$S_{LN} = \frac{P_{DC}}{TPF}$$

 S_{LN} mains connected load [VA] P_{DC} DC bus continuous power [W]

TPF Total Power Factor λ

Fig.7-11: Calculating the mains connected load

For the data of the **TPF**, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

Maximum Allowed Connected Load at the Mains The maximum allowed connected load at the mains depends on the allowed distortion of the mains voltage due to the load current with harmonics (mains pollution). The distortion is described by the total harmonic distortion (THD) of the mains current (see chapter 16 Calculations, page 319).

In order to limit the distortion of the mains voltage, take the mains short-circuit ratio R_{SC} (ratio of the source) into account:

$$R_{sc} = \frac{I_k}{I_{1N}} = \frac{S_k}{S_A} = \frac{S_k}{\sum S_{LN}}$$

k mains short-circuit current

I_{1N} fundamental wave of nominal current of all loads at connection point

S_k mains short-circuit power

S_A connected load of all electric loads at connection point (apparent power

of fundamental wave)

 $\Sigma S_{I\,N}$ sum of mains connected loads of the supply units or converters

Fig.7-12: Mains short-circuit ratio

Measures for Compliance with Allowed THD or Distortion Factor

For public mains we distinguish:

Mains connections under 16 A:

With an $R_{SC} \ge 1000$, there normally isn't any restriction of the allowed mains current distortion (according to EN 61000-3-2).

Mains connections over 16 A:

The power supply company determines the restrictions. Unless there are other values available, the following data can be considered as guide values.

R _{sc}	Allowed THD of mains current	Allowed distortion factor of mains current
≥ 1000	THD > 48%	K > 45%
≥ 120	THD ≤ 48%	K ≤ 45%
> 33	THD < 13%	K < 12 %

Fig.7-13: Required THD/distortion factor with given Rsc of the mains (U < 600 V)
Measures to comply with the maximum allowed THD or distortion factor:

- use of mains chokes
- use of supply units with incorporated power factor correction PFC



The following fact applies to the mains choke: the higher the inductance of the mains choke, the lower the TDH/distortion factor and the mains pollution.

Kind of device	Realizable THD of mains current	Realizable distor- tion factor of mains current	Supply unit or drive controller with and without mains choke	
all devices	THD ≥ 50%	K ≥ 60%	HMV01.1E HCS03.1 HCS02.1	without
devices with mains choke	THD < 48%	K < 45 %	HMV01.1E HCS03.1 HCS02.1	HNL01.1
devices with Power Factor Control (PFC)	THD < 13%	K < 12 %	HMV01.1R HMV02.1R	HNL01.1 HNL02.1

Fig.7-14: Realizable THD / distortion factor for drive controllers



The allowed distortion factors can be achieved with the indicated combinations of drive controller and mains choke.

Observe the assignment of mains choke to drive controller in the Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

For detailed information on the emitted harmonics, see this Project Planning Manual in chapter 16.2.4 Calculations for the Mains Harmonics, page 332.

Procedure for selecting the required mains connection components:

Determine maximum current I of mains connection.

Note: Classification for public mains according to European standards in

Selecting Mains Connection Components

- I < 16 A (EN 61000-3-2)
- 16 A < I < 75 A (EN 61000-3-12)
- I > 75 A (not defined by any standard at present)
- 2. Determine mains short-circuit power S_k of mains at place of destination of application (ask power supply company).
- 3. Determine sum of connected loads S_A.
- 4. Determine ratio R_{SC}.
- 5. Determine allowed THD or distortion factor K of mains current at place of destination of application (ask power supply company).
- 6. Select appropriate mains supply unit with additional component.

B

The table below does not replace the described procedure.

The table is used for first estimation of maximum allowed connected load S_A at point of power supply connection in low-voltage mains at known mains short-circuit power S_K .

Mr.	M.	R _{SC} = 250	R _{SC} = 200	R _{SC} = 100	R _{SC} = 50
Classification	S _k	S _A	S _A	S _A	S _A
the state of the s	MVA	kVA	kVA	kVA	kVA
^O HOLL	200	800	1000	2000	4000
1,000	150	600	750	1500	3000
rigid mains	100	400	500	1000	2000
	50	200	250	500	1000
5°5,	40	160	200	400	800
William,	30	120	150	300	600
- 300 Jill	20	80	100	200	400
2	15	60	75	150	300
semi-rigid mains	10	40	50	100	200
\$	5	20	25	50	100
30/40	4	16	20	40	80
7/0/2	3	12	15	30	60
3	2	8	10	20	40
non-rigid mains	122	4 4	5	10	20
	0,6	2,40	3	6	12

 R_{SC} mains short-circuit ratio S_k mains short-circuit power

S_A connected load of all electric loads at connection point (apparent power of fundamental wave)

Fig.7-15: Maximum allowed connected load

7.5 Protection Systems at the Mains Connection

7.5.1 General Information

Protection against contact always depends on the kind and structure of the supply mains and the mains conditions. For project planning of an installation, the typical behavior of the devices and supply mains should always be taken into account.

For protection against contact (indirect contact) in a machine or plant in which a drive system is used, the overcurrent protective device normally used is one with protective grounding according to IEC 364 and EN 50178 (Electronic equipment for use in power installations). This is also specified in UL 508C (Industrial Control Equipment) for North America. Housing cover or encapsulation by closed housing is used as protection against direct contact with live conductors.

7.5.2 Protective Grounding


General Information

Overcurrent protection normally is realized in the form of fuses or overcurrent release devices (circuit breakers, motor circuit breakers) installed at the mains connection. For details see figure.

Overcurrent protection generally is dimensioned or set with a release current of 1.3 × nominal current of the loads connected to this connection point.

In the case of an insulation error or a connection between mains phase and device housing connected to the equipment grounding conductor, the drive is disconnected from the mains.

Fusing by Protective Grounding in TN-S Mains



control cabinet A)

B) error


1 joint bar of equipment grounding conductors

2 aim of protective measures: contact voltage < 50 V at housing

DC bus connection L+/L-3

Fig.7-16: Protection against contact by protective grounding with overcurrent protection device in TN-S mains

Fusing by Protective Grounding in TN-C Mains




- control cabinet A)
- joint bar of equipment grounding conductors
- aim of protective measures: contact voltage < 50 V at housing
- B) ① ② ③ DC bus connection L+/L-
- Fig.7-17: Protection against contact by overcurrent protection device in TN-C

63/363

Project Planning of Mains Connection

mains

Fusing by Protective Grounding in IT Mains (Ungrounded Mains)



- A) control cabinet
- B) erro
- joint bar of equipment grounding conductors
- 2 aim of protective measures: contact voltage < 50 V at housing</p>
- ③ DC bus connection L+/L-
- Fig.7-18: Protection against contact by overcurrent protection device in IT mains

Rating of Mains Circuit Breaker



High contact voltage in the case of error!

Do not exceed maximum allowed ground resistance!

Select the mains circuit breaker such that the disconnecting times in the case of error (short circuit or ground fault) according to VDE0100-410 and VDE0100-540, as well as the maximum ground resistance required for this purpose are complied with:

- nominal fuse current ≤ 32 A: max. disconnecting time 0.2 s
- nominal fuse current > 32 A: max. disconnecting time 5 s

Determine the maximum allowed ground resistance at the site of installation with the tripping current (see tripping characteristic of selected fuse) and the maximum allowed contact voltage 50 V.

Rated currents for the mains circuit breakers and mains contactors: see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply"

The data apply under the following conditions:

- the mains supply units and converters are operated with individual supply
- in the arithmetical mean, the indicated continuous power P_{DC_cont} is not exceeded for 10 minutes
- easily separable contact-welded connections at the (external) contactor are allowed after short-circuit; corresponds to assignment type "2" according to DIN IEC 60947-4

Applications deviating from these conditions require detailed calculation of the mains connection values.

If several drive controllers are to be operated at one fuse and one mains contactor, add the mains-side phase currents and inrush currents calculated for the individual drives.



Damage to the drive controller caused by overload!

Observe the specified performance data peak power and continuous power.

Selectively fuse the mains connection of each drive system. The fuse must protect the drive controller with the lowest mains connected load.

The indicated types of certain manufacturers are examples. Equivalent products by other manufacturers may be used as well.



In order to prevent the mains contactor from being overloaded by the load current in the case of frequent cut-off:

- first switch off the drive, e.g. via drive enable in the master communication
- then switch off the mains contactor



Fuses of **characteristic gR** can protect the involved semiconductors against further damage in the case of short circuit.

Fuses of characteristic gL protect the lines.

For the switch-off delay of the mains contactor see the technical data of the selected type. Take into account that additional components at the operating coil cause changes in the switch-off delay.

Fusing Branches Within the Control Cabinet

In the wiring of the drive system devices, there are branches run from main lines to short circuit protection devices.

According to EN 60 204 part 1, 5.2.4, such supply lines to short circuit protection devices branching off main lines do not need to be especially protected against short circuit, when the following requirements have been fulfilled:

- The supply lines to the short circuit protection device have at least the cross section of the conductors continuing the line from the short circuit protection device (line cross sections from and to motor circuit breaker have the same size).
- No supply line to the short circuit protection device is longer than 3 m.
- The lines are protected against external influence by a housing or a wiring duct.
- The lines are not run close to combustible material.

7.5.3 Connecting Equipment Grounding Conductor

General Information



Lethal electric shock when touching the housing caused by faulty connection of equipment grounding conductor!

Observe the mentioned notes on installation in any case, in order to exclude danger by electric shock when touching the housing, even in case an equipment grounding conductor connection is broken.

Equipment Grounding Connection Between the Components

Observe the notes on installation in chapter 13.1.4 Connection Point of Equipment Grounding Conductor and Equipment Grounding Connections, page 182.

Connecting Equipment Grounding Conductor to Mains

According to the standards "Electronic equipment for use in power installations" (EN50178, chapter 5.3.2.1) and "Adjustable speed electrical power drive systems" (EN 61800-5-1, chapter 4.2.5.4.2), a **stationary connection** of the equipment grounding conductor is required and one or more of the following requirements have to be complied with:

- cross section of equipment grounding conductor at least 10 mm² (reason: sufficient mechanical stability required)
- mains and current supply automatically cut off when equipment grounding conductor interrupted (case of error)
- Routing of a second equipment grounding conductor, via separate terminal connectors, with the same cross section as the first equipment grounding conductor. Mounting of an additional terminal connector for this equipment grounding conductor.

7.5.4 Residual-Current-Operated Circuit Breakers (RCD, RCCB) as Additional Fusing

General Information

The following designations are used for residual-current-operated circuit breakers:

- RCCB (Residual-Current-Operated Circuit Breaker)
- RCD (Residual-Current-Operated Device)
- RCM (Residual-Current Monitoring Device)
- earth-leakage circuit breaker (voltage-independent)
- residual-current circuit breaker (voltage-dependent)



Residual-current-operated circuit breakers can only be used with Rexroth IndraDrive systems to a limited extent.

If these circuit breakers are to be used, the company erecting the installation has to check the mutual compatibility of the residual-current-operated circuit breakers and installation or machine with the drive system, in order to avoid accidental triggering of the residual-current-operated circuit breaker. This has to be taken into account

- for switch-on processes, due to high asymmetric inrush currents and
- during operation of the installation, due to leakage currents produced in normal operation.

Cause of Leakage Currents

For the purpose of stepless speed variation with a high degree of positioning accuracy and dynamic response, certain modulation procedures are necessary for drive systems. For physical reasons, these modulation procedures give rise to inevitable leakage current produced during normal operation. Especially with unbalanced loads of the mains phases or a large number of drives it can easily reach some amperes (rms value).

The leakage current is not sinusoidal but pulse-shaped. For this reason, measuring instruments normally dimensioned for alternating currents in the range of 50 Hz are not suited. Use measuring instruments with rms value measuring ranges up to at least 150 kHz.

The degree of leakage current depends on the following features of the installation:

- kind of inrush current limitation
- number, kind and size drives used
- length and cross section of connected motor power cables
- grounding conditions of the mains at the site of installation
- imbalance of the three-phase system
- kind of filters and chokes connected in the incoming circuit
- EMC measures that are taken

If measures are taken to improve the electromagnetic compatibility (EMC) of the installation (mains filters, shielded lines), the leakage current in the ground wire is inevitably increased, especially when switching on or in the case of mains unbalance. Given these operating conditions, residual-current-operated circuit breakers can trigger without an error having occurred.

The EMC measures are mainly based on capacitive short-circuiting of the interference currents within the drive system. Inductive filter measures can reduce the leakage currents, but affect the dynamic response of the drive and bring about higher construction volume, higher weight and expensive core material.

Possibilities of Use

Motor Cable Length

Keep the motor cables as short as possible. Only short motor cables do allow low leakage currents and thereby enable residual-current-operated circuit breakers to work.

Kinds of Residual-Current-Operated Circuit Breakers There are two kinds of residual-current-operated circuit breakers:

 Residual-current-operated circuit breakers sensitive to power pulse current (type A acc. to IEC 60755)

These are normally used. However, it is only pulsating direct fault currents of a maximum of 5 mA and sinusoidal alternating fault currents that they switch off safely. This is why they are not allowed for devices that can generate smoothed direct fault currents. In the case of smoothed direct fault currents that can be produced in power supply units, mains rectifiers and drive controllers with power converters in B6 circuit, the residual-current-operated circuit breaker is not triggered. This blocks the triggering of a residual-current-operated circuit breaker sensitive to power pulse current in the case of ground contact, i.e. in the case of error.

Residual-current-operated circuit breakers sensitive to power pulse current do not provide any protection against inadmissible contact voltage.

2. Residual-current-operated circuit breakers sensitive to universal current (type B acc. to IEC 60755)

These circuit breakers are suited for smoothed direct fault currents, too, and safely switch off devices with B6 input rectifiers.

When a current with 30 mA triggers the residual-current-operated circuit breaker, it is possible to use a residual-current-operated circuit breaker with higher tripping current for machine protection.

If this residual-current-operated circuit breaker triggers accidentally, too, check in how far the above conditions and dependencies can be improved (for example, by connecting current-compensated mains chokes in the incoming circuit, increasing the inrush current limitation).

Using Isolating Transformer to Reduce Leakage Current in Mains

If there is no improvement achieved and the residual-current-operated circuit breaker, due to specific mains conditions on site, has to be used nevertheless on the mains input side, connect an isolating transformer between mains connection and power connection of the drive system. This reduces the leakage current in the ground wire of the mains that is produced during normal operation which allows using the residual-current-operated circuit breaker. Connect the neutral point of the secondary winding of the isolating transformer to the equipment grounding conductor of the drive system.

Adjust the ground-fault loop impedance to the overcurrent protective device so that the unit can be switched off in the case of failure.

Before operating enable, check the correct function of the overcurrent protection device including activation in the case of failure.

Exclusive fusing by residual-current-operated circuit breaker

For drive systems with electronic drive controllers, exclusive protection by means of a residual-current-operated circuit breaker normally is not possible and not allowed.

Electronic equipment that has a nominal power higher than 4 kVA or is destined for permanent connection does not need residual-current-operated circuit breakers.

According to IEC 364 and EN 50178, the supply-side protection against contact for indirect contact, i.e. in the case of insulation failure, has to be provided in a different way, for example by means of overcurrent protective device, protective grounding, protective-conductor system, protective separation or total insulation.

Using Residual-Current-Operated Circuit Breakers at HCS Drive Controllers

HCS02 Drive Controllers at Residual-Current-Operated Circuit Breaker

At HCS02 drive controllers, residual-current-operated circuit breakers can be used under the following conditions:

- residual-current-operated circuit breaker is of type B (IEC60755)
- trip limit of the residual-current circuit breaker is ≥ 300 mA
- supplying TN-S mains
- maximum length of motor cable 20 m in shielded design
- use of a mains filter HNF01 or NFD03
- each residual-current-operated circuit breaker only supplies one HCS02 drive controller
- only Rexroth components and accessories including cables and filters are used

Using Residual-Current-Operated Circuit Breakers at HMV Supply Units

HMV01.1R, HMV02.1R at Residual-Current-Operated Circuit Break-

Due to their function, regenerative HMV0x.1R supply units are unsuitable for the use of residual-current-operated circuit breakers.

7.5.5 Insulation Monitoring Devices

Insulation monitoring devices are normally used in IT mains with insulated neutral point. The aim is to have a monitor triggered in the case of ground fault – which means in the case of error – without having to switch off the electrical equipment.

When the monitor signals an error, the ground fault is detected and removed without operation being interrupted. Switch-off only takes place if a second ground fault occurs before the first one has been removed.

As insulation monitoring devices are also measuring the ground current at the mains input of the building, too high leakage current can cause accidental false triggering.

There are the same notes on application applying as mentioned in the previous chapter 7.5 Protection Systems at the Mains Connection, page 60.

8 Configuration of the Drive System

8.1 General Information

Within the product range Rexroth IndraDrive, you may combine components of the subranges Rexroth IndraDrive C and Rexroth IndraDrive M, as well as Rexroth IndraDrive Mi.

You have to select:

Supply

- supply units
- converters
- type of mains connection additional component mains filter other additional components for mains connection

Drive

- motors with measuring systems
- power sections
- control sections with options
- firmware for selected power sections with control section

Additional components

- for the DC bus
- for the motor output

Cables

- for power supply to the motor
- for signal evaluation from motor to control electronics

8.2 Kind of Supply for Power Sections

8.2.1 General Information

The requirements to the individual axes are known from the drive task and the appropriate drive controllers - the drive system - have been selected for this purpose. For this drive system, select the appropriate supply. The following list will be explained in detail in this chapter:

- supply by HMV supply unit
 - in central supply
 - in parallel operation
- supply by HCS converter
 - in central supply
 - in parallel operation
- supply by third-party supply units (preliminary)
 - RD500 SFT converter

B

It is not allowed to use supply units not contained in this list to supply the IndraDrive components.



In the scope of UL, it is exclusively the following supply units which have been approved for supplying IndraDrive components:

- HMV01.1R
- HMV01.1E
- HMV02.1R
- HCS02.1E
- HCS03.1E

Orientation guide for selecting kind of supply

3	HMV su	pply unit	HCS co	onverter
Criterion	Central supply with HMVxx.x	Parallel op- eration with HMVxx.xE (not W0030)	Central supply	Parallel op- eration
number of axes = 1	х	x	•	- 12
1 < number of axes ≤ 6	•		•	.agi =
6 < number of axes ≤ 12	- 3	34 -	- 25	-
12 < number of axes ≤ 21	#1310N	•	and the same	-
number of KCU01 = 1	7/95	•	71/1/2 =	•
1 < number of KCU01 ≤ 4	br	- 42	-	- 37
high overload ratio	•	~ ·		
regenerative operation with great energy contents	■ HMVxx.xR	40.x		· ·
70,170	108151			
high kinetic energies in the case of mains failure	x	additionally use brak- ing resis- tors	additionally use brak- ing resis- tors	additionally use brak- ing resis- tors
single-phase operation	- Haller	<u>-</u>	only HCS02	-

recommended

suited to a limited extent

possible not allowed Fig.8-1: Orientation guide



Property damage caused by operation of combinations which are not allowed!

Only operate the listed, allowed combinations.

Operating components not mentioned in this documentation at the common DC bus with Rexroth IndraDrive components requires Rexroth's explicit confirmation.

HMVs are the preferred supply units for HMS, HMD and KCU inverters. HCS converters can be used, too, as supply units for HMS, HMD and KCU. The table

below shows the general assignment. In addition, observe the detailed notes on project planning in the corresponding section.

Supply unit / con- verter	HMS01	HMS02 1)	HMD01	HCS02	HCS03	KCU01
HMV01.1E	•	2016	•	-25/2	-	a 3)
HMV01.1R	- ,	Ollin -	•	101	-	3)
HMV02.1R	-900	•	ŏ	-	-	, B
HCS02	■ 3)	•	3)	•	- 4	2)
HCS03	-	- (•	-		3)

- allowed
- not allowed
- 1) HMS02 not with HMS01/HMD01
- only HCS02.1E-W0054, -W0070 with additional capacitances at the DC
- different mounting depths: control cabinet adapter HAS03 required

Fig.8-2: Supply units for power sections



KCU01 at HMV and HCS - number of axes, capacitances C_v

The electronic control system KCU01 allows operating a motor string of several KSM at the DC bus of Rexroth IndraDrive supply units and converters. KCU01 acts like an extension of the DC bus up to the inverters integrated in KSM.

A KCU01 with maximum hybrid cable length loads the supply unit like, for example, 5 devices HMS01.1N-W0110 (5 axes, $C_v = 5 \times 100 \text{ nF}$).



For the project planning of HMS and HMD inverters at HCS converters, take the following aspects into account for use in the scope of UL:

- The maximum output voltage (U_{DC}) of the supplying device (e.g. HCS) must be smaller than the allowed input voltage of the inverter (e.g. HMS).
- The symmetrical nominal short-circuit current at the mains connection (I_{SCCR}) of the supplying device (e.g. HCS) must be smaller than the symmetrical nominal short-circuit current specified for the inverter (e.g. HMS).


8.2.2 HMV Supply Units for HMS/HMD Power Sections

Central Supply HMV

Brief Description

The mains connection "central supply" (individual supply) is the standard type of connection for HMV. The "central supply" is characterized by one mains connection (mains circuit breaker, mains transformer, mains filter, mains choke) for the drive system. Other drive controllers and additional components are connected to the supply unit.

Block Diagram



HMVxx.xE components marked with gray background color: optional, depending

on the application


HMVxx.xR mains filter and mains choke; necessary

HMVxx.xR- mains filter, mains choke, external mains contactor; necessary

W0120

Fig.8-3: Individual supply HMV

The "group supply without DC bus connection of the groups" has to be handled like individual supply for HMV.



HMVxx.xE components marked with gray background color: optional, depending

on the application

HMVxx.xR mains filter and mains choke; necessary

HMVxx.xR- mains filter, mains choke, external mains contactor; necessary

W0120

Fig.8-4: Group supply HMV without DC bus connection of the groups

Notes on Project Planning

For mains connection, observe the control circuit for the mains connection.

Up to the indicated maximum allowed **number of devices**, **drive controllers** may be operated at the common DC bus. The number is limited by the charging ability of HMV to charge capacitances against ground in the connected components.

For the selected number of axes, select the appropriate mains filter and mains choke with the required EMC limit value. This may result in a limitation with

regard to the number of axes and the motor cable length; the limitation can be resolved by division into several systems.



Damage to the supply unit!

Do not exceed allowed peak and continuous powers in the DC bus.

Comply with minimum value of mean phase control factor \bar{a} (see data of continuous power of supply unit in the technical data, calculation see chapter 16, Calculations, page 319), in order to avoid overload of the integrated DC bus capacitors by wattless currents.

High load due to wattless current is generated, when, for example, synchronous motors permanently deliver high torque at low speed or asynchronous motors are operated with high magnetization currents.

In these cases of operation, use additional capacitances at the DC bus.

Central Supply HMV - Number of Components

Supp	ly unit		ponents at comm	
Туре	Charging ability capacitances C _y [nF]	Allowed num- ber of axes	HLB01.1	HLC01.1
HMV01.1E- W0030	2100	21 (21 × HMS01 or	2 × HLB01.1C or	take max. al- lowed external
HMV01.1E- W0075	2100	11 × HMD01) or 4 × KCU01	2 × HLB01.1D	DC bus capacitance C _{DCext} into account
HMV01.1E- W0120	2100	wig)		to account
HMV01.1R- W0018	2100	(A)	altomat,	autom'
HMV01.1R- W0045	2100	and the same		"MANI'I)
HMV01.1R- W0065	2100	à	d	
HMV01.1R- W0120	2100	Sight .	*OLUSIAHAO	, offi
HMV02.1R- W0015	2100	12 (12 × HMS02) 1 × KCU01	(Q)	WHAN I SPAIN


Fig.8-5: Allowed Rexroth IndraDrive M components at common DC bus

Parallel Operation HMV - Group Supply With DC Bus Connection HMV01, HMV02 Brief Description

"Group supply with DC bus connection" increases the available regenerative power, the continuous braking resistor and infeeding power in the common DC bus of several drive controllers.

This mains connection is mainly used to cover the power range above the biggest modular supply unit.

Block Diagram




HMVxx.xE components marked with gray background color: optional, depending on the application

HMVxx.xR mains filter and mains choke; necessary

HMVxx.xR- mains filter, mains choke, external mains contactor; necessary W0120

Fig.8-6: Parallel operation - group supply HMV with DC bus connection

Notes on Project Planning



For mains connection, observe the control circuit for the mains connection. Parallel operation of HMV01 supply units

- is allowed with HMV01.1E supply units of the same type current
- requires a mains choke for each supply unit (for current sharing)
- does not increase the maximum allowed number of drive controllers or axes when operated without mains filter
- requires a control circuit master-slave; see chapter 9, Control Circuits for the Mains Connection, page 111.

For detailed information on derating and mounting, there is the specification with document number 109-1261-4102-** (available on request).

For the selected number of axes, select the appropriate mains filter and mains choke with the required EMC limit value. This may result in a limitation with regard to the number of axes and the motor cable length; the limitation can be resolved by division into several systems.



One HMV01.1E-W0075 device replaces two HMV01.1E-W0030 devices connected in parallel.

Parallel Operation HMV - Number of Components

Supply unit type	Number of supply units at common DC bus					d		
1100/04/4	E-W*	*** (infee	eding)		R-W***	* (regene	erative)	4
HMV01.1	0030	0075	0120	0018	0045	0065	0120	0015

Supply unit type		Num	ber of su	pply unit	s at com	mon DC	bus	
HMV01.1E- W0030	2	-	-	When	-	-	$\bar{n}_{H_{\alpha}}$	-
HMV01.1E- W0075	-	2	19/0 (t)	-	-	13/12.21	-	-
HMV01.1E- W0120	-	AD THE	2	-	JOH <mark>E</mark> NOT	-	-	109401
HMV01.1R- W0018	-11/1/1	-	-	1,314	-	-	4 ray	-
HMV01.1R- W0045	-	-	12.0	-	1	12.01	-	-
HMV01.1R- W0065	-	- 110	(1)C)	-	-1000	1	-	Jior
HMV01.1R- W0120	- 4	igo.	-	-44	<u> </u>	-	1,41	26,-
HMV02.1R- W0015	-	-	- 6	-	-	-0	-	1

not allowed

Fig.8-7: Parallel operation HMV

8.2.3 Converter HCS as Supply Unit for Power Sections

General Information

Converters are designed for operating a single drive (see also Individual Supply with HCS). In particular, the power supply with the capacitors in the DC bus and the mains supply have been dimensioned with regard to operation under rated conditions of the converter. When HCS converters are used as supply units for further drive controllers, the power (P_{DC_cont} , P_{DC_peak}) of the converter is available at the motor output and at the DC bus connection of the converter. This causes additional loading which requires **additional measures** when the converter is used as supply unit. The measures reduce, for example, the resulting (higher) current load of the capacitors in the DC bus.



Damage to the converter!


Comply with the allowed peak power and continuous power (P_{DC_cont} , P_{DC_peak}) of the supplying drive controller.

Central Supply - HCS Supply HCS or HMS/HMD Drive Controllers

Brief Description

The "central supply" via HCS converters is the mains supply with which the converter supplies further drive controllers.

Block Diagram




components marked with gray background color: optional, depending on the application

Fig.8-8: Central supply HCS

B

When using the component HCS03.1E with HNK01.1, connect the mains contactor electrically before HNK and HCS03.

The "group supply without DC bus connection of the groups" allows using the additional components (HNL, HNF etc.) in the mains connection for several similar supplies.



components marked with gray background color: optional, depending on the application

Fig.8-9: Group supply HCS without DC bus connection of the groups

B

Control the mains contactor in such a way (connect Bb contacts in series) that errors of both groups lead to circuit interruption.

Notes on Project Planning HCS02

HCS02 converters as supply units for HMS01 / HMD01 require:

- accessory HAS03 (to adjust different mounting depths)
- accessory HAS04 (capacitances C_y at DC bus against ground)
- additional capacitors C_{DC_ext} at the DC bus (external DC bus capacitance C_{DCext}), if
 - the arithmetical mean of the output currents I_{out} is greater than $I_{\text{out_cont}}$ of the supplying device

 the accumulated chronological sequences of the output currents I_{out} and the DC bus power P_{DC} (superposition of the individual load profiles) are greater than the allowed load profiles

B

Additional capacitance C_{DC_ext} required for HCS02!

To determine the additionally required capacitance C_{DC_ext} , the following **guide values** apply when using an HLC01.1 DC bus capacitor unit:

- 10 µF per A type current of installed HMS01 drive controllers
- 20 μF per A type current of installed HMD01 drive controllers
- 50 μF pro kW of installed continuous power KCU01

There aren't any additional capacitances required for HMS02.

B

Arrangement of HCS02

Place HCS02 to the left of HMS01, HMS02 and HMD01.

Place the accessory HAS04 at the left of HCS02.

Place the DC bus capacitor unit HLC01.1 at the junction from HCS02.1 to HMS01.1 or HMD01.1.

Notes on Project Planning HCS03

HCS03 converters as supply units for HMS01 / HMD01 require braking resistors:

图

Operate HCS03 with HLR!

To supply HMD01 and HMS01, operate HCS03 converters with brake chopper (option -NNBV) and HLR braking resistor.

DC bus capacitors HLC01.1 may only be operated at HCS03.1E-W0210.

啄

Arrangement of HCS03

Place HCS03 to the left of HMS01 and HMD01.

Place the accessory HAS04 at the left of HCS03.

Notes on Commissioning

When converters are operated as supply units for inverters or supplied as inverters from another converter, the drive controller must be parameterized for this purpose.

For information on configuration and parameterization of the drive controllers, see Functional Description of firmware, chapter "Power Supply" and the involved parameters.

- P-0-0860, Converter configuration
- P-0-0861, Power supply status word

Central Supply HCS02 - Number of Components

Converter as supply unit	T ₁	Number o	f IndraDrive	components at cor	nmon DC bus	bus				
omatyka ol	HCS02.1E	- Official	Allowed sum of type cur- rents	Allowed number of axes	HLB01.1C	HLC01.1C				
central supply via HCS02.1E- W0028 without assigned mains choke	- 31	"Hich gare	- -	'iqpan -	1 dban	1 (up to -02M4)				
central supply via HCS02.1E- W0054 without assigned mains choke	up to W0054	3	166	12	1	1 (up to -02M4)				
central supply via HCS02.1E- W0054 with assigned mains choke HNL01.1	up to W0054	Millo House	222	12	1 WWW.	take max. allowed external DC bus capacitance C _{DCext} into account				
central supply via HCS02.1E- W0070 without assigned mains choke	up to W0070	T. E. C.	264	12	1	1 (up to -02M4)				
central supply via HCS02.1E- W0070 with assigned mains choke HNL01.1	up to W0070	^M ig _{loging}	402	12	1 WWW.IDIG	take max. allowed external DC bus capacitance C _{DCext} into account				
Uglika b	HMS01.1N HMS02.1N	HMD01.1N	, S	HEINE !	HLB01.1C	Cold Action				
central supply via HCS02.1E- W0054 without assigned mains choke	up to W0036	up to max. W0020	120	12 (1 × HCS02 and 11 × HMS01	1 ni	take max. allowed external DC bus capaci-				
central supply via HCS02.1E-W0054 with assigned mains choke HNL01.1	up to W0054	up to max. W0020	198	or 1 × HCS02 and 2 × HMS02	1	tance C _{DCext} into account				
central supply via HCS02.1E- W0070 without assigned mains choke	up to W0036	up to max. W0020	120	or 1 × HCS02 and 5 × HMD01 and	1 (dbauf	Light.				
central supply via HCS02.1E- W0070 with assigned mains choke HNL01.1	up to W0054	up to max. W0036	270	1 × HMS01)	Figure	n'in				

not allowed

Fig.8-10: Maximum number of IndraDrive C components at common DC bus HCS02

Example HCS02

Central supply via HCS02.1E-W0070 with assigned HNL01.1 mains choke:

- 1 × HCS02.1E-W0070 (supplying device)
- 7 × HCS02.1E-W0028
- 2 × HCS02.1E-W0054
- 1 × HCS02.1E-W0070
- 1 × HLB01.1C

1 × HLC01.1C

How to check the combination:

- Check sum of type currents to be supplied: 7×28 + 2×54 + 1×70 = 374;
 374 < 402 ⇒ sum of type currents is allowed
- Check sum of drive controller axes: 1×1 + 7×1 + 2×1 + 1×1 = 11; 11 < 12;
 ⇒ max. allowed number of axes is not exceeded
- 3. Check sum of drive controllers with braking resistor: 1×1 + 7×1 + 2×1 + 1×1 + 1×1 = 12; 12 ≤ 12; ⇒ max. allowed number of drive controllers is not exceeded

You may make replacements up to the maximum allowed sum of the type currents. For drive controllers with two motor outputs (e.g. HMD01), the **double** value of their type current applies.

Central Supply HCS03 - Number of Components

B

In central supply, HCS03 converters cannot supply any other HCS03.

Supply unit	2 de	Number o	f IndraDrive	components at cor	nmon DC bus	200
* OLUGIJAS D	HMS01.1N-	HMD01.1N-	Allowed sum of type cur- rents	Allowed number of axes	HLB01.1D	HLC01.1D
central supply via HCS03.1E- W0070 without assigned mains choke HNL01.1	up to W0054	up to W0036	120	12 (1 × HCS03 and 11 × HMS01	1	MAN I GO GOOD
central supply via HCS03.1E- W0070 with assigned mains choke HNL01.1	up to W0054	up to W0036	270	or 1 × HCS03 and 5 × HMD01 and	1	-
central supply via HCS03.1E- W0100 without assigned mains choke HNL01.1	up to W0070	up to W0036	270	1 × HMS01)) J ^{II} III 1	- Hallow
central supply via HCS03.1E- W0100 with assigned mains choke HNL01.1	up to W0070	up to W0036	270	9 224	1	m.
central supply via HCS03.1E- W0150 without assigned mains choke HNL01.1	up to W0070	up to W0036	270	3. S.	1110 (10 th 10 th	-
central supply via HCS03.1E- W0150 with assigned mains choke HNL01.1	up to W0070	up to W0036	270	40 ¹¹ 1.00	1	Naturi G
central supply via HCS03.1E- W0210 without assigned mains choke HNL01.1	up to W0150	up to W0036	270	340.2t	1 AND THE STATE OF	take max. allowed external DC bus capaci-
central supply via HCS03.1E- W0210 with assigned mains choke HNL01.1	up to W0150	up to W0036	270	1141.00	J ¹⁰ 1	tance C _{DCext} into account

not allowed

(1) for explanation see chapter "Types of Mains Connection"

Fig.8-11: Maximum number of IndraDrive C components at common DC bus

HCS03

Example HCS03

Central supply via HCS03.1E-W0070 with assigned mains choke HNL01.1:

- 1 × HCS03.1E-W0070 (supplying device)
- 1 × HMS01.1N-W0054
- 1 × HMS01.1N-W0036
- 1 × HMS01.1N-W0020
- 1 × HMD01.1N-W0036
- 1 × HMD01.1N-W0020
- 2 × HMD01.1N-W0012

How to check the combination:

- 1. Check sum of type currents to be supplied: $54 + 36 + 20 + 2 \times 36 + 2 \times 20 + 2 \times 12 \times 2 = 270$; $270 \le 270 \Rightarrow$ sum of type currents is allowed
- 2. Check sum of drive controller axes: $1 + 1 + 1 + 1 + 1 + 1 \times 2 + 1 \times 2 + 2 \times 2 = 12$; $12 \le 12 \Rightarrow$ max. allowed number of axes is not exceeded


You may make replacements up to the maximum allowed sum of the type currents. For drive controllers with two motor outputs (e.g. HMD01), the **double** value of their type current applies.

Parallel Operation HCS - Group Supply With DC Bus Connection of the Groups

Brief Description

"Group supply with DC bus connection" increases the available regenerative power, the continuous braking resistor and infeeding power in the common DC bus of several drive controllers or drive systems.

Block Diagram



components marked with gray background color: optional, depending on the application

Fig.8-12: Parallel operation HCS

Notes on Project Planning



Parallel operation

Parallel operation is only allowed with drive controllers of the same type current.

B

Connection lines

The connection lines to the drive controllers should preferably have the same impedances in order to achieve balanced load distribution at the power input of the drive controllers. From the common node of the lines, you therefore have to make sure that

- the lengths of the supply lines and
- the cross sections of the supply lines are the same.



Balancing factor

At the common DC bus there is less than the sum of the device-specific performance data available. This particularly applies to the continuous DC bus power $P_{DC\ cont}$ and the continuous regenerative power P_{BD} . The sum is generated with reduced performance data. The reduction takes place with the corresponding balancing factors for parallel operation.

For these data, see Project Planning Manual "Rexroth Indra-Drive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data of power section - DC bus".

Parallel Operation HCS - Number of Components

1.10°	Numbe	lumber of IndraDrive C components at common DC bus					
Converter		HLB01.1		HLC01.1			
HCS02.1E-W0012	-		-	à -			
HCS02.1E-W0028	8	Mor	1	take max. allowed exter-			
HCS02.1E-W0054	6,6	(P)	1	nal DC bus capacitance C _{DCext} into account 1)			
HCS02.1E-W0070	4		1 8	ODCext into docodin			
HCS03.1E-W0070	10		1,44	-114/2			
HCS03.1E-W0100	8		1	4.			
HCS03.1E-W0150	6	20	1	- 19 c			
HCS03.1E-W0210	4	S. S	1	take max. allowed external DC bus capacitance C _{DCext} into account			

1) limited to the value of one converter

- not allowed

Fig.8-13: Parallel operation IndraDrive converters

Example

Allowed parallel operation of HCS03.1E:

6 × HCS03.1E-W00150

8.2.4 Third-Party Supply Units for Power Sections


General Information

HMS01 and HMD01 power sections are designed to be supplied via HMV supply units or HCS converters. In exceptional cases, other supply units (called **third-party supply units** in the following paragraphs) can be used as supply units (e.g. SFT from the product range RD500). Third-party supply units cause loading which requires **additional measures**.

B

The UL listing only applies to use with HMV supply units and HCS converters.

Block Diagram



HLL DC bus choke
MM module bus master
SU third-party supply unit

Fig.8-14: Third-party supply unit with one drive system

Notes on Project Planning

Only HMS01 / HMD01 inverters, as well as additional components HLB and HLC, may be operated with third-party supply units.

Requirements to the third-party supply unit:

- **Minimum inductance**: In the mains connection of the third-party supply unit, install a mains choke with at least 100 µH.
- DC bus voltage: The DC bus voltage of the third-party supply unit must be in the range DC 540 ... 750 V. Take the limit values U_{DC_LIMIT_max} of the supplied devices into account.
- Allowed voltage control: sine-wave modulation with $f_s \ge 4.2 \text{ kHz}$.

Third-party supply units with block modulation or flat-top modulation are **not** allowed.

Requirements to the drive system:

- DC bus choke: Per drive system, use one additional component HLL01.1N for connection to the DC bus of the third-party supply unit.
- DC bus current: Comply with maximum allowed DC bus current of 100 A.
- Additional capacitances: Use at least 50 μFper kW of installed continuous power in the form of DC bus capacitor unit HLC01.
- Leakage capacitance C_{ab}: The leakage capacitance per drive system (motors and motor cables) mustn't be more than a maximum of 500 nF.

- Capacitances against housing C_Y: The total capacitance against housing per drive system mustn't exceed 850 nF and mustn't fall below 300 nF.
- Peak voltage: limit voltage L+ against and L- against to a maximum of 1 kV.
- If the drive system can be disconnected from the third-party supply unit in operation (e.g. in the case of overcurrent by fuses), use DC bus resistor unit HLB01 with W_{max} ≥ W_{max_installiert}.

Notes on Commissioning

Supply units, converters, inverters and additional components of the Rexroth IndraDrive product range have a module bus X1. Via the module bus, information on the status within the drive system is exchanged and the power supply from the mains is influenced.

Supply units of other product ranges have no module bus. With the drive firmware as of version MPx04VRS, you can configure an inverter as module bus master. Integrate the relay contact of the module bus master configured as Bb contact in the control circuit of the power supply in such a way that the circuit is interrupted when the relay contact opens.

For information on configuration and parameterization of the drive controllers, see Functional Description of firmware, chapter "Power Supply" and the involved parameters.

- P-0-0860, Converter configuration
- P-0-0861, Power supply status word

Observe the notes in chapter 9 Control Circuits for the Mains Connection, Seite 111.

8.3 Mains Connection Supply Units and Converters

8.3.1 General Information

The mains connection consists of:

- protection against overload (e.g. fuse for line protection)
- if necessary, an autotransformer or isolating transformer for voltage adjustment
- HNF mains filter
- HNL mains choke
- if necessary, combination of mains filter and HNK mains choke
- mains contactor (partly integrated for HMV)

Notes on Project Planning

By means of the tables in the following chapters, select the mains connection corresponding to the projected supply (HMV or HCS).



Property damage due to mains filter overload!

- Avoid series connection of mains filters as this can cause resonance effects on current and voltage.
- Only operate expressly allowed components at mains filters.

Do not operate any other components, such as additional power supply units and blowers, at HNF mains filters.

With mains filters at compensation units, make sure there aren't any resonance effects on current and voltage.

Observe the allowed harmonic limit values (THD) of the filter components (see chapter 16.3.4 Determining the Allowed Operating Data of Mains Filters, page 336).

Make sure that the nominal current of the mains contactor does not exceed the nominal current of the mains filter.



Control circuit for the mains connection

Observe the chapter 9 Control Circuits for the Mains Connection, page 111.



Mains filters HNF01, NFD at mains grounded via outer conductor

HNF01.1 or NFD03.1 mains filters are not suited for operation on mains grounded via outer conductor. Therefore, use an isolating transformer, if necessary.

Allowed mains connection voltage: see technical data of the respective component



Performance data without mains choke

For operation without mains choke, take the reduced performance data of the supply units and converters into account.

Performance data: see technical data of the respective component



EMC limits values and mains filter selection

Explanation on dimensioning criterion EMC limit value class:

See chapter Limit Values for Line-Based Disturbances, page 139

Calculation formulas for determining the allowed leakage capacitances:

See chapter 16.3.3 Determining the Leakage Capacitance, page 335

The mains filters used have been specifically dimensioned for Rexroth drive systems. For filters by other manufacturers, Rexroth cannot guarantee mains interference suppression with regard to allowed limit values.

The indicated EMC limit values apply to grounded mains. Ungrounded mains might possibly require additional measures.

The listed tables do not contain all practical applications (e.g. use of mains filters and mains chokes by several drive systems or exceeding the maximum motor line lengths). For such cases, mains filters and mains choke can be selected, too. See chapter:

16.3.1 Determining Mains Choke HNL, page 334

• 16.3.2 Determining Mains Filter HNF, page 334

8.3.2 Mains Connection of HMV Supply Units

Mains Connection of HMV Supply Units



For interference-free operation of supply units with regeneration back to the mains (HMVxx.xR), use appropriate HNL mains chokes and HNF mains filters.

Supply unit	Trans	former	Main	s filter	Mains filter, mains switch	NAM!	Mains choke	and the second
40°C	DST (auto)	DLT (isolat- ing)	HNF01.1*- ****- R ****	HNF01.1*- ****- E ****	HNS 02.1	HNL01.1E; HNL01.1E- ****-S	HNL01.1R; HNL01.1R- ****-S	HNL 02.1
HMV01.1E	1900 a	• ,	690 -	- 35	-	-92 ₉₂	-	9500
HMV01.1R	14.	 "H₂ 	(!)	" Play	-	"Hy.	(!)	Taly -
HMV02.1R	•	•	-	-	(!)	-	-	(!)

■ allowed
■ (!) must be used
- not allowed

Fig.8-15: Additional components in the mains connection

Mains Connection of HMV01.1E Supply Units

Supply unit	Mains chokes	Mains filter	Explanation	EMC limit val- ue class to be achieved ¹⁾ : max. leakage capacitance C _{ab_g}
HMV01.1E- W0030	HNL01.1E-0400- N0051	HNF01.1A-F240- E0051	standard combination up to 12 axes (6 HMD01) motor cable lengths: 280 m (f _s = 8 kHz) 110 m (f _s = 12 kHz)	A1: 290 nF
1031101111	without	HNF01.1A-F240- E0051	reduced performance data; see Project Plan- ning Manual	
io,	HNL01.1E-0400- N0051	HNF01.1A-M900- E0051	standard combination up to 21 axes (11 HMD01) motor cable lengths: 1,050 m (f_s = 8 kHz) 270 m (f_s = 12 kHz)	A1: 1100 nF
igp _{unt}	without	HNF01.1A-M900- E0051	reduced performance data; see Project Plan- ning Manual	
19 ¹⁶ 19	HNL01.1E-0400- N0051 with HNL01.1E-5700- S0051	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents	140 j.j.
Wallion .	without	without	not allowed	10.

	~	~2),		- 20°
Supply unit	Mains chokes	Mains filter	Explanation	EMC limit val- ue class to be achieved ¹⁾ : max. leakage capacitance C _{ab_g}
HMV01.1E- W0075	HNL01.1E-0200- N0125	HNF01.1A-F240- E0125	standard combination up to 12 axes (6 HMD01) motor cable lengths: 280 m (f _s = 8 kHz) 110 m (f _s = 12 kHz)	A2.2: 290 nF
Wo.	without	HNF01.1A-F240- E0125	reduced performance data; see Project Plan- ning Manual	
W. C. WHATE	HNL01.1E-0200- N0125	HNF01.1A-M900- E0125	standard combination up to 21 axes (11 HMD01) motor cable lengths: 1,050 m (f_s = 8 kHz) 270 m (f_s = 12 kHz)	A2.2: 1100 nF
	without	HNF01.1A-M900- E0125	reduced performance data; see Project Plan- ning Manual	all of
N NOWNE	HNL01.1E-0200- N0125 with HNL01.1E-2800- S0125	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents	MANIES
rents	without	without	standard combination for 1 axis (1 HMD01) motor cable lengths: 40 m (f _s = 8 kHz) 40 m (f _s = 12 kHz)	A2.1: 40 nF

Supply unit	Mains chokes	Mains filter	Explanation	EMC limit val- ue class to be achieved ¹⁾ : max. leakage capacitance C _{ab_g}
HMV01.1E- W0120	HNL01.1E-0100- N0202	HNF01.1A-F240- E0202	standard combination up to 12 axes (6 HMD01) motor cable lengths: $280 \text{ m } (f_s = 8 \text{ kHz})$ $110 \text{ m } (f_s = 12 \text{ kHz})$	A2.2: 290 nF
"Ottopho"	without	HNF01.1A-F240- E0202	reduced performance data; see Project Plan- ning Manual	Cally Carlot
1989 m	HNL01.1E-0100- N0202	HNF01.1A-M900- E0202	standard combination up to 21 axes (11 HMD01) motor cable lengths: 1,050 m (f_s = 8 kHz) 270 m (f_s = 12 kHz)	A2.2: 1100 nF
automats.	without	HNF01.1A-M900- E0202	reduced performance data; see Project Plan- ning Manual	Carlot Carlot
''9 ₂ ,	HNL01.1E-0100- N0202 with HNL01.1E-3400- S0202	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents	A ^{rt}
, (dbaltonathka b	without	without	standard combination for 1 axis (1 HMD01) motor cable lengths: 40 m (f_s = 8 kHz) 40 m (f_s = 12 kHz)	A2.1: 40 nF

in grounded mains

Fig.8-16: Mains connection HMV01.1E

Mains Connection of HMV01.1R Supply Units

Supply unit	Mains chokes	Mains filter	Explanation	EMC limit value class to be achieved ¹⁾ : max. leakage capacitance C _{ab_g}
HMV01.1R- W0018	HNL01.1R-0980- C0026	HNF01.1A-F240- R0026	standard combination up to 12 axes (6 HMD01) motor cable lengths:	A1: 290 nF
No.21	*13/4.0.d.)		280 m (f _s = 8 kHz) 110 m (f _s = 12 kHz)	
man.il	HNL01.1R-0980- C0026	HNF01.1A-M900- R0026	standard combination up to 21 axes (11 HMD01) motor cable lengths: 1,050 m (f _s = 8 kHz)	A1: 1100 nF
reg.	HNL01.1R-0980- C0026 with HNL01.1R-4200- S0026	customer-side	270 m (f _s = 12 kHz) standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents	''' '' '' '' '' '' '' '' '' '' '' '' ''
HMV01.1R- W0045	HNL01.1R-0590- C0065	HNF01.1A-F240- R0065	standard combination up to 12 axes (6 HMD01) motor cable lengths: 280 m (f _s = 8 kHz) 110 m (f _s = 12 kHz)	A1: 290 nF
No. C. Herri	HNL01.1R-0590- C0065	HNF01.1A-M900- R0065	standard combination up to 21 axes (11 HMD01) motor cable lengths: $1,050 \text{ m} \text{ (}f_s = 8 \text{ kHz)}$ 270 m ($f_s = 12 \text{ kHz}$)	A1: 1100 nF
May I	HNL01.1R-0590- C0065 with HNL01.1R-6300- S0065	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents	unnildballoff

Supply unit	Mains chokes	Mains filter	Explanation	EMC limit value class to be achieved ¹⁾ : max. leakage capacitance C _{ab_g}
HMV01.1R- W0065	HNL01.1R-0540- C0094	HNF01.1A-F240- R0094	standard combination up to 12 axes (6 HMD01) motor cable lengths: 280 m (f _s = 8 kHz) 110 m (f _s = 12 kHz)	A2.2: 290 nF
iggangungaye.	HNL01.1R-0540- C0094	HNF01.1A-M900- R0094	standard combination up to 21 axes (11 HMD01) motor cable lengths: 1,050 m (f_s = 8 kHz) 270 m (f_s = 12 kHz)	A2.2: 1100 nF
"OLIGIANO "	HNL01.1R-0540- C0094 with HNL01.1R-3000- S0094	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents	Kiily Kill
HMV01.1R- W0120	HNL01.1R-0300- C0180	HNF01.1A-H350- R0180	standard combination up to 8 axes (4 HMD01) motor cable lengths: 350 m (f _s = 8 kHz)	n ^a

in grounded mains

Fig.8-17: Mains connection phase HMV01.1R

Mains Connection of HMV02.1R Supply Units

Supply unit	Mains chokes	Mains filter	Explanation	EMC limit val- ue class to be achieved ¹⁾ : leakage ca- pacitance C _{ab_g}
HMV02.1R- W0015	HNL02.1R-0980- C0023	HNS02.1A-Q200- R0023	standard combination up to 12 axes motor cable lengths: 150 m (f _s = 8 kHz)	A2.1

in grounded mains

Fig.8-18: Mains connection phase HMV02.1R

8.3.3 Mains Connection for HCS Converters

Mains Connection for Converters - Overview

Converter	Transformer		Mains filter			Mains choke		
5	DST (auto)	DLT (isolat- ing)	NFD 03.1	HNF01.1*- ****- R ****	HNF01.1*- ****- E ****	HNK 01.1	HNL01.1 E ; HNL01.1 E - ****-S	HNL01.1R; HNL01.1R- ****-S
HCS02.1E	1.0° -	- "4 ₁ ;	o ■	■ 1)	■ 1)	"M; (c)	•	My Co
HCS03.1E	•	- 20,	-	1)	■ 1)	20	•	- 72

allowed

not allowed

observe the note "Minimum capacitance at the DC bus against ground required!"

Fig.8-19: Additional components in the mains connection of converters

B

Minimum capacitance at the DC bus against ground required!

When using HNF01.1 mains filters at HCS02.1 and HCS03.1, make sure that the condition of minimum capacitances against ground is complied with at the DC bus of the combined system.

The minimum capacitance is **330 nF** against ground each at L+ and L-.

If the system does not achieve the minimum capacitance, use the accessory HAS04.

Accessory HAS04

Drive controllers already have capacitances C_v against ground at L+ and L-.

See Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Mechanical System and Mounting" → "Dimensions, Mass, Insulation, Sound Pressure Level"

The integrated capacitances C_y of HCS02 or HCS03 converters are not sufficient for operating HNF01 mains filters. In systems combined of several drive controllers, higher capacitances C_y take effect. Use the HAS04 accessory depending on the involved components.

Drive controller	Capacitance C _Y against ground in nF ¹⁾	Use of HAS04
HMS01.1N: < W0110	2 × 68	number of HMS01 ≤ 3
HMS01.1N: ≥ W0110	2 × 100	number of HMS01 ≤ 3
HMS02	2 × 68	number of HMS01 ≤ 3
HMD01	2 × 68	number of HMS01 ≤ 3
HCS02	2 × 100	number of HCS02 ≤ 4 check other combinations

Drive controller	Capacitance C _Y against ground in nF 1)	Use of HAS04
HCS03	2 × 100	number of HCS03 ≤ 4 check other combinations
KCU01	2 × 470	not required

see also documentation "Supply Units and Power Sections - Project Planning Manual"

Fig.8-20: Capacitances Cy, capacitances at L+ and L- against ground

Accessory HAS04	For converter
HAS04.1-001 (2 × 470 nF)	HCS02
HAS04.1-002 (2 × 470 nF)	HCS03

Fig.8-21: Assignment HAS04 accessory

Mains Connection for HCS02 Converters

B

With HCS02.1E drive controllers, the **limit value class A2.1** (see "Limit Values for Line-Based Disturbances") can already be achieved in grounded mains **without using mains filters**.

Observe notes in chapter 11 Arranging the Components in the Control Cabinet , page 145.

Converter	Mains chokes	Mains filter	Explanation	EMC limit val- ue class to be achieved ²⁾ : max. leakage capacitance C _{ab_g}
HCS02.1E- W0012	HNL01.1E-1000- N0012 (optional)	NFD03.1-480-007	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)	A2.1
"CUSTANO"	HNL01.1E-1000- N0020	NFD03.1-480-016	group supply up to 6 HCS02 motor cable lengths: 120 m (f _s = 8 kHz)	A2.2: 60 nF A1: 50 nF B1: 40 nF
HCS02.1E- W0028	HNL01.1E-1000- N0012 (optional)	NFD03.1-480-016	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)	A2.1
utonatika o	HNL01.1E-0600- N0032	NFD03.1-480-030	group supply up to 6 HCS02 motor cable lengths: 120 m (f _s = 8 kHz)	A2.2: 80 nF A1: 50 nF

	777	all leaves and a second		all a
Converter	Mains chokes	Mains filter	Explanation	EMC limit value class to be achieved ²⁾ : max. leakage capacitance C _{ab_g}
HCS02.1E- W0054	HNL01.1E-1000- N0020	NFD03.1-480-030	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)	A2.1
Mary 1	HNL01.1E-1000- N0020	NFD03.1-480-030	central supply up to 6 axes motor cable lengths: 120 m (f _s = 8 kHz)	A2.2: 80 nF A1: 50 nF
nan!	HNL01.1E-1000- N0020	NFD03.1-480-055	central supply up to 6 axes motor cable lengths: 120 m (f _s = 8 kHz)	A2.2: 110 nF A1: 70 nF B1: 55 nF
160 P	HNL01.1E-1000- N0020	HNF01.1A-F240- R0026 ¹⁾	central supply up to 6 axes motor cable lengths: 240 m (f _s = 8 kHz)	A2.2: 350 nF A1: 300 nF B1: 89 nF
nam.i	HNL01.1E-1000- N0020	HNF01.1A-M900- R0026 ¹⁾	central supply up to 12 axes motor cable lengths: 900 m (f _s = 8 kHz)	A2.2: 350 nF
140.tj	HNL01.1E-1000- N0020	HNF01.1A-M900- E0051 ¹⁾	central supply up to 12 axes motor cable lengths: 900 m (f _s = 8 kHz)	A2.2: 350 nF A1: 350 nF B1: 350 nF
HCS02.1E- W0070	HNL01.1E-0600- N0032	NFD03.1-480-055	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)	A2.1
140.D	HNL01.1E-0600- N0032	NFD03.1-480-055	central supply up to 6 axes motor cable lengths: 120 m (f _s = 8 kHz)	A2.2: 100 nF A1: 70 nF B1: 52 nF
Way.	HNL01.1E-0600- N0032	NFD03.1-480-075	central supply up to 6 axes motor cable lengths: 120 m (f _s = 8 kHz)	A2.2: 110 nF A1: 70 nF B1: 55 nF
Warg.	HNL01.1E-0600- N0032	HNF01.1A-M900- E0051 ¹⁾	central supply up to 12 axes motor cable lengths: 900 m (f _s = 8 kHz)	A2.2: 350 nF

use HAS04.1-002 in grounded mains Fig.8-22: Mains connection HCS02

Mains Connection for HCS03 Converters

Converter	Mains chokes	Mains filter	Explanation
HCS03.1E- W0070	HNK01.1A-A	075-E0050	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)
ig _{Dane}	HNL01.1E-0571-N0050	Programme and the state of the	standard for operating one drive controller without mains filter
ka.pl	HNL01.1E-0571-N0050	HNF01.1A-F240-E0051 ¹⁾	central supply up to 6 axes (2 HMD01) motor cable lengths: 240 m (f _s = 8 kHz)
(dbattoffats)	HNL01.1E-0571-N0050	HNF01.1A-M900-E0051 ¹⁾	central supply up to 12 axes (5 HMD01) motor cable lengths: 900 m (f _s = 8 kHz)
, g	HNL01.1E-0400-N0051 with HNL01.1E-5700-S0051	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents
HCS03.1E- W0100	HNK01.1A-A(075-E0080	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)
	HNL01.1E-0362-N0080	W _W	standard for operating one drive controller without mains filter
outomatyka pl	HNL01.1E-0362-N0080	HNF01.1A-F240-E0125 ¹⁾	central supply up to 6 axes (2 HMD01) motor cable lengths: 240 m (f _s = 8 kHz)
'Go,	HNL01.1E-0362-N0080	HNF01.1A-M900-E0125 ¹⁾	central supply up to 12 axes (5 HMD01) motor cable lengths: 900 m (f _s = 8 kHz)
"OLUGAKO" by	HNL01.1E-0362-N0080 with HNL01.1E-2800-S0125	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents

Converter	Mains chokes	Mains filter	Explanation
HCS03.1E- W0150	HNK01.1A-A	075-E0106	standard combination for 1 converter motor cable length:
18. S.	100		75 m (f _s = 4 kHz)
9.	HNL01.1E-0240-N0106	without	standard for operating one drive controller without mains filter
"HAHH" (QC,	HNL01.1E-0240-N0106	HNF01.1A-F240-E0125 ¹⁾	central supply up to 6 axes (2 HMD01) motor cable lengths: 240 m (f _s = 8 kHz);
No. of	HNL01.1E-0240-N0106	HNF01.1A-M900-E0125 ¹⁾	central supply up to 12 axes (5 HMD01) motor cable lengths: 900 m (f _s = 8 kHz)
	HNL01.1E-0240-N0106 with HNL01.1E-2800-S0125	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents
HCS03.1E- W0210	HNK01.1A-A	075-E0146	standard combination for 1 converter motor cable length: 75 m (f _s = 4 kHz)
1800	HNL01.1E-0170-N0146	without	standard for operating one drive controller without mains filter
Manuel Ma	HNL01.1E-0170-N0146	HNF01.1A-F240-E0202 ¹⁾	central supply up to 6 axes (2 HMD01) motor cable lengths: 240 m (f _s = 8 kHz)
' (<u>R</u> ₀)	HNL01.1E-0170-N0146	HNF01.1A-M900-E0202 ¹⁾	central supply up to 12 axes (5 HMD01) motor cable lengths: 900 m (f _s = 8 kHz)
White.	HNL01.1E-0170-N0146 with HNL01.1E-3400-S0202	customer-side	standard mains choke connected in series with current-compensated mains choke to reduce line-frequency leakage currents

1) use HAS04.1-002 Fig.8-23: Mains connection HCS03

8.4 Additional Components

8.4.1 Additional Components at the DC Bus

General Information

Converters and supply units basically differ in the following features:

- braking resistor integrated
- possible connection for external HLR braking resistor
- operation of DC bus resistor unit HLB
- operation of DC bus capacitor unit HLC

Allowed Combinations

The table below shows which additional components are allowed at the DC bus of HMV supply units and HCS converters.

Supply unit or converter	HLB01.1C	HLB01.1D	HLC01.1C	HLC01.1D	HLR01.1
HMV01.1E	- -	24;0 =	= 2)	- ₁₈₄ 50	-
HMV01.1R	-	77,	= 2)	- 73°	- 2
HMV02.1R	- 3	- 🐧	-	- ĝ -	3
HCS02.1	~ 4/L	2)	•	= 2)	■3)
HCS03.1	Total	*10L		■ 1)	■4)

- allowed
- not allowed
- only HCS03.1E-...-W0210
- different mounting depths: control cabinet adapter HAS03 required
- 3) HCS02.1E-W0054, -W0070 (standard equipment: braking transistor integrated)
- 4) HCS03.1E in optional design -xxBx (integrated braking transistor) required

Fig.8-24: Combinations with additional components



HCS03.1 with HLC01

In the HCS03 product line, it is allowed to operate external capacitances at the DC bus for the HCS03.1E-**W0210** type.

Observe the data C_{DCext} in the Project Planning Manual "Rexorth IndraDrive Supply Units and Power Sections" → "HCS03 Power Sections" → "Technical Data" → "Basic Data" → Data of power section - DC bus

Notes on Project Planning for HLR Braking Resistors



High temperatures in the proximity of braking resistors!

Mount the braking resistors to temperature-resistant mounting surfaces in such a way that the air can freely enter and escape and heat does not accumulate.

Take the minimum distances d_{top} , d_{bot} and d_{hor} into account.

Take into account that the temperatures in the range of the indicated minimum distances can be above 250 °C.

Leave sufficient distance to combustible objects and take into account that braking resistors dissipate a lot of heat.

Make sure there is free cooling air supply at the bottom d_{bot} and cooling air discharge at the top d_{top} .

The space must be able to discharge the energy converted by the braking resistor.

Orientation guide for selecting additional components HLR, HLB

Criterion	DC bus resistor units HLB	Braking resistor HLR
regenerative operation with great energy contents, e.g. deceleration of great centrifugal masses at centrifuges long braking processes for crane lifting gears	take energy absorption capacity and continuous power into account	type of construction N check use of HMVxx.xR
kinetic energy is generated in control cabinet and can be dissi- pated	"Ake d	type of construction A
kinetic energy cannot be dissipa- ted in control cabinet		type of construction N observe degree of protection
quick discharge of DC bus required DC bus short circuit device	all Maria	ight d
deceleration of synchronous motors in the case of error "mains failure"	• Maridianica	- HHIGIZITE
supply unit HMV01.1R-W0120	₹0	<u>1</u>
converter HCS02 selected	<u>₫</u> •	<u>₫</u> -
converter HCS03 selected	913/h •	option -xxBx required

■ recommended

suited to a limited extent

- not allowed Fig.8-25: Orientation guide

Required type data

To select an appropriate HLR braking resistor, the following type data of the application are required:

- peak regenerative power P_{RS, Anlage}
- continuous regenerative power P_{RD, Anlage}
- regenerative power W_{R, Anlage}

For calculating the type data, see chapter 16.1 Determining the Appropriate Drive Controller, page 319.

R.

HCS02, HCS03 with HLR01 and simultaneously HLB01

- The continuous power of the selected HLR01 has to be at least as high as the continuous power of the HLB used.
- Due to differences in balance, the total continuous power is lower than the sum of the individual continuous powers. The balancing factor of 0.8 is regarded as the guide value.

B

Function of integrated braking resistor in HCS02 for operation with HLR01

Braking resistors have been integrated in HCS02 drive controllers. When operating external HLR01 baking resistors, the integrated braking resistors are not loaded.

See also parameter

- P-0-0859, Data of internal braking resistor
- P-0-0860, Converter configuration

B

Observe degree of protection!

When mounted outdoor or at the outside of the control cabinet, observe the degree of protection IP20 of the braking resistor.

Protect the devices against intrusion of water.

B

Protection against overload!

The HCS drive controller monitors the external braking resistor by means of the firmware which calculates a thermal image of the current braking power. When the limit values for the thermal image are exceeded, the converter switches off with the error "F8820 Braking resistor overload" to protect the baking resistor against overload.

- Exclusively operate the combinations of converter braking resistor type listed below.
- At the drive controllers HCS02 and HCS03, parameterize the performance data of the selected braking resistor in parameter "P-0-0858, Data of external braking resistor". For this purpose, from the technical data take the data on: resistance value, braking resistor continuous power and maximum regenerative power to be absorbed.
- Activate the selected braking resistor by setting, in parameter "P-0-0860, Converter configuration", bit 8 = 1.

Braking Resistors HLR01 for HCS02

Converter	Braking resistor type ¹⁾	Type of construction 2)	Type Dimensions 3)	
HCS02.1E-W0054- A-03-xNNx	HLR01.1N-01K8-N40R0	N for free assembly	A7	
HCS02.1E-W0054- A-03-xNNx	HLR01.1N-03K8-N40R0	N for free assembly	B1 ,,,,,	
HCS02.1E-W0070- A-03-xNNx	HLR01.1N-02K4-N28R0	N for free assembly	A8	
HCS02.1E-W0070- A-03-xNNx	HLR01.1N-05K5-N28R0	N for free assembly	B2	

- 1) complete type with: A-007-NNNN
- see Project Planning Manual "Rexroth IndraDrive Additional Components", type code HLR
- see Project Planning Manual "Rexroth IndraDrive Additional Components", dimensions tables HLR

Fig.8-26: Assignment braking resistors HLR - HCS02

Braking Resistors HLR01 for HCS03

Converter	verter Braking resistor type ¹⁾		Type Dimensions ³⁾	
HCS03.1E-W0070- A-05-xNBV	HLR01.1A-0300-N17R5	A for de- vice mounting	. «	
HCS03.1E-W0100- A-05-xNBV	HLR01.1A-0470-N11R7	A for de- vice mounting	see correspond- ing dimensional	
HCS03.1E-W0150- A-05-xNBV	HLR01.1A-0780-N07R0	A for de- vice mounting	drawing HLR01.1N	
HCS03.1E-W0210- A-05-xNBV	HLR01.1A-1K08-N05R0	A for de- vice mounting	, diferile f	
HCS03.1E-W0070- A-05-xNBV	HLR01.1N-01K6-N18R0	N for free assembly	A5	
HCS03.1E-W0100- A-05-xNBV	HLR01.1N-02K0-N15R0	N for free assembly	A6	
HCS03.1E-W0150- A-05-xNBV	HLR01.1N-04K5-N07R4	N for free assembly	B1	
HCS03.1E-W0210- A-05-xNBV	HLR01.1N-06K5-N06R1	N for free assembly	B2	
HCS03.1E-W0070- A-05-xNBV	HLR01.1N-03K5-N19R0	N for free assembly	B1	
HCS03.1E-W0100- A-05-xNBV	HLR01.1N-05K0-N15R0	N for free assembly	B2	
HCS03.1E-W0150- A-05-xNBV	HLR01.1N-08K5-N08R0	N for free assembly	В3	
HCS03.1E-W0210- A-05-xNBV	HLR01.1N-12K5-N05R5	N for free assembly	B4	
HCS03.1E-W0070- A-05-xNBV	HLR01.1N-04K5-N18R0	N for free assembly	B2	
HCS03.1E-W0100- A-05-xNBV	HLR01.1N-07K0-N14R0	N for free assembly	В3	
HCS03.1E-W0150- A-05-xNBV	HLR01.1N-11K0-N07R3	N for free assembly	B3	
HCS03.1E-W0210- A-05-xNBV	HLR01.1N-17K0-N05R1	N for free assembly	B5	
HCS03.1E-W0070- A-05-xNBV	HLR01.1N-06K5-N18R0	N for free assembly	B2	
HCS03.1E-W0100- A-05-xNBV	HLR01.1N-09K5-N13R0	N for free assembly	B3	
HCS03.1E-W0150- A-05-xNBV	HLR01.1N-15K0-N08R1	N for free assembly	B4	

Converter	Braking resistor type ¹⁾	Type of construction ²⁾	Type Dimensions 3)
HCS03.1E-W0210- A-05-xNBV	HLR01.1N-23K0-N05R5	N for free assembly	C2
HCS03.1E-W0070- A-05-xNBV	HLR01.1N-10K0-N18R0	N for free assembly	B3
HCS03.1E-W0100- A-05-xNBV	HLR01.1N-14K5-N13R0	N for free assembly	B4
HCS03.1E-W0150- A-05-xNBV	HLR01.1N-24K0-N07R2	N for free assembly	СЗ
HCS03.1E-W0210- A-05-xNBV	HLR01.1N-36K0-N05R4	N for free assembly	C4

- complete type with: A-007-NNNN
- see Project Planning Manual "Rexroth IndraDrive Additional Components",type code HLR 2)
- see Project Planning Manual "Rexroth IndraDrive Additional Compo-3)
- nents", dimensions tables HLR
- Fig.8-27: Assignment braking resistors HLR - HCS03

8.4.2 Additional Components at the Motor Output

General Information

In conjunction with long motor cables, the steep switching edges at the motor output of the drive controllers can cause transient overvoltages and high rise of voltage at the motor.

Motor Filters HMF01



Damage caused by too high switching frequency!

Only operate HMF01 motor filters up to the maximum allowed switching frequency f_s of 4 kHz.

Motor filter HMF01	Drive controller
HMF01.1A-N0K2-M0012	HCS02.1E-W0012
HMF01.1A-N0K2-M0028	HCS02.1E-W0028
HMF01.1A-N0K2-D0045	HCS03.1E-W0070
HMF01.1A-N0K2-D0073	HCS03.1E-W0100
HMF01.1A-N0K2-D0095	HCS03.1E-W0150
HMF01.1A-N0K2-D0145	HCS03.1E-W0210

Fig.8-28: Assignment HMF01 to HCS03

8.5 Control Section and Firmware for Drive Controllers

8.5.1 General Information

The modular structure of the IndraDrive controllers allows a multitude of combinations of control sections and drive controllers. Depending on the firmware design, the firmware of the Rexroth IndraDrive product range supports the combinations of control section and power section listed below.

Allowed Combination Control Section - Firmware

190	186	Firmware	120
Control section	МРВ	MPH	MPD
CSH01.1-C ¹⁾		_	
CSH01.2-C 1)	- W25.		S, -
CSB01.1-N ²⁾	-Carolina -	- West,	- 🦽
CSB01.1-C ¹⁾	¹⁰ 800.■	1123116	- 709/1
CDB01.1-C ¹⁾	"14' ₁₀₀ " -	"MAJES"	77-1100

allowednot allowed

control section can be configured
 control section cannot be configured
 Combination control section - firmware

Allowed Combination Control Section - Power Section

Power Section	HMS01	HMS02	HMD01	HCS02	HCS03
Control section	Myles		Thy.		Tyles
CSH01.1-C ¹⁾	14.	_	4.	_	Z
CSH01.2C ¹⁾	•	, di	-	20	•
CSB01.1-N ²⁾	•	282	-	- ig/6-	-
CSB01.1-C ¹⁾	•	10 =	- ,5		-770
CDB01.1-C ¹⁾	- (90°	-	■ 200°	-	1900

allowednot allowed

control section can be configured
 control section cannot be configured
 Fig. 8-30: Combination control section - power section



The control section of a drive controller mustn't be mounted and dismounted more than a maximum of 20 times. If this number is exceeded, the electrical data of the internal connection can be above the specified minimum requirements. This can cause malfunction of the drive controllers.

8.5.2 Required Equipment of Control Sections With Optional Modules for Evaluating Encoder Systems

The control sections of the Rexroth IndraDrive product range support different encoder systems. The table below shows the assignment of the encoder system to the required equipment of the control section with options.



Operating other encoder systems than the ones listed above requires detailed control of the technical data of the encoder system used and the interface specification of the control section.

When using third-party encoders, observe that the optional modules provide different supply voltages.

Encoder sys- tem 1)	Brief description of encoder system (informal)		nal mod er evalu	Cable for direct connection ²⁾	
		ENS	EN1	EN2	-
R0	resolver	12.0	-	-	IKS4043
R1	resolver with integrated absolute multi-turn encoder	2 ₂ ,-	-	-	IKS4043
S0	optical encoder single-turn IIC, 512 increments, supply voltage 8 V	-	-	-35	IKS4042
S1	optical encoder single-turn HIPERFACE, 128 increments, supply voltage 712 V	•	-10	41.C.	RKG4200
S2	optical encoder single-turn EnDat2.1, 2048 increments, supply voltage 12 V	-0	-	_	RKG4200
МО	optical encoder multi-turn absolute IIC, 512 increments, supply voltage 8 V	27.	-	- 85	IKS4042
M1	optical encoder multi-turn absolute HIPERFACE, 128 increments, supply voltage 7 12 V	-	- 3	41900	RKG4200
M2	optical encoder multi-turn absolute EnDat2.1, 2048 increments, supply voltage 12V	-	11,	_	RKG4200
C0 No	optical encoder incremental 1 V _{pp} , 2048 increments (sin/cos)	M3.K	-	•	RKG0014
SHL01.1	Hall sensor box for position detection of primary part of, for example, IndraDyn L and LSF motors	-	3)	~81 <u>1</u> 1	IKS4042
SHL02.1	Hall sensor box for position detection of primary part of, for example,	-	4)	410	IKS4042
(preliminary data)	IndraDyn L and LSF motors	•	- 20,	-	RKG0027
12°S	Rexroth ServoDyn D servo motors SF	10.9			15,5
STG	single-turn encoder, absolute	20,		-	RKG0015
MTG	multi-turn encoder, 4096 revs. absolute			-375	RKG0015
0.	Rexroth ServoDyn D servo motors SR		3	4:0.	
	resolver	_	1/1/4	-	- 4

- allowed
- not allowed
- see note below
- without extension and control cabinet duct
- up to MPx04VRS, only allowed on option 2 (X8)
- 1) 2) 3) 4) up to MPx04VRS, only allowed on option 2 (X8); as of MPx05VRS configurable

Fig.8-31: Combination control section equipment - motor encoder

B For the kind of encoder system, see the type code of the selected




Fig.8-32: Type code section of motor

8.6 Combination with Other Rexroth Components

8.6.1 Combination with Components of the Control Range Rexroth IndraControl V

Operator Terminals VCP

The VCP operator terminals allow comfortable operation of the Rexroth Indra-Drive drive system with the IndraControl V control range.

The operator terminals VCP02, VCP05, VCP08, VCP20 and VCP25 are suited for control cabinet mounting and operated via the serial interface RS232 (X2) of the control sections.

The comfort control panel VCP01 is operated directly at the drive controller at the connection "H1". It then replaces the supplied standard control panel. The scope of functions is described in the Operating Instructions "Rexroth Indra-Drive C Drive Controllers HCS02.1, HCS03.1".



Simultaneous operation of VCP operator terminals and standard control panels or comfort control panels is allowed.

8.6.2 SERCOS Analog Converter

General Information

To modernize machines the drive range Rexroth IndraDrive provides the possibility of operating drive controllers of the "ANAX" and "Diax 02" ranges with analog command value input.

SERCOS Analog Converter

The SERCOS analog converter is used to

- connect control units with SERCOS interface to components with analog interface
- convert SERCOS position command values to analog speed command values

The SERCOS analog converter consists of:

- housing for HAC01.1-002 control sections
- configurable control section with SERCOS master communication
 - for MAC motors at TDM drive controllers:
 BASIC CDB01.1C-SE-EN1-EN1-MA1-MA1--NN-S-NN-FW

- for MDD motors at DDS drive controllers:
 BASIC CDB01.1C-SE-EN2-EN2-MA1-MA1--NN-S-NN-FW
- BASIC CDB01.1C-SE-ENS-ENS-MA1-MA1-NN-S-NN-FW (preliminary)
- firmware e.g. FWA-INDRV*-MPD-04VRS-**-*-***
- optional accessory HAS01.1-065-NNN-CN



Make sure that parameter "P-0-0860, Converter configuration" has been set to operation as "SERCOS analog converter" (bit 15 = 1). Wrong setting will generate the error message "F8091 Power section defective".

8.7 Connection Cables to Motor

8.7.1 General Information

The connection from drive controller to motor is established by means of two cables:

- motor cable (power cable)
- encoder cable

The motor cable contains lines to connect the drive controller

- to the motor windings
- to the motor holding brake
- to the temperature measurement system of the motor




Fig.8-33: Power cable to connect drive controller to motor

啜

Use shielded motor cables of the RKL line for Rexroth IndraDrive systems.

For selecting the motor cables and other connections (e.g. encoder cables), use the documentation "Rexroth Connection Cables - Selection Data".

8.7.2 Motor Cables

General Information

For projecting and selecting the motor cable, observe the following aspects:

- required cross section depends on occurring loading with continuous current and peak current
 - allowed length depends on PWM frequency, output filter and shielding
- length due to voltage drop on connection line to motor brake
- other mechanical requirements resulting from use of motor cable, such as bending radiuses, material compatibility; see documentation "Rexroth Connection Cables - Selection Data".

Required Cross Section

To find the appropriate cable for the selected combination of motor and drive controller, see documentation "Rexroth Connection Cables - Selection Data".

Allowed Length of Motor Cable

The length of the motor power cable is limited to protect the drive controllers. The longer the motor cable and the higher the switching frequency f_s of the drive controller which has been set, the higher the occurring losses.



Observe that the allowed motor cable length depends on the switching frequency f_s of the power output stage which has been set. As a matter of principle, the higher the switching frequency, the shorter the allowed cable length (to protect the drive controllers against overload).

Only set such switching frequencies which are supported by the involved components! Observe the technical data for drive controllers and motors.

See also Parameter Description "P-0-0001, Switching frequency of the power output stage".

Allowed cable lengths at ambient temperature $T_{a_work} \le 40$ °C according to EN 60 204:

PWM frequency / kHz	Allowed cable length / m		
Wiles.	without or	utput filter	with output filter ³⁾
1031JIC	shielded	unshi	elded ¹⁾
2 ²⁾	100	175	200
4	75	150	200
8	38	150	onot allowed

PWM frequency / kHz	ali.		
12	25	not allowed	not allowed
16	18	not allowed	not allowed

 only allowed for HCS drive controllers, see also note below "Unshielded motor cables"

depending on the drive controller which is used

3) additional components HMF or HML

Fig.8-34: Line lengths

B

Unshielded motor cables

Operation with unshielded motor cables

- aims at applications with "sensorless operation" (open-loop operation)
- does not include the control voltage lines to the motor; brake supply and evaluation of the temperature sensors in the motor might possibly require further measures
- requires additional measures with regard to EMC on the part of the operating company



For lines connected in parallel, half the indicated lengths apply.

Voltage Drop on Connection to Motor Holding Brake

The motor holding brake is controlled via the drive controller. For this purpose, the 24V supply is connected to the output at the connection point X6. To operate the motor holding brake reliably, observe its requirements on voltage supply.

For operating the integrated motor holding brakes of the motor line Rexroth IndraDyn at Rexroth IndraDrive controllers with Rexroth connection cables, the data of 24V supply are considered as guide values.

For the data of 24V supply, see Project Planning Manual "Rexroth Indra-Drive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → "Data for control voltage supply".

Mechanical Requirements

Depending on the application, there are different requirements.

See the technical data of the cables in the documentation "Rexroth Connection Cables - Selection Data" for whether the properties comply with the requirements.

Third-Party Power Cables

Requirements on third-party motor power cables:

Maximum allowed cable length at A1, A2, A3:

see chapter 8.7 Connection Cables to Motor, page 106

Maximum allowed capacitance per unit length at A1, A2, A3:

against ground, each: 0.5 nF/m

against each other: 0.5 nF/m

Maximum allowed inductance per unit length at A1, A2, A3:

• 100 nH/m each



If you use third-party motor cables not corresponding to the requirements, Rexroth's guarantee for the drive system will expire. Use ready-made Rexroth cables.

To select the cables, use the documentation "Rexroth Connection Cables - Selection Data".

8.7.3 Encoder Cables

To select the cables, use the documentation "Rexroth Connection Cables - Selection Data".

8.8 Using Rexroth IndraDyn Motors

8.8.1 Rexroth IndraDyn H – Frameless Synchronous Spindle Motors

When selecting the drive controllers and supply units, make sure that, when using **MBS** motors, the occurring peak power does not cause overvoltage in the DC bus.

Therefore, make sure for your selection that the developed peak power of the motor is smaller than the peak power (or sum of peak powers) of the braking resistors at the DC bus. Take into account that, in particular during operation in the field weakening range, high peak powers occur when control voltage fails.

The assignment table below shows the supply units or drive controllers basically suited for operating MBS motors.

Drive controller or supply unit	IndraDyn H	Notes
7192	MBS	120
HMV01	- 1212,	H _{II}
HMV02		
HCS02	"Milling Age"	capacity P _{BS} of braking resistor is too low for occurring peak power
HCS03	-	720°

allowednot allowedFig.8-35: Combinations

9 Control Circuits for the Mains Connection

9.1 General Information

The controls of mains contactor and DC bus short circuit for supply units and drive controllers suggested in this documentation describe the **functional principles**.



The selection of the control and its effects depend on the extent of the functions and the operating sequence of the installation or machine. The selection of the control falls to the installation or machine manufacturer's responsibility.

9.2 Mains Contactor, Bb Contact

The central components in the control circuit for the mains connection are:

- mains contactor
- Bb contact

Mains Contactor

Mains contactors in the power circuit of the mains connection switch the power supply. In the case of error, mains contactors interrupt the energy flow from the supply mains and therewith the power supply of the drive controllers.

When the drive system is supplied via another circuit, e.g. in regenerative form via **permanently** driven motor:

- Integrate this supply in the control circuit for the mains connection.
- Take this into account when selecting the drive controllers and additional components.



Risk of fire caused by the "sacrificing behavior" of the ZKS stage!

The "ZKS" input activates the function "DC bus short circuit", when there hasn't any voltage been applied and when there isn't any current flowing to the input. This status occurs both in the case of wire break and when the 24V supply fails.

When the 24V supply fails in applications in which energy does not only get to the DC bus via the mains connection, but also via regeneratively operated motors (e.g. following-on rollers), the ZKS stage converts this energy into heat until it is destroyed ("sacrificing behavior").

Counter measures with such applications:

- Do not use drive controllers with integrated ZKS stage or
- buffer the 24V supply (e.g. by means of a UPS) to evaluate the monitor and switch off the energy flow in the case of error.

Switching off the power supply protects the supply units and drive controllers against permanently present error states and damage being caused by the persistent effect of these error states.

The mains contactor does not replace overcurrent protection devices connected in the incoming circuit, but is a functional complement. The mains contactor itself needs overcurrent protection to allow reliably operating it after switch-off processes.

In conjunction with the corresponding "control circuit for the mains connection", the mains contactor only switches the DC bus voltage to the drive controllers when they are ready to consume power voltage and when there isn't any error present.

In order that the drive controllers can signal their status, they must be supplied with the 24V control voltage.

The following scenarios are typical cases in which the control circuit for the mains connection is to switch off the mains contactor and lead to the power supply being switched off:

- short circuit at the output of the inverters with error "F8060 Overcurrent in power section"
- switch-on upon activated DC bus short circuit (ZKS) with error message "F2820 Braking resistor overload"
- operation at mains voltages outside of the allowed range with error message "F2815 Overvoltage in mains"

See also Troubleshooting Guide of the firmware used.

Bb Contact

The mains contactor has to be controlled depending on the error status of the supply unit or drive controller.

At the control section of the HCS drive controllers and at the supply units, there is an isolated contact available for this purpose (relay contact Rel1) that has been configured as Bb contact in the condition as supplied. When the Bb contact closes, the drive or drive system is ready for power on.

For detailed information on the Bb contact, see Project Planning Manual "Rexroth IndraDrive Drive Controllers Control Sections".



Danger of consequential damage!

Make sure that the mains contactor interrupts power supply from the mains when the Bb contact opens.



Load of Bb Contact

Observe the load capability limits of the Bb contact (see Project Planning Manual "Rexroth IndraDrive Control Sections" for the control section used [connection point X31.1, X31.2]).

Control contactors with AC excitation and contactors exceeding the load capability limits of the involved contact elements (Bb contacts etc.) via contactor relays.



See also Functional Description of firmware: Power Supply



Suppressor circuit for contactor coil

When the mains contactor is switched off, the contactor coil causes overvoltages. These overvoltages may result in premature failure of the Bb contact. To attenuate overvoltages, use overvoltage limiters with diode combination.

Varistors and RC elements are not allowed as suppressor circuit. Varistors are subject to aging and increase their reverse currents. RC elements overload the switching capacity of the Bb contact. This results in premature failure of the connected components and devices.

Fig.9-1: Recommended suppressor circuit

Switching on the Power Supply

Switch-on sequence:

- 1. apply 24V control voltage
- 2. wait for readiness for operation of the connected components
- 3. switch on power supply (e.g. close mains contactor)

Switching off the Power Supply

Switch-off sequence:

- 1. switch power supply off
- 2. if required, switch 24V control voltage off

Using and Arranging the Mains Contactor

For HCS drive controllers of the Rexroth IndraDrive C product range, use an external mains contactor in the main connection for the control circuit. Connect the mains contactor electrically between mains filter and mains input (connection $X3)^{1}$).

The HMV01.1 supply units of the Rexroth IndraDrive M range have an integrated mains $contactor^2$.



Lethal injuries caused by live parts with more than 50 V!

Design and install the mains connection according to the valid standards.

Observe the protection goals

- electrical safety
- mechanical safety with incorrect movements
- protection against fire

Make sure you can provide evidence of the mechanisms of protection by means of FMEA and hazard analysis.

¹⁾ Exception: When using HNK01 at HCS03, it is allowed to connect the mains contactor electrically before HNK.

Exception: HMV01.1R-W0120 have no integrated mains contactor and additionally require an external mains contactor.



Mains connection without mains contactor

You do not need to use mains contactors in the mains connection, if the following conditions simultaneously apply to the respective application:

- the safety-related requirements of the application allow this
- the local safety regulations at the site of installation allow this
- HCS02 and HCS03 drive controllers with integrated 24V supply in individual supply
- the drive controller has no DC bus short circuit protection device (ZKS) and has passive charging current limitation (R_{Softstart})
- no components with DC bus short circuit protection device (e.g. HLB) are supplied at the DC bus of the drive controller
- the 24V supply of other drive controllers (e.g. HMS, HMD) and additional components (e.g. HLB, HLC) operated at the DC bus has already been applied, before mains voltage is switch-

Before doing without mains contactors, make sure that operator protection is as good as with external mains contactors!

Make use of the protection by mains contactors in the mains connection.

For the data for the rating of appropriate mains contactors incl. fuses and cable cross section, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

Using and Arranging an Additional Mains Contactor

When the safety regulations require the circuit interruption in the mains connection to be carried out in redundant form, it is necessary to have additional mains contactors in the mains connection.

Additional mains contactors are allowed at

- HMV supply units
- HCS drive controllers



Place the additional mains contactor electrically before

- mains filter
- mains choke
- mains contactor (integrated or externally installed)
- mains input of supply unit or drive controller

Observe the following aspect for PLC programming:

The additional mains contactor must already have been connected, before the request "power ON" is applied to the supply unit or drive controller.

At installations with additional mains contactor, there are 2 mains contactors effective:

- the integrated or external mains contactor of the supply unit or drive controller which is controlled by the control circuit for mains connection
- the additional mains contactor which is controlled by an independent control circuit (e.g. from a PLC)

9.3 Control Circuits for Mains Connection of Rexroth IndraDrive C Drive Controllers

9.3.1 General Information

The mains contactor connected in the incoming circuit controls the energy flow to the drive controller. This allows separation from the mains in the case of error. The Bb contact at the control section of the drive controller or the Bb contact of the mains supply decisively influences the control circuit.

Control Circuits HCS02

For HCS02 drive controllers, the following control circuits for the mains connection are described:

- control via external mains contactor
- control via external mains contactor for devices with integrated control voltage supply
- control via external mains contactor with DC bus resistor unit HLB01.1C

Control Circuits HCS03

For HCS03 drive controllers, the following control circuits for the mains connection are described:

control via external mains contactor

Configuration Rel 1 as Bb Contact

Power voltage is only switched to drive system, when the closing of the Bb contact signals readiness for power voltage on.

For this purpose, there is the isolated contact "Rel 1" at the control sections. The behavior of this contact can be configured via the "P-0-0860, Converter configuration" parameter:

- behaves as converter, if drive controller is to get supply voltage via mains connection (e.g. for type of mains connection individual supply or central supply)
- behaves as inverter, if drive controller is to get supply voltage via connection DC bus (L+, L-) (e.g. for type of mains connection central supply as supplied device)

Include the converter contacts in the control circuit in such a way that they make the mains contactor drop out in the case of error (when the contact opens).

You can assign other information to the "Rel 1" contacts of the drive controllers configured as inverters. Via this contact you can, for example, control a second holding brake by entering a signal from "S-0-0398, IDN list of configurable data in signal status word" in parameter "P-0-0300, Digital I/Os, assignment list".

(See also Functional Description of firmware: "Power Supply" and Parameter Description of firmware for P-0-0300 and P-0-0861)

9.3.2 Control via External Mains Contactor - HCS02 and HCS03


General Information



Risk of damage!

Before switching the drive controller on again, wait at least for **300 ms plus the switch-off delay of the mains contactor**.

Standard Design for HCS02 and HCS03 Drive Controllers



- 1) integration of the Bb contacts of other devices and configuration (see "Configuration Rel 1")
- 2) take switching capacity of Bb contact into account Fig.9-2: Control circuit

Design for HCS02 and HCS03 Drive Controllers with Integrated 24V Control Voltage Supply

Drive controllers with integrated 24V control voltage supply are used, for example, to maintain signal processing for controlled return motion in case the external 24V control voltage supply fails.




The integrated 24V control voltage supply cannot be used for motor brake supply.

To supply the motor brakes, use an external 24V supply.

Design for HCS02 and HCS03 Drive Controllers with Integrated 24V Control Voltage Supply and CSB01.1N-FU Control Sections

When using the drive controllers HCS02.1E-...-NNNV and HCS03.1E-...-NNNV with CSB01.1N-FU control sections, it is possible to do without the external 24V control voltage supply.



- integration of the Bb contacts of other devices and configuration (see "Configuration Rel 1")
- take switching capacity of Bb contact into account (see Project Planning 2) Manual of control section), CSB01.1N-FU control sections have switch contacts with high switching capacity
- Control circuit for HCS02.1E-...-NNNV drive controllers Fig.9-3:

礟

Observe the allowed switching capacity of the Bb contact of the CSB01.1-FU control sections.

Compared to other control sections, only the CSB01.1-FU control section has a Bb contact with allowed switching voltage of AC 250 V.

图

Until the internal supply voltages are built up and the firmware is actively working in the drive controller, the Bb contact at the control section of the drive controller is open.

Take these times into account for the design of the mains connection.

Control Circuits HCS02 and HCS03 with DC Bus Resistor Unit 9.3.3 **HLB01.1C or HLB01.1D**

Usage Use this variant, when

- only motors with permanent magnet excitation are connected
- motors with permanent magnet excitation and asynchronous motors (induction machines) are connected

Features

Due to the DC bus short circuit, motors with permanent magnet excitation can be shutdown with deceleration even if the electronic system of the drive is disturbed.



Personal injury caused by uncontrolled axis motion!


The DC bus short circuit protects machines in the case of drive errors. By itself it cannot assume the function of personal protection. In the case of errors in the drive or supply unit, uncontrolled drive motion can occur even when the DC bus short circuit has been activated.

Asynchronous machines do not brake when the DC bus has been short-circuited. Personal injury can occur according to the machine design.

Provide additional monitors and protective devices on the installation side.

Operating Principle

When the emergency stop pushbutton is actuated, the mains contactor drops out which activates the DC bus short circuit device in HLB.



- integration of the Bb contacts of other devices and configuration (see "Configuration Rel 1")
- 2) take switching capacity of Bb contact into account (see technical data)

 K1 auxiliary contacts at mains contactor

Fig.9-4: Wiring diagram HLB01.1 and HCS



Connect the Bb contact of HLB in series with the Bb contacts of the involved IndraDrive components so that the mains contactor can be opened even if the module bus is defective.

119/363

B

Avoid switching on upon short circuit in DC bus!

Switch auxiliary contact K1 (N/O contact) before the ZKS1 input so that DC bus short circuit device is deactivated before mains contactor is switched on.

9.4 Control Circuits for Mains Connection of Rexroth IndraDrive M Supply Units

9.4.1 General Information



Damage to the supply unit!

At **HMV01.1R** supply units, there must be **at least 10 ms** between the request mains OFF (signal at X32.6 / X32.7) and the disconnection of the mains voltage, so that the energy flow has been interrupted when the disconnection process starts.

You can make sure this order is observed by appropriate switch elements (e.g. by a main switch of the control cabinet with leading auxiliary contact). For this purpose, connect the auxiliary contact in series with mains OFF.



Do not switch on HMV supply units simultaneously!

In the switch-on sequence of the supply unit, the supplying mains is loaded with the current $I_{L_trans_max_on}$ for the purpose of analysis.

During the unloading process, voltage overshoot can occur at the mains components connected in the incoming circuit (e.g. mains filters) due to inductances connected in the incoming circuit, e.g. the leakage inductance of the mains transformer.

With 3 or more HMV supply units at the common supply mains: Switch on supply units one after the other with a time interval of at least 0.5 seconds so that the inrush currents are not added.


Control Circuits HMV

For HMV01.1E, HMV01.1R and HMV02.1R supply units, the following control circuits for the mains connection are described:

- control circuit for parallel operation HMV01.1E master-slave
- deceleration in the case of disturbed electronic system of drive
- deceleration in the case of emergency stop or mains failure
- control by emergency stop relay with DC bus short circuit
- control by emergency stop relay without DC bus short circuit
- control by control unit
- combination with DC bus resistor unit HLB01.1D

9.4.2 Parallel Operation HMV01

For the type of mains connection "group supply with DC bus connection", use the control circuit master-slave when using HMV01.1E supply units. See the block diagram below:



Control circuit for parallel operation HMV01.1E master-slave

1) braking resistor switch-on threshold activated
Fig.9-5: Block diagram control circuit master-slave for parallel operation
HMV01.1E

DA000094v01 nn.fh

9.4.3 Deceleration in the Case of Disturbed Electronic System of Drive (DC Bus Short Circuit is Activated)

General Information

If the electronic system of the drive is disturbed, motors can coast in an uncontrolled way. In these cases, it is possible to short-circuit the DC bus voltage as a measure in addition to shutdown with deceleration of the drives in case the electronic system is disturbed.

In HMV supply units³⁾ a circuit has been integrated which can discharge the DC bus as quickly as possible to low voltage. This circuit is called **DC bus short**

³⁾ not available in HMV01.1R-W0120

121/363

circuit (ZKS). With active DC bus short circuit, a low-impedance resistor is connected to the DC bus between L+ and L- via a wear-free switch.

图

Type of motor and DC bus short circuit

Asynchronous drives do not decelerate when the DC bus voltage has been short-circuited!

When the DC bus has been short-circuited, motors with permanent magnet excitation generate brake torque and are decelerated.

Control Circuits With DC Bus Short Circuit (ZKS)

If you control the mains contactor in the supply unit by an emergency stop relay and short-circuit the DC bus, you achieve a high degree of safety with little effort. The monitoring functions of the drive system are then used in the most effective way.



DC bus short circuit at HMV without integrated circuit for DC bus short circuit

Use HLB01 DC bus resistor units for DC bus short circuit. It is not recommended to short-circuit the motor connections.

Usage Use this variant, when

- only motors with permanent magnet excitation are connected
- motors with permanent magnet excitation and asynchronous motors (induction machines) are connected
- the emergency stop switch has to be duplicated or a safety door monitor, for example, is required
- your drive system has an extensive emergency stop circuit



Maximum resistance of control circuit

The pickup current of the auxiliary relay for control of the mains contactor flows via the emergency stop circuit. In order that the mains contactor picks up reliably, the total resistance of the emergency stop circuit taking effect between connections X32/1 and X32/9 has to be less than 45 Ω !

Features

Due to the DC bus short circuit, motors with permanent magnet excitation can be shutdown with deceleration even if the electronic system of the drive is disturbed. In order to trigger a DC bus short circuit in such a case, the Bb contacts of the drive controllers have to be connected in series with the control contact and wired in the emergency stop circuit. The DC bus short circuit only takes effect in the case of drive failure. If emergency stop is actuated, asynchronous drives therefore are braking, too.

When the Bb contacts **of the supply unit** are connected in series with the control contact in the emergency stop circuit, the DC bus dynamic brake is only triggered in the case of a supply unit error.

In the case of emergency stop or when the monitors of the supply unit trigger (e.g. mains failure), the electronic system of the drives shuts them down according to the error reaction that was set.



Personal injury caused by uncontrolled axis motion!

The circuit for DC bus short circuit protects machines in the case of drive errors. By itself it cannot assume the function of personal protection. In the case of errors in the drive and supply unit, uncontrolled drive motion can occur even when the DC bus short circuit has been activated.

Asynchronous machines do not brake when the DC bus has been short-circuited. Personal injury can occur according to the machine design.

Use additional monitors and protective devices on the installation side.

Use Rexroth's "integrated safety technology".


Operating Principle

When the emergency stop pushbutton is actuated, the mains contactor in the supply unit opens. The emergency stop relay or an auxiliary contact of the mains contactor switches off the drive enable signals. The drives are shut down according to the error reaction set in the drive controller.

The mains contactor is switched off and the DC bus short circuit (ZKS) takes effect, when

- the supply unit (Bb1 contact) outputs a drive error message
- the control unit (CNC contact) outputs an error message
- the limit switch (S2) is passed

Control circuit "DC bus short circuit (ZKS) in the case of disturbed electronic system of drive" for the mains connection of HMV01.1E supply units with integrated mains contactor (e.g. HMV01.1E-W0030, -W0070, -W0120)




F1	fuse of power supply
F3	fuse of 24V power supply unit
1)	control of K1, if A10 is not used
2)	drive enable (via input at control section or via master communication); see also parameter "P-0-4028, Device control word"
A10	emergency stop relay (example of circuit)
Bb1	readiness for operation of supply unit
Bb	readiness for operation of drive controllers (see control section X31.1 and X31.2)
CNC	lag error message of control unit
K1	integrated mains contactor
K4	control of drive enable
S1	emergency stop
S2	axis end position
S4	power Off
S5	power On
S11, S12	safety door monitor
ZKS	DC bus short circuit
HNL, HNF	optional, depending on the application

Fig.9-6:

Control circuit DC bus short circuit (ZKS) in the case of disturbed elec-

tronic system of drive for HMV01.1E supply units with integrated mains contactor

Control circuit "DC bus short circuit (ZKS) in the case of disturbed electronic system of drive" for the mains connection of HMV01.1R supply units with integrated mains contactor (e.g. HMV01.1R-W0018, -W0045, -W0065)



F1.	fuse of power supply	
F2	fuse of synchronization connection X14	
F3	fuse of 24V power supply unit	
1)	control of K1, if A10 is not used	
2)	drive enable (via input at control section or via massee also parameter "P-0-4028, Device control wor	ster communication); d"
A10	emergency stop relay (example of circuit)	
Bb1	readiness for operation of supply unit	
Bb	readiness for operation of drive controllers (see c and X31.2)	ontrol section X31.1
CNC	lag error message of control unit	
K1	integrated mains contactor	
K4	control of drive enable	
S1	emergency stop	
S2	axis end position	
S4	power Off	
S5	power On	
S11, S12	safety door monitor	
ZKS	DC bus short circuit	

Control circuit DC bus short circuit (ZKS) in the case of disturbed elec-

Fig.9-7:

tronic system of drive for HMV01.1R supply units with integrated mains contactor

Operating Principle With HLB01.1D

When the emergency stop pushbutton is actuated, the mains contactor in the supply unit drops out. The emergency stop relay or an auxiliary contact of the mains contactor switches off the drive enable signals. The drives are shut down according to the error reaction set in the drive controller.

The mains contactor is switched off and the DC bus short circuit (ZKS) takes effect in HMV and HLB, when

- the supply unit (Bb1 contact) outputs a drive error message
- the control unit (CNC contact) outputs an error message
- the limit switch (S2) is passed




Risk of damage to the device!

Establish connection from HMV_X32/8 to HLB_X32/7.

This avoids energy from the mains connection being supplied and the DC bus short circuit protection device of the DC bus resistor unit HLB being simultaneously active.

Control circuit "DC bus short circuit (ZKS) at HMV and HLB in the case of disturbed electronic system of drive" for the mains connection of HMV01.1R supply

units with integrated mains contactor (e.g. HMV01.1R-W0018, -W0045, -W0065) and DC bus resistor unit HLB01.1D



fuse of power supply
fuse of synchronization connection X14
fuse of 24V power supply unit
control of K1, if A10 is not used
drive enable (via input at control section or via master communication); see also parameter "P-0-4028, Device control word"
emergency stop relay (example of circuit)
readiness for operation of supply unit
readiness for operation of drive controllers (see control section X31.1 and X31.2)
lag error message of control unit
integrated mains contactor
control of drive enable
emergency stop
axis end position
power Off
power On
safety door monitor
DC bus short circuit
Control circuit DC bus short circuit (ZKS) at HMV and HLB in the case

of disturbed electronic system of drive for HMV01.1R supply units with integrated mains contactor and HLB01.1D

9.4.4 Deceleration in the Case of Emergency Stop or Mains Failure

General Information

In the case of emergency stop or mains failures, the drives normally are shutdown by drive control.

In the case of emergency stop or when the drive-internal monitors trigger, the drive control inputs the command value "zero". The drives are thereby decelerating in a controlled way with maximum torque.

In some applications (e.g. electronically coupled gear cutting machines) it is required that the drive shutdown is controlled by the control unit in the case of emergency stop or mains failures. In the case of emergency stop or when the drive-internal monitors trigger, the control unit decelerates the drives in a position-controlled way. In such applications, the DC bus short circuit must not be activated.

For further details, see the Functional Description of the firmware under the index entry "Best possible deceleration".

Control Circuit "Position-Controlled Shutdown by the Control Unit" Without DC Bus Short Circuit (ZKS)

If the mains contactor is controlled by the control unit, the drive, in the case of emergency stop or when the drive-internal monitor triggers, can be shut down in a position-controlled way by a control unit.

Usage

This kind of mains contactor control is mainly used for electronically coupled drives that are shut down synchronously even in the case of mains failure.

Features

The DC bus voltage is not short-circuited so that there is energy available for position-controlled shutdown of the drives.



The energy stored in the DC bus or the regenerated energy has to be greater than the energy required for excitation of asynchronous machines or for return motions.

The parameter "Activation of NC reaction on error" has to be set accordingly in the drive controller (P-0-0117, bit 0 = 1).

In the case of emergency stop or when the monitors of the supply unit trigger (e.g. mains failure), the drives are shut down in a position-controlled way by the positioning control.

Operating Principle

When the emergency stop circuit opens or the monitors of the supply unit trigger (e.g. mains failure), the mains contactor in the supply unit drops out.

For drives with SERCOS interface, the error is signaled to the control unit and the drives can be shut down in a position-controlled way.


For drives without SERCOS interface, the control unit has to evaluate the UD contact. When the UD contact triggers, the control unit has to shut down the drives.



Damage to machines caused by unbraked coasting to stop of the drives in case DC bus voltage is too low!

The control unit should evaluate the UD contact and shut the drives down when the contact triggers.

Control circuit "position-controlled shutdown by the control unit" for the mains connection of HMV01.1R supply units with integrated mains contactor (e.g. HMV01.1R-W0018, -W0045, -W0065)



F1	fuse of power supply
F2	fuse of synchronization connection X14
F3	fuse of 24V power supply unit
1)	control of K1, if A10 is not used
2)	drive enable (via input at control section or via master communication); see also parameter "P-0-4028, Device control word"
A10	emergency stop relay (example of circuit)
Bb1	readiness for operation of supply unit
Bb	readiness for operation of drive controllers (see control section X31.1 and X31.2)
CNC	control unit of installation
K1	integrated mains contactor
K4	control of drive enable
S1	emergency stop
S2	axis end position
S4	power Off
S5 🜿	power On
S11, S12	safety door monitor
ZKS	DC bus short circuit

Control circuit without DC bus short circuit (ZKS), position-controlled

Fig.9-9:

shutdown by the control unit for HMV01.1R supply units with integrated mains contactor

Control Circuit Emergency Stop Relay Without DC Bus Short Circuit (ZKS)

Usage

- If unbraked coasting to stop of the drives does not damage the installation.
- If only asynchronous motors are connected to the supply unit.
- If the end positions of the feed axes have been sufficiently cushioned.
- If external braking devices are used.

Features

The DC bus voltage is not short-circuited.

In the case of emergency stop or when the monitors of the supply unit trigger (e.g. mains failure), the drives are shut down according to the error reaction set in the drive controller.

Operating Principle

When the emergency stop circuit opens, the mains contactor in the supply unit drops out immediately. The emergency stop relay or an auxiliary contact of the mains contactor switches off the drive enable signals. The drives are shut down according to the error reaction set in the drive controller.




Damage to machines caused by unbraked coasting to stop of the drives in case their electronic system is disturbed!

Use motors with mechanical brake (a holding brake mustn't be used as service brake).

Sufficiently cushion end positions of feed axes.


Example Control circuit "without DC bus short circuit (ZKS)" for the mains connection of HMV01.1E supply units with integrated mains contactor (e.g. HMV01.1E-W0030, -W0070, -W0120)



F1 30	fuse of power supply
F3	fuse of 24V power supply unit
	(1) (0)
1)	control of K1, if A10 is not used
2)	drive enable (via input at control section or via master communication); see also parameter "P-0-4028, Device control word"
A10	emergency stop relay (example of circuit)
Bb1	readiness for operation of supply unit
Bb	readiness for operation of drive controllers (see control section X31.1 and X31.2)
K1	integrated mains contactor
K4	control of drive enable
S1	emergency stop
S4	power Off
S5	power On
S11, S12	safety door monitor
ZKS	DC bus short circuit
HNL, HNF	optional, depending on the application
Fig.9-10:	Control circuit without DC bus short circuit (ZKS) for HMV01.1E supply

units with integrated mains contactor


Example Control circuit "without DC bus short circuit (ZKS)" for the mains connection of HMV01.1R supply units with integrated mains contactor (e.g. HMV01.1R-W0018, -W0045, -W0065)



F1	fuse of power supply
F2	fuse of synchronization connection X14
F3	fuse of 24V power supply unit
1)	control of K1, if A10 is not used
2)	drive enable (via input at control section or via master communication); see also parameter "P-0-4028, Device control word"
A10	emergency stop relay (example of circuit)
Bb1	readiness for operation of supply unit
Bb	readiness for operation of drive controllers (see control section X31.1 and X31.2)
K1 💢	integrated mains contactor
K4	control of drive enable
S1	emergency stop
S4	power Off
S5	power On
S11, S12	safety door monitor
ZKS	DC bus short circuit
Fig.9-11:	Control circuit without DC bus short circuit (ZKS) for HMV01.1R supply

units with integrated mains contactor

Example Control circuit "without DC bus short circuit (ZKS)" for the mains connection of HMV01.1R supply units without integrated mains contactor (e.g. HMV01.1R-W0120)



F1 💉		fuse of power supply
F2		fuse of synchronization connection X14
F3		fuse of 24V power supply unit
F4		fuse of contactor control X34
1)		control of K1, if A10 is not used
2)		drive enable (via input at control section or via master communication); see also parameter "P-0-4028, Device control word"
A10		emergency stop relay (example of circuit)
Bb1		readiness for operation of supply unit
Bb		readiness for operation of drive controllers (see control section X31.1 and X31.2)
K1		mains contactor
K4		control of drive enable
S1		emergency stop
S4		power Off
S5		power On
S11, S	12	safety door monitor
Fig.9-1.	2:	Control circuit without DC bus short circuit (ZKS) for HMV01.1R supply

units without integrated mains contactor

9.4.5 Time Behaviors When Switching HMV Supply Units ON and OFF Switching On


B

Do not switch on HMV supply units simultaneously!

In the switch-on sequence of the supply unit, the supplying mains is loaded with the current $I_{L_trans_max_on}$ for the purpose of analysis.

During the unloading process, voltage overshoot can occur at the mains components connected in the incoming circuit (e.g. mains filters) due to inductances connected in the incoming circuit, e.g. the leakage inductance of the mains transformer.

With 3 or more HMV supply units at the common supply mains: Switch on supply units one after the other with a time interval of at least 0.5 seconds so that the inrush currents are not added.




t1 5.2 s; time for internal booting until Bb1 contact closes Time can be set by the user. Take the time into account which is required t2 for run-up of all devices connected to the module bus. This time depends on the control unit or the machine. at least 250 ms; switch-on pulse t3 500 ms; time for internal test routines before the DC bus is loaded t4 t5 time depends on DC bus capacitance (internal, external) and mains t6 500 ms; delay time until mains contactor closes maximum 200 ms; depends on device (ON delay of mains contactor) t7 Fig.9-13: Time behavior when switching on

Involved Connection Points

See "Rexroth IndraDrive Supply Units and Power Sections" → chapter "Functions and Electrical Connection Points"

Switching Off



maximum 200 ms; depends on device (OFF delay of mains contactor) time can be set by the user Fig.9-14: Time behavior when switching off

B

Damage to the supply unit!

At HMV01.1R supply units, there must be at least 10 ms between the request mains OFF (signal at X32.6 / X32.7) and the disconnection of the mains voltage, so that the energy flow has been interrupted when the disconnection process starts.

You can make sure this order is observed by appropriate switch elements (e.g. by a main switch of the control cabinet with leading auxiliary contact). For this purpose, connect the auxiliary contact in series with mains OFF.

Involved Connection Points

See "Rexroth IndraDrive Supply Units and Power Sections" → chapter "Functions and Electrical Connection Points"

10 Electromagnetic Compatibility (EMC)

EMC Requirements 10.1

General Information 10.1.1

The electromagnetic compatibility (EMC) or electromagnetic interference (EMI) includes the following requirements:

- sufficient noise immunity of an electric installation or an electric device against external electric, magnetic or electromagnetic interference via lines or through air
- sufficiently low noise emission of electric, magnetic or electromagnetic noise of an electric installation or an electric device to other surrounding devices via lines or through air

10.1.2 Noise Immunity in the Drive System

Basic Structure for Noise Immunity

The figure below illustrates the interfaces for definition of noise immunity requirements in the drive system.




Fig. 10-1: Basic structure and noise immunity

Noise Immunity Limit Values

No	Place of effect	Phenom- enom	Standard	Conditions	Coupling	Test values accord- ing standard EN 61800-3	Perform- ance level
	Enclosure port	, of 12	IEC 61000-4-2	xOffidially.	CD, AD	6 kV CD, 8 kV AD, if CD not possible	В
igo,)*	RF Field	IEC 61000-4-3	30°	Via antenna on EUT	10 V / m	А
	Power port	Burst	IEC 61000-4-4	length > 3 m	mains connection I < 100 A: discou- pling network I > 100 A: clamp	4 kV / 2,5 kHz (clamp)	В
		Surge	IEC 61000-4-5	Only mains connection; I < 63 A, light load test	MAN I GO STATE OF THE STATE OF	Line – line 1 kV (2 ohm) Line – earth 2 kV (12 ohm)	В
	. 8		IEC 61000-4-6	length > 3 m	clamp	10 V, 0,15–80 MHz	∂ A
	Power Interface	Burst	IEC 61000-4-4	length > 3 m	clamp	ziè	В
	Signal Interface	Burst	IEC 61000-4-4	length > 3 m	clamp	1000	В
900		1900	IEC 61000-4-6	length > 3 m	Clamp or CDN	10 V, 0,15–80 MHz	В
	Ports of process; measurement control lines	Burst	IEC 61000-4-4	length > 3 m	clamp	N. Mary	В
	12/6°2		IEC 61000-4-6	length > 3 m	Clamp or CDN	10 V, 0,15–80 MHz	P A

Fig. 10-2: Noise immunity limit values

Evaluation cri- terion	Explanation (abbreviated form from EN 1800-3)				
Α	deviations within allowed range				
В	automatic recovery after interference				
С	Switched off without automatic recovery. Device remains undamaged.				

Fig. 10-3: Evaluation criterion

10.1.3 Noise Emission of the Drive System

Causes of Noise Emission

Controlled variable-speed drives contain converters containing snappy semiconductors. The advantage of modifying the speed with high precision is achieved by means of pulse width modulation of the converter voltage. This can generate sinusoidal currents with variable amplitude and frequency in the motor

The steep voltage rise, the high clock rate and the resulting harmonics cause unwanted but physically unavoidable emission of interference voltage and interference fields (wide band interference). The interference mainly is asymmetric interference against ground.

The propagation of this interference strongly depends on:

139/363

- configuration of the connected drives
- number of the connected drives
- conditions of mounting
- site of installation
- radiation conditions
- wiring and installation

If the interference gets from the device to the connected lines in unfiltered form, these lines can radiate the interference into the air (antenna effect). This applies to power lines, too.

Limit Values for Line-Based Disturbances

According to IEC EN 61800-3 or CISPR 11 (corresponds to EN55011), the limit values in the table below are distinguished. For this documentation both standards are combined in the limit value classes A2.1 to B1.

IEC / EN 61800-3	CISPR 11 (EN55011)	Explanation	In this docu- mentation	Curves of limit value charac- teristic
Category C4 2nd environment	none	One of the following 3 requirements must have been ful- filled: Mains connection current >400 A, IT mains or re- quired dynamic drive behavior not reached by means of EMC filter. Adjust limit values to use and operation on site. User has to carry out and provide evidence of EMC plan- ning.	none	
Category C3 2nd environment	Class A; Group 2 I > 100 A	limit value in industrial areas to be complied with for applications operated at supply mains with nominal currents > 100 A	A2.1	1.1 1.2
Category C3 2nd environment	Class A; Group 2 I < 100 A	limit value in industrial areas to be complied with for applications operated at supply mains with nominal currents < 100 A	A2.2	2.1 2.2
Category C2 1st environment; restricted distribu- tion	Class A; Group 1	Limit value in residential area or at facilities at low-voltage mains supplying buildings in residential areas. To be complied with for applications with restricted distribution.	A1	3.1 3.2
Category C1 1st environment; unrestricted distri- bution	Class B; Group 1	limit value in residential areas to be complied with for applications with unrestricted distribution	B1	4.1 4.2

Fig. 10-4: Limit value classes





Fig. 10-5:



Limit values for line-based disturbances (IEC 61800-3); limit value char-

acteristic through frequency range

Second Environment, Industrial Area

Facilities not directly connected to a low-voltage mains to supply buildings in residential areas.

If the limit values in an industrial area separated from public supply by a transformer station only have to be complied with at the property boundary or in the neighboring low-voltage mains, the filter might not be necessary. In the vicinity of broadcast receivers or other sensitive devices as regards high-frequency, such as measuring sensors, measuring lines or measuring devices, it is normally required to use the interference suppression filter.

Increasing the noise immunity of a sensitive device can often be the economically better solution compared to measures of interference suppression at the drive system of the installation.

First Environment

Environment containing residential areas and facilities directly connected, without interstage transformer, to a low-voltage mains supplying buildings in residential areas.

Medium-sized manufacturing plants and industrial establishments can be connected to the public low-voltage mains together with residential buildings. In this case there is a high risk for radio and television reception if there aren't any measures for radio interference suppression taken. Therefore, the indicated measures are generally recommended.

Nominal Current of Supply Mains

The nominal current of the supply mains (> 100 A or < 100 A) is specified by the local power supply company at the connection point of the mains. For industrial companies, for example, such connection points are the interconnecting stations from the power supply system.

Unrestricted Distribution

Channel of distribution for which placing on the market is independent of the EMC expert knowledge of the customer or user of electric drives.

Restricted Distribution

Channel of distribution for which the placing on the market is restricted to traders, customers or users who individually or together have technical expert knowledge of EMC for the use of electric drives.

Since it is impossible to obtain the lower limit values for residential areas with all applications by means of the usual measures (like for example in the case of large and electrically not closed installations, longer motor cables or a large number of drives), the following note included in EN 61800-3 has to be observed.



Components of the drive system Rexroth IndraDrive are **products** of category C3 (with restricted distribution) according to IEC 61800-3. They are not provided for use in a public low-voltage mains supplying residential areas. If they are used in such a mains, high-frequency interference is to be expected. This can require additional measures of radio interference suppression.

See the following chapters for the limit value classes (as per categories C1, C2, C3, C4 according to EN 61800-3) which can be reached for the individual drive systems and devices:

- Mains Connection of HMV01.1E Supply Units
- Mains Connection of HMV01.1R Supply Units
- Mains Connection for HCS02 Converters

10.2 Ensuring the EMC Requirements

Standards and Laws

On the European level there are the EU Directives. In the EU states these Directives are transformed into laws valid on a national level. The relevant

directive for EMC is EU Directive 89/336/EWG which was transformed on the national level in Germany into the law EMVG ("Law concerning electromagnetic compatibility of devices") of 1992-11-09.

EMC Properties of Components

Drive and control components by Rexroth are designed and built, in accordance with the present state-of-the-art of standardization, according to legal regulations of the EU Directive EMC 89/336/EEC and the German EMC law.

The compliance with EMC standards was tested by means of a typical arrangement with a test setup conforming to standard with the indicated mains filters. The limit values according to product standard EN 61800-3 have been complied with.

Apart from the internal test at the factory, a conformity test was carried out for individual drive systems in an accredited laboratory of a CE-responsible au-

Applicability for End Product

Measurements of the drive system with an arrangement typical for the system are not in all cases applicable to the status as installed in a machine or installation. Noise immunity and noise emission strongly depend on:

- configuration of the connected drives
- number of the connected drives
- conditions of mounting
- site of installation
- radiation conditions
- wiring and installation

In addition, the required measures depend on the requirements of electric safety technology and economic efficiency in the application.

In order to prevent interference as far as possible, notes on mounting and installation are contained in the application manuals of the components and in this documentation.



Observe the descriptions and notes in chapter 11 Arranging the Components in the Control Cabinet, page 145.

Cases to Distinguish for Declaration of EMC Conformity

For validity of the harmonized standards, we distinguish the following cases:

Case 1: **Delivery** of the drive system.

According to the regulations, the product standard EN 61800-3 is complied with for Rexroth drive systems. The drive system is listed in the declaration of EMC conformity. This fulfills the legal requirements according to EMC directive.

Case 2: Acceptance test of a machine or installation with the installed drive systems.

The product standard for the respective type of machine/installation, if existing, applies to the acceptance test of the machine or installation. In the last years, some new product standards were created for certain machine types and some are being created at present. These new product standards contain references to the product standard EN 61800-3 for drives or specify higher-level requirements demanding increased filter and installation efforts. When the machine manufacturer wants to put the machine/ installation into circulation, the product standard relevant to his machine/ installation has to be complied with for his end product "machine/installation". The authorities and test laboratories responsible for EMC normally refer to this product standard.

This documentation specifies the EMC properties which can be achieved, in a machine or installation, with a drive system consisting of the standard components.

It also specifies the conditions under which the indicated EMC properties can be achieved.

10.3 Measures to Reduce Noise Emission

10.3.1 General Information

To reduce noise emission there are mainly three possible measures:

- filtering by means of mains filter
- shielding by mounting and shielded cables
- grounding by electrical bonding

Noise Emission of the Drive Systems

In order to comply with the limit values for noise emission (mainly line-based radio interference of more than 9 kHz) at the connection points of the machine or installation, observe the notes on application contained in this documentation.

10.3.2 Shielding

Sufficient metallic shielding prevents radiation into the air. This is achieved by mounting the devices in a grounded control cabinet or in a housing (metallic encapsulation). The shielding of line connections is realized by shielded cables and lines, the shield has to be grounded over a large surface area.

To connect the shield at the motor, a suitable PG gland with shield connection can be used (e.g. "SKINDICHT SHV/SRE/E" from the Lapp company, Stuttgart). Make sure that the connection between the motor terminal box and the motor housing has a low impedance. If necessary, use an additional grounding strap between them. Never use plastic motor terminal boxes!

10.3.3 Grounding

Grounding discharges interference to ground and makes it flow back to the source of interference over the shortest distance. Realize grounding via a sufficiently **short connection over the largest possible surface area** in order to achieve low inductive resistance with a low degree of line inductance. The higher the frequency of disturbances, the lower the line inductance of grounding has to be.



In ungrounded mains the measure "grounding" cannot be generally used.

10.3.4 Filtering

Filtering prevents emission of noise via the lines, especially via the mains connection. For this purpose, there are special interference suppression filters available with which

- the allowed limit values of the line-based interference emission can be complied with in the range of 50 kHz to 30 MHz.
- interference via the mains connection to devices connected near by (e.g. control unit components) can be reduced.

11 Arranging the Components in the Control Cabinet

11.1 Dimensions and Distances

11.1.1 Main Dimensions of the System Components

General Information



The **mounting depths** of the Rexroth IndraDrive product range have been optimized for mounting in control cabinets:

- mounting depths up to 265 mm: for control cabinets with a depth of 300 mm
- mounting depths up to 322 mm: for control cabinets with a depth of 400 mm

The figure below contains a rough overview of the main dimensions.

For other data and required mounting dimensions, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Mechanical System and Mounting"

Device Depths and Device Heights




Fig.11-1: Main dimensions in mm

11.1.2 Distances

General Information

In addition to the mounting dimensions, the devices of the Rexroth IndraDrive range require additional mounting clearance:

- to ventilate the devices
- to mount accessories and connections
- to take temperature limits of neighboring mounting parts, such as cable ducts etc., into account

For the required mounting clearance in the control cabinet, take additional distances between the devices and on their tops and bottoms into account.

For the distances to be complied with d_{top} (distance to top of device), d_{bot} (distance to bottom of device) and d_{hor} (distance to side of device), see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" \rightarrow Chapter of the respective device \rightarrow "Technical Data" \rightarrow "Mechanical System and Mounting" \rightarrow "Power Dissipation, Mounting Position, Cooling, Distances"

Distance Between the Devices

Owing to power dissipation in the devices, especially due to integrated braking resistors, the temperatures of neighboring devices are rising. In the case of lateral mounting, trouble-free operation therefore requires the following minimum distances (in mm) between the devices.

		Minim	num distance [mn	n]			
10.0	and and						
between	HCS02	HCS03 (HNK01, HLR01)	HMV01	HMV02	HMS01 / HMD01	HMS02	
HCS02.1E	5	North State of State	- 4 - 4	 '4 _{1'}	0 (HMS to the right of HCS) 5 (HMS to the left of HCS)	0 (HMS to the right of HCS) 5 (HMS to the left of HCS)	
HCS03.1E with HNK01 and HLR01	- Holliger	0	Olligia,	, 11 <u>0, 1</u> 010)	0 1		
HMV01.1E / HMV01.1R	Mulipo-	- RA (Q) (0	KH (QC)	0		
HMS01.1 / HMD01.1	0 (HMS to the right of HCS) 5 (HMS to the left of HCS)	0	0	- nathrad	0	- A. Walley	
HMV02.1R	7.23.C.		ò. 	100	- 20/1/0	0	
HMS02.1	0 (HMS to the right of HCS) 5 (HMS to the left of HCS)	0	0	0	0	0	

-- not allowed Fig. 11-2: Minimum distances



For arrangement of the devices in the control cabinet, take the required minimum distances into account besides the device dimensions.

Distance to the Bottom of the Devices

In order that there is sufficient cooling air available for cooling the devices, a minimum distance to other devices must be complied with from the bottom of the devices. This applies both to the intake space of devices with forced cooling and to devices with cooling by natural convection.

In the thermal steady-state condition of the drive system, the temperature at the **air intake** of the device is the ambient temperature of the device. The temperature at the air intake is relevant when you check whether the allowed ambient temperature range T_{a_work} (see technical data of the respective device) has been complied with.



Keep the space at the air intake free from unnecessary barriers.

Run the cables as short as possible and without loops.

Do not place loads with power dissipation (e.g. mains chokes, braking resistors) near the air intake.

Use barrier plates, if necessary.

Form a **channel** which is as obstacle-free as possible and corresponds at least to the cross section "d_{bot} × mounting depth". The channel should lead with at least this cross section to the air intakes at the bottom and at the top of the devices.



If there are different minimum distances for the individual devices in a drive system, the greatest value determines the minimum distance to be observed for the entire row in the drive system.

Distance to the Top of the Devices

In order that the cooling systems can transport the cooling air through the devices and heat does not accumulate, a minimum distance to the top of the devices must be complied with.



Keep the space at the air outlet free from unnecessary barriers. Where possible, run the cables and lines outside the outlet apertures.

The supplied cooling air is heated up due to the power dissipation generated in the devices.


In a distance of d_{top} above the devices, the temperature of the cooling air is up to 105 °C.

Directly at the outlet apertures – especially of devices with integrated braking resistor – the temperature of the cooling air can be significantly higher than 105 °C.



Property damage due to temperatures higher than 105 °C!

Comply with indicated minimum distances!



air intake В air outlet

С mounting surface in control cabinet

 $d_{top} \\$ distance to top of device distance to bottom of device d_{bot}

Fig.11-3: Air intake and air outlet at drive controller



If there are different minimum distances for the individual devices in a drive system, the greatest value determines the minimum distance to be observed for the entire row in the drive system.

For example, if a supply unit with integrated braking resistor is used and operated with nominal power, its minimum distance d_{top} of for example 300 mm determines the minimum distance for the connected HMS / HMD drive controllers, see figure "Minimum distance at HMV supply units".

Minimum Distance of HMV Supply

The braking resistor in HMV01.1E heats up during operation, the braking resistor in HMV01.1R and HMV02.1R does so particularly after power has been switched off.

Under rated load, the escaping cooling air has cooled down in the minimum distance to below 105 °C. If the integrated braking resistor is not loaded, the distance can be reduced to 80 mm.




Fig.11-4: Minimum distance at HMV supply units

Lateral Distance at Drive System

In order that the cooling air can circulate in the closed control cabinet, a distance at the sides of the drive system is required in addition to the distances at the top and at the bottom.

In the closed control cabinet, the circulation is provoked by the natural convection and supported by the device-internal blowers.

11.1.3 Boring Dimensions for the Mounting Plate

Individually Arranged Devices




Fig.11-5: Boring dimensions

The figure shows the back of a device.

Device	K [mm]	L [mm]	M [mm]	P [mm]	R [mm]	Notes	
HCS02.1E-W0012	0	316	32,5	13	7	observe additional distance to lateral nei boring devices	igh-
HCS02.1E-W0028	0	378	32,5	13	7	observe additional distance to lateral nei boring devices	igh-
HCS02.1E-W0054	55	378	25	13	7	observe additional distance to lateral nei boring devices	gh-
HCS02.1E-W0070	55	378	25	13	7	observe additional distance to lateral nei boring devices	igh-
HCS03.1E-W0070	75	466	25	13	7		
HCS03.1E-W0100	175	466	25	13	7	"Ollips"	, of
HCS03.1E-W0150	175	466	25	13	7	1931	2
HCS03.1E-W0210	250	466	50	13	7	Thu _{1.2}	
HMV01.1E-W0030	100	466	25	13	7	7,	
HMV01.1E-W0075	200	466	25	13	7	\$	
HMV01.1E-W0120	300	466	25	13	7	Zill)	
HMV01.1R-W0018	125	466	25	13	Ji ⁰ 7	SINC.	300
HMV01.1R-W0045	200	466	25	13	7	7/90	
HMV01.1R-W0065	300	466	25	13	7	May May	
HMV02.1R-W0015	100	378	25	13	7	2	
HMS01.1N-W0020	© 0	466	25	13	7	3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
HMS01.1N-W0036	0	466	25	13	7	- SKI	.6
HMS01.1N-W0054	0	466	25	13	7	70 ⁰	5
HMS01.1N-W0070	50	466	25	13	7	Maje,	
HMS01.1N-W0150	100	466	25	13	7	4,	
HMS01.1N-W0210	150	466	25	13	7	ĝ ĝ	
HMS02.1N-W0028	0	378	25	13	7	789	
HMS02.1N-W0054	0	378	25	13	JO 7	"Tipe,	3100
HMD01.1N-W0012	0	466	25	13	7	"idg, "idg,	
HMD01.1N-W0020	0 -	466	25	13	7	May May	
HMD01.1N-W0036	0	466	25	13	7	2	
HNL02.1	100	378	20	13	7	9 _%	
HNS02.1	0	378	55	13	7	, of the same of t	, of
HLB01.1C	0	378	32,5	13	7	120 m	5
HLB01.1D	50	466	25	13	7	and the state of	
HLC01.1C-01M0	0	378	25	13	7	Al. Ala	

Device	K [mm]	L [mm]	M [mm]	P [mm]	R [mm]	Notes
HLC01.1C-02M4	0	378	25	13	7	
HLC01.1D-05M0	0	466	25	13	7	16 Z

Fig. 11-6: Boring dimensions

Ground the housings of the devices!

- 1. Connect the bare metal back panel of the device in conductive form to the mounting surface in the control cabinet.
- 2. Use the supplied mounting screws and fix the screws with a tightening torque of typically 6 Nm.
- 3. Connect the mounting surface of the control cabinet in conductive form to the equipment grounding system.

Combination of Devices of the Rexroth IndraDrive M Product Range




Fig.11-7: Rexroth IndraDrive M devices

图

The prevailing grid of fixing bores within the Rexroth IndraDrive M product range is 25 mm.

Arrange the drive controllers with high capacity as close to the supplying unit as possible.

The HAS02 accessories in the figure require additional downward mounting clearance.

Dimension Z is significantly determined by the involved devices. The table below contains the dimensions Z between the device arranged to the left and the device arranged to the right.

Device left	Device right	Dimension Z [mm]
HMV01.1E-W0030		
HMV01.1E-W0075	HMS01.1N-W0020	⁹ .5,
HMV01.1E-W0120	HMS01.1N-W0036	
HMV01.1R-W0018	HMS01.1N-W0054	, Jich
HMV01.1R-W0045	HMS01.1N-W0070	1900
HMV01.1R-W0065	HMS01.1N-W0110	"Hy.
HMS01.1N-W0020	HMS01.1N-W0150	
HMS01.1N-W0036	HMS01.1N-W0210	50
HMS01.1N-W0070	HMS01.1N-W0350	0
HMS01.1N-W0110	HMD01.1N-W0012	x.Ó
HMS01.1N-W0150	HMD01.1N-W0020	1000
HMS01.1N-W0210	HMD01.1N-W0036	"Hall
HMS01.1N-W0350	HLC01.1D-05M0	2/2
HMD01.1N-W0012	HLB01.1D	9
HMD01.1N-W0020	240×	D. 2
*O(CO	HMV01.1E-W0030	,xô
	HMV01.1E-W0075	1000
	HMV01.1E-W0120	241.00
	HMV01.1R-W0018	AL.
	HMV01.1R-W0045	A
	HMV01.1R-W0065	30.X
	HMS01.1N-W0020	
HMS01.1N-W0054	HMS01.1N-W0036	~ Julie
HMD01.1N-W0036	HMS01.1N-W0070	75
HLC01.1D-05M0	HMS01.1N-W0110	The state of the s
	HMS01.1N-W0150	
	HMS01.1N-W0210	⁹ -2,
	HMS01.1N-W0350	
	HMD01.1N-W0012	, Jic
	HMD01.1N-W0020	190
	HLC01.1D-05M0	The states
	HLB01.1D	

Device left	Device right	Dimension Z [mm]
	HMV01.1E-W0030	
3, 793,	HMV01.1E-W0075	12.2
Chich.	HMV01.1E-W0120	a did.
"Afor"	HMV01.1R-W0018	"Ito"
1900	HMV01.1R-W0045	Ž; ,
They.	HMV01.1R-W0065	E.
4.	HMS01.1N-W0020	7
	HMS01.1N-W0036	, j
HLC01.1C-01M0	HMS01.1N-W0070	57,5
HLC01.1C-02M4	HMS01.1N-W0110	Willer.
. Kapa	HMS01.1N-W0150	Page 1
THE STATES	HMS01.1N-W0210	. Si
37	HMS01.1N-W0350	27,
6 6	HMD01.1N-W0012	6
N. Maria	HMD01.1N-W0020	"AD"
all the second	HLC01.1D-05M0	"Oldger"
100 July	HLB01.1D	10 giller
HLC01.1C-01M0	HLC01.1C-01M0	05
HLC01.1C-02M4	HLC01.1C-02M4	65

Fig. 11-8: Table for dimension Z

Combination of Drive Controllers of the Rexroth IndraDrive C Product Range




Fig.11-9: Rexroth IndraDrive C devices

B

The accessory **HAS04** requires additional mounting clearance at the HCS arranged at the utmost left position.

Rexroth IndraDrive devices are arranged in line **to the right** starting from the supplying device. Arrange the drive controllers with high capacity as close to the supplying unit as possible.

The **HAS02** accessories in the figure require additional downward mounting clearance.

Dimension Z is significantly determined by the involved devices. The table below contains the dimensions Z between the device arranged to the left and the device arranged to the right.

	Device left	Device right	Dimension Z [mm]
3.01	HCS02.1E-W0012 HCS02.1E-W0028 HLB01.1C	HCS02.1E-W0012 HCS02.1E-W0028 HLB01.1C	70
	HCS02.1E-W0054 HCS02.1E-W0070	HCS02.1E-W0054 HCS02.1E-W0070	55
, (?)	HLC01.1C-01M0 HLC01.1C-02M4 HCS02.1E-W0054 HCS02.1E-W0070	HLC01.1C-01M0 HLC01.1C-02M4	50 (without distance be- tween the devices)
	HCS02.1E-W0012 HCS02.1E-W0028 HLB01.1C	HLC01.1C-01M0 HLC01.1C-02M4	57,5 (without distance between the devices)
, ();	HCS02.1E-W0054 HCS02.1E-W0070 HLC01.1C-01M0 HLC01.1C-02M4	HCS02.1E-W0012 HCS02.1E-W0028 HLB01.1C	62,5
	HCS03.1E-W0070 HCS03.1E-W0100 HCS03.1E-W0150	HCS03.1E-W0070 HCS03.1E-W0100 HCS03.1E-W0150	50 (without distance between the devices)
, <u>?</u>	HCS03.1E-W0210	HCS03.1E-W0210	100 (without distance between the devices)
	HCS03.1E-W0070 HCS03.1E-W0100 HCS03.1E-W0150	HCS03.1E-W0210	75 (without distance between the devices)
,Q	HCS03.1E-W0210	HCS03.1E-W0070 HCS03.1E-W0100 HCS03.1E-W0150	75 (without distance between the devices)

Fig.11-10: Table for dimension Z

Combination of Drive Controllers of the Rexroth IndraDrive C and IndraDrive M Product Ranges



The accessory **HAS04** requires additional mounting clearance at the HCS arranged at the utmost left position.

Rexroth IndraDrive M devices are arranged in line **to the right** starting from the supplying drive controller HCS.

Dimension Z is significantly determined by the involved devices. The table below contains the dimensions Z between the device arranged to the left and the device arranged to the right.

HCS02 Drive Controllers

Device left	Device right	Dimension Z [mm]
	HMS01.1N-W0020	
J.KOfratyka P	HMS01.1N-W0036	50 (without distance be- tween the devices)
	HMS01.1N-W0054	
	HMS02.1N-W0028	
HCS02.1E-W0054	HMS02.1N-W0054	
HCS02.1E-W0070	HMD01.1N-W0012	
	HMD01.1N-W0020	
	HMD01.1N-W0036	
	HLC01.1D-05M0	
	HLB01.1D	20%

Fig. 11-11: Table for dimension Z

HCS03 Drive Controllers

Device left	Device right	Dimension Z [mm]
16.5	HMS01.1N-W0020	3. ⁽²⁾
	HMS01.1N-W0036	
HCS03.1E-W0070	HMS01.1N-W0054	50
HCS03.1E-W0100	HMS01.1N-W0070	(without distance be- tween the devices)
HCS03.1E-W0150	HMD01.1N-W0012	
	HMD01.1N-W0020	
	HMD01.1N-W0036	a di
National Contract of the Contr	HMS01.1N-W0020	
HCS03.1E-W0210	HMS01.1N-W0036	Tile?
	HMS01.1N-W0054	1900
	HMS01.1N-W0070	75
	HMS01.1N-W0110	(without distance be- tween the devices)
	HMS01.1N-W0150	
	HMD01.1N-W0012	
	HMD01.1N-W0020	305
	HMD01.1N-W0036	10g11

Fig. 11-12: Table for dimension Z

For the dimensions Z between other combinations see previous tables.

11.2 Arranging Components From Electrical Point of View

11.2.1 General Information

The section below contains information and recommendations on the arrangement of the devices in the control cabinet from mainly electrical points of view. These points of view include aspects of performance-dependent arrangement and electromagnetically compatible installation.

11.2.2 Performance-Dependent Arrangement

Arrangement With HMV

The **HMV01** supply units can supply HMS and HMD drive controllers **on both sides**.

B

When you use HNS02 and HNL02, the supply units **HMV02** only allow mounting them on one side to the **right**.

- Arrange drive controllers according to their performance. Arrange drive controllers with high performance as close to the supply unit as possible. Ideally the drive controllers should be distributed equally to the left and right side of the supply unit.
- Arrange DC bus capacitor unit (HLC) next to the supply unit.
- Arrange DC bus resistor unit (HLB) next to the supply unit.
- When simultaneously using DC bus resistor unit and DC bus capacitor unit in a drive system, arrange the DC bus capacitor unit between supply unit and DC bus resistor unit.




Fig.11-13: Example of an arrangement

Arrangement With HCS

When you operate **HCS** converters in the type of mains connection "central supply", place the supplied drive controllers to the **right** of the HCS converters.

- Arrange DC bus capacitor unit next to drive controller with the greatest DC bus continuous power.
- Arrange DC bus resistor unit next to drive controller with the greatest regenerative power.
- When simultaneously using DC bus resistor unit and DC bus capacitor unit in a drive system, arrange the DC bus capacitor unit to the right of HCS and the DC bus resistor unit to the right of the DC bus capacitor unit.
- Arrange HLR braking resistors in "standard" design above the HCS03 drive controller.

11.2.3 EMC Measures for Design and Installation

Rules for Design of Installations With Drive Controllers in Compliance with EMC

The following rules are the basics for designing and installing drives in compliance with EMC.

Mains Filter

Correctly use a mains filter recommended by Rexroth for radio interference suppression in the supply feeder of the drive system.

Control Cabinet Grounding

Connect all metal parts of the cabinet with one another over the largest possible surface area to establish a good electrical connection. This, too, applies to the mounting of the EMC filter. If required, use serrated washers which cut through the paint surface. Connect the cabinet door to the control cabinet using the shortest possible grounding straps.

Line Routing

- Avoid coupling routes between lines with high potential of noise and noisefree lines; therefore signal, mains and motor lines and power cables have to be routed separately from another. Minimum distance: 10 cm. Provide separating sheets between power and signal lines. Ground separating sheets several times.
- The lines with high potential of noise include:
 - at the drive controller the lines at the mains connection (incl. synchronization connection)
 - the lines at the motor connection and the connections at the DC bus
- Generally, interference injection are reduced by routing cables close to grounded sheet steel plates. For this reason, cables and wires should not be routed freely in the cabinet, but close to the cabinet housing or mounting panels. Separate the incoming and outgoing cables of the radio interference suppression filter.

Interference Suppression Elements

Provide the following components in the control cabinet with interference suppression combinations:

- contactors
- relays
- solenoid valves
- electromechanical operating hour counters

Connect these combinations directly at each coil.

Twisted Wires

Twist unshielded wires belonging to the same circuit (feeder and return cable) or keep the surface between feeder and return cable as small as possible. Ground wires that are not used at both ends.

Lines of Measuring Systems

Lines of measuring systems must be shielded. Connect the shield to ground at both ends and over the largest possible surface area. The shield may not be interrupted, e.g. using intermediate terminals.

Digital Signal Lines

Ground the shields of digital signal lines at both ends (transmitter **and** receiver) over the largest possible surface area and with low impedance. In the case of bad ground connection between transmitter and receiver, additionally route a bonding conductor (min. 10 mm²). Braided shields are better than foil shields.

Analog Signal Lines

Ground the shields of analog signal lines at one end (transmitter **or** receiver) over the largest possible surface area and with low impedance. This avoids low-frequency interference current (in the mains frequency range) on the shield.

Connection of Mains Choke

Keep connection lines of the mains choke at the drive controller as short as possible and twist them.

Installation of Motor Power Cable

Preferably use Rexroth's motor power cables with shield. If you use other
motor power cables, they have to be run in shielded form.

- Keep length of motor power cable as short as possible.
- Ground shield of motor cable at both ends over the largest possible surface area to establish a good electrical connection.
- Run motor lines in shielded form inside the control cabinet.
- Do not use any steel-shielded lines.
- The shield of the motor cable mustn't be interrupted by mounted components, such as output chokes, sine filters, motor filters.

11.2.4 **EMC-Optimal Installation in Facility and Control Cabinet**

General Information

For EMC-optimal installation, a spatial separation of the interference-free area (mains connection) and the interference-susceptible area (drive components) is recommended, as shown in the figures below.



For EMC-optimal installation in the control cabinet, use a separate control cabinet panel for the drive components.

Division Into Areas (Zones)

Exemplary arrangements in the control cabinet: see section Control Cabinet Mounting According to Interference Areas - Exemplary Arrangements, page 161.

We distinguish three areas:

1. Interference-free area of control cabinet (area A):

This includes:

- supply feeder, input terminals, fuse, main switch, mains side of mains filter for drives and corresponding connecting lines
- control voltage or auxiliary voltage connection with power supply unit, fuse and other parts unless connection is run via the mains filter of the AC
- all components that aren't electrically connected with the drive system
- Interference-susceptible area area B:
- mains connections between drive system and mains filter for drives, mains contactor
- interface lines of drive controller
- Strongly interference-susceptible area area C:
- motor cable including single strands

Never run lines of one of these areas in parallel with lines of another area so that there isn't any unwanted interference injection from one area to the other and that the filter is jumpered with regard to high frequency. Keep connection lines as short as possible.

Recommendation for complex systems: Install drive components in one cabinet and the control units in a second, separate cabinet.

Badly grounded control cabinet doors act as antennas. Therefore, connect the control cabinet doors to the cabinet on top, in the middle and on the bottom via short equipment grounding conductors with a cross section of at least 6 mm² or, even better, via grounding straps with the same cross section. Make sure connection points have good contact.

Control Cabinet Mounting According to Interference Areas - Exemplary Arrangements

Supply Units With Regeneration




Do not operate any additional loads at the mains filter!

Do not operate any other loads at the connection from the mains filter output to the mains connection of the supply unit.

For motor blowers and power supply units, for example, use separate mains filters.

HMVxx.xR supply unit



DR1	mains choke
K1	external mains contactor for supply units without integrated mains contactor
M_L	motor blower
NT	power supply unit
Q2	fuse
T	transformer
Z1, Z2	shield connection points for cable
Fig.11-14:	HMVxx.xR - EMC areas in the control cabinet

HMVxx.xE supply unit or HCSxx.xE converter




Fig.11-15:

DR1	mains choke (optional)
K1	external mains contactor for supply units and converters without integrated mains contactor
M_L	motor blower
NT	power supply unit
Q2	fuse
2 ² T	transformer
Z1, Z2	shield connection points for cable

HMVxx.xE; HCSxx.xE - EMC areas in the control cabinet

Design and Installation in Area A - Interference-Free Area of Control Cabinet

Arranging the Components in the Control Cabinet

Comply with a distance of at least 200 mm (distance d1 in the figure):

between components and electrical elements (switches, pushbuttons, fuses, terminal connectors) in the interference-free area A and the components in the two other areas B and C

Comply with a distance of at least 500 mm:

between magnetic components (such as transformers, mains chokes and DC bus chokes that are directly connected to the power connections of the drive system) and the interference-free components and lines between mains and filter including the mains filter in area A

If this distance is not kept, the magnetic leakage fields are injected to the interference-free components and lines connected to the mains so that the limit values at the supply connection are exceeded in spite of the installed filter.

Cable Routing of the Interference-Free Lines to the Mains Connection

Comply with a distance of at least **200 mm** (distance d1 and d3 in the figure):

between supply feeder or lines between filter and exit point from the control cabinet in area A and the lines in area B and C

If this is impossible, there are two alternatives:

- Install lines in shielded form and connect the shield at several points (at least at the beginning and at the end of the line) to the mounting plate or the control cabinet housing over a large surface area.
- 2. Separate lines from the other interference-susceptible lines in areas B and C by means of a grounded distance plate vertically attached to the mounting plate.

Keep lines as short as possible within the control cabinet and install them directly on the grounded metal surface of the mounting plate or of the control cabinet housing.

Mains supply lines from areas B and C must not be connected to the mains without a filter.



In case the information on cable routing given in this section is not observed, the effect of the mains filter is totally or partly neutralized. You must then expect the noise level of the interference emission to be higher within the range of 150 kHz to 40 MHz and the limit values at the connection points of the machine or installation to be exceeded.

Routing and Connecting a Neutral Conductor (N)

If a neutral conductor is used together with a three-phase connection, it must not be installed unfiltered in zones B and C, in order to keep interference off the mains.

Motor Blower at Mains Filter

Single-phase or three-phase supply lines of motor blowers, that are usually routed in parallel with motor cables or interference-susceptible lines, must be filtered:

- in drive systems with **regenerative supply units**, via a separate singlephase (NFE type) or three-phase filter (HNF, NFD type) near the mains connection of the control cabinet
- in drive systems with only infeeding supply units, via the available threephase filter of the drive system

When switching power off, make sure the blower is not switched off.

Loads at Mains Filter of Drive Sys-



Only operate allowed loads at the mains filter of the drive system!

At the three-phase filter for the power connection of regenerative supply units, it is only allowed to operate the following loads:

HMV supply unit with mains choke and, if necessary, mains contactor

Do not operate any motor blowers, power supply units etc. at the mains filter of the drive system.

Shielding Mains Supply Lines in Control Cabinet

If there is a high degree of interference injection to the mains supply line within the control cabinet, although you have observed the above instructions (to be found out by EMC measurement according to standard), proceed as follows:

- only use shielded lines in area A
- connect shields to the mounting plate at the beginning and the end of the line by means of clips

The same procedure may be required for long cables of more than 2 m between the point of power supply connection of the control cabinet and the filter within the control cabinet.

Mains Filters for AC Drives

Ideally, mount the mains filter on the parting line between area A and B. Make sure the ground connection between filter housing and housing of the drive controllers has good electrically conductive properties.

If single-phase loads are connected on the load side of the filter, their current may only be a maximum of 10% of the three-phase operating current. A highly imbalanced load of the filter would deteriorate its interference suppression capacity.

If the mains voltage is more than 480 V, connect the filter to the output side of the transformer and not to the supply side of the transformer.

Grounding

In the case of bad ground connections in the installation, the distance between the lines to the grounding points E1, E2 in area A and the other grounding points of the drive system should be at least d4 = 400 mm, in order to minimize interference injection from ground and ground cables to the power input lines.

See also Division Into Areas (Zones), page 160.

Point of Connection for Equipment Grounding Conductor at Machine, Installation, Control Cabinet

The equipment grounding conductor of the power cable of the machine, installation or control cabinet has to be **firmly connected** at point PE and have a **cross section of at least 10 mm²** or to be complemented by a second equipment grounding conductor via separate terminal connectors (according to EN50178/1997, section 5.3.2.1). If the cross section of the outer conductor is bigger, the cross section of the equipment grounding conductor must be accordingly bigger.

Design and Installation in Area B - Interference-Susceptible Area of Control Cabinet

Arranging Components and Lines

Modules, components and lines in area B should be placed at a distance of at least **d1 = 200 mm** from modules and lines in area A.

Alternative: Shield modules, components and lines in area B by distance plates mounted vertically on the mounting plate from modules and lines in area A or use shielded lines.

Only connect power supply units for auxiliary or control voltage connections in the drive system to the mains via a mains filter. See Division Into Areas (Zones), page 160.

Keep the length of the lines between drive controller and filter as short as possible.

Control Voltage or Auxiliary Voltage Connection

Only in exceptional cases should you connect power supply unit and fusing for the control voltage connection to phase and neutral conductor. In this case,

mount and install these components in area A far away from the areas B and C of the drive system. For details see section Design and Installation in Area A - Interference-Free Area of Control Cabinet, page 164.

Run the connection between control voltage connection of the drive system and power supply unit used through area B over the shortest distance.

Line Routing

Run the lines along grounded metal surfaces, in order to minimize radiation of interference fields to area A (transmitting antenna effect).

Design and Installation in Area C - Strongly Interference-Susceptible Area of Control Cabinet

Area C mainly concerns the motor cables, especially at the connection point at the device.

Influence of the Motor Power Cable

The discharge capacitance is limited to ensure compliance with the limit values. For the calculation of the discharge capacitance, see chapter 16 Calculations, page 319.

Keep the length of the cables as short as possible.

Routing the Motor Cables

Only use shielded motor cables.

Route the motor cables with a distance of **d5 = 100 mm** to the other interference-free lines, as well as to signal cables and signal lines. Alternative: Route motor cables separated by a grounded distance plate. This is not necessary for the feedback cables to the Rexroth motors.

At the drive controller connection, route the motor lines and the (unfiltered) mains connection lines in parallel for a maximum distance of 300 mm. After that distance, route motor cables and power supply cables in opposite directions in separate cable ducts (see following figures with the example of a drive system with separate mains connection per drive axis IndraDrive HCS).




Fig.11-16: Option 1: separate routing of motor cable and mains connection lines via 2 cable ducts

Arranging the Components in the Control Cabinet




Fig. 11-17: Option 2: separate routing of motor cable and mains connection lines

Additional Recommendations for Cable Routing Route the motor cables along grounded metal surfaces, both inside the control cabinet and outside of it, in order to minimize radiation of interference fields. If possible, route the motor cables in metal-grounded cable ducts.

Ideally, the outlet of the motor cables at the control cabinet should be provided in a distance of at least **d3 = 200 mm** from the (filtered) power supply cable.

11.2.5 Ground Connections

Housing and Mounting Plate

By means of appropriate ground connections, it is possible to avoid the emission of interference, because interference is discharged to ground on the shortest possible way.

Ground connections of the metal housings of EMC-critical components (such as filters, devices of the drive system, connection points of the cable shields, devices with microprocessor and switching power supply units) have to be well contacted over a large surface area. This also applies to all screw connections between mounting plate and control cabinet wall and to the mounting of a ground bus to the mounting plate.

The best solution is to use a zinc-coated or chromatized mounting plate. Compared to a lacquered plate, the connections in this case have a good long-time stability.

Arranging the Components in the Control Cabinet

Connection Elements

For lacquered mounting plates, always use screw connections with tooth lock washers and zinc-coated, tinned screws as connection elements. At the connection points, scratch off the lacquer so that there is safe electrical contact over a large surface area. You achieve contact over a large surface area by means of bare connection surfaces or several connection screws. For screw connections, you can establish the contact to lacquered surfaces by using tooth lock washers.

Metal Surfaces

Always use connection elements (screws, nuts, plain washers) with good electroconductive surface.

Bare zinc-coated, tinned and chromatized metal surfaces have **good electro-conductive properties**. Anodized, yellow chromatized, black gunmetal finish or lacquered metal surfaces have **bad electroconductive properties**.

Ground Wires and Shield Connections

For connecting ground wires and shield connections, it is not the cross section but the size of contact surface that is important, as the high-frequency interference currents mainly flow on the surface of the conductor.

Always connect cable shields, especially shields of the motor power cables with ground potential over a large surface area.

11.2.6 Installing Signal Lines and Signal Cables

Line Routing

For measures to prevent interference, see the Project Planning Manuals of the respective device. In addition, we recommend the following measures:

Route signal and control lines separately from the power cables with a minimum distance of **d5 = 100 mm** (see Division Into Areas (Zones), page 160) or with a grounded separating sheet. The optimum way is to route them in separate cable ducts. If possible, lead signal lines into control cabinet at one point only.

Exception: If there is no other way to do it, motor feedback cables can be routed together with the motor power cables.

If signal lines are crossing power cables, route them in an angle of 90° in order to avoid interference injection.

Ground spare cables, that are not used and have been connected, at least at both ends so that they don't have any antenna effect.

Avoid unnecessary line lengths.

Run cables as close as possible to grounded metal surfaces (reference potential). The ideal solution are closed, grounded cable ducts or metal pipes which, however, is only obligatory for high requirements (sensitive instrument leads).

Avoid suspended lines or lines routed along synthetic carriers, because they are functioning both like good reception antennas (noise immunity) and like good transmitting antennas (emission of interference). Exceptional cases are flexible cable tracks over short distances of a maximum of 5 m.

Shielding

Connect the cable shield immediately at the devices in the shortest and most direct possible way and over the largest possible surface area.

Connect the shield of **analog signal lines** at one end over a large surface area, normally in the control cabinet at the analog device. Make sure the connection to ground/housing is short and over a large surface area.

Connect the shield of **digital signal lines** at both ends over a large surface area and in short form. In the case of potential differences between beginning and end of the line, run an additional bonding conductor in parallel. The guide value for the cross section is 10 mm².

You absolutely have to equip separable connections with connectors with grounded metal housing.

Arranging the Components in the Control Cabinet

In the case of non-shielded lines belonging to the same circuit, twist feeder and return cable.

11.2.7 General Measures of Radio Interference Suppression for Relays, Contactors, Switches, Chokes, Inductive Loads

If, in conjunction with electronic devices and components, inductive loads, such as chokes, contactors, relays are switched by contacts or semiconductors, appropriate interference suppression has to be provided for them:

- by arranging free-wheeling diodes in the case of d.c. operation
- in the case of a.c. operation, by arranging usual RC interference suppression elements depending on the contactor type, immediately at the inductance

Only the interference suppression element arranged immediately at the inductance does serve this purpose. Otherwise, the emitted noise level is too high which can affect the function of the electronic system and of the drive.

If possible, mechanical switches and contacts should only be realized as snap contacts. Contact pressure and contact material must be suited for the corresponding switching currents.

Slow-action contacts should be replaced by snap switches or by solid-state switches, because slow-action contacts strongly bounce and are in an undefined switching status for a long time which emits electromagnetic waves in the case of inductive loads. These waves are an especially critical aspect in the case of manometric or temperature switches.

12 Control Cabinet Cooling

12.1 General Information

All devices operated in the control cabinet generate heat due to their power dissipation. The power dissipation increases the temperature inside the control cabinet compared to the ambient temperature of the control cabinet. The temperature inside the control cabinet is decisive as the ambient temperature of the devices.

You may only operate the devices within the allowed ambient temperature range T_{a_work} (with derating within $T_{a_work_red}$). The control cabinet must therefore be cooled. It is possible to cool the control cabinet in a passive or active way.

The table below contains an orientation guide showing the criteria on which the type of cooling depends.



The following table does not replace your detailed calculation of the heat levels. The data required for this calculation are explained in the following paragraphs.

Check your calculation of the heat levels by measuring the temperature in the control cabinet at the air intake of the components (area A in figure 11-3 Air intake and air outlet at drive controller on page 148) under full load operation.

Criterion	Small temperature difference T _{a_work} - T _a	Big temperature difference T _{a_work_red} - T _a Low degree of power dissipation		High degree of power er dissipation (e.g. with HMVxx.xE, HLBxx.x)	
low degree of power dissipation (e.g. with derating)	A, B	A MINITARY	- mini	- ⁻	
high degree of power dissipation (e.g. with HMVxx.xE, HLBxx.x)	C	B, C	11 <u>i</u> jbane	-119001110	
small control cabinet surface	B, C	ий В	В	С	
big control cabinet surface	B, C	Α	Α	С	


A cooling via surface of control cabinet
B forced ventilation of control cabinet

C cooling unit

Fig. 12-1: Orientation guide for the appropriate cooling type

12.2 Passive Control Cabinet Cooling

12.2.1 Cooling via the Surface of the Control Cabinet



- 1 heat dissipation via surface of control cabinet
- 2 interior of control cabinet
- 3 convection flow of air in control cabinet
- device in control cabinet
- 5 air intake at device

Fig. 12-2: Control cabinet airtight to the outside

Advantage: Control cabinet airtight to the outside without blower and filter.

The surface of the airtight control cabinet required for discharging the power dissipation is to be calculated below.

Input Data

- ΣP_{Diss}: power dissipation of all devices installed in the control cabinet
- T_a: maximum temperature outside of the control cabinet
- T_{a work}: maximum allowed ambient temperature of the devices
- **k**: heat transition coefficient resulting from material and surface condition of the control cabinet

礟

Avoid additional heating of the control cabinet, e.g. by directly attached constructions and solar radiation.

Allow the cooling air to freely circulate in the control cabinet. For devices with cooling type "n", use additional blowers, if necessary, to force the circulation.

Required Surface

$$A_{wirk} \ge \frac{\sum P_{Diss}}{k \times (T_{a_{-work}} - T_{a})}$$

Fig. 12-3: Required surface

Exemplary Calculation

Power sections

2 × HCS02.1E-W0012 with

$$\bullet$$
 P_{BD} = 50 W

Control sections

 $2 \times CSB01.1N$ -FC with $P_{N3} = 8.5 \text{ W}$

General conditions

- material of control cabinet: lacquered steel plate
- maximum temperature outside of the control cabinet: 30 °C

Result

$$\Sigma P_{Diss}$$
= 2 × (80 + 50 + 12) + 2 × 8.5 = 301 W

$$T_a = 30 \, ^{\circ}C$$

$$T_{a_work}$$
 = 40 °C

k ~ 5.5 W/(m²K) (lacquered steel plate)


Required effective surface:

$$A_{wink} \ge \frac{301}{5.5 \times (40 - 30)} = 5,472 \approx 5,5 \text{ m}^2$$

174/363

12.3 Active Control Cabinet Cooling

12.3.1 Ventilation of the Control Cabinet



heat dissipation via control cabinet blower
control cabinet blower
interior of control cabinet
device in control cabinet
air intake at device
air intake at control cabinet

Fig. 12-4: Ventilation of the control cabinet

Advantage: compact control cabinet

The cooling air current required for discharging the power dissipation from the control cabinet is to be calculated below. This will allow selecting the appropriate control cabinet blower.

Input Data

- ΣP_{Diss}: power dissipation of all devices installed in the control cabinet
- T_a: maximum temperature outside of the control cabinet
- T_{a work}: maximum allowed ambient temperature of the devices
- f_{air}: air constant at 1000 m installation altitude (operation under rated conditions without derating of the devices)

Required Cooling Air Current

$$\dot{V_{\text{min}}} = \frac{\sum P_{\textit{Diss}}}{\mathcal{T}_{\textit{a_work}} - \mathcal{T}_{\textit{a}}} \times f_{\textit{air}}$$

Fig. 12-5: Required cooling air current

Exemplary Calculation

Power sections

2 × HCS02.1E-W0012 with

P_{Diss cont} = 80 W (at I_{out cont})

 \bullet P_{BD} = 50 W

P_{N3} = 12 W

Control sections

 $2 \times CSB01.1N$ -FC with $P_{N3} = 8.5 \text{ W}$

General conditions

maximum temperature outside of the control cabinet: 30 °C

Regulf

$$\Sigma P_{\text{Diss}} = 2 \times (80 + 50 + 12) + 2 \times 8.5 = 301 \text{ W}$$

$$T_a = 30 \, ^{\circ}C$$

 $f_{air} \sim 3.5 \text{ m}^3 \text{ K/Wh (1000 m)}$

Required cooling air current:

$$\dot{V}_{min} \ge \frac{301}{40-30} \times 3.5 = 105.35 \approx 106 \frac{m^3}{h}$$



The integrated blowers of the devices have been dimensioned with regard to the pressure conditions of their cooling systems and are not provided for control cabinet cooling.

Select a control cabinet blower which at least conveys the calculated cooling air current. Take into account that installed filters, for example, reduce the output of the control cabinet blower.

12.4 Arrangement of Cooling Units

Unless the nominal data are reduced, the drive controller may only be operated up to a specified maximum ambient temperature. Therefore, a cooling unit might possibly be required.



Possible damage to the drive controller! Operational safety of the machine endangered!


Take the information below into account.

Avoiding Dripping or Spraying Wa-

Due to their operating principle, condensation water is formed when cooling units are used.


For this reason, observe the following aspects:

- Always position cooling units in such a way that condensation water cannot drip onto the devices in the control cabinet.
- Position the cooling unit in such a way that the blower of the cooling unit does not spray accumulated condensation water onto the devices in the control cabinet. Mount the air duct in the control cabinet accordingly.



- cooling unit
- air duct (protects devices against condensation water)
- 2 interior of control cabinet device in control cabinet

Fig. 12-6: Cooling unit on top of the control cabinet



1 interior of control cabinet

2 cooling unit

3 air duct (protects devices against condensation water)

4 device in control cabinet

Fig. 12-7: Cooling unit at the front of the control cabinet

Avoiding Moisture Condensation

Moisture condensation occurs when the temperature of the device is lower than the ambient temperature.

- Set cooling units with temperature adjustment to the maximum surrounding temperature and not lower!
- Set cooling units with follow-up temperature in such a way that the interior temperature of the control cabinet is no lower than the temperature of the surrounding air. Set the temperature limitation to the maximum surrounding temperature!
- Only use well-sealed control cabinets so that moisture condensation cannot arise as a result of warm and moist external air entering the cabinet.
- In the event that control cabinets are operated with the doors open (commissioning, servicing etc.), it is essential to ensure that after the doors are closed the drive controllers cannot at any time be cooler than the air in the control cabinet. For this reason, sufficient circulation must be provided inside the control cabinet to avoid pockets of heat.

12.5 Multiple-Line Design of the Control Cabinet



Air guides, blowers, arrangement

Particular attention should be paid to the maximum allowed air intake temperature of devices when they are arranged in multiple lines in the control cabinet.

If possible, place devices with a high degree of power dissipation (e.g. supply units with braking resistors, DC bus resistor units)

- in the top line and
- near the outlet air aperture to the cooling unit.


To protect the devices in the upper lines against the warm air of the air outlet of the devices beneath, mount **air guides** between the lines.

Additional blowers are used to convey the warm air to the cooling unit and to supply cooling air to the upper lines.

At the installed control cabinet, check the temperature at the air intake of all devices.



To extend the module bus connection, the accessory RKB0001 is available. Observe the assignment.



discharge of heated air to cooling unit
interior of control cabinet
conveying direction of heated air in area where air flows off
device in control cabinet
air intake at device
air guide in control cabinet
blower in control cabinet
blower in control cabinet
supply of cooled air from cooling unit
Fig. 12-8:

Example of arrangement for double-line design

13 Connections of the Components in the Drive System

13.1 System Connections of the Components

13.1.1 General Information

Electrical connections for operating the drive system Rexroth IndraDrive:


In the System Environment

- connection X3 or PE to equipment grounding system
- connection X3 to supply with power voltage
- connection X13 or terminal block 0V / +24V to supply with control voltage
- connection to control unit and/or master communication

Within the Drive System

- equipment grounding conductor connections PE to X3 or joint bars at the devices
- DC bus connections L+ with bars
- DC bus connections L- with bars
- control voltage connections 0V with bars
- control voltage connections +24V with bars
- module bus connections X1 with ribbon cable
- motor power connections via motor power cable at X5
- connections for motor temperature monitoring and motor holding brake via motor power cable at X6

13.1.2 Position of System Connections



1) control voltage

2) DC bus

equipment grounding conductor

X1 out, X1 in module bus

Fig. 13-1: Connections at power section

13.1.3 Ground Connection of Housing

The ground connection of the housing is used to provide functional safety of the drive controllers and protection against contact in conjunction with the equipment grounding conductor.

B

Avoid spark discharge of static charges!

In some applications (e.g. printing or packaging), high static charges can develop. Make sure that these charges can be directly discharged against ground at their point of origin. If necessary, install additional lines between the fixing points of the motor flanges (charge acceptance) and the ground connection of the drive system (e.g. mounting surface of the drive controllers in the control cabinet).

Ground the housings of the devices:

- Connect the bare metal back panel of the device in conductive form to the mounting surface in the control cabinet. To do this, use the supplied mounting screws.
- 2. Connect the mounting surface of the control cabinet in conductive form to the equipment grounding system.
- Connect the bare metal back panel of the mains filter in conductive form
 to the mounting surface in the control cabinet. Connect the mounting surface of the mains filter with the lowest possible impedance (over a large
 surface area) to the mounting surface of the drive controllers (see item 1).

13.1.4 Connection Point of Equipment Grounding Conductor and Equipment Grounding Connections

General Information

The connection of the equipment grounding conductors of the devices and their connection to the equipment grounding system are indispensable for the electrical safety of the drive system.



Dangerous contact voltage at device housing! Lethal electric shock!

Devices of the Rexroth IndraDrive product range are devices with increased leakage current (greater than AC 3.5 mA or DC 10 mA). Therefore, always install a stationary connection of the equipment grounding conductor.

Observe the description below.

In the drive system Rexroth IndraDrive, connect the equipment grounding conductor connections of all devices and additional components to the equipment grounding system.

Involved devices	Equipment grounding connections ces	between devi-	Connection to equipment grounding trol cabinet at devices	system in con-
HMV01 HCS03 HMS01 HMD01 HLB01.1D HLC01.1D	interconnect joint bars at front of devices	HMV01 HCS03 HMS01 HMD01 HLB01.1D HLC01.1D	realized in central form one connection at	HMV01 HCS03
HCS02 with HAS04 HLB01.1C HLC01.1C HMS01 HMD01	interconnect joint bars at front of devices	HAS04 HLB01.1C HLC01.1C HMS01 HMS02 HMD01	realized in central form one connection at	HCS02
HCS02 without HAS04 HCS02 HMS01 HMS02 HMD01 HLB01.1C HLC01.1C HLC01.1D	interconnect joint bars at front of devices	HMS01 HMS02 HMD01 HLB01.1C HLC01.1C HLB01.1D	and one connection at connected drive system, consisting of all	HCS02 HMS01 HMS02 HMD01 HLB01.1C HLC01.1C HLC01.1D
HMV02 HMS02 HNL02 HNS02	interconnect joint bars at front of devices	HMV02 HMS02	one connection each at all and one connection at connected drive system, consisting of all	HNL02 HNS02 HMV02 HMS02

Fig. 13-2: Equipment grounding connections

Equipment Grounding Connections Between Devices





Fig. 13-3: Equipment grounding connections between devices

Connection to Equipment Grounding System in Control Cabinet




1 joint bar

2 connection point for connection to equipment grounding system in con-

trol cabinet


Fig. 13-4: Equipment grounding connections



1 joint bar

2 connection to equipment grounding system

Fig. 13-5: Equipment grounding connection in the case of supply via HMV01, HMV02 or HCS03



1 joint bar

connection to equipment grounding system

Fig. 13-6: Equipment grounding connection in the case of supply via HCS02



Equipment grounding conductor: material and cross section

For the equipment grounding conductor, use the same metal (e.g. copper) as for the outer conductors.

For the connections from the equipment grounding conductor connection of the device to the equipment grounding conductor system in the control cabinet, make sure the cross sections of the lines are sufficient.

Cross sections of the equipment grounding connections:

- for HCS03.1E drive controllers and HMV01 supply units, at least 10 mm², but not smaller than the cross sections of the outer conductors of the mains supply feeder
- for HCS02.1E drive controllers, at least 4 mm², but not smaller than the cross sections of the outer conductors of the mains supply feeder

Additionally, mount the housing of HCS02.1E to a bare metal mounting plate. Connect the mounting plate, too, with at least the same cross section to the equipment grounding conductor system in the control cabinet.

For outer conductors with a cross section greater than 16 mm², you can reduce the cross section of the equipment grounding connection according to the table "Cross section of equipment grounding conductor, excerpt from EN 61800-5-1:2003".

Cross-sectional area A of outer conductors	Minimum cross-sectional area A _{PE} of equipment grounding connection		
A ≤ 16 mm²	A S		
16 mm² < A ≤ 35 mm²	16		
35 mm² < A	A / 2		

Fig. 13-7: Cross section of equipment grounding conductor, excerpt from EN 61800-5-1:2003, table 2

13.1.5 Connection to Mains Choke and Mains Filter

Order of the connections to the supply mains:

supply mains → mains filter → mains choke → supply unit or drive controller



Only operate allowed loads at the mains filter of the drive system!

At the three-phase filter for the power connection of regenerative supply units, it is only allowed to operate the following loads:


HMV supply unit with mains choke and, if necessary, mains contactor

Do not operate any motor blowers, power supply units etc. at the mains filter of the drive system.

The cables to the mains choke and mains filter carry a high potential of interference; you should therefore keep them as short as possible and twist them.



The cables allowed at HMV supply units between mains choke and the HMV mains input must be of a maximum length of 5 m and twisted (or run in a grounded, metallic cable duct).



- 1) fusing of connection X14
- 2) in-phase connection required
- 3) mains choke
- 4) mains filter

Fig. 13-8: Synchronizing voltage HMV01.1R

See also EMC measures for design and installation in chapter 11.2.3 EMC Measures for Design and Installation, page 159.

13.1.6 Connection of the DC Bus Connections

General Information



Property damage in case of error caused by too small line cross section!

Observe the current carrying capacity of the connection lines at the DC bus connections of the components used; see chapter"DC Bus Connection (L+, L-)" in the Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections".

Install connection lines at the DC bus connections in such a way that they are protected by the line protection at the mains connection of the supply unit or by additional fuses before the connection line.

View	Technical Data	Identifica- tion	Function
		} [™] L+	connections to connect the DC bus connections
L+ [O O L+	L-	tpantoling, ipantoling, ipantoling,
L- [0 0 L-	3	The state of the s
16	DA000176v01_nn.FH11	40.G	atalka ti

S)'	- S	- 300		
Screw connection	Unit	Min.	Max.	
M6 thread at device (terminal block)		10	2, 2,	
tightening torque	Nm	5,5	6,5	
short circuit protection	amati	(A)	sted in the incoming circuit to the connection	
overload protection	(qp _{grite}	via fusing elements connected in the incoming circuit to the mains connection		
current carrying capacity "looping through" from L	+ to L+, L-	:o L- 444	Mr. A	
(contact bars in scope of supply of accessory HAS	S01)			
with contact bars -072	Α	3.5. "M3.5.	220	
additionally with contact bars -042 and end piece	A	"(Light)	245	

Fig. 13-9: Function, pin assignment, properties

Single-Line Arrangement

The figure below illustrates the connection point and connection of the DC bus connections in the case of single-line arrangement with contact bars for the system components

- HMV01
- HMS01
- HMD01
- HLB01.1D
- HCS03

Design




Fig. 13-10: Contact bars

Multiple-Line Arrangement

For multiple-line arrangement of drive controllers, the connection for DC bus and control voltage supply is realized with twisted cables.

189/363

Connections of the Components in the Drive System



Damage to the drive controller!

- The DC bus connections of stacked drive controllers must be correctly interconnected.
- Connect L+ connections only to other L+ connections and L- connections only to other L- connections.
- Observe the measures regarding maximum allowed line lengths and minimum required line cross sections.

Maximum Allowed Line Length at DC Bus Connection

The line length at the DC bus connection is limited to protect the devices. For the maximum allowed line lengths between the electrical connections, see table below.



In this context, observe the data in chapter "Minimum Requirements to the Connection Lines"!

			J. 10		(O-			
4	410	145	Allow	ed line lengt	h/m	³⁴ /Q,		7/1/07
from		Ma		212	to	100		Ma.
3.Q	HMV01	HMV02	HCS03	HCS02	HMS01 / HMD01	HMS02	HLB01	HLC01
HMV01	0,5		- Carrier		21)		0,35	0,35
HMV02	.1081 <u>112</u>	0,5	10 ¹¹ 1111	- ~	Dille	0,35	0,35	0,35
HCS03	41.00	24/	0,5	-44.60	2 ¹⁾	"41'C		0,35
HCS02		- 22		0,5	2 ¹⁾	0,35	0,35	0,35
HMS01 / HMD01	- 4	, - ·	- ₁₂		21)		0,35	0,35
HMS02	10 No.		** <u>**</u> 20x		voltio-	2 ¹⁾	0,35	0,35
HLB01	1923-	,(10 th	- %		1900	0,35	0,35
HLC01		- " "				1241.		0,35

1) Fig. 13-11:

additional lateral distance requires the module bus connection RKB0001 Maximum allowed line lengths at DC bus



Line length > 2 m between supply unit and drive controller

For arrangements of supply units which supply, for example, drive controllers over line lengths > 2 m, take special measures:

- Use HLC01 DC bus capacitor units at every drive system.
- Dimension the minimum size of HLC01 according to the projected continuous power of the respective drive system:
 47 µF per kilowatt [kW] of continuous power.

Example: 50 kW calculated continuous power in DC bus requires 2350 µF at this system, thus at least 1 HLC01.1D-02M4.



Maximum length between drive systems and drive controllers

Multiple-line arrangement or distance between the devices requires the accessory **RKB0001** for the **module bus connection** between the devices (see chapter 14 Accessories in the Drive System Rexroth IndraDrive, page 201).

The maximum length of the accessory RBK0001 limits the length of the DC bus connection to be achieved between drive systems.

Minimum Requirements to the Connection Lines

Dielectric Strength

The connection lines from the supply unit to the drive systems and between the drive systems must have a dielectric strength of at least:

- 1000 V against each other
- 700 V against ground

Line Cross Section

Determine the minimum line cross section from supply unit to drive systems and between drive systems by means of the rated current. For rated current, use the higher value from the following calculations:

- calculate the mains-side phase current
- calculate the current in the branch with the greatest DC bus power

B

Minimum cross section UL

Use in the scope of UL requires the line cross section $A \ge 35 \text{ mm}^2$ (AWG2).



For connecting line cross sections of 35 mm² (AWG2) and 50 mm² (AWG1/0), use the accessory HAS05.1-004.

Routing

Routing of the connection lines from the supply unit to drive systems and between the drive systems:

- twist the lines with the minimum possible length of lay, but 120 mm as a maximum
- with minimum mechanical distance to ground potential
- with a minimum distance of 200 mm to control voltage lines

The figures below illustrate the correct DC bus connection for stacked drive controllers. The illustrated way of connection keeps bare wire sections from being situated directly vis-à-vis. This avoids voltage arcing.

Cable Routing to the Left



Damage caused by voltage arcing!

Insulate ring terminals and connecting lines with a heat-shrinkable sleeve. Afterwards only strip the insulation of the contact surface of the ring terminal. Realize connections according to figure.




Fig. 13-12: DC bus connections for cable routing to the left

Cable Routing to the Right



Damage caused by voltage arcing!

Insulate ring terminals and connecting lines with a heat-shrinkable sleeve. Afterwards only strip the insulation of the contact surface of the ring terminal.




Fig. 13-13: DC bus connections for cable routing to the right

13.1.7 Connection of the Control Voltage Connections

General Information



Property damage in case of error caused by too small line cross section!

Make use of the contact bars provided to loop-through.

Observe the current carrying capacity of the connections for 24V supply at the devices used; see section "Terminal Block, 24 V - 0V (24V Supply)" and "X13, Control Voltage (24V, 0V)" in the Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections".



Connect the connections X13 of components with connector for 24V supply individually and in star-shaped form to the 24V supply in the control cabinet.


Connection of 24V Supply per Ter- minal Block			r- k	Identifica- tion	Function	
24V •=	0	0	24V	S.	+24V	power supply connection to neighboring devices with contact bars from the HAS01.1 accessory
0V	OV O OV DA000175v01_nn.FH11		0V	reference potential for power supply connection to neighboring devices with contact bars from the HAS01.1 accessory		

Salle.		7.01/10.	116.	
Screw connection M6 thread at device (terminal block)	Unit	Min.	Max.	
tightening torque	Nm	5,5	6,5	
power consumption	W see P _{N3} (see index entry with reference to the co			
voltage load capacity	V	see U_{N3} (see index entry with reference to the correspage)		
polarity reversal protection		within the allowed voltage rang	e by internal protective diode	
current carrying capacity "looping through" from (contact bars in scope of supply of accessory H		, 0V to 0V	**************************************	
with contact bars -072-	Α	220	TOURS.	

Fig. 13-14: Function, pin assignment, properties

Single-Line Arrangement

The figure below illustrates the connection point and connection of the control voltage connections for devices HMV01, HMV02, HMS01, HMS02, HMD01 HLB01.1D and HCS03 in single-line arrangement.



cable (to source of control voltage supply)

В contact bars

Fig. 13-15: Connection points and connections of control voltage

Multiple-Line Arrangement

The following figures show the correct control voltage connection for stacked drive controllers. The illustrated way of connection ensures that the touch guard can be correctly mounted and the required clearances and creepage distances can be complied with.

The cables have to be twisted.

Cable Routing to the Left




Fig. 13-16: Control voltage connections for cable routing to the left

Cable Routing to the Right




Fig.13-17: Control voltage connections for cable routing to the right

Module Bus Connection X1 13.1.8

The module bus connection is used for signal exchange within the drive system and takes place via the supplied ribbon cables.

Graphic Representation




Fig. 13-18: X1

图

When extension cables are used for the module bus, they must be shielded. Their total length mustn't exceed a maximum of 40 m.

To extend the module bus connection, the accessory RKB0001 is available.

Connection of Motor to Drive Controller X5, X6 13.1.9

General Information

The connection to the motor takes place with Rexroth power cables. The motor power cables contain:

Connection X5 (power)

- outputs to motor A1, A2, A3
- equipment grounding conductor connection
- overall shield

Connection X6 (control contacts)

- motor temperature monitoring with partial shield
- motor holding brake with partial shield




Fig. 13-19: Motor connection



For detailed information, particularly on suitable additional parts, such as control cabinet ducts and extensions, see documentation "Rexroth Connection Cables".

Minimum requirements for connecting the motor power cables to the drive controller:

- Connect the shield of the motor power cable over the largest possible surface area (with low impedance) to the drive controller. The connection of cable shields by means of round wires (so-called "pig tails") at the cable ends to ground and housing is normally insufficient.
- Make sure there is sufficient **strain relief** for the motor power cable itself.
- For further notes on how to route the cables, see section "Arranging the Components in the Control Cabinet" under "EMC Measures" and "EMC-Optimal Installation".

According to the individual connection properties, these requirements can be fulfilled with or without the HAS02 accessory.

Shield Connection with Accessory HAS02

Using the optional accessory HAS02 with connection over a large surface area directly to the device is the best solution for shield connection. The figure below illustrates this **by the example of** HCS02 drive controllers:



Fig. 13-20: Connecting HAS02 to HCS02



For information on the available accessory HAS02 and how to mount it, see chapter "Accessories in the Drive System Rexroth IndraDrive" under "Shield Connection HAS02" and "Mounting the HAS02 Accessories"


Shield Connection Without Accessory HAS02

For shield connection without HAS02 accessory, connect the cable shield with the lowest possible impedance to the drive controller.

The following paragraphs describe two basic alternatives of this kind of connection.

Alternative 1

Connect cable shield to a ground bus. The maximum distance between ground bus and device connection is 100 mm. For this purpose take the given length of the single strands at the cable end into account for ready-made Rexroth motor power cables.




drive controller clip for shield connection overall shield of the motor power cable folded back ground bus in control cabinet single strands of motor power cable 5: 6: connection of ground bus to supplying device strain relief (as near as possible to exit point from control cabinet) 7:

Fig.13-21: Shield connection, alternative 1

- With a clip (2) connect overall shield of motor power cable (3) to ground bus (4). (If you use your own cable, make sure the shields of the two inner pairs of wires are in contact with the overall shield.)
- With a cable (6) (line cross section at least 10 mm²), connect ground bus (4) to ground connection at supplying device (Rexroth IndraDrive supply unit or Rexroth IndraDrive drive controller HCS).

Alternative 2 Connect cable shield to a ground bus. The cable length between device and ground bus mustn't be more than a maximum of 1 m. For this purpose, prepare the motor cable in accordance with the description below:



- 2: cable tie
 3: overall shield of the motor power cable folded back
 4: ground bus in control cabinet
 5: connection between overall shield of motor power cable
- 5: connection between overall shield of motor power cable laying bare and ground bus
- 6: connection of ground bus to supplying device
- 7: strain relief (as near as possible to the drive-side cable end)
- 8: strain relief (as near as possible to exit point from control cabinet)
- A: cable length between ground bus and device: < 1 m

Fig. 13-22: Shield connection, alternative 2

- With a cable tie (2) press the drive-side cable end in such a way that the shields of the two inner pairs of wires (motor temperature, holding brake) have good contact with the overall shield of the motor power cable (3). (If you use your own cable, make sure the shields of the two inner pairs of wires are in contact with the overall shield.)
- On the level of the ground bus in the control cabinet remove a piece of the cable sheath from the motor power cable in order to lay bare the overall shield (5).
- Connect overall shield (5) to ground bus in the control cabinet with an appropriate connection (clip). The connection must have a cross section of at least 10 mm².
- With a cable (6) (line cross section at least 10 mm²), connect ground bus (4) to ground connection at supplying device (Rexroth IndraDrive supply unit or Rexroth IndraDrive drive controller HCS).
- Make sure there is sufficient strain relief for the motor power cable as near as possible to the drive-side cable end (7).

In addition, make sure there is sufficient strain relief for the motor power cable as near as possible to the exit point from the control cabinet of the motor power cable (8).

B

Do not remove the shield of the motor cable between ground bus and device.

If the motor power cables are routed to the control cabinet via flange sockets, directly connect the shield to the wall of the control cabinet over a large surface area via the housing of the flange socket. Make sure there is sufficient separate strain relief.

Bonding Conductor

Bad ground connection between motor housing and control cabinet housing, as well as long motor cables, can require additional routing of a bonding conductor of a cross section of normally 10 mm² between control cabinet housing and motor housing.

啄

For cable lengths of more than 50 m, the cross section should be at least 35 mm².

Shield Connection of Kit Motors

For kit motors, make sure that the connection lines are run in shielded form or under metal between winding and terminal box, if the terminal box is not directly mounted on the spindle case.

Shield Connection of Linear Motors

For linear motors, connect the shield of the connection cable between primary part and terminal box via clips to machine housing or metal shell.

Shielding of Motor Temperature Monitoring and Motor Holding Brake The inner shields of motor temperature monitor and motor holding brake in the motor cable are connected to the drive controller at one end.

13.2 Overall Connection Diagrams of the System

To draw up the overall connection diagrams there are ePlan macros of the devices available. Please ask our sales representative.

14 Accessories in the Drive System Rexroth IndraDrive

14.1 HAS01 Basic Accessories

14.1.1 Type Code



The following figure illustrates the basic structure of the type code. Our sales representative will help you with the current status of available versions.




Fig.14-1: Type code HAS01.1

14.1.2 Brief Description

Accessories for mounting and installing the drive controllers in a group, i.e. next to each other.

Accessories in the Drive System Rexroth IndraDrive

As adjusted to the device widths, we distinguish 3 types:

- HAS01 without contact bars (-NNN)
- HAS01 with contact bars (-072-) to connect the DC buses
- HAS01 with contact bars (-072-) to connect the DC buses and joint bars to connect the equipment grounding conductors of the devices



Observe that the contact bars of the basic accessories HAS01 are used for connection to the drive controller on the **left-hand** side.

14.1.3 Usage

The HAS01 accessories are used to

- fix the drive controllers to a mounting surface
- connect the DC bus connections of drive controllers
- connect the 24V supply of drive controllers of the Rexroth IndraDrive M range
- connect the equipment grounding conductor from drive controller to drive controller or supply unit
- increase the current carrying capacity of the contact bars in the DC bus for high-performance devices (by means of the parts "end piece" and "bar" in HAS01; see chapter "Assignment")

B

Use of the parts "end piece" and "bar"

For high-performance devices, you have to mount the end pieces and bars contained in the HAS01 accessory (see chapter "Assignment").

See sections "Terminal Block L+, L- (DC Bus Connection)" and "Terminal Block, 24V - 0V (24V Supply)" in the Project Planning Manual "Rexroth IndraDrive, Supply Units and Power Sections".

14.1.4 Assignment

The accessories are assigned to the individual devices depending on the device width (see section "Type Code").

3.Z.	Devic	Device type Width / mm		Accessory HAS01.1-		
			The state of the s		with "end piece"	
	HMS01.1N-	W0020	50	050	-	
		W0036	50	050	5	
		W0054	75	075	- 30	
Ŕ.		W0070	100	100	- 2-	
		W0110	125	125	~ig/6 -	
		W0150	150	150		
		W0210	200	200	•	
		W0350	350	350	- 222	

Device type		Width / mm	Accessory HAS01.1-	
	May.	The		with "end piece"
HMD01.1N-	W0012	50	050	-
	W0020	50	050	-
	W0036	75	075	60
HMS02.1N-	W0028	49.5	050	-10975
	W0054	74.5	075	"hy.
HLB01.1	D	100	100	1,
HLC01.1	D	100	100	-
HMV01.1E-	W0030	150	150	- ,
	W0075	250	250	- ⁷ 70,
	W0120	350	350	7-200
HMV01.1R-	W0018	175	175	24
	W0045	250	250	•
	W0065	350	350	•
	W0120	350	350	∞
HMV02.1R-	W0015	150	150	-1090
HCS02.1N-	W0012	65	065	74 -
	W0028	65	065	-
	W0054	105	105	-
	W0070	105	105	-
HLB01.1	C NO	65	065	- 710
HLC01.1	C "iggs	50	050	77:000
HCS03.1N-	W0070	125	125	1 ₁₁₁ .
	W0100	225	225	-
	W0150	225	225	-
	W0210	350	350	• .6

Fig. 14-2: Device width

14.1.5 Scope of Supply

Components of the accessory: see accompanying notes

204/363





Fig. 14-3: Accompanying note







Fig. 14-5: Accompanying note








Fig. 14-7: Accompanying note








Fig. 14-10: Accompanying note





Fig. 14-11: Accompanying note







Fig. 14-13: Accompanying note







Fig. 14-15: Accompanying note






Fig. 14-17: Accompanying note




Fig. 14-18: Accompanying note





Fig.14-19: Accompanying note







Fig.14-21: Accompanying note






Fig. 14-23: Accompanying note



Material-Nr.

Datei

R911306678

DB166387

Zeich-Nr. 109-1253-4227-07

Ers.durch

AEM-Nr. 5-017509






Fig. 14-25: Accompanying note



14.1.6 Mounting the Parts "Bar" and "End Piece" of the Accessories HAS01

The parts "bar" and "end piece" increase the current carrying capacity of the DC bus connections by reducing the involved contact resistances.



ba

2 end piece (right end) 3 end piece (left end)

Fig.14-27: Mounting bar and end piece of HAS01

- Ad 1: Use the bars (-042) contained in all HAS01.1-***-072-** as shown in the figure at L+ and L-.
- Ad 2 and 3: Use the end pieces contained in all HAS01.1-350-***-** and HAS01.1-200-***-** at the right and left ends of the DC bus connections in the drive system.

14.2 HAS02 Shield Connection

14.2.1 General Information

Accessories for appropriate connection of the motor cable to the drive controller, especially the shield connection of the motor cable.

There are appropriate HAS02 accessories for the different drive controllers.

14.2.2 Type Code




Fig. 14-28: Type code HAS02.1

14.2.3 Usage

The HAS02 accessories are used for


- strain relief of the motor cable
- connecting the shield of the motor cable to the drive controller

14.2.4 Assignment of Accessory HAS02

See section "Type Code (Device assignment)"

14.2.5 Scope of Supply

For the scope of supply and the components of HAS02, see the corresponding accompanying notes.







Fig. 14-30: Accompanying note







Fig. 14-32: Accompanying note







Fig. 14-34: Accompanying note







Fig. 14-36: Accompanying note







Fig. 14-38: Accompanying note







Fig. 14-40: Accompanying note








Fig.14-41: Accompanying note





Fig. 14-42: Accompanying note

14.2.6 Mounting the Accessory HAS02

General Information



screw in thread XS2

fixing device of shielding plate

3 shielding plate4 shield of motor cable

5 clip

Fig. 14-43: Shield connection of motor cable

- Unscrew bottom or bottom left fixing screw of drive controller.
- Put fixing device of accessories to bottom of drive controller and screw down fixing screw of drive controller again.




Risk of damage to the drive controller caused by too long screws!

Exclusively use the supplied screws of a length of **12 mm** for the thread of the shield connection XS2.

- Screw second screw (M6 x 12) in thread XS2 at bottom of drive controller.
- Screw shielding plate to sheet metal of accessories according to desired cable routing of motor cable (45° or horizontal). (The figure below illustrates cable routing with 45°.)
- According to diameter of motor cable, fix motor cable at corresponding point of shielding plate (12–18 mm or 19–30 mm) with a clip. Make sure that shield of motor cable has good contact with shielding plate (see figure below).

HAS02.1-001 at HMS01.1N-W0054




- fixing device
- 2 shielding plate
- 3 clip
- different possibilities of mounting the shielding plate, according to motor cable routing

Fig. 14-44: HAS02.1-001 at bottom of drive controller HMS01.1N-W0054

- By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable routing.
- 3. Fix shield of cable to shielding plate with appropriate clip.

HAS02.1-002 at HCS02.1E-W0054




- fixing device shielding plate clip
- different possibilities of mounting the shielding plate, according to motor cable routing

Fig. 14-45: HAS02.1-002 at bottom of drive controller HCS02.1E-W0054

- By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable routing.
- 3. Fix shield of cable to shielding plate with appropriate clip.

HAS02.1-003 at HMS01.1N-W0210




- fixing deviceshielding plate
- 3 clip
- 4 different possibilities of mounting the shielding plate, according to motor cable routing

Fig. 14-46: HAS02.1-003 at bottom of drive controller HMS01.1N-W0210

- By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable routing.
- 3. Fix shield of cable to shielding plate with appropriate clip.

HAS02.1-004 at HCS03.1E-W0070




- fixing device shielding plate
- 3 clip
- different possibilities of mounting the shielding plate, according to motor cable routing

Fig. 14-47: HAS02.1-004 at bottom of drive controller HCS03.1E-W0070

- By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable routing.
- 3. Fix shield of cable to shielding plate with appropriate clip.

HAS02.1-005 at HCS03.1E-W0100 / 150




- fixing device 2 shielding plate
- 3 clip
- different possibilities of mounting the shielding plate, according to motor cable routing

Fig.14-48: HAS02.1-005 at bottom of drive controller HCS03.1E-W0100 / 0150

- By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable rout-
- Fix shield of cable to shielding plate with appropriate clip.

HAS02.1-008 at HCS03.1E-W0210




- 1 fixing device 2 shielding plate
- 3 clip
- 4 different possibilities of mounting the shielding plate, according to motor cable routing

Fig. 14-49: HAS02.1-008 at bottom of drive controller HCS03.1E-W0210

Mounting

- 1. By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable routing.
- 3. Fix shield of cable to shielding plate with appropriate clip.

HAS02.1-010 at HMS02.1N-W0028 / 54




fixing device
 shielding plate

Fig. 14-50: HAS02.1-010-NNN-NN at bottom of drive controller HMS02.1N-W0028 / 54

- Screw fixing device to equipment grounding conductor connection of drive controller.
- 2. Fix shield of cable with shielding plate to fixing device.

HAS02.1-014 at HMS01.1N-W0350



- fixing device shielding plate
- 3 clip

Fig. 14-51: HAS02.1-014 at bottom of drive controller HMS01.1N-W0350

- 1. By means of supplied screws, fasten fixing device to front of blower unit.
- 2. Fix shielding plate to fixing device.
- 3. Fix shield of cable to shielding plate with appropriate clip.

14.2.7 Shield Connection of the Motor Cable via Mains Filter

General Information


There is a special shielding plate for shield connection of the motor cable via the mains filter at the drive controller:



Using the shielding plate guarantees optimum shield contact of the motor cable. You should therefore, **where possible, always** use the shielding plate.

The shielding plate is only available as an option.

HAS02.1-006 With Motor Cable and Mains Filter



1 fixing device 2 shielding plate


Fig. 14-52: HAS02.1-006 at bottom of mains filter (rated current 50 A)

- **1.** Hang up fixing device at bottom of mains filter at threaded bolts and fasten with supplied nuts.
- 2. Screw shielding plate to fixing device.
- 3. Fix shield of cable to shielding plate with appropriate clip.



The shield terminals must not be used to provide strain relief.

HAS02.1-007 With Power Supply Cable and Mains Filter



- fixing deviceshielding plate
- 3 clip
- 4 different possibilities of mounting the shielding plate, according to cable
 - routing
- 5 power supply cable
- 6 motor cable

Fig. 14-53: HAS02.1-007 at bottom of mains filter (rated current 80 A / 106 A)

- 1. Hang up fixing device at bottom of mains filter and fasten with supplied screws.
- 2. Screw shielding plate to fixing device.


According to desired cable routing, the shielding plate can be mounted in different positions

3. Fix shield of cable to shielding plate with clip.

B

The shield terminals must not be used to provide strain relief.

HAS02.1-009 With Power Supply Cable and Mains Filter



1 fixing device 2 shielding plate

3 clip

4 different possibilities of mounting the shielding plate, according to cable routing

5 power supply cable

6 motor cable

Fig.14-54: HAS02.1-009 at bottom of mains filter (rated current 146 A)

Mounting

- By means of supplied screws, fasten fixing device to bottom of drive controller.
- 2. Fix shielding plate to fixing device according to desired motor cable routing.
- 3. Fix shield of cable to shielding plate with appropriate clip.

B

The shield terminals must not be used to provide strain relief.

14.3 HAS03 - Control Cabinet Adapter

14.3.1 Type Code

256/363





Fig. 14-55: Type code HAS03.1

14.3.2 Usage

The control cabinet adapter is used to compensate different mounting depths of drive controllers HCS02.1E and HLC01.1C and HMS01 / HMD01 when mounted to a common mounting surface.



A control cabinet adapter
B mounting surface in control cabinet

Fig. 14-56: How to use the control cabinet adapters

礟

Observe the maximum allowed **tightening torque** of **6 Nm** at HAS03.



Mechanical stability of the adapted device requires a rigid connection via DC bus rails to a neighboring device without adapter.

- Do not operate HAS03 without neighboring device.
- Mount HAS03 to bare metal mounting plate.

14.3.3 Assignment HAS03 Accessories

See section "Type Code (Device Assignment)".

14.3.4 Scope of Supply

Scope of Supply For the scope of supply and the parts of HAS03, see the corresponding accompanying note.





Fig.14-57: Accompanying note



14.4 Capacitor HAS04

14.4.1 General Information

Capacitors from the DC bus connections L+ and L- against housing.

14.4.2 Type Code

260/363




Fig.14-59: Type code HAS04.1

B

Using the HAS04 accessories requires additional mounting clearance at the drive controller.

Observe the dimensions of HAS04.

14.4.3 Usage

The HAS04 accessories are used to

- operate HCS02 and HCS03 drive controllers at the HNF01.1 mains filter
- operate HMS01 drive controllers at HCS02 and HCS03 drive controllers

HAS04 type	Usage
HAS04.1-001-NNN-NN	at DC bus connections of HCS02 drive controllers
HAS04.1-002-NNN-NN	at DC bus connections of HCS03 drive controllers

Fig. 14-60: HAS04 type


14.4.4 Assignment


No.	HAS	604.1
Device (type)	-001	-002
HCS02.1E-W0028	tollion -	50° - x50°
HCS02.1E-W0054	Page - 122	- 122
HCS02.1E-W0070	- WH.	- 44,
HCS03.1E-W0070	-	•
HCS03.1E-W0100	780)-	32 -
HCS03.1E-W0150	Calcala.	Calcy -
HCS03.1E-W0210	alico.	• "IIIO.

Fig. 14-61: Assignment HAS04 accessory

14.4.5 Scope of Supply

The HAS04 accessories are available as an option, they are not part of the standard scope of supply.





14.4.6 Capacitor

Connection HAS04




Fig. 14-64: Connection HAS04

14.4.7 Mounting Dimensions




Fig. 14-65: Mounting dimensions HAS04

Device	Min. mounting width B [mm]	Device height H [mm]	Device depth [mm]
HAS04.1-001	30	75	< 150
HAS04.1-002	40	75	< 150


Fig. 14-66: Mounting dimensions

14.4.8 Mounting the HAS04.1-001 Accessories



Dangerous contact voltage at device housing! Lethal electric shock!

Connect HMx01 drive controllers to the HCS02 drive controller by means of bus bar 2 (see figure below). Bus bar 2 replaces the equipment grounding connection 3 at HMx01 (see figure below) to the equipment grounding system.



1 mounted HAS04.1-001 accessories with connection to L+ and L-

2 mounted bus bar

3 equipment grounding connection at HMx01

Fig. 14-67: HAS04.1-001 at drive system HCS02 with HMx01 without touch guard

mounted



1 mounted HAS04.1-001 accessories

2 mounted bus bar

Fig. 14-68: HAS04.1-001 at drive system HCS02 with HMx01 with touch guard


mounted

14.4.9 Mounting the HAS04.1-002 Accessories



Dangerous contact voltage at device housing! Lethal electric shock!

Connect the HAS04.1-002 accessories to drive controller HCS03 via the joint bar (see figure below).



mounted HAS04.1-002 accessories with connection to L+ and L-joint bar

Fig. 14-69: HAS04.1-002 at drive system HCS03.1E-W0070, -W0100, -W0150 with HMx01 without touch guard mounted



1 mounted HAS04.1-002 accessories with connection to L+ and L-Fig. 14-70: HAS04.1-002 at drive system HCS03.1E-W0210 with HMx01 without touch guard mounted



Fig.14-71: HAS04.1-002 at drive system HCS03 with HMx01 with touch guard mounted

14.5 Accessories HAS05

14.5.1 Overview of Types

The product line HAS05 includes:

- cables
- connectors
- adapters

HAS05 type	Brief description / usage
3. To	adapter for mains and motor connection
HAS05.1-001-NNN-NN	is used for electrical connection between output filter HMF01.1A-D0K2-D0045 and HCS03.1E-W0070, as well as between mains filter HNK01.1A-A075-E0050 and HCS03.1E-W0070
HAS05.1-002-NNN-NN	extension is used for electrical connection between mains filter HNK01.1A-A075-E0050 and HCS03.1E-W0070, if an output filter has been mounted between HCS03.1 and mains filter
HAS05.1-003-NNN-NN	signal level converter encoder emulation increases voltage level at output of optional module MEM (encoder emulation) to voltage range 5 30 V

HAS05 type	Brief description / usage	
" Alah	adapter DC bus connection	
HAS05.1-004-NNL-NN HAS05.1-004-NN R -NN	with this accessory, you can wire several systems of dicontrollers with greater cross sections at DC bus conntions L+ and L-	
	NNL: outgoing direction "left"	
	NNR: outgoing direction "right"	
M. M.	signal level converter RS232/RS485	
HAS05.1-005-NNN-NN	converts serial interface of control sections from RS2 standard to RS485 standard	32
HAS05.1-006-NNN-NN (preliminary)	adapter for controlling motor holding brake	
	adapter from D-Sub to terminal connector	
HAS05.1-007-NN L -NN (preliminary)	universal adapter for safety technology for easier X47 wiring of 2nd channel	1
HAS05.1-007-NN R -NN	NNL: for mounting to double-axis control sections CDE at OP ST1	301
(preliminary)	NNR: for mounting to double-axis control sections CDE at OP ST2	301
10 ²¹ 111	adapter for connecting two cables	1
HAS05.1-008-NNN-NN	with this accessory, you can connect 2 ring cable lug- each at connections A1, A2 and A3 of X5 (motor conn tion)	

Fig. 14-72: HAS05 type

14.5.2 Type Code



The following figure illustrates the basic structure of the type code. Our sales representative will help you with the current status of available versions.




Fig.14-73: Type code HAS05.1

14.5.3 HAS05.1-001, Adapter for Mains and Motor Connection

Brief Description and Usage

Brief Description

The accessory HAS05.1-001 brings the mains and motor connections from the bottom of the device to the front of an HCS03.1-W0070.

You need this adapter when additional components are mounted to HCS03.1E-W0070 in order to connect them to the mains and motor input.

Assignment

HAS05.1-001 can be used at the following drive controllers:

Device	HAS05.1-001
HCS03.1E-W0070	W.

Fig. 14-74: Assignment accessory HAS05.1-001

Scope of Supply

Order this accessory as a separate item. It is not part of the scope of supply of the device.

Parts of the accessory: see accompanying note

Parts of HAS05.1-001




Fig. 14-75: Parts of HAS05.1-001

Technical Data

Connection, Mounting Dimensions

Allowed Cross Sections

The accessory HAS05.1 has been dimensioned to insert lines with ferrules in it.

	Unit	HAS05.1-001
allowed connection cross section stranded wire	mm²	16
allowed connection cross section stranded wire	AWG	6

Fig. 14-76: Connection cross section HAS05.1-001

Mounting Dimensions

The mounted adapter remains within the outer housing dimensions of the involved components HMF and HCS03.

Connection

HMF01

Connect input of output filter HMF01 to X5 at HAS05.1-001 (motor output of HCS03).

HNK01

Connect output of mains filter HNK01 to X3 at HAS05.1-001 (mains input of HCS03).

Examples of Installation

Mounted accessory




Fig.14-77: Arrangement HCS03 / HAS05.1-001 / HMF01

14.5.4 HAS05.1-002, Extension

Brief Description and Usage

Brief Description

The accessory HAS05.1-002 is an extension which connects the output of the HNK01 mains filter to the mains input of HCS03 (X3).

This adapter is required when the additional components HNK01 **and** HMF01 are mounted to HCS03.1E-W0070. The adapter is not required without HMF01.

Assignment

HAS05.1-002 can be used at the following drive controllers:

Device	HAS05.1-002
HCS03.1E-W0070	
with HNK01 and HMF01	W.G

Fig.14-78: Assignment accessory HAS05.1-002

Scope of Supply

Order this accessory as a separate item. It is not part of the scope of supply of the device.

Parts of the accessory: see accompanying note

Parts of HAS05.1-002




Fig. 14-79: Parts of HAS05.1-002

14.5.5 HAS05.1-003, Signal Level Converter Encoder Emulation Usage

Accessory	Usage
0007	adjusts voltage level at output of optional module MEM to voltage range 5–30 V

Fig.14-80: Usage

Scope of Supply

Scope of Supply

Order this accessory as a separate item. It is not part of the scope of supply of the device.

Parts of the accessory: see accompanying note

Dimensions





Fig. 14-81: Dimensions HAS05.1-003

Parts



top shell of connector housing 2 bottom shell of connector housing

electronics circuit board with internal connection point

Fig.14-82: Parts

Description




Fig. 14-83: Accessory HAS05.1-003

Connection point	Туре	No. of poles	Stranded wire [mm²]
X2	screw terminal block	6	0,14–1,5

Fig. 14-84: Connection

Pin Assignment

1 19.14-04.	Connectic	<i>// 1</i>	
Pin	Signal	Function	
1 1	UB	voltage supply for electronics	.6
2	UL	voltage supply for output driver	- ALICO
3	UA2+	incremental encoder track A2	M. (O)
4	0Vext	reference potential	
5	UA1+	incremental encoder track A1	
6	UA0+	incremental encoder reference track A0	
,of 100	Shield	connect cable shield to connector housing	,of ¹
	•		

Fig. 14-85: Assignment


If the required output voltage UL is greater than 7V, it can be used to supply the electronics (UB), too.

Electrical Data

Data	Unit	Min.	Тур.	Max.
supply voltage UL (output driver)	V	5 414		30
supply current UL (output driver)	mA	33,	16	⁹ .5.
supply voltage UB (electronics)	V	7	"i'iq _{Dullo}	30
supply current UB (electronics)	mA	7 74	17	7 342
output voltage UA0+, UA1+, UA2+	V	12° ×	J.) UL
allowed output current per output UA0+, UA1+, UA2+	mA		~altoffee	40
output resistance	kOhm		410	
short circuit protection		included		274
overload protection		included, or	utput voltage i	s reduced

Fig. 14-86: Supply and outputs

Example of Connection



SYS target, e.g. PLC; incremental input, counter or trigger function Fig.14-87: Example of connection

14.5.6 HAS05.1-004, Adapter DC Bus Connection (Preliminary)

Brief Description and Usage

Brief Description

The accessory HAS05.1-004-NNR and HAS05.1-004-NNL is an adapter which allows connecting lines with cross sections of up to 2 × 50 mm² to the DC bus connections.

It is typically used at the DC bus connections of high-performance supply units and inverters, when these devices have not been arranged directly side by side (e.g. with multiple-line arrangement or with decentralized supply concepts between several control cabinets).

The types "NNR" and "NNL" allow connections with outgoing directions to the right and left (view to front of drive controller).

Assignment

The use of the HAS05.1-004 accessory is restricted by the width of the drive controllers:

- NNL: device width is at least 125 mm
- NNR: can be used independently of the device width

At devices with a width of 50 mm, the outgoing direction to the left can also be used with the type "NNR".

For devices up to a width of 125 mm and for the outgoing direction to the left, you can fix lines with a **maximum cross section of 1 × 35 mm²** (1 ring cable lug) without fixing device (01) and without bar (05) directly at the terminal block (see picture 4).

The accessory can be used at the following drive controllers:

Device	HAS05	5.1-004-
	NNL	NNR
HMV01.1E-W0030, -W0075, -W0120	-	No.
HMV01.1R-W0018, -W0065, -W0120	• 9	•
HMS01.1N: type current < W0110	-9/s.	•
HMS01.1N: type current ≥ W0110	1010	- 10 ¹ C
HMD01.1N-W0012, -W0020, -W0036	'92 ₀₀ -	3 2000
HCS03.1E: type current ≥ W0070	hu	"Huy.
HLB01.1D	-	•
HLC01.1D	- 10.5	•

Fig. 14-88: Assignment accessory HAS05.1-004


Scope of Supply


Order this accessory as a separate item. It is not part of the scope of supply of the device.

Parts of the accessory: see accompanying note


Accompanying note HAS05.1-004-NNR-NN







Accompanying note HAS05.1-004-NNL



Technical Data

Connection, Mounting Dimensions

Allowed Cross Sections, Lengths

The accessory HAS05.1-004 is used to connect lines with ring cable lugs. At each connection point, it is allowed to use 1 or 2 lines of the same cross section.

"Trough	Unit	HAS05.1-004- NNL	HAS05.1-004- NNR	
allowed connection cross section	mm²	35	35	
stranded wire;		50	50	
1 ring cable lug mounted	AWG	2	2	
, j		1/0	1/0	
allowed connection cross section	mm²	35	35	
stranded wire;		50	50	
2 ring cable lugs mounted	AWG	2	2	
The T		1/0	1/0	
maximum tightening torque	Nm	6,6	6,6	
minimum tightening torque	Nm Nm	5,4	5,4	
allowed length, required lengths of lay etc.	, dbaltomat,	see chapter 13.1.6 Connection the DC Bus Connections on page 187		
fusing		-704	ment on line pro- ion!	
(g)		the DC Bus C	1.6 Connection of connections on a 187	

Fig. 14-91: Connection cross section HAS05.1-004

Mounting Dimensions

When mounted, the accessory requires the following mounting clearance to the left or to the right.




Fig. 14-92: Mounting dimensions HAS05.1-004-NNR, -NNL

B

Observe the minimum bending radiuses of the lines used. This requires additional mounting clearance, particularly on the left side.

Dimension	Unit	HAS05.1-004-NNL	HAS05.1-004-NNR
mounting dimension B	mm	41	50
mounting dimension H	mm	50	51
mounting dimension T	mm	35	56

Fig. 14-93: Mounting dimensions HAS05.1-004

How to Mount HAS05.1-004

Cases to be Distinguished

- outgoing direction of the lines to the right (HAS05.1-004-NNR)
- outgoing direction of the lines to the left (HAS05.1-004-NNL)
- outgoing direction of the lines to both sides (HAS05.1-004-NNR and HAS05.1-004-NNL)

Outgoing Direction of the Lines to the Right (HAS05.1-004-NNR)

1. Mount bar:

Without DC bus contact bars (see picture 1):

screw bar (5) and end piece (12) to terminal block (tightening torque: 6 Nm)

With DC bus contact bars (see picture 2):

screw bar (5), DC bus contact bar (11) and connection piece (13) to terminal block (tightening torque: 6 Nm)

2. Mount line:

(see picture 1 and picture 2)

screw ring cable lug (10) to bar (5) (tightening torque: 6 Nm; with 2 ring cable lugs, observe inverse arrangement)

3. Mount touch guard:

(see picture 3)

mount touch guard of drive controller (tightening torque: max. 2.8 Nm) insert touch guard of bars (2) and touch guard cover (1) and screw them together (tightening torque: 1.6 Nm)

Picture 1




Fig.14-94: HAS05.1-004-NNR; outgoing direction of the lines to the right; without DC bus contact bars

Picture 2




Fig.14-95: HAS05.1-004-NNR; outgoing direction of the lines to the right; with DC bus contact bars

Picture 3




Fig. 14-96: HAS05.1-004-NNR; mounting the touch guard

图

Make sure there is strain relief for the lines outgoing backward.

Outgoing Direction of the Lines to the Left (HAS05.1-004-NNL)

1. Mount bar:

Without DC bus contact bars (see picture 4):

screw bar (05) and end piece (12) to terminal block (tightening torque: 6 Nm)

With DC bus contact bars (see picture 5):

screw bar (05), DC bus contact bar (11) and connection piece (13) to terminal block (tightening torque: 6 Nm)

- 2. Put fixing device (01) on bar (05)
- 3. Screw cable holder (02) to left equipment grounding connection
- 4. Mount line:


(see picture 4 and picture 5)

screw ring cable lug (10) to bar (05) (tightening torque: 6 Nm; with 2 ring cable lugs, observe inverse arrangement)

fix lines with cable tie to cable holder (02)


5. Mount touch guard of drive controller (tightening torque: max. 2.8 Nm)

Picture 4



HAS05.1-004-NNL; outgoing direction of the lines to the left; without DC bus contact bars Fig.14-97:

Picture 5



HAS05.1-004-NNL; outgoing direction of the lines to the left; with DC bus contact bars Fig.14-98:



Beneath the touch guard, run the non-twisted lines in parallel.

Outside of the touch guard (after the strain relief), twist the line pairs. In the case of four lines at the connections L+ and L-, twist L+ and L- to form one pair.

Keep the surface between the individual lines of a pair as small as possible.

Run the line pairs with the smallest possible distance to each other.

Outgoing Direction of the Lines to Both Sides (HAS05.1-004-NNR and HAS05.1-004-NNL)

For mounting with outgoing direction to both sides, observe the descriptions on "Outgoing Direction of the Lines to the Left (HAS05.1-004-NNL)" and "Outgoing Direction of the Lines to the Right (HAS05.1-004-NNR)".




Fig. 14-99: Mounting HAS05.1-004-NNL and -NNR

14.5.7 HAS05.1-005, Signal Level Converter RS232/RS485 (Preliminary) Usage

Accessory	Usage	nn.
HAS05.1-005-NNN-NN		erface of Rexroth Indra- ons from RS232 stand- dard

Fig.14-100: Usage

Scope of Supply

Scope of Supply

Order this accessory as a separate item. It is not part of the scope of supply of the device.

Parts of the accessory: see accompanying note

Scope of supply

- converter
- connector at X2 and X3
- cable tie
- accompanying note

Technical Data

Dimensions




Fig.14-101: **Dimensions**



HAS05.1-005 can be mounted on a top-hat rail. For mounting it at a wall, remove the top-hat rail clip at the back of the housing.

You can also mount HAS05.1-005 on electrically insulating surfa-

Electrical Data

Characteristic	Unit	Min.	Тур.	Max.
number of nodes	× 0	130	,0103	31
allowed cable length 1)	m		'Apan	500
transmission rates 2)	kBaud	9,6	Tay,	115
mode of operation		ser	mi-duplex 2-wire	e line
connection between X1 and X2, X3		galvanically connected		ected
allowed voltage difference be- tween the reference potentials of the drive controllers (housing)	V		.H.idbalitorri	20
current consumption at X1.1	mA		1000	50
termination (TERM)		S	witchable ON, 0	OFF
short-circuit protection		Data+ against Data- Data+, Data- against GND		
cable length at X1	m		Palit	5
cable length at X2, X3	m	comply with bus length, see allowed ca		e allowed ca-

Characteristic	Unit	Min.	Тур.	Max.
connections X2, X3		"Ayio S	spring termina	al _{al} a ^(O)
connection cross section stran- ded wire	mm² / AWG	0.14–1.5 / 28	-16; ferrule w ing sleeve	ithout insulat-

- 1) bus length RS485, corresponds to total length of all connected cables
- 2) is set via firmware used

Fig. 14-102: Technical characteristics

Position of Connections, Termination



Fig. 14-103: HAS05.1-005 with connection cables

Pin Assignment X1

rig. 14-103.	TA303. 1-003 W	itii connection cables	- 20
Connection	Signal	Function	"M'10p.
1	V _{cc}	supply voltage (+5V)	20
2	RxD	reception line (Receive Data)	
3	TxD	transmission line (Transmit Data)	
4	n. c.	n. c.	101
<i>J</i> J ²⁰ 5	GND	reference potential	'Span
6	n. c.	n. c.	427.
7	n. c.	n. c.	
8	RTS	Request to send	
9	n. c.	n. c.	_6

Fig. 14-104: Pin assignment X1

Pin Assignment X2

Connection	Signal	Function	
1,52	Data+	data transmission +	The state of the s
2	Data-	data transmission -	
3	Shield	connection overall shield	740 ×

Fig.14-105: Pin assignment X2

Pin Assignment X3

Connection	Signal	Function
1,44	Data+	data transmission +
2	Data-	data transmission -
3	Shield	connection overall shield
4	GND	connection internal shield (signal shield)

Fig.14-106: Pin assignment X3

Installation

General Information

Three connections connect the accessory HAS05.1-005 to form an RS485 bus:

- connection X1 to serial interface X2 at control section
- connection X2 to connection X3 at next HAS05
- connection X2 to bus master (e.g. RS232/485 converter controlled by a PC)



Terminate the RS485 bus line at the most remote bus ends.

To do this, switch on the termination at the bus master (converter at PC). At the last node, set the "TERM" switch to "ON".

See also Functional Description of firmware "Communication via RS485 Interface" and Parameter Description, e.g. "P-0-4050, Answer delay RS-232/485"

Example of Connection




Fig. 14-107: Example of connection



Connect PC and RS485 bus to a so-called bus master converter; this RS232/485 converter automatically generates the RTS control signal.

The accessory HAS05.1-005 does not accomplish this function!

Connection at X1

Connection From X1 to Control Section (X2)




Fig. 14-108: Connection cable RKB0010




For **direct** connection from X1 to the control section, use our cable **RKB0010** and observe its maximum allowed length (see "Electrical Data" on page 286).

Connection at X2 and X3

Connect X2 and X3 with a cable according to the interconnection diagram below.

Connection between X2 and X3



Connection cable at X2 and X3 Fig. 14-109:

B

To assemble connection cables at X2 and X3, use our non-assembled cable INK0572.

Strain Relief at Connection X2 and



Fig. 14-110: Strain relief at connection X2 and X3

礟

Provide sufficient strain relief for the connections at X2 and X3! Use the supplied cable ties.

HAS05.1-006, Adapter for Controlling Motor Holding Brake (Prelimina-14.5.8 ry)

Usage

Assignment The accessory HAS05.1-006 can be used at the following drive controllers:

HMS02.1N-W0028

HMS02.1N-W0054

Function The accessory HAS05.1-006 switches the voltage supply of the motor holding

brake (connection point X6, motor temperature monitoring and motor holding


brake) and has a feedback contact to the switching action.

Scope of Supply Connector at X44

(Connector at X6 is not part of the scope of supply. Use the connector of the

power section.)

Identification, Parts The accessory has a type plate for identification.



type plate

connector at connection point X44


HAS05.1-006

Fig. 14-111: HAS05.1-006 at connection point X6 at drive controller

Technical Data

Mounting Dimensions

The accessory requires the following mounting clearance at the drive controller.



data in mm Fig. 14-112: Mounting dimensions



Observe the minimum bending radiuses of the lines used. This requires additional mounting clearance at the drive controller, particularly downward.

Connection Points

Xe

The connection point is described in the Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → "Functions and Electrical Connection Points" → "X6, Motor Temperature Monitoring and Motor Holding Brake".

X44


View	Connec- tion	Signal name	Function
	X44.1	+24V	relay control
2	X44.2		4.
3	X44.3	0V	10.0
55	X44.4		Taily.
6	X44.5	nc_Rel	relay contact "N/C"
DG000147v01_nn.FH11	X44.6	nc_Rel	and the said
Spring terminal (connector)	Unit	Min.	Max.
connection cross section solid wire	mm ²	0,14	1,5
connection cross section stranded wire	mm ²	0,14	1,5
connection cross section	AWG	28	16
Electrical data	1	May	14, 14,
supply d1 (X44.1/2, X44.3/4)	V	19,2	28,8
alke,	mA	24/2×	50
switching capacity K1 (X44.5, X44.6)	Α	- 1000	2
switching capacity K2 (X6.3, X6.4)	V	'9 ₂₂	28,8
minimum load of the contacts	mA	10	West, W.
contact resistance at minimum current	Ω		1
pick up delay	ms	, 70 j	30
drop out delay	ms	-Match	30
time constant of load	ms	oh	mic
number of switching actions at maximum time constant of load	160,	1 × 10 ⁶	Maryles Ma
number of mechanical switching cycles		1 × 10 ⁶	

short circuit protection		see description of connection point "X6, Motor Temperature
overload protection	45	Monitoring and Motor Holding Brake" in the Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sec-
		tions"

Fig. 14-113: Function, pin assignment

Usage

Block Diagram




D1 free-wheeling diode

D2 polarity reversal protection diode

d1 relay
K1 N/C contact
K2 N/O contact
Fig.14-114: Block diagram

Example of Use



1) safety door monitor

2) safety door contacts Fig.14-115: Example of connection

Mounting

Mount HAS05.1-006

1. Plug HAS05.1-006 in connection point X6 at drive controller

Make sure that HAS05.1-006 snaps into at X6 at the drive controller.

2. Plug connectors X6 and X44 in HAS05.1-006

Make sure there is sufficient strain relief for the connectors.

Dismount HAS05.1-006

1. Remove connection cable from HAS05.1-006

2. Loosen snap-in connection with screwdriver and remove HAS05.1-006 from drive controller

14.5.9 HAS05.1-007, Adapter From D-Sub to Terminal Connector (Preliminary)

Usage

The adapter HAS05.1-007 exists in the following types of design:

- NNL: mounting direction left (outgoing direction spring terminal left)
- NNR: mounting direction right (outgoing direction spring terminal right)




Fig. 14-116: Types of design

Assignment

The accessory HAS05.1-007 can be used at the following control sections:

HAS05.1-007-NNL	HAS05.1-007-NNR		
CSH01.1C at X41 (condition: option 3 not equipped)	CSH01.1C at X41		
CDB01.1C at X41.1 (option ST1)	CSH01.2C at X41		
9 9	CDB01.1C at X41.2 (option ST2)		

Fig. 14-117: Assignment HAS05.1-007

At **CDB01** control sections, you can use both types of design together. However, there is the following restriction:

When using the type of design NNL at HMD01.1N-W0012 or HMD01.1N-W0020 drive controllers of a width of 50 mm, you cannot use the adapter of type of design NNR to the left of the neighboring control section.




Fig.14-118: HAS05.1-007-NNL and -NNR at HMD drive controller of a width of 50 mm

Function

Universal adapter for safety technology


Usage:

- 1. Converter of D-Sub connection to terminal connection for an axis
- 2. Connection of additional component HAT01 to control section and optional module S1
- Converter of D-Sub connection to terminal connection for bus connection of optional modules S1 of the axes of one zone (see figure "Wiring Example With HAS05.1-007-NNR" on page 300)

Identification, Parts

The accessory has a type plate for identification.

HAS05.1-007-NNL




adapter

connector (spring terminal)

type plate

Fig. 14-119: HAS05.1-007-NNL

HAS05.1-007-NNR



adapter

connector (spring terminal)

type plate

HAS05.1-007-NNR Fig. 14-120:


The adapter is plugged in the connection point X41 (resp. X41.1 or X41.2 for double-axis devices) of the control section and secured with screws.

Technical Data

Mounting Dimensions

The accessory requires the following mounting clearance at the drive controller.


HAS05.1-007-NNL



data in mm

Fig. 14-121: Mounting dimensions HAS05.1-007-NNL

HAS05.1-007-NNR



data in mm

Fig.14-122: Mounting dimensions HAS05.1-007-NNR



Observe the minimum bending radiuses of the lines used. This requires additional mounting clearance at the front of the drive controller.

coding

At both types of design, the connection point 5 has been coded, i.e. provided with a coding section. The spring terminal was already assembled

Connection Point X41

9	View	tion (termi- nal)	Signal name	Function
12 Jes	HAS05.1-007- NNL	1	X41.1	The adapter brings the con-
spring	terminal / D-Sub female connector	2	X41.2	nections of the optional mod- ules L1 or S1 to the connec-
	HAS05.1-007-NNL spring terminal / D-Sub female connector DA000233v01_nn.FH11 HAS05.1-007-NNR D-Sub female connector / spring terminal DA000220v01_nn.FH11 DA000220v01_nn.FH11	3	X41.3	tions 1–9 of a spring terminal
3		4	X41.4	and a D-Sub female connector.
		5	X41.5	= -
15,		6	X41.6	Description of connec-
20	HAS05.1-007-NNL spring terminal / D-Sub female connector DA000233v01_nn.FH11 HAS05.1-007-NNR D-Sub female connector / spring terminal DA000220v01_nn.FH11 DA000220v01_nn.FH11	7	X41.7	tion point X41: see Project
		8	X41.8	Planning Manual "Rexroth IndraDrive Control Sections",
4	DA000233v01_nn.FH11	9	X41.9	section "Optional Modules for Control Sections, Safety Technology".
Maril Day		3/10.01		23/2027
D-Sub		in the state of th	ANTI OF STEELING SHEET STAND	IN STEELING HEAD
200		, gl	- 2	2
Spring terr	minal (connector)	Unit	Min.	Max.
cable cros	s section stranded wire	mm ²	0,5	1,5
cable cros	s section	AWG	20	16

accordingly at the factory.

Electrical data	Description of connection point X41: see Project Planning Manual "Rexroth IndraDrive Control Sections", section "Optional Modules for Control Sections, Safety Technology".
 mating connector for D-Sub female connector ribbon cable 	 RBS0017/S05 → D-Sub connector, 9-pin REB0401 → ribbon cable, 9-pin, can be ordered in steps of 0.5 m For professional assembly of the ribbon cable in the D-Sub connector, use the following Tyco tools:
(g) Halling	 Pistol-Grip tool (part number 734155-1) matrix for D-Sub connector (part number 734148-1)

Fig. 14-123: Function, pin assignment





Fig.14-124: HAS05.1-007-NNL and HAS05.1-007-NNR at CDB control section

Wiring Example With HAS05.1-007-NNR

 $\mbox{HAS05.1-007-NN}\mbox{\bf R}$ is the preferred adapter for the bus connection of several optional modules S1.



RBS0017/ S05 D-Sub connector with connection for ribbon cable

ribbon cable

REB0401 Fig. 14-125: HAS05.1-007-NNR

At CSH01.1C control sections, the adapter HAS05.1-007-NNL can only be used at the left end of the bus connection, when option 3 has not been equipped.




Fig.14-126: HAS05.1-007-NNR, RBS0017/S05 and REB0401 for bus connection of optional modules \$1 of the axes of one zone

14.5.10 HAS05.1-008, Adapter for Connecting two Cables Usage

Assignment The accessory HAS05.1-008 can be used at the following drive controllers:

HCS03.1E-W0100...0210

HMS01.1N-W0150...0210

Function With the accessory HAS05.1-008, you can connect two 16 mm² cables with

ring cable lugs at the mentioned devices at terminal block X5 (motor connec-

tion), each at A1, A2 and A3.

Scope of Supply The accessory contains:

3 × adapter

3 × screw M6 × 25





Fig.14-127: Accompanying note

Mounting




transverse profile of connection HAS05.1-008 at an X5 connection point Fig.14-128:

- 1. Screw adapter to connection point with supplied screw.
- 2. Connect cable as shown and screw it on.
- 3. Repeat steps 1 and 2 for each connection point.

14.6 Fiber Optic Cable Connections

14.6.1 Overview of Types



- fiber optic cable connections outside of control cabinet control cabinet duct
- 3 fiber optic cable connections inside of control cabinet

Fig. 14-129: Fiber optic cable connections

Installation location	Description	Type designation
outside of control cabinet	robust fiber optic cable connections from peripherals to control cabinet	RKO0101
at control cabinet	control cabinet duct with plug-in connectors	INS0610
inside of control cabinet	fiber optic cable connections to and between drive controllers	RKO0100

Fig. 14-130: Fiber optic cable connection elements



For ordering the fiber optic cable connection, you have to generate the complete order code containing details on type and length.

For the type designation see the above table and add the required length to it.

Determine the length by means of the list of different device arrangements.

Example of order code for arrangement HCS02 (left 105 mm) next to HCS02 (right 65 mm):

required length: 0.25 m
type designation: RKO0100
order code: RKO0100 / 0,25

14.6.2 Interconnection of Drive Controllers

General Information

For selecting the fiber optic cable connection of drive controllers, take different possible combinations and different device widths into account.

Combination of HCS02 and HCS02




Fig. 14-131: HCS02 with HCS02



For fiber optic cables from **CSB01.1N-SE** control sections to other control section types, take fiber optic cables which are **0.05 m** longer (at the devices, SERCOS connections are at different heights and sides).

Observe the routing guidelines and technical data (e.g. allowed bending radiuses) contained in documentation "Rexroth Connection Cables", DOK-CONNEC-CABLE*LWL**-AW**-**-*.

Required fiber optic cable length [m]					
Width left HCS02 [mm]	Width right HCS02 [mm]	*0[Co.			
'sp _{ilor}	65	105			
65	0,15	0,15			
105	0,25	0,25			

Fig. 14-132: Fiber optic cable lengths

Combination of HCS02 to the Right of HMS or HMD




Fig. 14-133: HCS02 to the right of HMS or HMD Independent of the width of the devices, cable length is 0.15 m.

Combination of HCS02 to the Left of HMS or HMD




Fig. 14-134: HCS02 to the left of HMS or HMD



For fiber optic cables from **CSB01.1N-SE** control sections to other control section types, take fiber optic cables which are **0.05 m** longer (at the devices, SERCOS connections are at different heights and sides).

Observe the routing guidelines and technical data (e.g. allowed bending radiuses) contained in documentation "Rexroth Connection Cables", DOK-CONNEC-CABLE*LWL**-AW**-**-*.

Cable length = width HCS02 + width HMS/HMD + 10 cm

, H	Required fibe	er op	otic cable leng	jth [m]	Way.
Width HCS02 [mm]	Width HMS / HMD [mm]				
7/0/2	50	125			

Required fiber optic cable length [m]					
65	0,25	0,25	My-	- 72,	
105	0,25	0,30	0,30	0,30	

Fig. 14-135: Fiber optic cable lengths

Combination of HCS03 to the Right of HMS or HMD




Fig. 14-136: HCS03 to the right of HMS or HMD

Combination of HCS03 to the Left of HMS or HMD




Fig. 14-137: HCS03 to the left of HMS or HMD

B

For fiber optic cables from CSB01.1N-SE control sections to other control section types, take fiber optic cables which are 0.05 m longer (at the devices, SERCOS connections are at different heights and sides).

Observe the routing guidelines and technical data (e.g. allowed bending radiuses) contained in documentation "Rexroth Connection Cables", DOK-CONNEC-CABLE*LWL**-AW**-**-*.

1900		Require	d fiber op	tic cable	length [m	i]	45	350
Width left device [mm]	Width right device [mm]							
9	50	75	100	125	150	200	225	350
50	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
75	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
100	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
125	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
150	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
200	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
225	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50
350	0,15	0,25	0,25	0,25	0,30	0,50	0,50	0,50

Fig. 14-138: Fiber optic cable lengths

14.7 RKB0001, Extension for Module Bus Connections

14.7.1 Usage

Assignment

The extension RKB0001 can be used at:

- HMV01.1E
- HMV01.1R
- HMS01.1N
- HMD01.1N
- HMV02.1R
- HMS02.1N
- HCS03.1E-W0070, -W0100; -W0150



The extension RKB0001 cannot be used at HCS02 drive control-

Function

With the accessory RKB0001 you can extend the module bus connection between devices, when the distance between the drive controllers is greater than 5 mm (e.g. in the case of multiple-line arrangement).

Lengths That can be Ordered, Order Code

Lengths: 0.5 m to 40 m (in steps of 0.5 m)

Parts:

- housing with hinged cover
- cable with strain relief mounted at both ends

Indicate the complete order code for your order.

Example:

required length: 2.5 m
type designation: RKB0001
order code: RKB0001 / 02,5

14.7.2 Mounting




Fig.14-139: Dimensions RKB0001

Accessories in the Drive System Rexroth IndraDrive



Fig. 14-140: Extension of module bus

Mounting RKB bus cable

- 1. Mount housing to point of connection for equipment grounding conductor.
- 2. Open cover and plug ribbon cable of right device into circuit board.
- 3. Close cover.
- 4. Screw strain relief down to point of connection for equipment grounding conductor.
- 5. Plug ribbon cable into X1.



Make sure the connection between strain relief and point of connection for equipment grounding conductor is well conductive.

By means of appropriate wiring, establish equipment grounding connections of devices that are not directly adjoining.

15 Third-Party Motors at IndraDrive Controllers

15.1 General Information on Third-Party Motors

15.1.1 Why Use Third-Party Motors at IndraDrive?

Today machine axes are mainly moved with electric drives. Motors of standard design are used in most cases as this is the most cost-efficient solution.

Special Requirements

Due to special requirements at machine axes, constructional or safety-related aspects, it may be necessary for the machine manufacturer to use a motor construction diverging from the standard.

Motor Design not Included in Product Range For these cases there is the demand on the drive supplier to realize drives with motors that are not included in his own product range due to the special design.

Check Before Using Third-Party Motors At drive controllers of the Rexroth IndraDrive range, it is possible to use third-party motors. For this purpose, check whether the third-party motor complies with the requirements of use.

15.1.2 Which are the Important Directives?

According to the legal regulations (EU Directive EMC 89/336/EEC and the German EMC laws), installations and machines must be designed and built in accordance with the present state-of-the-art of standardization.

In order to comply with the machine directives regarding "electromagnetic compatibility (EMC)", a conformity test of the drive system (motor with controller and connection design) has to be carried out. The test of the drive system and compliance with the directives have to be guaranteed by the machine manufacturer.

15.1.3 Third-Party Motors to be Controlled

Motor Types The following motor types can be controlled:

- asynchronous motors, rotary
- asynchronous motors, linear
- synchronous motors, rotary
- synchronous motors, linear

These motors can be operated within the scope of the technical data of the selected Rexroth IndraDrive controller. If motors have been provided with a holding brake, it should be controlled via the drive controller. Make sure that the relevant technical data of the motor holding brake are complying with those of the holding brake output.



For third-party motors Bosch Rexroth, as a matter of principle, does not assume the guarantee for the power data at the motor shaft!

Synchronous Motors

In the case of synchronous motors, the commutation offset has to be set during commissioning. The drive firmware provides several methods for determining this offset so that it is possible to determine the value for different motor characteristics.



Observe the restrictions in conjunction with the commutation offset determination when using synchronous motors! See firmware documentation chapter "Drive Control", "Motor Control: Commutation Setting".

Possibly available reluctance property cannot be used for synchronous third-party motors! For third-party motors, it is impossible to determine fail-safe motor parameter values for using the reluctance property. The respective bit of "P-0-4014, Type of construction of motor" therefore mustn't be set!

15.2 Requirements on Third-Party Motors

15.2.1 **General Information**

For successful and fail-safe use of a third-party motor, check

- whether the third-party motor to be controlled satisfies the voltage loads
- which controller, including supply, is suitable due to the motor power to be delivered
- whether the third-party motor has the required minimum inductance
- whether the motor can be protected against inadmissible temperature rise in the case of overload (temperature evaluation)
- whether the mounted position measuring system can be evaluated by the drive controller or which position measuring system can be selected for kit motors

15.2.2 Voltage Load of the Third-Party Motor

The voltage load of the insulation system of a motor occurring in practical application is mainly influenced by the following characteristics:

- the output variables of the drive controller which is used (feed the transmission distance)
- cable parameters depending on cable design and length (determine the properties of the transmission distance, such as attenuation)
- the motor design regarding capacitive and inductive properties (form the end of the transmission distance)

As a result of the variables, the insulation system of the third-party motor, as regards voltage, is loaded by the following values:

- peak voltage Upp and
- voltage change dv/dt

The occurring peak voltages at the motor are caused by reflections in the motor cable. The insulation of the motor is thereby loaded with other peak voltages and voltage changes than the ones occurring at the output of the power section.



Determine the occurring voltage load at the terminals of the thirdparty motor in the application with all involved components.

Using the HMF Motor Filter

Use voltage-reducing components (e.g. motor filter HMF), if one of the following criteria applies:

- allowed voltage change (dv/dt) of third-party motor: < 5 kV/µs
- allowed peak voltage (crest value) of third-party motor between phasephase and phase-housing: < 1500 V
- Both values (voltage change, peak voltage) are influenced by:

Mains voltage:

The higher the mains voltage at which the drive system is operated, the higher the value of the voltage change and the occurring peak voltage.

Length and electrical properties of the motor cable:

The shorter the motor cable, the less the attenuation effects.

The longer the motor cable, the higher the degree of voltage overshoot at the motor-side cable end.

For a motor cable length I < 25 m and mains voltage U_{N3} > AC 440 V, it is recommended that you use voltage-reducing components.



Apart from the nominal current I_N, especially take the maximum allowed switching frequency of the power output stage (f_s) into account with which the motor filter HMF may be operated.

Verify the success of the voltage-reducing measures.

Minimum Inductance of Third-Party Motor 15.2.3

Depending on the drive controller used, the motor has to have a minimum value for inductance. The actually available inductance of a motor can be measured directly between two motor terminals by means of an inductance measuring bridge. The measurement has to be made for a complete motor wired for normal operation but not yet connected. During the measurement one motor terminal remains open! For asynchronous motors, the measured value can only be used if the rotor doesn't have closed slots!

	Drive controller	Minimum required motor inductance
13.9	HCS at 3 × AC 230 V	$L_{U-V} = 60 \times 4 / (\sqrt{2} \times I_{Typ} \times f_s)$ (in mH)
83,	HMS, HMD at HMV (3 × AC 400 V) HMS,	1 = 90 × 4 / / /2 × 1 × f \ (in mH)
	HMD at HCS (3 × AC 400 V)	$L_{U-V} = 80 \times 4 / (\sqrt{2} \times I_{Typ} \times f_s) \text{ (in mH)}$
	HMS, HMD at HMV (3 × AC 480 V) HMS,	$L_{U-V} = 116 \times 4 / (\sqrt{2} \times I_{Tvp} \times f_s) \text{ (in mH)}$
	HMD at HCS (3 × AC 480 V)	L _{U-V} - 110 ^ 47 (\(\(\) \

 $\mathbf{I}_{\mathsf{Typ}}$

maximum current of drive controller according to type code (rms value) desired switching frequency in kHz

Fig. 15-1: Minimum inductances depending on drive controller data, supply units and supply voltage

Install a three-phase choke in the motor feed wire, if the inductance of the thirdparty motor is smaller than indicated in the table above. This choke has to increase the inductance that can be measured between two motor terminals to the minimum value.



When the inductance is measured, different inductance values can be determined at different rotor positions within one pole pair distance of the motor. The average value is relevant for the check of the minimum value.

Correct values can only be determined when the motor is in stand-

Available third-party motor Planned third-party motor Calculate the leakage inductance (asynchronous motor) or inductance (synchronous motor) of the third-party mo--U-Vmin tor by means of the single-phase equivalent circuit diagram (manufacturer's specification!). U Determine choke by means of calculation, if necessary. It is recommended that you contact Bosch Rexroth! Motor W $3 \times L_{Dr}$ DA000111v01_nn.fh11 0,5 × (LU-Vmin - LU-V) (inductance measurement $L_{Dr} =$ with 1 kHz) Fig. 15-2: mounting of 3 × LDr (three-phase choke)

Requirements on the choke:

- I_{n Dr} ≥ I_{n Mot}
 - The rated current of the choke has to be greater than or equal to the rated motor current.
- Depending on the maximum speed, the choke is loaded with the respective output frequency and the PWM frequency
 of the drive controller.
- The insulation class has to correspond at least to that of the motor or has to be dimensioned for higher temperatures.
- The voltage load of the choke depends on the drive controller used.

Fig. 15-3: Data for possibly required choke

15.2.4 Temperature Evaluation of Third-Party Motor

Only operate such motors with incorporated temperature sensor at IndraDrive controllers so that the motor can be thermally monitored by the controller and protected against destruction by too high temperature rise (see "P-0-0512, Temperature sensor").

When, in exceptional cases, you want to operate third-party motors without temperature sensor at IndraDrive controllers, you must determine the thermal time constants of motor housing (P-0-4035) and motor winding (P-0-4034, P-0-4037). By means of its temperature model, the firmware can correctly reflect the cooling situation of the motor.



In case the motor housing or blower is dirty, this worsens the cooling situation of the motor and protection against thermal overload is therefore insufficient!

15.3 Requirements on the Encoder of the Third-Party Motor

15.3.1 Motor Encoder of Asynchronous Third-Party Motor

Asynchronous motors can also be controlled by IndraDrive controllers in "open-loop" operation (without motor encoder). In "closed-loop" operation (with motor encoder), a relative measuring system is sufficient for asynchronous motors.

15.3.2 Motor Encoder of Synchronous Third-Party Motor

For fail-safe drives with synchronous third-party motors at IndraDrive controllers, the following possible combinations or restrictions have to be taken into account when selecting the measuring system:

Drive range	Motor measuring system	Synchronous third-party motor
la des Deixa	absolute	•
IndraDrive	relative	1977 -

advantageous combination

Combination is possible (restrictions specific to application), commis-

sioning may be more complicated!

Fig. 15-4: Possible combinations of synchronous third-party motor and motor

measuring system

B

The control section integrated in the drive controller can evaluate measuring systems as a motor encoder, if they are contained in "P-0-0074, Encoder type 1 (motor encoder)" (see also Project Planning Manual "Rexroth IndraDrive Drive Controllers Control Sections").

For information on absolute and relative measuring systems, see section "Measuring Systems" of firmware documentation!

Motor Encoder Resolver - Notes on Selection 15.3.3

For operating "resolver" encoder types, there is the optional module EN1 available (see also Project Planning Manual "Rexroth IndraDrive Drive Controllers Control Sections").

Observe:

- data of resolver system to be compared must be available at 4 kHz
- current consumption
- DC resistance of stator
- No. of poles
- phase shift

You can get more detailed information on request.

15.4 Notes on Selection and Commissioning

15.4.1 Selecting the Controller as Regards Continuous Current

The drive controller required for the respective motor and the supply unit are determined by comparing the motor data to the data of these devices (see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections").



The continuous current of the controller should be greater than the one of the motor. The continuous power of the supply must be greater than the sum of all average powers of the axes of the drive system!

15.4.2 Selecting the Connection Technique

For the available power and encoder cables, see documentation "Rexroth Connection Cables" (DOK-CONNEC-CABLE*STAND-AU...).

15.4.3 Notes on Commissioning



For further information, notes on commissioning and supporting documents (e.g. forms for entering the required data) see firmware documentation.

16 Calculations

16.1 Determining the Appropriate Drive Controller

16.1.1 Introduction

Supply for the drive system Rexroth IndraDrive takes place by means of compact HCS converters or HMV supply units. According to drive task, design of drive controller and operating conditions, you can in addition use chokes, additional capacitors, braking resistors, transformers etc.

The drive controller or supply unit has to supply the DC bus continuous power and for acceleration the DC bus peak power. With regenerative operation, they must be able to absorb the continuous recovery power and peak recovery power.

Before the drive controller or supply unit and the additional components can be selected, the motors and drive controllers to be used must be defined.

To ensure correct dimensioning of the drive system, you should do the calculations as described in the following sections.

16.1.2 DC Bus Continuous Power

The DC bus continuous power is calculated from the mechanical power, taking the following aspects into consideration:

- motor and controller efficiency
- simultaneity factors

Mechanical Power

$$P_{m}[W] = M \times \omega = \frac{M \times n \times 2\pi}{60}$$

$$P_{m}[kW] = \frac{M \times n}{9550}$$

P_m mechanical power
M torque [Nm]
ω angular velocity [m

ω angular velocity [min-1]n motor speed [min-1]Fig. 16-1: Mechanical power

Mechanical Continuous Power for Servo Drives To calculate the mechanical continuous power of a servo drive, you need the effective motor torque and the average motor speed.

The effective motor torque can be taken over from the servo drive calculation. The average motor speed is determined as follows.

Average Motor Speed

For servo drive tasks at common NC machine tools, the average motor speed is approx. 25% of the rapid traverse speed. In some cases, however, this rough estimation is not sufficient. An exact calculation of the average motor speed is required.

Average Speed with Run-Up and Braking Times not Taken into Account

If the period during which the motor is run at constant speed is significantly greater than the run-up and braking time, the following applies:

$$n_{av} = \frac{n_1 \times t_1 + n_2 \times t_2 \dots + n_n \times t_n}{t_1 + t_2 \dots + t_n}$$

n_{av} average motor speed [min-1]

 $n_1 \dots n_n$ motor speed [min-1]

t₁ ... t_n duty cycle [s]

Fig. 16-2: Average speed; effects of run-up and braking times not taken into account




Fig.16-3: Speed characteristic; effects of run-up and braking times not taken into account

In dynamic applications with short cycle times, e.g. roll feeds and nibbling machines, run-up and braking times must be taken into account.



Damage to the drive controller!

- The DC bus capacitors in the drive controller have been dimensioned for loading with continuous power.
- If loaded with cyclic charging and discharging processes of high energy content, the DC bus capacitors can be overloaded, especially with decreasing mains connection voltage.

Operate additional capacitors at the DC bus.

Average Speed with Run-Up and Braking Times Taken into Account

(A) -	$\frac{\frac{n}{2} \times t_H + n \times t_1 + \frac{n}{2} \times t_B}{}$	J. 20. P.
$n_{av} -$	$\overline{t_H + t_1 + t_B + t_2}$	OLUGIAL.


n_{av} average motor speed [min-1]

n motor speed [min-1]

t time [s]

t_H run-up time [s] t_B braking time [s]

Fig. 16-4: Average speed; effects of run-up and braking times taken into account



Mechanical Power for Servo Drives

Fig. 16-5: Average speed; effects of run-up and braking times taken into account

$$P_{\text{mSe}} = \frac{M_{\text{eff}} \times n_{\text{av}}}{9550}$$

P_{mSe} mechanical continuous power for servo drives [kW]

M_{eff} effective motor torque [Nm]
n_{av} average motor speed [min-1]

Fig. 16-6: Mechanical power for servo drives

Mechanical Power for Main Drives

Main drives are drives which are mainly used in the constant power speed range. Thus, nominal power is decisive for dimensioning the mains supply. The mechanical nominal power of the main drives can be taken from the operating characteristic or calculated from nominal speed and nominal torque.

$$P_{mHa} = \frac{M_n \times n_n}{9550}$$

P_{mHa} mechanical nominal power for main drives (shaft output) [kW]

M_n nominal motor torque [Nm]
n_n nominal motor speed [min-1]
Fig.16-7: Mechanical power for main drives

DC Bus Continuous Power for Servo Drives

The drive controller or the combination of drive controllers has to make available the DC bus power. However, in most applications, simultaneous loading of all drives will not occur; thus, only the simultaneous load must be considered for calculating the DC bus continuous power to be made available for servo drives. To calculate the DC bus continuous power to be made available for typical NC feed axes at machine tools, inclusion of a so-called simultaneity factor has proved to be favorable in practical application:

Num- ber of axes	1	2	3	4	5	6	7	n=n+1
Simul- taneity factor (F _G)	EICH D	1,15	1,32	1,75	2,0	2,25	F _G =2,5	$F_{Gn} = F$ $G + 0.25$

Fig. 16-8: Simultaneity factors

$$P_{\mathit{ZWDSe}} = \frac{(P_{\mathit{mSe}1} + P_{\mathit{mSe}2} \, \ldots + P_{\mathit{mSen}}) \times 1,25}{F_{\mathit{G}}}$$

 P_{ZWDSe} DC bus continuous power for servo drives [kW] $P_{mSe1} \dots P_{mSen}$ mechanical continuous power for servo drives [kW]

F_G simultaneity factor

1,25 constant for motor and controller efficiency *DC bus continuous power for servo drives*

DC Bus Continuous Power for Main Drives

If several main drives are operated at one DC bus, the simultaneously required DC bus continuous powers must be added:

$$P_{ZWF60}(P_{mF601} + P_{mF602} \dots + P_{mF60m}) \times 1,25$$

P_{ZWHa} DC bus continuous power for main drives [kW]
P_{mHa1}...P_{mHan} mechanical continuous power for main drives [kW]
1,25 constant for motor and controller efficiency
Fig. 16-10: DC bus continuous power for main drives

Chokes and additional capacitors have to be selected according to the actually required DC bus continuous power. It is determined by the nominal power of the main drives.

B

When selecting the drive controllers, make sure that their maximum DC bus continuous power will not restrict the short-time operation power of the main drives.

DC Bus Continuous Power for Main and Servo Drives

When main and servo drives are operated at a drive controller, the required DC bus continuous powers must be added.

At a typical NC machine tool, the required DC bus continuous power will be primarily defined by the main drive. Accordingly, the following equation is to be used for such applications:

$$P_{\text{ZWD}} = [P_{\text{mHB}} + 0.3 \times (P_{\text{mSel}} + P_{\text{mSel}} \dots + P_{\text{mSen}})] \times 1.25$$

0,3 experimental value for standard machine tools
1,25 constant for motor and controller efficiency

P_{ZWD} DC bus continuous power [kW]

 $P_{mSe1} \dots P_{mSen}$ mechanical continuous power for servo drives [kW] P_{mHa} nominal power for main drive (shaft output) [kW]

Fig. 16-11: DC bus continuous power for main and servo drives at NC machine tools

$$\sum P_{ZWD,Anlage} \le \sum P_{ZWD,Gerotte}$$

P_{ZWD,Anlage} generated DC bus continuous power of the installation allowed DC bus continuous power of the devices Fig. 16-12: Supply condition: DC bus continuous power

16.1.3 DC Bus Peak Power

The drive controller or combination of drive controllers has to produce DC bus peak power for example when several axes of a machine tool simultaneously accelerate to rapid traverse rate after a tool change, approaching the workpiece.



Damage due to supply unit overload!

To avoid damage to the drive controller the sum of peak powers of all drives mustn't exceed the DC bus peak power of the supplying drive controller (central supply).

$$P_{\mathrm{ZWS}} = \frac{\left(M_{\mathrm{NC}} \pm M_{\mathrm{G}}\right) \times n_{\mathrm{ell}} \times 1,25}{9550}$$

 $\begin{array}{ll} M_{NC} & \text{acceleration torque in the drive [Nm]} \\ M_{G} & \text{torque due to weight for vertical axes [Nm]} \\ n_{eil} & \text{speed at rapid traverse rate [min-1]} \end{array}$

P_{ZWS} DC bus peak power [kW]

1,25 constant for motor and controller efficiency

Fig. 16-13: DC bus peak power per drive

$$\sum P_{\rm ZWS,\, Anlage} \leq \sum P_{\rm ZWS,\, Gerotte}$$

P_{ZWS,Anlage} generated DC bus peak power of the installation P_{ZWS,Geräte} allowed DC bus peak power of the devices Fig. 16-14: Supply condition: DC bus peak power

16.1.4 Regenerative Power

When all main and servo drives connected to a drive controller or combination of drive controllers brake simultaneously, the generated regenerative power must not be greater than the maximum regenerative power of the drive controller or combination of drive controllers. If this is not taken into consideration in dimensioning the system, thermal destruction of the braking resistors in the drive controllers may occur.



Destruction due to braking resistor overload!

Do the project planning for drive controllers or combinations of drive controllers in such a way that the resulting regenerative power can be absorbed when all main and servo drives connected to the drive controller or combination of drive controllers brake simultaneously.

$$W_{rot} = \frac{J_G}{2} \times \left(n_{eil} \times \frac{2\pi}{60}\right)^2$$

W_{rot} rotary energy [Ws]

n_{eil} speed at rapid traverse rate [min-1]

J_G motor inertia and load inertia reduced to the motor shaft [kgm²]

Fig. 16-15: Regenerative power per drive

$$\sum W_{R,Anlage} \le \sum W_{R,Gente}$$

W_{R,Anlage} generated regenerative power of the installation allowed regenerative power of the devices

Fig. 16-16: Supply condition: regenerative power

"O(L)

B

Influence of efficiency

The energy absorption occurring in the steady-state condition in the majority of cases is less than the calculated energy absorption, because all involved components (such as load, gear, motor, cables) absorb a part of the regenerative power.

Only reduce the generated regenerative power when the efficiency behavior is known.

Energy Absorption of Braking Resistor

Within the minimum cycle time $T_{\rm cycl}$, the braking resistor dissipates the electrically absorbed energy to its environment as heat. The braking resistor makes available the energy absorption during its duty cycle. The energy absorption is calculated as follows:

$$W_R = t_{on} \times P_{BS}$$

 $W_R \approx P_{BD} \times (T_{cycl} - t_{on})$

W_R absorbed regenerative power

t_{on} allowed duty cycle

P_{BS} allowed peak power of braking resistor
P_{BD} allowed continuous power of braking resistor

T_{cycl} allowed cycle time

Fig. 16-17: Energy absorption of braking resistor



Energy absorption capacity with long cycle times

For cycles with "T > 5 × T_{cycl} ", the indicated maximum regenerative power to be absorbed $W_{R_{max}}$ can be used.



Several braking resistors (e.g. HLR) at common DC bus

With several braking resistors at the DC bus, the available energy absorption is determined as the sum of the individual energy absorptions. For this purpose, the same switch-on threshold must take effect for all involved braking resistors.



Adjustment of switch-on threshold!

For the adjustment of the switch-on threshold, see also the following parameters:

- P-0-0833, Braking resistor threshold
- P-0-0858, Data of external braking resistor

16.1.5 Reduction of Generated Power Dissipation - Additional External Capacitors at DC Bus

When the drive brakes, the rotary energy present in the mechanical system is released as regenerative power in the DC bus of the drive controller or combination of drive controllers. It can

• be converted into dissipation heat via the braking resistor integrated in the drive controller or the additional braking resistor

or

• be stored as energy in the drive controllers and possibly available additional capacitors and reused for following acceleration processes. This

reduces the power dissipation generated in the control cabinet and lowers the energy consumption.

The following applies to successful use of additional capacitors to avoid unnecessary power dissipation in the control cabinet:

$$\sum W_{R, \; Anlage} \leq \sum W_{ZW, \; Germe}$$

 $W_{R,Anlage}$ generated regenerative power of the installation $W_{ZW,Ger\"{a}te}$ storable energy of the DC bus capacitors

Fig. 16-18: Condition to avoid power dissipation from the regenerative power

Additional Capacitors as Energy Stores

Many acceleration and deceleration processes are typical for applications with servo drives (e.g. nibbling machines or roll feeds). This is why it can be useful for such applications to connect additional capacitors to the DC bus of the drive controllers. This provides the following advantages:

- For drive controllers without mains regeneration function this prevents the braking resistor in the drive controller from being switched on when the drives brake. The dissipation heat in the control cabinet is considerably reduced.
- The energy stored in the DC bus capacitors can be used for acceleration.
 The energy demand of the installation is reduced.

Storable Energy in DC Bus

The specific energy absorption capacity of the drive controllers can be determined with the formula below.

$$W_{DC} = \frac{\left(C_{DC} + C_{DCint}\right)}{2} \times \left(U_{R_DC_On}^2 - U_{DC}^2\right)$$

 $\begin{array}{ll} W_{DC} & \text{storable energy in DC bus} \\ C_{DC} & DC \text{ bus capacitance in device [F]} \\ C_{DC\text{ext}} & \text{external DC bus capacitance [F]} \\ U_{R \ DC \ On} & \text{braking resistor switch-on threshold} \end{array}$

U_{DC} DC bus voltage

Fig. 16-19: Storable energy in DC bus

The additional capacitor has to be dimensioned in such a way that it can store the rotary drive energy:

$$C_{DCent} \geq \frac{2W_{rot}}{\left(U_{R-DC_Ot}^2 - U_{DC}^2\right)} - C_{DC}$$

U_{R DC On} braking resistor switch-on threshold

 $\begin{array}{ll} \mbox{U}_{\mbox{DC}} & \mbox{DC bus voltage} \\ \mbox{W}_{\mbox{rot}} & \mbox{rotary energy [Ws]} \\ \mbox{C}_{\mbox{DC}} & \mbox{internal capacitance [F]} \end{array}$

C_{DCext} required external DC bus capacitance [F] Fig.16-20: Required additional capacitance [F]



Property damage caused by overload of HMV and HCS devices!

Comply with max. allowed external DC bus capacitances! See electrical data of the HMV and HCS components.



Property damage caused by overload of the additional external capacitors!

- Only use allowed components.
- The properties of the additional capacitors have to comply with minimum requirements:

- min. dielectric strength: DC 900 V

– min. current load capacity: 15 A_{eff} / mF

min. heat resistance: 105 °Cmax. discharge time: 30 min

- Take measures against fire in the case of overload, e.g. by housing the capacitors.
- Connect correct polarity: Connect L+ to positive pole and L- to negative pole of the additional capacitors.



- For additional external capacitors, observe that the series connection of these units can require a balancing device.
- Dimension additional capacitors at the DC bus for 10% overvoltage at the mains connection.
- As the supply voltage increases the storable energy in the DC bus decreases, because the differential voltage between braking resistor switch-on threshold U_B and DC bus voltage U_{ZW}
 (crest value of supply voltage) is reduced.

The figure below illustrates the characteristic of the storable energy in the DC bus versus mains voltage with fixed braking resistor switch-on threshold $U_{\rm B}$ by the example of HCS02.1E devices.




Fig.16-21: Storable energy in DC bus

16.1.6 Continuous Regenerative Power



In terms of average period of time, the sum of the continuous regenerative power of all drives mustn't exceed the allowed continuous power of the regenerative device (regeneration of supply units or braking resistors of converters).

In applications with servo drives at typical NC machine tools, machining time is relatively long relative to the cycle time. Accordingly, the continuous regenerative powers are small. For this type of applications, exact calculation is not required. It is sufficient to make sure that the regenerative peak power is not exceeded.

Exact calculation is required, for example, for one of the following applications:

- applications with servo drives which are characterized by many acceleration and deceleration processes (e.g. nibbling machines or roll feeds)
- machine tools with modular main drive
- applications which involve lowering of large masses, e.g. loading bridges, warehousing and transport systems

Before the continuous regenerative power can be calculated, the rotary energy of the drives and the potential energy of non-balanced masses must be calculated.

$$W_{rot} = \frac{J_G}{2} \times \left(n_{eil} \times \frac{2\pi}{60}\right)^2 \times z$$

W_{rot} rotary energy [Ws]

n_{eil} speed at rapid traverse rate [min-1]

J_g inertia (motor + load) [kgm²]

z number of braking processes per cycle

Fig. 16-22: Rotary energy of the drives

$$W_{pot} = m \times g \times h \times z$$

W_{pot} potential energy [Ws] m load mass [kg]

g gravitational acceleration = 9.81 m/s²

h lowering height [m]

z number of lowering processes per cycle Fig.16-23: Potential energy of non-balanced masses

$$P_{\text{RD,Anlage}} = \frac{W_{\text{pot}} + W_{\text{notg}}}{t_z}$$

$$\sum P_{RD,\,Anlage} \leq \sum P_{BD,\,Gentle}$$

 $\begin{array}{ll} P_{RD,Anlage} & \text{generated continuous regenerative power [kW]} \\ P_{BD,Ger\"{a}te} & \text{allowed braking resistor continuous power [kW]} \end{array}$

t_z cycle time [s]

W_{potg} sum of potential energies [kWs]
W_{rotg} sum of rotary energies [kWs]
Fig.16-24: Continuous regenerative power

328/363

B

Influence of efficiency

The continuous regenerative power occurring in the steady-state condition in the majority of cases is less than the calculated energy absorption, because all involved components (such as load, gear, motor, cables) absorb a part of the regenerative energy.

Only reduce the generated continuous regenerative power when the efficiency behavior is known.

Continuous Power of Braking Resistor

Continuous power of the braking resistor:

$$P_{BD} = \frac{t_{on} \times P_{BS}}{T_{cycl}}$$

P_{BD} allowed continuous power of braking resistor

t_{on} allowed duty cycle

P_{BS} allowed peak power of braking resistor

T_{cycl} allowed cycle time

Fig. 16-25: Braking resistor continuous power



Several braking resistors (e.g. HLR) at common DC bus

With several braking resistors at the DC bus, the available continuous power is less than the sum of the individual continuous powers.

$$\sum P_{BB} = f \times (P_{BB_1} + P_{BB_2} + ... + P_{BB_n})$$

 $P_{BD_{-1}}$, $P_{BD_{-2}}$, data sheet data of the braking resistors

 P_{BD_n}

balancing factor for PDB (f = 0.8 (guide value); see also technical data

of converter and supply unit)

Fig. 16-26: Sum of braking resistor continuous powers

Relative Duty Cycle of Braking Resistor

The quotient of t_{on} and T_{cycl} is understood by the duty cycle ED. The maximum allowed relative duty cycle ED_{max} is calculated from the nominal data for HLR braking resistors:

$$ED_{\text{max}} = \frac{t_{on}}{T_{evcl}}$$

ED_{max} maximum allowed relative duty cycle

 t_{on} allowed duty cycle T_{cycl} allowed cycle time

Fig. 16-27: Relative duty cycle of braking resistor



Braking times

Within the indicated minimum cycle time T_{cycl} , the braking resistor may be switched on, as a maximum, for the time t_{on} .

16.1.7 Peak Regenerative Power

Usually, peak regenerative power will occur when an E-Stop signal is triggered and all axes brake simultaneously.



Risk of damage due to extended braking times and distances!

Select the supply unit such that the sum of peak regenerative powers of all drives does not exceed braking resistor peak power of the supply unit.

See the respective motor selection data for the peak regenerative powers.

Peak regenerative power can be roughly calculated by the following equation:

$$P_{\text{RS}} = \frac{M_{\text{max}} \times n_{\text{max}}}{9550 \times 1,25}$$

$$\sum P_{\mathit{ES},\,\mathit{Anlage}} \leq \sum P_{\mathit{ES},\,\mathit{Gentuse}}$$

P_{RS,Anlage} generated peak regenerated power [kW]
P_{BS,Geräte} allowed braking resistor peak power [kW]

M_{max} maximum drive torque [Nm]
n_{max} maximum NC useful speed [min-1]
1,25 constant for motor and controller efficiency

Fig. 16-28: Peak regenerative power

Peak Power of Braking Resistor

The braking resistor makes available the peak power during its duty cycle. The peak power is calculated as follows:

$$P_{BS} = \frac{U_{R_DC_on}^2}{R_{DC_Bleeder}}$$

 ${\sf P}_{\sf BS}$ effective peak power ${\sf U}_{\sf R_DC_on}$ switch-on threshold

 $R_{DC_Bleeder}$

Fig.16-29: Braking resistor peak power

Several braking resistors (e.g. HLR) at common DC bus

With several braking resistors at the DC bus, the available peak power is determined as the sum of the individual peak powers. For this purpose, the same switch-on threshold must take effect for all involved braking resistors.

Adjustment of switch-on threshold!

For the adjustment of the switch-on threshold, see also the following parameters:

- P-0-0833, Braking resistor threshold
- P-0-0858, Data of external braking resistor

16.1.8 Calculating the Control Factor

The control factor of an inverter is the ratio of its output voltage to a reference output voltage.

The reference output voltage is the output voltage of the inverter at mains input voltage without overload.

$$a = \frac{U_{out}}{U_{out_ref}} = \frac{U_{out}}{U_{\mathit{LN}}}$$

 $egin{array}{ll} U_{\text{out}} & & \text{output voltage of inverter} \\ U_{\text{out_ref}} & & \text{reference output voltage} \\ \end{array}$

U_{LN} mains voltage Fig. 16-30: Control factor

If several inverters have effect on one supply unit at the same time, you have to consider the so-called mean control factor scaled with the axis power.

$$\overline{\mathbf{a}} = \frac{1}{\mathbf{n} \times P_{ZWD}} \times \sum_{j=1}^{n} (\mathbf{a_j} \times P_{mj} \times 1,25)$$

n number of inverters a; several control factors

 P_{ZWD} DC bus continuous power [kW] P_{mi} mechanical continuous power [kW]

Fig. 16-31: Mean, scaled control factor

When the control factor falls below the required value (see data P_{DC_cont} in the technical data of the corresponding supply unit), additional wattless power occurs. The additional wattless power can be compensated with additional capacitors in the DC bus. The required additional capacitance can be approximately calculated with the following formula.

$$C_{DC_ext} = (a_0 - \overline{a}) \times P_{DC_nenn} \times k_a$$

 C_{DC_ext} required additional capacitance in DC bus in μF

a₀ minimum required control factor

a calculated mean control factor (e.g. a0 > 0.8)

 P_{DC_nenn} nominal power of supply unit [kW]

k_a 200 (preliminary); factor capacitance [μF] / nominal power [kW]
 Fig. 16-32: Required additional capacitances when control factor falls below minimum value

16.2 Calculations for the Mains Connection

16.2.1 Calculating the Mains-Side Phase Current

To select the appropriate mains contactor and the appropriate fusing of the power connection, the mains-side phase current I_N has to be calculated before.

The mains-side phase current \mathbf{I}_{N} is determined from the mains connected load $\mathbf{S}_{LN}.$

For the maximum mains connected load, see technical data of the drive controllers or calculate it according to the formula below and the formulas contained in the appendix. For several drive controllers, add the individual mains connected loads.

$$P_{DC} = \frac{M_{\text{eff}} \times n_{\text{m}} \times 2\pi}{60} \times k$$

P_{DC} required DC bus continuous power in W

 M_{eff} effective torque in Nm n_{m} average speed in min-1

k factor for motor and controller efficiency = 1.25

Fig. 16-33: Calculating the DC bus power

$$S_{LN} = \frac{P_{DC}}{TPF}$$

 ${
m S_{LN}}$ mains connected load in VA ${
m P_{DC}}$ DC bus continuous power in W

TPF Total Power Factor λ

Fig. 16-34: Calculating the mains connected load

For the data of **TPF** at nominal power and **TPF**₁₀ (at 10% of nominal power), see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

Intermediate values can be interpolated with the diagram contained in this chapter.

$$I_{I\!\!I\!\!V} = \frac{S_{I\!\!I\!\!V}}{U_{I\!\!I\!\!V}}$$

 $\begin{array}{ll} {\rm I_{LN}} & {\rm mains\mbox{-}side\mbox{ phase current in A}} \\ {\rm S_{LN}} & {\rm mains\mbox{-}connected\mbox{ load in VA}} \\ \end{array}$

U_{LN} voltage between phases of mains in V

Fig. 16-35: Calculating the mains-side phase current (single-phase)

$$I_{LN} = \frac{S_{LN}}{U_{LN}\sqrt{3}}$$

 I_{LN} mains-side phase current in A S_{LN} mains connected load in VA

U_{LN} voltage between phases of mains in V

Fig. 16-36: Calculating the mains-side phase current (three-phase)

16.2.2 Calculating the Inrush Current

For calculating the inrush current, take all devices connected to mains voltage into account. The resulting inrush current is the sum of the inrush currents of the individual devices.

For the data of the **inrush current I**_{Ltrans_max_on}, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

16.2.3 Mains Contactor and Fusing

For the data of mains contactor, fusing and the required connection cross section in operation under rated conditions, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

16.2.4 Calculations for the Mains Harmonics

Harmonic Load THD

The harmonic load of the mains is described by the THD (total harmonic distortion):

$$THD = \sqrt{\sum_{n=2}^{40} \left(\frac{I_n}{I_1}\right)^2}$$

I_n harmonic current of the n-th harmonic

rms value of the 1st harmonic (fundamental wave)

I₂ rms value of the 2nd harmonic I_n rms value of the n-th harmonic Fig. 16-37: THD (total harmonic distortion)

Harmonic Content / Distortion Factor k

The harmonic content of, for example, the mains current is described by the distortion factor k. The distortion factor contains all alternating components, both those of the fundamental wave (I_1) and of the harmonics (I_k) . Direct components (I_0) are not contained.

$$k\mathbf{i} = \sqrt{\frac{\sum_{k=2}^{n} I_{k}^{2}}{\sum_{k=1}^{n} I_{k}^{2}}} = \sqrt{\frac{I_{2}^{2} + I_{3}^{2} + \dots}{I_{1}^{2} + I_{2}^{2} + I_{3}^{2} \dots}}$$

ki distortion factor or harmonic content
lk harmonic current of the k-th harmonic

I₁ rms value of the 1st harmonic (fundamental wave)

rms value of the 2nd harmonic

Fig. 16-38: Distortion factor k or harmonic content

Power Factor cosφ1 or DPF for Calculating the Wattless Power Load of the Mains

The power factor $cos\phi1$ or DPF (distortion power factor) is used to calculate the wattless power load of the mains:

$$DPF = \cos \varphi_1 = \frac{P_{\text{netz}}}{S_{1LW}}$$

P_{netz} effective mains power

 S_{1LN} apparent mains power of fundamental wave

Fig. 16-39: Power factor cosφ1 / DPF

Power Factor cosφ or TPF (λ)

The power factor $\cos \varphi$ or TPF is used for rating mains components (transformer, fuse etc.):

$$TPF = \lambda = \cos \varphi = \frac{P_{netx}}{S_{IN}}$$

 P_{netz} effective mains power S_{LN} apparent mains power Fig. 16-40: $Power factor cos \phi / TPF/\lambda$

B

Only for sinusoidal values does the power factor $cos\phi$ equal the total power factor TPF (λ).

16.2.5 Mains Voltage Unbalance

The voltage unbalance is described by a three-phase system consisting of the combination of the following systems:

- clockwise a.c. system (positive-sequence system U_m)
- counter-clockwise a.c. system (negative-sequence system U_a)
- d.c. system (U₀)

 U_x phase-to-phase voltage with highest deviation from average value U_{AVE} = (U12 + U23 + U31) / 3; U12 , U23 , U31 being voltages between the phases

Fig. 16-41: Definition of voltage unbalance

16.2.6 Calculating the Allowed Continuous Power in the Common DC Bus

By interconnecting the DC bus connections of several HCS02 and HLB01 drive controllers, the regenerative power and continuous power generated in the common DC bus are equally distributed to all IndraDrive C devices with braking resistor.

Distribution to the involved devices takes place with high balancing factor.

For Central Supply and Group Supply with DC Bus Connection

$$\sum P_{\mathit{BD},\mathit{Germin}} = \sum \left(P_{\mathit{BD},\mathit{HCS}} + P_{\mathit{BD},\mathit{HLB}}\right) \!\! \times f$$

P_{BD, Geräte} braking resistor continuous power that all devices at common DC bus can process in continuous operation, in kW

P_{BD, HCS02} braking resistor continuous power that the drive controller can process in continuous operation, in kW

P_{BD, HLB01} braking resistor continuous power that the additional braking resistor module can process in continuous operation, in kW

f balancing factor for parallel operation

Fig. 16-42: Available braking resistor continuous power at common DC bus

334/363

$$\sum P_{\mathit{ZW},\mathit{Gerttle}} = \sum P_{\mathit{ZW}} \times f$$

 $P_{ZW, \; Ger ext{ate}}$ available DC bus continuous power at common DC bus, in kW DC bus continuous power of the individual devices, in kW

f balancing factor for parallel operation

Fig. 16-43: Available DC bus continuous power at common DC bus

16.3 Determining Components in the Mains Connection

16.3.1 Determining Mains Choke HNL

When using mains chokes, take their effect on the connected drive controllers into account. Due to their inductance, mains chokes have a smoothing effect on the current and thereby reduce harmonics.

To have the inductance available, comply with the nominal current of the mains choke.

Depending on the type of mains connection, we distinguish two cases.

Case 1 (standard): Only one drive controller or supply unit is connected to the mains choke (individual supply and central supply).

Selection criteria:

 Use of assigned mains choke according to Project Planning Manual of drive controller or supply unit.

Case 2: Several drive controllers or supply units are connected to the mains choke (group supply with and without DC bus connection).

Selection criteria:

Nominal current:

$$I_N \ge \sum I_{DV}$$

I_{LN} mains-side phase current in A I_N nominal current of mains choke in A

Fig. 16-44: Mains choke conditions

• **Nominal inductance**: The nominal inductance of the individual mains choke has to be at least as high as the inductance of the greatest assigned mains choke of the connected drive controllers or supply units.

16.3.2 Determining Mains Filter HNF

Criteria for Selecting the Mains Fil-

For selecting the appropriate mains filter, take the following criteria into account:

- EMC limit value class on site
- ambient conditions on site
- loading by harmonics on site
- loading by mains voltage and frequency on site
- loading by mains-side phase current
- total length of connected motor cables
- sum of leakage capacitances
- harmonics on mains voltage on site

How to Proceed for Selecting the Mains Filter

The selection of the mains filter is significantly determined by the operating conditions. How to proceed for selecting the mains filter:



When using HNF01, NFD03, HNS02 and HNK01 mains filters at mains grounded via outer conductor, install an isolating transformer between mains and mains filter.

- 1. Determine the required EMC limit value class for the application.
- 2. Determine the maximum applied mains voltage. Observe that not all Rexroth IndraDrive mains filters are suited for a mains voltage of 3 AC 500 V and, in the case of harmonics on mains voltage,

check whether the mains voltage of the mains filter is loaded with harmonics and still allowed for the mains filter. For the allowed operating data depending on existing harmonics, see chapter 17.3 Emitted Harmonics on Mains Current and Mains Voltage, page 344.

If necessary, make sure the harmonics are reduced on site.

- 3. Determine the kind of mains connection, such as central supply, group supply etc. (to do this, it is useful to outline the involved components and their interaction).
- 4. Calculate the **mains-side phase current** of the mains filter. For selecting the components, calculate the effective rms value. Chapter 16.2 Calculations for the Mains Connection, page 330 helps you with the calculation.

Check or determine the maximum occurring ambient temperature. Select a mains filter with higher nominal current, when the ambient temperature is between 45 °C and 55 °C.

- 5. Select a mains contactor the nominal current of which does not exceed nominal current of mains filter.
- 6. Determine the number of drive axes. Take into account that HMD01 power sections are equipped with 2 axes.
- 7. Determine the total length of the connected motor cables.
- 8. Calculate the sum of the leakage capacitances on the load side of the mains filter. Determine the sum of the leakage capacitances from the number of operated axes and the length of the connected motor cables. Chapter 16.3.3 Determining the Leakage Capacitance, page 335 helps you with the calculation.
- 9. Select the appropriate mains connection (supply unit/converter, mains choke, mains filter) from the tables in chapter 8.3 Mains Connection Supply Units and Converters, page 85.

The **capacity of the mains filters** regarding the maximum allowed number of drive controllers and the maximum allowed total motor cable length depends on whether you use an HMV supply unit or supply other drive controllers with HCS drive controllers. For supply by an HMV supply unit, the allowed number and allowed total length are higher.

16.3.3 Determining the Leakage Capacitance

The capacitances which generate so-called leakage currents against ground at the outputs of inverters are regarded as leakage capacitance C_{ab} . The decisive values for the total value $C_{ab\ q}$ of the leakage capacitance are:

- capacitances of output filters
- capacitances of motor cables (capacitance per unit length against shield and ground wire)
- capacitances of motors (winding capacitance against housing)

336/363

Calculations



The capacitance per unit length of the hybrid cable of Rexroth IndraDrive Mi is insignificant for determining the leakage capacitance, because the hybrid cable is at the DC bus and not at the output of the inverter.

The leakage capacitance consists of the values of motor cable and motor of all individual drives operated at the mains filter.

Calculation:

$$C_{ab_g} = C_{ab_Mg} + C_{ab_Kg}$$

 C_{ab_g} total value of leakage capacitance

total value of leakage capacitance of motor C_{ab_Mg} total value of leakage capacitance of cable $\mathsf{C}_{\mathsf{ab}\mathsf{_Kg}}$

Fig. 16-45: Total leakage capacitance

The total capacitance C_{ab_Mg} results from the sum of capacitances of the individual motors. For these individual capacitances, see documentation of the motor. For a list of selected values, see Appendix of this documentation under "Capacitances Against Ground".

$$C_{ab_Mg} = C_{ab(Motor_1)} + C_{ab(Motor_2)} \dots + C_{ab(Motor_n)}$$

 $C_{ab(motor)}$ leakage capacitance of a motor Fig. 16-46: Total leakage capacitance of motor

$$C_{ab_Kg} = C_{Y_K \text{ typ } (K1)} \times I_{(K1)} + C_{Y_K \text{ typ } (K2)} \times I_{(K2)} \dots + C_{Y_K \text{ typ } (Kn)} \times I_{(Kn)}$$

capacitance per unit length of cables $C_{Y_K typ}$ total leakage capacitance of cables $\mathsf{C}_{\mathsf{ab}\mathsf{_Kg}}$ Fig. 16-47: Total leakage capacitance of cables

The total capacitance C_ab_Kg consists of the sum of capacitances of the individual motor cables. For the individual capacitances per unit length, see the technical data of the motor cables. For a list of selected values, see Appendix of this documentation under "Capacitances Against Ground".

16.3.4 Determining the Allowed Operating Data of Mains Filters

Reducing Allowed Operating Voltage Depending on Actual Temperature Rise Due to Harmon-

The mains filters may only be operated in the allowed mains voltage range. Harmonics (f_n) at the system voltage cause additional temperature rise of the dielectric of the capacitors used in the filter. Calculating the temperature rise:

$$\Delta T_{n} = \frac{10 \times \left(U_{Mh}\right)^{2}}{\left(U_{Gn}\right)^{2}} [K]$$

measured voltage value at frequency fn (harmonic) U_{Mn}

 U_{Gn} voltage limit value for frequency fn

 ΔT_n calculated temperature rise of the dielectric for frequency fn

Fig.16-48: Calculating the temperature rise of the dielectric

The temperature rises have to be added up for all frequencies $f_n \ge f_k$ (f_k : frequency at which the voltage derating of the filter starts):

$$\Delta T_{ges} = \sum_{\nu=1}^{m} \Delta T_{\nu} = \sum_{\nu=1}^{m} \frac{10 \times \left(U_{Mb}\right)^{2}}{\left(U_{G\nu}\right)^{2}} [K] \le 10 [K]$$

 U_{Mv} voltage value at frequency fv U_{Gv} voltage limit value for frequency fv

 ΔT_{ges} calculated temperature rise of the dielectric for all frequencies Fig. 16-49: Calculating the temperature rise of the dielectric for all frequencies

With the above formulas and the measured voltages, it is possible to determine the real load of a filter with voltages of higher frequencies. To this end, the rms value of the voltage on the mains side of the filter with all occurring frequencies (higher than $f_{\boldsymbol{k}}$) must be measured by means of a Fourier analysis for all combinations of line/line and line/PE. You always have to measure the voltages under conditions of operation at the nominal working point, the filter having been installed. By means of the measured values, it is then possible to calculate the temperature rise. To do this, the limit values of the following diagram are read at the respective frequency and used in the formula together with the measured value.




Fig. 16-50: Derating

If the total of the temperature values is greater than 10 K, the harmonics have to be reduced by means of appropriate measures.

Current Reduction in the Case of Overtemperature

The mains filters recommended by Rexroth have been dimensioned for an ambient temperature of 45 °C.

For higher temperatures, reduce the mains current according to the following formula:

338/363

Calculations

$$I = I_{\textit{Nets}} \times \sqrt{\frac{85 - T_{\textit{amb}}}{40}}$$

nominal current of filter at 45 °C ambient temperature on site

Fig.16-51: Current reduction in the case of overtemperature

Other Calculations

16.4.1 Charging the DC Bus

To estimate the delay time t_d which a supply unit or a converter needs to charge the DC bus, consider the following interrelation:

Delay time t_d from connection of mains voltage to the device (from status "ready for operation") and the status "drive ready". See also parameter "P-0-0115, Device control: status word " or "S-0-0135, Drive status word"

Delay Time td

$$t_d = R_{tade} \times 1, 2 \times C_{DC} \times 3 + 200 ms$$

delay time

effective charging resistance R_{lade} C_{DC} effective DC bus capacitance Fig.16-52: Delay time for three-phase operation

The interrelation applies to three-phase mains connection. For single-phase mains operation assume the double time or control following processes via the status "P-0-0115, Device control: status word".

Effective Charging Resistance with Several Mains Supplies Effective charging resistance of all drive controllers at common DC bus connected to mains voltage:

$$\frac{1}{R_{lade}} = \frac{1}{R_{lade_1}} + \frac{1}{R_{lade_2}} \dots + \frac{1}{R_{lade_n}}$$

Fig. 16-53: Several charging resistances

Effective Charging Resistance with **One Mains Supply**

Effective charging resistance of one drive controller at common DC bus connected to mains voltage:

$$R_{lade} = \frac{U_{LW}}{I_{L_trans_max_(on)}}$$

 U_{LN} mains voltage inrush current L_trans_max_(on) Fig.16-54: Charging resistance

For the data of the inrush current $I_{L_trans_max_on}$ and the mains voltage U_{LN}, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" → Chapter of the respective device → "Technical Data" → "Basic Data" → table "Data for mains voltage supply".

Resulting DC Bus Capacitance

Effective DC bus capacitance of all devices at common DC bus:

$$\boldsymbol{C}_{DC} = \boldsymbol{C}_{DC1} + \boldsymbol{C}_{DC2} \ldots + \boldsymbol{C}_{DCt} + \boldsymbol{C}_{DCtt}$$

C_{DC} capacitance in DC bus *Fig.16-55: DC bus capacitance*

For the data of the **capacitance in DC bus C**_{DC}, see Project Planning Manual "Rexroth IndraDrive Supply Units and Power Sections" \rightarrow Chapter of the respective device \rightarrow "Technical Data" \rightarrow "Basic Data" \rightarrow table "Data of power section - DC bus".

17 Appendix

17.1 System Elements - Product Overview, Short Designations

Short designation	System element / product	Description
BAM	motor holding brake	10th,
CSB01.1	control section single-axis	scope of functions BASIC
CDB01.1	control section double-axis	- Why when the state of the sta
CSH01.1, CSH01.2	control section single-axis	scope of functions ADVANCED
CZ 1.2	additional capacitor	capacitor with touch guard
DLT	isolating transformer	Laghe Malaye
DST	matching transformer	lito) lito)
HAT01.1	71/1/2	control unit for motor holding brake (e.g. BAM)
HAB01	blower unit	blower to be mounted to certain HMV01 and HMS01
HAC01	hosing for control sections	à à
HAS01	basic accessories	accessories for connecting the components (contact bars, fixing material)
HAS02	shield connection	accessory for connecting shielded motor cables to power sections
HAS03	control cabinet adapter	accessory for adjusting the mounting depth
HAS04	capacitor	accessory DC bus capacitors against ground potential
HAS05	cables, connectors, adapters	accessories to adjust electrical interfaces
HCS02.1	drive controller	converter
HCS03.1	drive controller	converter
HLB01.1C	DC bus resistor unit	for IndraDrive C
HLB01.1D	DC bus resistor unit	for IndraDrive M
HLC01.1C	DC bus capacitor unit	for IndraDrive C
HLC01.1D	DC bus capacitor unit	for IndraDrive M
HLR01	braking resistor	JIGE JEGE JEGE
HMD01.1	drive controller	power section, double-axis
HMF01.1	motor filter	New New New
HMS01.1	drive controller	power section, single-axis
HMS02.1	drive controller	power section, single-axis
HMV01.1E	supply unit	supply unit, infeeding
HMV01.1R	supply unit	supply unit, infeeding and regenerative
HMV02.1R	supply unit	supply unit, infeeding and regenerative
HNF01.1	mains filter	2, 2,
NF01.1	mains filter	

Short designation	System element / product	Description
HNL01.1	mains choke	designs for infeeding systems (E)
		regenerative systems (R)
	16 J	in current-compensated design
HNL02.1	mains choke	mains choke with housing for control cabinet mounting
HNS02.1	mains filter	mains filter with integrated switch-disconnector and motor circuit breaker
HNK01.1	mains filter	mains filter with integrated mains choke, variant for mounting
KCU01	electronic control system	additional component of IndraDrive Mi product range, to connect KSM to HMV supply units or HCS converters
KSM	distributed servo motor	distributed servo motor of IndraDrive Mi product range
MPB	firmware	scope of functions BASIC
MPD	firmware	scope of functions BASIC, double-axis
MPH	firmware	scope of functions ADVANCED
MSK	synchronous motor	
NFD03.1	mains filter	They
RKL	ready-made cable	ready-made motor power cable
RKS	ready-made cable	ready-made control cable
RKG	ready-made cable	ready-made encoder cable
RKH	ready-made cable	system cable of IndraDrive Mi product range
VCP01	comfort control panel	variant to be plugged on
VCP02	operator terminal	variant for assembly
VCP05	operator terminal	variant for assembly
VCP08	operator terminal	variant for assembly
VCP20	operator terminal	variant for assembly
VCP25	operator terminal	variant for assembly

Fig. 17-1: Product short designations

17.2 Capacitances Against Ground

17.2.1 General Information

The given capacitance values are used to select appropriate mains filters of the HNF01 and NFD03 lines.

17.2.2 Capacitance Data for Motors

Rexroth motors have the typical capacitance values listed below. The data refer to the total capacitance of the power connections $U,\,V,\,W$ against the motor housing.

Motor types	Length	Symbol	Unit	Typ. value
MKD025	Α	C_ab	nF	20/
MKE037	В	C _{ab}	nF	1,0

Motor types	Length	Symbol	Unit	Typ. value
MKD	Α	C _{ab}	nF	1/2/2
MHD				
MHP041	В	C _{ab}	nF	1,6
MKE047	age.		90,	
MKD	Α	C _{ab}	nF	1,2
MHD	В	C _{ab}	nF	2,5
MHP071		ab	111	2,5
MKD				
MHD	В	C _{ab}	nF	6,7
MHP090	D.	.00		.05
MKE098		109/100		109/100
MHD	А	C _{ab}	nF	4,8
MHP093	В	C _{ab}	nF	7,8
6	C	C _{ab}	nF	9,5
² 13/ ₁₀ .	A	C _{ab}	nF	3,7
MHD	В	C _{ab}	nF	5,3
MHP095	С	C _{ab}	nF	6,7
MKD	Α	C _{ab}	nF	5,3
MHD	В	C _{ab}	nF	10,3
MHP112	С	C _{ab}	nF	14,1
MKE118	D	C _{ab}	nF	20,2
MKD	А	C _{ab}	nF	6,9
MHD	В	C _{ab}	nF	13,2
MHP115	С	C _{ab}	nF	18,2
74/2°5.	В	C _{ab}	₩ nF	13,9
MHD131	D	C _{ab}	nF	25,7
	В	C _{ab}	nF	2,1
MSK050	С	C _{ab}	nF	2,6
	В	C _{ab}	nF	2,1
MSK060	C	C _{ab}	nF	
uoffice uof	С	C _{ab}	nF	3,1
MSK070	D	C _{ab}	nF	(g)
	E	C _{ab}	nF	212/2
Ara di	Size, length, winding		"Moij	preliminary

Motor types	Length	Symbol	Unit	Typ. value
My.	041C-42	C _{ab}	nF	11,3
	061C-35	C _{ab}	nF	2,4
LONG A OD	061C-61	C _{ab}	nF	2,2
KSM01.2B-	071C-24	C _{ab}	nF	5,0
	071C-35	C _{ab}	nF	4,7
	076C-35	C _{ab}	nF	6,9

Fig. 17-2: Leakage capacitance of selected motors

The scope of available motors is continuously extended. Please ask for data of motors not contained in this list.

17.2.3 Capacitance Data for Power Cables

The motor cables of Rexroth's "RKL" line have the capacitances per unit length listed below. The values refer to the sum of the single capacitances of power strands 1, 2 and 3 against the overall shield. For motor cables of the "RKH" line (hybrid cable of IndraDrive Mi), the value refers to the power strands L+, L-against the overall shield.

Type of non-assem- bled cable	Nominal cross section [mm²]	Symbol	Unit	Value	
INK 653	1,0	C _{Y_K typ}	nF/m	0,6	
INK 650	1,5	C _{Y_K typ}	nF/m	0,8	
INK 602	2,5	C _{Y_K typ}	nF/m	0,7	
INK 603	4	C _{Y_K typ}	nF/m	tbd	
INK 604	6	C _{Y_K typ}	nF/m	0,8	
INK 605	10	C _{Y_K typ}	nF/m	1,0	
INK 606	16	C _{Y_K typ}	nF/m	1,2	
INK 607	25	C _{Y_K typ}	nF/m	21,1	
INK 667	35	C _{Y_K typ}	nF/m	tbd	
INK 668	50	C _{Y_K typ}	nF/m	tbd	
REH0800	n.s.	C _{Y_K typ}	nF/m	0,2	

Fig. 17-3: Capacitance values of power cables (non-assembled cables)

B

Approximate calculation is allowed with the following values:

- 1 nF/m for cross sections from 1 mm² to 6 mm²
- 1.2 nF/m for cross sections from 10 mm² to 50 mm²

17.3 Emitted Harmonics on Mains Current and Mains Voltage

17.3.1 General Information

Due to their electric design, the drive controllers and supply units generate harmonics in the mains current and on the mains voltage during operation at the

mains. Using appropriate mains chokes decisively influences power factors and mains harmonics.

B

For comments on the short designations used, see chapter 16.2 Calculations for the Mains Connection, page 330.

17.3.2 Harmonics of Mains Current

Harmonics of Supply Units, Infeeding (HMV...E and HCS)

B

The harmonics of the mains current are decisively reduced by the use of mains chokes.

B

For mains with mains frequency f_{LN} = 60 Hz, the values accordingly are multiples of f_{LN} = 60 Hz.

Formulas see chapter "Calculations"

	WHY IDE	Without mains choke			With HNL Mains choke			With mains choke of higher inductance 1.7 x L _N of HNL		
13.2	I _{L_cont}	5%	50%	100%	5%	50%	100%	5%	50%	100%
k	f	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1
	Hz	%	%	%	%	%	%	%	%	%
1	50	100%	100%	100%	100%	100%	100%	100%	100%	100%
2	100	3	2	1	2	1	0,2	2	1 3	0,5
3	150	9	3	2	8	2	1	7	2	1
4	200	. P	2	1	1	1,300	0,2	1	1	0,5
5	250	95	90	85	84	70	61	71	55	38
6	300	3	2 000	1	2	2	0,5	2	1	0,5
7	350	85	80	75	71	40	36	58	28	13
8	400	3	3	1	1	2	0,5	1	2	0,5
9	450	2	2	1,0	6	1 🔏	9 1	5	₁₀ ,2 ¹ 1	0,5
10	500	(S ^(C) 1	1	. 1	1	1000	0,5	1 🔊	1	0,5
11	550	70	60	50	40	6	4,2	27	7	6,5
12	600	1	1,0	1	1,450	1	0,5	1	1	M19
13	650	46	55	45	28	5	5,1	17	5	3
14	700	2	2	1 8	1	1	<u>1</u>	2	₆ 1	1
15	750	2	1	1	1	1,3	1	2	1	1
16	800	1	1	رارات 1 ا	1	109	0,5	2	1	1 3
17	850	30	25	20	1 ,8	0,5	0,5	6	3	2,5
18	900	1		1	15234.	0,5	0,5	1	1	1 1 E
19	950	20	13	10	1	0,5	0,5	7	1	2
20	1000	2	2	1.00	0,5	0,5	0,5	2	<u></u>	1
21	1050	2	1	<u>1</u>	0,5	0,5	0,5	1 🔊	1	1

I _{L_cont} f Hz 1100 1150 1200	5% Ik/I1 %	50% lk/l1	100%	5%					NL
Hz 1100 1150		lk/l1		570	50%	100%	5%	50%	100%
1100 1150	% _<	x-4"	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1
1150		%	%	%	%	%	%	%	%
4	1	1	1,500	0,5	0,5	0,5	1	0,5	0,5
1200	10	8	5	0,5	0,5	0,5	0,5	0,5	0,5
	1	1	1	0,5	0,5	0,5	0,5	0,5	0,5
1250	8	5	3	0,5	0,5	0,5	0,5	0,5	0,5
1300	2	2	1	0,5	0,5	0,5	0,5	0,5	0,5
1350	2	1	1 🐧	0,5	0,5	0,5	0,5	0,5	0,5
1400		1	100	0,5	0,5	0,5	0,5	0,5	0,5
1450	5	3	2	0,5	0,5	0,5	0,5	0,5	0,5
1500	1	1	1	0,5	0,5	0,5	0,5	0,5	0,5
1550	3	2	1	0,5	0,5	0,5	0,5	0,5	0,5
1600	1 💉	1	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1650	100	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1700	₁ 1	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1750	3	1	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1800	1	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1850	2	1 1 E	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1900	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
1950	! ² 1	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2000 🔻	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2050	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2100	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2150	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2200	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2250	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2300	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2350	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2400	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
2450	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5	0,5
	- O-	0.5	0.6	0.5	0,5	0,5	0,5	0 0 5	0,5
	1750 1800 1850 1900 1950 2000 2050 2100 2150 2200 2250 2300 2350 2400 2450	1750 3 1800 1 1850 2 1900 0,5 1950 1 2000 0,5 2050 0,5 2100 0,5 2200 0,5 2250 0,5 2300 0,5 2350 0,5 2400 0,5 2450 0,5	1750 3 1 1800 1 0,5 1850 2 1 1900 0,5 0,5 1950 1 0,5 2000 0,5 0,5 2050 0,5 0,5 2100 0,5 0,5 2150 0,5 0,5 2200 0,5 0,5 2250 0,5 0,5 2300 0,5 0,5 2350 0,5 0,5 2400 0,5 0,5 2450 0,5 0,5	1750 3 1 0,5 1800 1 0,5 0,5 1850 2 1 0,5 1900 0,5 0,5 0,5 1950 1 0,5 0,5 2000 0,5 0,5 0,5 2050 0,5 0,5 0,5 2100 0,5 0,5 0,5 2100 0,5 0,5 0,5 2200 0,5 0,5 0,5 2200 0,5 0,5 0,5 2250 0,5 0,5 0,5 2300 0,5 0,5 0,5 2350 0,5 0,5 0,5 2400 0,5 0,5 0,5 2450 0,5 0,5 0,5	1750 3 1 0,5 0,5 1800 1 0,5 0,5 0,5 1850 2 1 0,5 0,5 1900 0,5 0,5 0,5 0,5 1950 1 0,5 0,5 0,5 2000 0,5 0,5 0,5 0,5 2050 0,5 0,5 0,5 0,5 2100 0,5 0,5 0,5 0,5 2150 0,5 0,5 0,5 0,5 2200 0,5 0,5 0,5 0,5 2250 0,5 0,5 0,5 0,5 2300 0,5 0,5 0,5 0,5 2350 0,5 0,5 0,5 0,5 2400 0,5 0,5 0,5 0,5	1750 3 1 0,5 0,5 0,5 1800 1 0,5 0,5 0,5 0,5 1850 2 1 0,5 0,5 0,5 1900 0,5 0,5 0,5 0,5 0,5 1950 1 0,5 0,5 0,5 0,5 2000 0,5 0,5 0,5 0,5 0,5 2000 0,5 0,5 0,5 0,5 0,5 2050 0,5 0,5 0,5 0,5 0,5 2100 0,5 0,5 0,5 0,5 0,5 2100 0,5 0,5 0,5 0,5 0,5 2200 0,5 0,5 0,5 0,5 0,5 2200 0,5 0,5 0,5 0,5 0,5 2250 0,5 0,5 0,5 0,5 0,5 2300 0,5 0,5 0,5 0,5 0,5	1750 3 1 0,5 0,5 0,5 0,5 1800 1 0,5 0,5 0,5 0,5 0,5 1850 2 1 0,5 0,5 0,5 0,5 1900 0,5 0,5 0,5 0,5 0,5 0,5 1950 1 0,5 0,5 0,5 0,5 0,5 2000 0,5 0,5 0,5 0,5 0,5 0,5 2000 0,5 0,5 0,5 0,5 0,5 0,5 2050 0,5 0,5 0,5 0,5 0,5 0,5 2100 0,5 0,5 0,5 0,5 0,5 0,5 2150 0,5 0,5 0,5 0,5 0,5 0,5 2200 0,5 0,5 0,5 0,5 0,5 0,5 2250 0,5 0,5 0,5 0,5 0,5 0,5 2350 0,5	1750 3 1 0,5 0,5 0,5 0,5 0,5 1800 1 0,5 0,5 0,5 0,5 0,5 0,5 1850 2 1 0,5 0,5 0,5 0,5 0,5 1900 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1950 1 0,5 0,5 0,5 0,5 0,5 0,5 2000 0,5 0,5 0,5 0,5 0,5 0,5 0,5 2050 0,5 0,5 0,5 0,5 0,5 0,5 0,5 2050 0,5 0,5 0,5 0,5 0,5 0,5 0,5 2100 0,5 0,5 0,5 0,5 0,5 0,5 0,5 2200 0,5 0,5 0,5 0,5 0,5 0,5 0,5 2250 0,5 0,5 0,5 0,5 0,5 0,5 0,5 <td>1750 3 1 0,5 0,5 0,5 0,5 0,5 0,5 1800 1 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1850 2 1 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1900 0,5 0,5 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1950 1 0,5 0</td>	1750 3 1 0,5 0,5 0,5 0,5 0,5 0,5 1800 1 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1850 2 1 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1900 0,5 0,5 0,5 0,5 0,5 0,5 0,5 0,5 0,5 1950 1 0,5 0

	100	2016	2000	With mains choke of higher in-	-
.H.(O)	Withou	ut mains choke	With HNL Mains chok	oke ductance	

	With		out mains o	choke	With I	HNL Mains	choke	190	ductance 7 x L _N of H	"High.
A	I _{L_cont}	5%	50%	100%	5%	50%	100%	5%	50%	100%
√e ^X k	f	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1	lk/l1
	Hz	%	%	%	%	%	%	% ~	%	% _
THD	%	173,08	156,32	144,86	120,86	81,18	71,24	98,08	62,61	41,12
ki	Ny.	0,87	0,84	0,82	0,77	0,63	0,58	0,70	0,53	0,38

k k = 1: fundamental wave; $k \ge 2$: harmonics number I_{L_cont} maximum input current (mains input continuous current), see technical data of device - Data for mains voltage supply ki distortion factor or harmonic content harmonic current of the k-th harmonic rms value of the 1st harmonic (fundamental wave) I_1 THD **Total Harmonic Distortion** Harmonics HMV...E and HCS Fig.17-4:

Harmonics of Supply Units, Regenerative (HMV...R)



In the end application, the harmonics values are within the minimum and maximum values listed below. The harmonics values depend

- load distribution
- conditions in the mains
- mains pollution which other devices feed in the mains

If the degree of mains pollution generated by other devices is low, the resulting values of the harmonics in the mains current of the drive system are minimum values. If there is a high degree of mains pollution generated by other devices, the maximum values of the table can be reached in the worst case.

		<u> </u>			
. dollar	diane		lk/l1		
k	_{int} †	Min.	Тур.	Max.	
	Hz	%	%	%	
1 2	50	100%	100%	100%	
2	100	2,5	4	25	
3	150	2	, 1 ¹⁰ 5	25	
4	200	2	3	25	
5	250	2	17	35	
6	300	2	2	30	
7	350	1,6	7,10	30	
8	400	1	2	12	
9	450	1	10 ⁰⁰ 2	10	
10	500	1 25	2	8	
11	550	1	5	12	
12	600	1	2	7	
13	650	1	2	6	
		V.	0,0		

		N. B. Lille	lk/l1	
k. w. (O)	f	Min.	Тур.	Max.
20,000	Hz	%	%	%
<u>}</u> 14	700	1 3	2	3
15	750	1 3	2	3
16	800	0,5	2	3
17	850	0,5	2 (1)	3
18	900	0,5	2	3
19	950	0,5	2	3
20	1000	0,5	2	2
21	1050	0,5	1	2
22	1100	0,5	1 .50	2
23	1150	0,5	14,0	2
24	1200	0,5	11	2
25	1250	0,5	1	2
26	1300	0,5	1	3 1 1
27	1350	0,5	1	1
28	1400	0,5	1,000	1
29	1450	0,5	_A G ^A C ^A	1 🖟
30	1500	0,5	0,5	_1
31	1550	0,5	0,5	10.7
32	1600	0,5	0,5	1
33	1650	0,5	0,5	0,5
34	1700	0,5	0,5	0,5
35	1750	0,5	0,5	0,5
36	1800	0,5	0,5	0,5
37	1850	0,5	0,5	0,5
38	1900	0,5	0,5	0,5
39	1950	0,5	0,5	0,5
40	2000	0,5	0,5	0,5
41	2050	0,5	0,5	0,5
42	2100	0,5	0,5	0,5
43	2150	0,5	0,5	0,5
44	2200	0,5	0,5	0,5
45	2250	0,5	0,5	0,5
46	2300	0,5	0,5	0,5
47	2350	0,5	0,5	0,5
48	2400	0,5	0,5	0,5

Parie Parie		lk/l1			
k	71,00	Min.	Тур.	Max.	
	Hz	%	%	%	
49	2450	0,5	0,5	0,5	
50	2500	0,5	0,5	0,5	
Not.	7400		"HOL.	30	
THD	%	6,45	21,89	74,34	
ki	21212	0,06	0,21	0,60	

THD Total Harmonic Distortion Fig. 17-5: Harmonics HMV01.1R

17.3.3 Harmonics on Mains Voltage

The voltage harmonics depend on the structure of the mains, especially on the mains inductance or the mains short-circuit power at the connection point. At different mains and mains connection points, one device can cause different voltage harmonics.

For a normal mains, the harmonics content of the mains voltage when operating drives generally is below 10%. Short-time drops in mains voltage are below 20%.

More precise values can only be calculated with exact knowledge of the mains data (mains topology), such as line inductance and line capacitance related to the connection point.

These values, however, can temporally vary quite strongly, according to the switch status of the mains. The harmonics of the mains voltage thereby change, too.

Rough estimated values of the mains data are not sufficient for pre-calculation of the harmonics, as mainly the resonance points always present in the mains have a strong influence on the harmonics content.

In order to keep the degree of mains voltage harmonics as low as possible, you should, if possible, not connect capacitors or compensation units (capacitor batteries) directly to the mains. If capacitors or compensation units are absolutely required, you should only connect them to the mains via chokes.

17.4 Voltage Pulse for Test According to EN61000

The figure below shows the voltage pulse for defining the impulse withstand voltage according to EN61000.




Fig. 17-6: Impulse withstand voltage 1,2/50 µs and 8/20 µs according to EN 61000

17.5 Discharging of Capacitors

17.5.1 Discharging of DC Bus Capacitors

In the drive system Rexroth IndraDrive, capacitors are used in the DC bus as energy stores. In the drive controllers and particularly in the supply units, such capacitors have already been integrated.

Energy stores maintain their energy even when energy supply has been cut off and have to be discharged before somebody gets in contact with them.

Discharging devices have been integrated in the components of the drive system Rexroth IndraDrive; within the indicated discharging time, these devices discharge the voltage below the allowed 50 V.

If additional capacitances in the form of

- DC bus capacitor units or
- additional capacitors

are connected, make sure that these capacitors, too, are discharged before somebody gets in contact with them.

Due to the operating principle, the discharging time is the longer

- the bigger the energy store (the capacitance value)
- the higher the voltage to which the energy store has been charged
- the greater the resistance for discharging the capacitors.

Components of the drive system Rexroth IndraDrive have been dimensioned in such a way that after the energy supply was cut off the voltage value falls below 50 V within a discharging time of a maximum of 30 minutes.



Lethal electric shock caused by live parts with more than 50 V!

- Wait at least 30 minutes after switching off power to allow discharging.
- Check whether voltage has fallen below 50 V before touching live parts!

To shorten the waiting time until voltage has fallen below 50 V, you can take the following measures:

Activate the function "ZKS" when using HMV01 supply units.



Lethal electric shock caused by live parts with more than 50 V!

Check whether voltage has fallen below 50 V before touching live parts!

Use the discharging device described below.

17.5.2 Discharging Device




Lethal electric shock caused by live parts with more than 50 V!

Before touching live parts, check in any case whether the voltage between the DC bus terminals L+ and L- has fallen below 50 V!

Operating Principle

A contactor is installed to switch a resistor to the terminals L+ and L- of the DC bus connection to discharge the capacitors. The contactor is activated via a control input which is supplied with appropriate control voltage.



R: discharging resistor K: contactor contact

Fig. 17-7: Operating principle of discharging device

Dimensioning

The individual components have to be sufficiently dimensioned:

- The value of the discharging resistor has to be dimensioned with 1000 ohm and at least 1000 W.
- The discharging resistor and the contactor contact have to withstand the loads of practical operation (for example in the case of frequent use of the discharging device of the occurring continuous power).
- The contactor contact has to withstand the occurring direct voltage of min. 1000 V.
- The contactor contact has to withstand the occurring discharge current according to the resistance value that is used, i.e. 1 A with 1000 ohm.

How to Proceed for Discharging

Observe the proceeding when using the discharging device:

- Install discharging device before switching energy supply on for the first time and establish safe electrical connection between discharging device and object to be discharged.
- 2. On mains side, switch off energy supply to drive system before activating discharging device.
- 3. Activate discharging device.

Disposal and Environmental Protection

18 Disposal and Environmental Protection

18.1 Disposal

18.1.1 Products

Our products can be returned to us free of charge for disposal. However, it is a precondition that the products are free of oil, grease or other dirt.

Furthermore, the products returned for disposal must not contain any undue foreign matter or foreign component.

Please send the products free domicile to the following address:

Bosch Rexroth AG

Electric Drives and Controls

Bürgermeister-Dr.-Nebel-Strasse 2

D-97816 Lohr am Main

18.1.2 Packaging Materials

The packaging materials consist of cardboard, wood and polystyrene. These materials can be easily recycled in any municipal recycling system. For ecological reasons, please refrain from returning the empty packages to us.

18.2 Environmental Protection

18.2.1 No Release of Hazardous Substances

Our products do not contain any hazardous substances which may be released in the case of appropriate use. Accordingly, our products will normally not have any negative effect on the environment.

18.2.2 Materials Contained in the Products

Electronic Devices

Electronic devices mainly contain:

- steel
- aluminum
- copper
- synthetic materials
- electronic components and modules

Motors

Motors mainly contain:

- steel
- aluminum
- copper
- brass
- magnetic materials
- electronic components and modules

Disposal and Environmental Protection

18.2.3 Recycling

Due to their high content of metal, most of the product components can be recycled. In order to recycle the metal in the best possible way, the products must be disassembled into individual modules.

Metals contained in electric and electronic modules can also be recycled by means of special separation processes. The synthetic materials remaining after these processes can be thermally recycled.

If the products contain batteries or rechargeable batteries, these batteries are to be removed before recycling and disposed of.

Service and Support

19 Service and Support

19.1 Helpdesk

Our service helpdesk at our headquarters in Lohr, Germany, will assist you with all kinds of inquiries.

Contact us:

- By phone through the Service Call Entry Center,
 Monday to Friday 7:00 am 6:00 pm CET
 - +49 (0) 9352 40 50 60
- By fax
 - +49 (0) 9352 40 49 41
- By e-mail: service.svc@boschrexroth.de

19.2 Service Hotline

Out of helpdesk hours please contact our German service department directly:

+49 (0) 171 333 88 26

or

+49 (0) 172 660 04 06

Hotline numbers for other countries can be found in the addresses of each region (see below).

19.3 Internet

Additional notes regarding service, maintenance and training, as well as the current addresses of our sales and service offices can be found on

http://www.boschrexroth.com

Outwith Germany please contact our sales/service office in your area first.

19.4 Helpful Information

For quick and efficient help please have the following information ready:

- Detailed description of the fault and the circumstances
- Information on the type plate of the affected products, especially type codes and serial numbers
- Your phone and fax numbers as well as your e-mail address so we can contact you in case of questions

Symbols	Boring dimensions
24V control voltage supply 43	For the mounting plate 150
24V supply 40	Braking resistor
Continuous power 44	Continuous power 328
Determining the data for selection 43	Duty cycle 328
Installation 45	Duty cycle, relative 328
Internal 41	Energy absorption 324
Peak current 45	Peak power 329
r can durion 40	Braking resistor HLR01
Λ	Brief description 30
A Abbraviations 244	Braking resistors HLR
Abbreviations 341	For HCS02 100
Accessories	For HCS03 101
In the drive system Rexroth IndraDrive 201	Branch
Accessories HAS	Fusing 66
Brief description 32	Bus cable
Accessories HAS01 201	Extension 309
Accessories HAS05 268	Bus master 288
Accessory	Dus master 200
Connection of two cables, adapter 302	0
D-Sub to terminal connector, adapter 295	C
HAS05.1-001 270	Cable
HAS05.1-002 272	INK0572 290
HAS05.1-003 273	RKB0010 289
HAS05.1-005 285	Cables
HAS05.1-006 290	Capacitance 344
HAS05.1-007 295	Connection cables to motor 106
HAS05.1-008 302	Calculations 319
Motor holding brake control, adapter 290	Additional external capacitors 324
Adapter	Charging the DC bus 338
Mains and motor connection 270	Continuous power in the common DC bus 333
Additional components	Continuous regenerative power 326
Arrangement 158	Control factor 329
For supply units and converters 97	DC bus continuous power 319
Additional external capacitors	DC bus peak power 322
Calculations 324	Distortion factor 332
Ambient conditions 36	DPF 332
ANAX 105	Harmonic content 332
Applications	Inrush current 331
Drive system Rexroth IndraDrive 27	Leakage capacitance 335
Appropriate use 15	Mains choke HNL 334
Applications 15	Mains connection 330
Arrangement	Mains filters: allowed operating data 336
Performance-dependent 158	Mains harmonics 332
	Peak regenerative power 329
B's "tj	Phase current 330
Bar, 228	Power dissipation 324
Use 202	Power factor cosφ 333
Bb contact 111	Power factor cosφ1 332
Properties 112	Regenerative power 323
Bb Contact	TPF (λ) 333
Load capability limits 112	Wattless power load 332
Blower unit HAB01	Capacitance
Brief description 31	Motors 342
Bonding conductor 200	Power cables 344
bonding conductor 200	Capacitance per unit length 108
	P P

Capacitors Heat dissipation 171 Discharging 351 Control cabinet adapter Capacity utilization 38 HAS03 256 CCC, China Compulsory Certification 34 Control cabinet areas CDB01 Area A, interference-free 164 Brief description 29 Area B, interference-susceptible 165 CE label 33 Area C, strongly interference-susceptible 166 Central supply Interference areas 161 **HCS 77** Control cabinet blower 174 **HMV 73** Control circuit Certifications 33 Parallel operation 120 Control circuit position-controlled shutdown Charging the DC bus Calculations 338 Supply unit HMV01.1R with integrated mains Circulation 149 contactor 129 Combination Control circuits Firmware, control section, power section 102 For mains connection of Rexroth IndraDrive M With components of the control range supply units 119 Rexroth IndraControl V 105 For the mains connection 111 With motor filters HMF01 102 HCS02 with DC bus resistor unit HLB01.1C 117 Commutation drops 50 HCS03 with DC bus resistor unit HLB01.1D 117 Control circuit with DC bus short circuit (ZKS) Compatibility with foreign matters 38 Supply unit HMV01.1E with integrated mains Components Arranging the components in the control cabinet contactor 123 Supply unit HMV01.1R with integrated mains Main dimensions of the system components contactor 125, 127 Control circuit without DC bus short circuit (ZKS) Performance-dependent arrangement 158 Supply unit HMV01.1E with integrated mains Short designations 341 contactor 131 Connected load Supply unit HMV01.1R with integrated mains Mains, maximum 57 contactor 132 Connection Supply unit HMV01.1R without integrated mains Control voltage 192 contactor 133 DC bus 187 Control factor Ground connection 182 Calculations 329 Mains choke 186 Control section Motor 195 In drive controller 9 Connection cables Control section CDB01 To motor 106 Usage 29 Connection point Control section CSB01 Equipment grounding conductor 182 Usage 29 Control section CSH01 Connection points X44 292 Usage 29 Connections Control sections In the drive system 181 **Brief description 29** Contactor Control voltage Selection 65 Connection 192 Continuous powers in the common DC bus Specification 40 Calculations 333 Supply 41 Continuous regenerative power Supply with control voltage 24 V 43 Calculations 326 Control voltage supply Loop-through contacts 47 Control Convection 149 By emergency stop relay 130 By the control unit 128 Cooling Via external mains contactor - HCS02 and Control cabinet 171 HCS03 115 Cooling air current 174 Control cabinet Cooling units Arranging the components 145 Arrangement 175 Cooling 171 Corner-grounded delta mains 54

cosφ 57	Drive system	
CSB01	Combination o	of components 71
Brief description 29	Configuration	
CSH01	Connections 1	
Brief description 29	Rexroth Indra	
	Rexroth Indra	
C-UL-US listing 33		
,	Rexroth Indra	
D 36	Drive system Rex	
DC bus	Applications 2	7 250
Connection 187	DST	
DC bus capacitors	Brief description	on 27
Discharging 351	Duty cycle ED	
DC bus capacitor unit HLC01	Relative 328	
Brief description 31		
	E M	
DC bus continuous power		annatibility (EMC) 127
Calculations 319		compatibility (EMC) 137
DC bus peak power	EMC 137	
Calculations 322		nstallation in facility and control
DC bus resistor unit HLB01	cabinet 160	
Brief description 30	EMC measures	
Declaration of Conformity 33	For design and	d installation 159
Devices	Emergency stop r	elay
Short designations 341		t DC bus short circuit (ZKS) 130
Dimensions	EMI 137	Ton,
Main dimensions of the system components	Encoder emulatio	n 💖
145		level converter 273
Discharging device 351	Encoder systems	iovoi conventor 210
Distance 146		ulo encoder evaluation 103
		lle encoder evaluation 103
Between the devices 146	EnDat 103	
Lateral 149	End piece	
To the bottom 147	Use 202	
To the top 147	End Piece	
Distortion factor 57, 345	Mounting 228	
Calculations 332	ePlan macros 200) ₂₀ 6°
DLT	Equipment ground	ding conductor
Brief description 27	Connection 66	the state of the s
Documentation	Connection po	
Changes 11	Connections 1	
Purpose 11	Cross section	
Documentations	Extension	The state of the s
Overview 12		ains filters and HCS03 mains input
Reference 12	272	and rices and rices mains input
	212	
DPF	7:\0,_	
Calculations 332	The F	
Drive controller	Fiber optic cable	
Basic design 8	Accessories 30	05
Control section 9	Fiber optic cable of	connection
Determine appropriate drive controller 319	Accessories 30	
HCS02, brief description 30	Fields of applicati	
HCS03, brief description 30		Rexroth IndraDrive 27
HMD01, brief description 29	Foreign matters	15.1.5111111111111111111111111111111111
HMS01, brief description 29	Compatibility v	vith 38
HMS02, brief description 29		AIRT OO
Power section 8	Functions 11	
Drive controllers	Fusing	
	Selection 65	
Multiple-line arrangement 178		

G C		Heat dissipation
G1, G2, G3, G4, G5		Control cabinet 171
Mounting positions 37		Hierarchical levels 1
Ground connection		High-voltage test 39
Of Housing 182		HIPERFACE 103
Ground connections 167		HLB01
Ground resistance		Brief description 30
Maximum allowed 65		HLC01
Maximum allowed 65		Brief description 31
190, 190, 190, 190, 190, 190, 190, 190,		HLR01
H		
HAB01		Brief description 30 HMD01
Brief description 31		
HAC01		Brief description 29
Brief description 32		HMF01
Hall sensor box 103		Brief description 31
Hall sensor box SHL01		HMS01
Brief description 32		Brief description 29
Harmonic content, 345		HMS02
Calculations 332		Brief description 29
Harmonics		HMV
Emitted 344		Central supply 73
Mains current 345		Central supply, number 75
Mains voltage 349		HMV01
HAS		Brief description 29
Brief description 32		HMV02
HAS01		Brief description 29
Assignment 202		HNF
Basic accessories 201		Brief description 27
HAS02		HNF01
Shield connection 228		HAS04 required 93
	UA 902 106	Minimum capacitance 93
Shield connection with accessory	11A302 190	HNK
HAS03		Brief description 27
Control cabinet adapter 256		HNL
HAS04		Brief description 28
Capacitor 260		HNS02
Use 93		Brief description 27
HAS05		Housing HAC01 for control sections
Overview 268		Brief description 32
HAS05.1-		brief description 32
001 270		790,
002 272		
003 273		Impulse withstand voltage 349
005 285		Inappropriate use, 16
006 290		Consequences, exclusion of liability 15
007 295		IndraDrive
008 302		Hierarchical levels 1
HCS O		IndraDyn H 109
Central supply 77		Inductance per unit length 108
Parallel operation 83		Industrial sectors 27
Supply unit 77		Inrush current
HCS02		Calculations 331
Brief description 30		INS0610 305
Central supply, number 80		Installation
HCS03		EMC-optimal 160
Brief description 30		Installation conditions 36
		Insulation monitoring devices 69
Central supply, number 81		Introducing the system 1
		minouncing the system i

1000D	7.90°
ISCCR	Mains filters
Short-circuit current ratio 56	Brief description 27
IT mains type 52	Operating data, allowed 336
	Mains harmonics 50
K o	Calculations 332
K	Emitted 344
Distortion factor 345	Mains overvoltages
Kind of supply	Maximum allowed 50
For power sections 71	Mains short-circuit power 55
76	Mains short-circuit ratio 57
 """ """ "" """ """ """ """ """ """ """	Mains transformers
L cakago canacitanos	Brief description 27
Leakage capacitance	Mains types 51
Calculations 335	Mains voltage
Leakage currents	Harmonics 349
Cause 67	Mains voltage unbalance 333
	Master-slave 120
M XS ²	Measures of radio interference suppression
Mains	
Maximum connected load 57	General measures of radio interference suppres
Measures for compliance with allowed THD or	sion for relays, contactors, switches, chokes, in
distortion factor 57	ductive loads 169
Selecting mains connection components 58	Minimum capacitance
With grounded outer conductor 54	At the DC bus 93
Mains and motor connection	Use of HNF01 93
Adapter HAS05.1-001 270	Minimum inductance 57
Mains choke	Module bus
Connection 186	Connection 195
Mains choke HNL	Extension 309
	Motor
Calculations 334	Connection 195
Mains chokes	IndraDyn H 109
Brief description 28	Third-party motors 313
Mains circuit breaker	Motor blower
Ground resistance 65	Mains filter 164
Selection 65	Motor cable
Mains classes 56	Allowed length 107
Mains connected load 57	Connection to drive controller 195
Mains connection	Cross section 107
Calculations 330	Motor cables
Control circuits 111	Capacitance per unit length 108
Protection systems 60	Connected in parallel 108
Requirements 49	Inductance per unit length 108
With HNL mains chokes, HNF mains filters and	Unshielded 108
HNK mains chokes 85	
Mains contactor, 111	Motor cables connected in parallel 108
Additional 114	Motor encoder systems
Control by the control unit 128	Optional module encoder evaluation 103
Control via external mains contactor - HCS02	Motor filters HMF01, 102
and HCS03 115	Brief description 31
Redundant 114	Motor holding brake
Selection 65	Voltage drop 108
Suppressor circuit 112	Motors
Mains filter	Capacitance 342
Connection 186	Mounting
	Bar 228
Motor blower 164	Boring dimensions for the mounting plate 150
Other loads 165	End Piece 228
Selection 334	Mounting position
	Definitions 37

Multiple-line arrangement of drive controll	lers 178	Residual-current-operated circuit breakers 67	
		Resolver 103	
1		Rexroth IndraDrive C 1	
NFD		Rexroth IndraDrive M 3	
Brief description 27		Rexroth IndraDrive Mi 5	
NFE		RKB0001 309	
Brief description 27		RKO0100 305	
Noise emission		RKO0101 305	
Measures to reduce 143		RS232/485	
Noise emission of the drive system 138		Signal level converter 285	
		olgital level converter 200	
Noise immunity in the drive system 137		S	
		Safety instructions for electric drives 17	
		Scope of supply	
Operating conditions 36		HAS01 203	
Operator terminals 105			
Overvoltage limiters 51		SERCOS analog converter 105	
		Shield connection	
		Accessory HAS02 228	
Parallel operation		Motor cable 195	
HCS02 with HCS02 82		SHL01, 103	
HCS03 with HCS03 82		Brief description 32	
HMV 75		Short-circuit current	
Number of components HCS 83		Symmetrical 56	
Number of HMVs 76		Short designations 341	
Parallel operation HMV01 120		Short-time interruptions 50	
Peak regenerative power		Signal level converter	
Calculations 329		Voltage signal level converter (for encoder emu	-8
Phase current		lation) 273	
Calculations 330		Signal level converter RS232/485 285	
		Signal lines	
Power consumption Maximum 45		Installation 168	
		Simultaneity factor 321	
Typical 45		Specifications	
Power dissipation		Of the components 33	
Calculations 324		State-of-the-art 15	
Power factor cosp		Storage	
Calculations 333		Of the components 35	
Power factor cosφ1		Supply	
Calculations 332		With control voltage 24 V 43	
Power factors 344		With power voltage 49	
Power supply		Supply unit	
Switching off 113		HMV01, brief description 29	
Switching on 113			
Power voltage		HMV02, brief description 29	
Power voltage supply 49		Switching off	
Products		Power supply 113	
Short designations 341		Time behavior 134	
Protection systems		Switching on	
At the mains connection 60		Power supply 113	
Protective grounding 60		Time behavior 134	
ingo, -		System connections 181	
₹ ⁰⁰		Position 181	
RCCB 67		System impedance 56	
RCD 67		System platform 1	
RD500			
Supply unit 83		T &	
Regenerative power		TERM	
Calculations 323		HAS05.1-005 286	
Calculation 3 323		V. Carrier	

Termination HAS05.1-005 286 THD 57, 332, 345 Third-party motors 313 Third-party supply units 83 Time behavior When switching on and off 134 TN-C mains type 52 TN-S mains type 51 Total Harmonic Distortion (THD) 332 **TPF 57** TPF (λ) Calculations 333 **Transport** Of the components 35 TT system 54 Type current 9 Type performance 9

Ungrounded mains 52

Use A

Appropriate use 15 Inappropriate use 16

V

VCP 105 Voltage drop 108 Voltage drops 50 Voltage pulse 349

W

Wattless power load Calculations 332

X

X44 292

