# AUTOMATION SYSTEM PRODUCT RANGE

EDITION 9/95

PLC SYSTEMS			A	
			HHHILCY D	/mmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmm
VISUALIZATION			В	
INDUSTRIAL NETW	ORKS AND COM	1MUNICATION	THE STATE OF THE LEGISLAND OF THE PARTY OF T	
INDUSTRIAL COM	IPUTERS (STATE OF THE STATE OF		D	
ACCESSORIES			<u> </u>	
			WHIPE -	"WHE TO SHEET SHEE
DOCUMENTATION	X Jak		Fagi	



# AUTOMATION SYSTEM

	GENERAL INF	ORMATION			d <sub>D</sub>	4
	- 6,		4,			<u>, j</u>
Α	PLC SYSTE	MS AF		- 47/ <sub>10</sub>	Eig	5
	A1	SYSTEM SELECTION	TOLL			12
	A2		OL			
	A3		1(5)			
	A4	MINICONTROL COMPO	NENTS	744.		48
	A5	MULTICONTROL SYSTE	M			80
	A6	MULTICONTROL COMP	ONENTS			88
	A7	PLC PROGRAMMING				168
	A8					
	A9	PID LOOP CONTROL				202
В	VISUALIZAT	ION	and the same of th	THU,	"Hyp.	213
	B1					
	B2		UALIZATION			
	B3 B4		ZATION IZATION			
	Б4	FULL GRAPHIC VISUAL	IZATION			240
	INDUIGEDIAL	NETWORKS AND SO	ANNUAL TION	44	44	0.45
С	INDUSTRIAL	NETWORKS AND CO	DMMUNICATION			245
	C1	SYSTEM SELECTION	\$	Š	<b>\</b>	248
	C2					
	C3	ARCNET				270
	C4	CAN BUS			10,	274
	C5	B&R MININET				278
	C6	OTHER PROTOCOLS				284
	6	9	6	3	×	9
D	INDUSTRIAL	COMPUTERS	Mr.	-2/to.,	Es.	289
	SEC.	DOD 144 FOTO 0 01/0==-	· office			<b>a</b> .c.=
	D1		M			
	D2	B&R MAESTRO COMPC	NENTS			
	D3	INDUSTRIAL COMPUTE	K SULTWARE			320

# AUTOMATION SYSTEM PRODUCT RANG



E	ACCESSORIES		2/2,	th,	325
	CABLE, TERMINAL BLOCKS, DUI	MMY FRONTS, BATT	ERIES, TEST EQUIPMENT		
F	DOCUMENTATION	7/2,	"'G	77/202	337
	USER'S MANUALS, SHORT DESC	CRIPTIONS	New York	Thy.	alet.
	INDEX MODEL NUMBER INDEX	No.lin	Alektri,	Nicities.	351 355



# **GENERAL INFORMATION**

### **AUTOMATION SYSTEM PRODUCT RANGE**

### **GENERAL INFORMATION**

This catalog should give you an overview of the B&R product range which includes PLC systems, visualization devices, industrial networks, communication software and industrial computers.

The products described in this catalog are divided into seven main chapters which are labeled from A to G. The seven chapters are:

- PLC Systems
- Visualizations
- Industrial Networks & Communication
- Industrial Computers
- Accessories
- Documentation
- Sales and Support

The pages that belong to a chapter are marked with a colored bar. The colored bar can be seen from the edge of the catalog.


Most of the chapters are separated into sections. The sections are numbered. For example, the chapter B "Visualization" contains following sections:

- System Selection
- Operator Panel Visualization
- Semigraphic Visualization
- Full Graphic Visualization

The table of contents on pages 2 and 3 contain a list of all main chapters and their sections. The main chapter and section description can be found on the top of each page. Additionally, a pictograph can be found on the top outside edge which corresponds to the respective chapter. This should allow you to quickly find the chapter that you need.

### Example

Section "Operator Panel Visualization" can be found in chapter B "Visualization". It is the second section (2). The chapter is labeled B2. These labels can be found on all pages of the respective section:



- a ... Section Description
- b ... Chapter Description c ... Chapter Label
- d ... Section Number
- . Pictograph

A detailed table of contents can be found at the beginning of each chapter that contains the products described in that section.

An index and model number index can be found at the end of the catalog. The index refers to important key words in the text.

			- 40 <sub>04</sub>	CHRONICAL DESIGNATION OF THE PARTY OF THE PA
	PLC SYSTEMS		A	
WALL STORY	SYSTEM SELECTION	in man in	Hard Garage	
	B&R COMPACT PLC		2	
	MINICONTROL SYSTEM		3	
	MINICONTROL COMPONENTS		4	
	MULTICONTROL SYSTEM		444 Table 1	
	MULTICONTROL COMPONENTS		6	
	PLC PROGRAMMING		7	
	POSITIONING		8	
WHA! PASIFICE	PID LOOP CONTROL	Hun idps House	9	

1600

16. G

1200

140.0

143.0



A1	SYSTEM SELECTION	al.	ap.	M.	
	and the same of th				200
	CONTENTSGENERAL INFORMATION				
	FUNCTIONALITYRELIABILITY				
	OPERATING SECURITY				
	SYSTEM SELECTION				
	PERFORMANCE DATA / MEASUREMEN				
	SLOT OVERVIEW				
	MODULE OVERVIEW				
	.67	'C2 <sub>20</sub>	741,	-G <sub>1</sub>	
A2	B&R COMPACT PLC			12.P	
	CONTENTS				
	GENERAL INFORMATION				24
					_
	ACCESSORIES				
	PERFORMANCE DATA				
	MEASUREMENTS				
	INSTALLATION GUIDELINES MOUNTING				
	WIRING				
	GROUNDING / SHIELDING				
	CABLE SHIELD GROUNDING				
	PROTECTIVE ELEMENTS				
	STORAGE TEMPERATURE				
	ELECTROSTATIC DISCHARGE				
	CPU				28
	DIGITAL INPUTS				
	DIGITAL OUTPUTS				3
	ANALOG INPUTS				20
	ANALOG INPUTS				
	ANALOG OUTPUTS				30
	IF1 - RS232 INTERFACE				34
	IF2 - RS232/RS485 INTERFACE				
	IF3 - PATA/SSI INTERFACE				
	IF5 - CAN BUS				36
	LITHIUM BATTERY				37
	- 182				
	ADDITIONAL APPLICATION EEPROM				3
	SUPPLY VOLTAGE				0-
	SUPPLY VOLIAGE				3
	RELAY EXPANSION CARD				2
	RELAT EXPANSION CARD	- C	725	*C.	
A3	MINICONTROL SYSTEM	25,0	2	25	
A3	WINICONTROL STSTEM				
	CONTENTS				43
	GENERAL INFORMATION				
	PERFORMANCE DATA	(A)	17.4		
	SLOT OVERVIEW	200	200	(A.)	
	I/O MODULE OVERVIEW				
	INSTALLATION GUIDELINES				
	CABLING				
	GROUNDING / SHIELDING				
	CABLE SHIELD GROUNDING				
	PROTECTION CIRCUITS				47
	STORAGE TEMPERATURE				
	ELECTROSTATIC DISCHARGE		700		4 <sup>-</sup>





<b>A4</b>	MINICONTROL COMPONENTS	,	7.00		- A.C
	CONTENTS				45
	SLOT OVERVIEW				
	I/O MODULE OVERVIEW				
	SLOTS AND MODULES				
	OPERATING TEMPERATURE / RELAT	IVE HUMIDITY			50
	BASE UNITS	76,	760	760	5 <sup>^</sup>
	GENERAL INFORMATION				
	CPUS				
	HOUSING				
	POWER SUPPLY MODULE				-7/4
	APPLICATION PROGRAM MEMOR				
	DIGITAL INPUT / OUTPUT MODULES				56
	E16A - 16 INPUTS 24 VDC	20,			57
	MAEA - 8 INPUTS 24 VDC, 6 OUT				
	MAEB - 16 INPUTS 24 VDC, 16 O	UTPUTS 24 VDC / 0.5 A			59
	A12A - 12 RELAY OUTPUTS 220 V				
	A12B / A12C - 12 TRANSISTOR O				
	ANALOG INPUT / OUTPUT MODULES	2,		5,	62
	PEA4 - 4 INPUTS 0 - 10 V / 0 - 20 r				
	PEA8 - 4 INPUTS, 4 OUTPUTS 0				
	PT41 - 4 INPUTS FOR PT100 SEN				
	PTA2 - 2 INPUTS FOR PT100 SEN				
	PTE6 - 6 INPUTS FOR THERMOE				
	PTE8 - 8 INPUTS FOR KTY10 SEN	v(C)'			()-
	PRTA - 4 INPUTS 0 - 10 V / 0 - 20 i				
	INTERFACE MODULES				70
	PIFA - SERIAL RS232 INTERFACE				
	PATA - MINICONTROL OPERATOR				
	TAIA - MINICONTROL OF ENAFOR	TANLE / SSI INTERIA	DE CONTROL	Δ.	
	COUNTING AND POSITIONING MODU	11.50			7
	PNC4 - COUNTING MODULE FOR				
	PZL2 - COUNTING MODULE FOR				
	PSA2 - POSITIONING MODULE FOR				
	PSAZ - POSITIONING MODULE FO	JR STEPPER MOTORS			
	OTHER MODULES				- 70°
	MZEA / MZEB - INPUT /TIMER MO				
	WZEA / WZEB - INPUT / TIWER WO	DOLES			10
NP.	MULTICONTDOL SYSTEM	7.0%	- 10 <sup>2</sup> 5	195.	
A5	MULTICONTROL SYSTEM	24	- W.		
	CONTENTS				0.0
	CONTENTS				
	GENERAL INFORMATION				
	THE B&R MULTIPROCESSOR TECHN				
	RACKS				
	PERFORMANCE DATA				
	SLOT OVERVIEW				83
	I/O MODULE OVERVIEW	<u>7</u> 6		<u>d</u>	84
	EXPANSIONS				84
	INSTALLATION GUIDELINES	The.	$\mathcal{H}_{\Omega}$	The same	85
	CABLING				85
	GROUNDING / SHIELDING				
	CABLE SHIELD GROUNDING				100
	ELECTROSTATIC DISCHARGE				
	PROTECTION CIRCUITS				
	STORAGE TEMPERATURE				



### **PLC SYSTEMS**

<b>A6</b>	MULTICONTROL COMPONENTS	" " " " " " " " " " " " " " " " " " "	41 <sub>CO.</sub> "47;	0,
	CONTENTS			00
	MODULE OVERVIEW			
	BASE UNITS			
	OPERATING TEMPERATURE / RELATIVE	: LI IMIDITY		90
	OPERATING TEMPERATURE / RELATIVE	: HUMIDITY		90
	CPUS			01
	MULTI AND MIDI RACKS			
	M264			
	TECHNICAL DATA			(V)
	ONLINE INTERFACE			
	APPLICATION INTERFACE			
	INSTRUCTION SET			
	DATA MEMORY			
	MATHEMATICS INSTRUCTIONS			
	FIRST SCAN FLAG			
	TIMING PULSE, TIMING CYCLE, SOF			
	SOFTWARE CLOCK, REAL TIME CLO			
	SAFETY AND DIAGNOSIS FUNCTION			
	CP40 - MULTICONTROL CPU TYPE A	- A.N.		
	CP60 - MULTICONTROL CPU TYPE B			
	CP70 - MULTICONTROL CPU TYPE B			
	NTCP33 - MULTICONTROL CPU TYPI			
	NTCP6# - MULTICONTROL CPU TYP			
	NTCI O# - MOLITICONTROL CI O TTI	L D		90
	RACKS			100
	GENERAL INFORMATION			
	EXPANSION RACKS			
	SLOTS			
	INSTALLATION			
	SLOTS FOR INDUSTRIAL COMPUTE			
	OVERVIEW			
	MEASUREMENTS AND TECHNICAL			
	POWER SUPPLY MODULES			102
	GENERAL INFORMATION			
	M264 RACK			-1/2
	OVERVIEW			
	SLOTS			
	STRUCTURE			
	BATTERY			
	FUSES			

 STATUS LEDS
 103

 EXPANDED DIAGNOSIS FUNCTIONS
 103

 SELECTING A POWER SUPPLY MODULE
 103

 NT43 - MULTICONTROL POWER SUPPLY MODULE 24 VDC / 100 W
 104

 NT44 - MULTICONTROL POWER SUPPLY MODULE 240 VAC / 100 W
 105

 PS45 - MULTICONTROL POWER SUPPLY MODULE 120 VAC / 100 W
 106

 NTCP#3 - MULTICONTROL POWER SUPPLY MODULE 24 VDC / 50 W
 107

 NTCP64 - MULTICONTROL POWER SUPPLY MODULE 240 VAC / 60 W
 108

 PSCP65 - MULTICONTROL POWER SUPPLY MODULE 120 VAC / 60 W
 109



DIGITAL INPUT MODULES	116
GENERAL INFORMATION	
E161 - 16 INPUTS 24 VDC / AC	117
E162 - 16 INPUTS 220 VAC	118
E163 - 16 INPUTS 24 VDC	120
I164 - 16 INPUTS 120 VAC	121
E243- 24 INPUTS 24 VDC	
DIGITAL OUTPUT MODULES	
GENERAL INFORMATION	124
A161 - 16 RELAY OUTPUTS 220 VAC / 2 A	
A163 - 16 RELAY OUTPUTS 220 VAC / 2 A	
A162 - 16 TRANSISTOR OUTPUTS 24 VDC / 2 A	
A115 - 16 TRANSISTOR OUTPUTS 24 VDC / 0,5 A	
A244 - 24 TRANSISTOR OUTPUTS 24 VDC / 0,5 A	
A121 / O125 - 12 TRIAC OUTPUTS 220 VAC / 120 VAC	
7.12.1 7.0.120 1.2 7.10 0.01 0.10 2.20 7.00 1.20 7.00 1.20 7.00 1.20 7.00 1.20 7.00 1.20 7.00 1.20 7.00 7.00 7.00 7.00 7.00 7.00 7.00 7	
ANALOG INPUT MODULES	132
GENERAL INFORMATION	
PE42 / PE82 - 4 / 8 INPUTS 0 - 10 V / 0 - 20 mA (10, 12 BIT)	
PE84 - 8 INPUTS 0 - 10 V / 0 - 25 mA (16 / 15 BIT)	
PE16 - 16 INPUTS U, I, PT100, NTC, PTC (16 BIT)	136
PTE8 - 8 INPUTS FOR FeCuNi OR NiCrNi TEMPERATURE SENSORS (10 BIT)	
PT81 - 8 INPUTS FOR PT100 TEMPERATURE SENSORS (10 BIT)	138
ANALOG OUTPUT MODULES	140
GENERAL INFORMATION	
PA42 / PA81 - 4 / 8 OUTPUTS ±10 V / 0 - 20 mA (11, 13 BIT)	
INTERFACE MODULES	142
GENERAL INFORMATION	
SERIAL INTERFACES	
B&R INTERFACE MODULES	
STANDARD SOFTWARE	
INTERFACE CONVERTER	
PIF1 - 1 SERIAL RS232/TTY OR 1 RS422 INTERFACE	
PIF3 - 2 SERIAL RS232/TTY AND 1 CENTRONICS INTERFACE	
INT1 - RS232 / RS485 INTERFACE CONVERTER	
PARALLEL PROCESSORS	148
GENERAL INFORMATION	
PP60 - PARALLEL PROCESSOR TYPE B	
PP60 MEM - PARALLEL PROCESSOR TYPE B WITH 128 KBYTE DATA MEMORY	
COUNTING AND POSITIONING MODULES	152
GENERAL INFORMATION	
STANDARD SOFTWARE	
PNC3 - COUNTING MODULE FOR POSITIONING APPLICATIONS	153
PSA2 - POSITIONING MODULE FOR 2 STEPPER MOTORS	
PZL1 - COUNTING MODULE FOR EVENT COUNTING	
PNC8 - POSITIONING MODULE FOR 4 AXES	
PWP4 - ULTRASONIC TRANSDUCER MODULE	
OTHER MODULES AND DEVICES	160
GENERAL INFORMATION	
EXS2 / EXE3 - EXPANSION SENDER / EXPANSION RECEIVER MODULE	
NP02 - COMMUNICATION PROCESSOR FOR OTHER PROTOCOLS	
PMV4 - PROPORTIONAL SOLENOID MODULE	
BRMEC MASS MEMORY	





Δ7	РI	$\mathbf{C}$	PR	ററു	$\Delta M$	MING

CONTENTS				168
GENERAL INFORMATION				170
PROGRAMMING DEVICE				170
ONLINE PROGRAMMING	'92,	70,	Š	171
GENERAL INFORMATION				
CENTRONICS / ONLINE CONVERTER		7/2	7/2	171
B&R ONLINE INTERFACE MODULE		70,0	70,0	171
ONLINE NETWORK AND MODEM DIAGNOSIS				
BRADOL - ONLINE / MODEM CONVERTER				
ONLINE ADAPTER				
ONLINE CABLE				
9	9	9		9
THE B&R PROGRAMMING SYSTEM				175
GENERAL INFORMATION				
PERSONAL COMPUTER				
STATEMENT LIST PROGRAMMING (STL)				
FUNCTION BLOCK PROGRAMMING (FBK)				
LADDER DIAGRAM PROGRAMMING (LAD)				
LOGIC PLAN PROGRAMMING (LP)				
FBK EDITOR				
TABLES				
SYMBOL ASSIGNMENT (SYMB)				
PROGRAM DOCUMENTATION				
DEBUGGING				
ORDER DATA				
ONDER DATA		30		177
STANDARD SOFTWARE				170
STANDARD SOFTWARE PACKAGE 1				
STANDARD SOFTWARE PACKAGE 2				
STANDARD SOFTWARE PACKAGE 2				
STANDARD SOFTWARE PACKAGE 4				
STANDARD SOFTWARE PACKAGE 4				





A8	POSITIONING	45	3	" <sub>V</sub> ' <sub>(Q)</sub>	77/07
	CONTENTS				
	GENERAL INFORMATION				
	SHORT DESCRIPTION OF POSITIONING				
	REQUIRED SYSTEM COMPONENTS				
	FEEDBACK SIGNALS (POSITION DETECT	TION)			190
	END SWITCHES AND LIGHT BARRIER	RS	,		190
	INCREMENTAL AND ABSOLUTE ENCO	ODERS	Ö		190
					14/
	ELECTRICAL MOTORS				
	OVERVIEW				
	RELAY CONTROLLED ASYNCHRONO				
	FREQUENCY CONVERTER CONTROL				
	DC SERVO MOTORS				192
	THREE PHASE SYNCHRONOUS SER				
	THREE PHASE ASYNCHRONOUS SE				
	POSITIONING METHODS				400
	START/STOP POSITIONING				
	DUAL SPEED POSITIONING				
	STEPPER MOTOR POSITIONING				
	POSITIONING DEPENDENT SPEED C				
	LOOP CONTROL WITH PRECEDING S				
	MAC1 AXIS CONTROLLER				
	WAOT AND CONTROLLER	79,	79,		
	B&R CNC				198
	CONFIGURATION				
	MOVEMENT PROFILE				
	ASYMMETRIC ACCELERATION / DECI				
	SPEED CHARACTERISTICS IN EXTRE				
	FUNCTIONS OF THE B&R CNC				
	OTHER B&R CNC CHARACTERISTICS	3			201
A9	PID LOOP CONTROL	260	.00	-0(1)	.01
	700	Ò.	- 25.		
	CONTENTS				202
	GENERAL INFORMATION				
	BASIC TERMINOLOGY				
	DYNAMIC PROCESS CONTROL				
	CONTROL LOOP CHARACTERISTICS				
	TYPES OF LOOP CONTROLLERS				
	ALGORITHMS OF A DIGITAL PID LOOP CO				
	FUNCTIONS OF THE PID LOOP CONTRO				
	PARAMETERS	5			206
	PROPORTIONAL BAND (PB)				206
	DEAD BAND (DB)		<u> </u>		206
	DEVIATION ALARMS (DEV+, TDEV+, DEV-				
	SETPOINT RAMP (RAMP)			72	207
	WORKING POINT (BIAS)			-	208
	CONTROL SIGNAL LIMITS (MV_HI, MV_LC	O)			208
	CONTROL SIGNAL RAMP dy/dt (VEL)				
	TIME PROPORTIONAL CONTROL (TP+, T	Pmin+, TP-, TPmin-)	The same of the sa		209
	STEP SIGNAL (TS, TSmin)			<u>, (A. )</u>	210
	SYSTEM CONFIGURATIONS	<i>2</i> 7			
	SOFTWARE COMPONENTS				211



PLC SYSTEM
SYSTEM SELECTION

PLC SYSTEM
SYSTEM SELECTION





# A1 SYSTEM SELECTION

CONTENTS					12
GENERAL INFORMATION	(6)	·····		70.	14
FUNCTIONALITY	-24				14
RELIABILITY	4,		- 4		14
OPERATING SECURITY					14
SYSTEM SELECTION		<u> </u>			15
PERFORMANCE DATA / MEAS	SUREMENTS	Χ			16
SLOT OVERVIEW					20
MODULE OVERVIEW			(C	<u> </u>	20



### **GENERAL INFORMATION**

# PLC SYSTEM SYSTEM SELECTION

### **GENERAL INFORMATION**

The PLC serves as the foundation of an automation system. All process or machine level information passes through the PLC. The efficiency and the reliability of the entire system depends directly on the efficiency and reliability of the PLC.

B&R has used this knowledge to produce a philosophy based on three criteria:

- Functionality
- Reliability
- Operation Security

### **FUNCTIONALITY**

Functionality is the ability of PLC systems to accomplish specific tasks. Such as:

- Logic Control
- Positioning
- Visualization
- Communication
- Data Acquisition, Storage and Management

A PLC system not only needs to be able to solve all current automation tasks, but it also must provide enough reserve efficiency for future expansion.

A PLC system with only one processor has two technological limitations to it's efficiency:

- Limited application program execution speed
- Limited program memory


In practice, such a system can usually only accomplish part of the required tasks and will not allow subsequent function extensions.

The modular concept of B&R PLC systems guarantees that your resources are never completely used. The efficiency of the entire system can be extended at any time with parallel processors. The network capability of all B&R PLC systems enables the formation of distributed PLC groups.

### RELIABILITY

The functionality describes only the basic abilities of a PLC system to complete tasks. Reliability is the ability of a PLC system to complete these tasks continually over a long period of time.

Reliability is always a limited value because the occurrence of errors can never be completely excluded. One measurement of reliability is the failure rate. The following diagram shows the development of the failure rate over a period of time:



Early Failure

The early failure phase is caused by material and production defects and is distinguished by a comparatively steep decreasing failure rate during the first operating period. This phase can be eliminated before delivery by testing for several days at increasing operating temperatures.

tures.

Random Failure

The random failure phase is marked by a small, relatively constant

failure rate.

Wear-out Failure

The failure rate increases in the wear-out phase and is equivalent to the end of serviceability. This occurs with electronic controls after a

very long period of time (decades).

Once made aware of these facts, the question of how to put these failure rates into relation often arises, especially with random failures. Procedures have been developed in order to establish the expected durability of electronic devices. The "meantime-between-failure" - (MTBF) is basically determined from experience. For a certain observation period, the number of failed units is compared with the sum of the operating times of all delivered units. The observation time must be very long in order to achieve relevant results with this procedure. Different methods for establishing MTBF rates are usually expensive and do not produce reliable results. Therefore, the MTBF indications are theoretical and can only be applied limitedly in reality.

### **B&R Systems are Reliable:**

- All B&R components are developed, manufactured and tested. Utilization of high quality components, precise control of received products, visual check of all manufacturing steps, computer supported rack testing and 48 hour function test at increased operating temperatures in a controlled climate are part of the B&R quality control process.
- A new B&R product is only put on the market after it is thoroughly tested.
- PLC reliability within a system is usually overemphasized during the overall evaluation of the reliability of a machine/device. Statistics have proven that only about 5 % of all errors in PLC controlled machines or devices are caused by the PLC. 95 % of the errors emerge from signalling devices, drives, wiring positioning devices etc.

### **OPERATING SECURITY**

Errors in operation cannot be 100% excluded despite the measures mentioned above for achieving maximum reliability. A PLC system is "operation secure" if eventual hardware or software errors do not create a machine/device failure, which could possibly cause personal injury or damage. Errors must be recognized immediately and the system must react correspondingly.

All B&R PLC systems have extensive security and diagnosis functions which quickly and reliably detect hardware errors as well as software errors and bring the system to a safe operation mode in case of a defect. If an error occurs, all system outputs are set to a secure operating state, i.e. digital outputs are reset (log. 0), analog outputs are reset to 0 V or 0 mA.

Diagnostic functions can be grouped as:

- Hardware controlled diagnosis functions
- Hardware/software controlled diagnosis functions
- Software controlled diagnosis functions

### **GENERAL INFORMATION**

### **PLC SYSTEM** SYSTEM SELECTION





### **Hardware Controlled Security and Diagnosis Functions**

Hardware controlled security and diagnosis functions are still effective in case of a complete failure of the CPU module.

Hardware Watchdog The hardware watchdog is a protection function that brings the system to a secure operating mode in case of complete failure of the PLC processor or other components required for the

operation of the PLC

All outputs of the PLC system are reset if an error occurs. This Hardware Reset

guarantees that a safe operating mode is achieved in case of

a complete CPU breakdown.

Ready Relay The ready relay provides a contact that is only closed if the PLC

is functioning correctly. Any hardware or software errors cause this relay to be released. The ready relay represents an additional security function when wired correctly.

### Hardware/Software Controlled Security and Diagnosis Functions

For these functions, the fault testing is executed by the software on the appropriate hardware.

**Bus Monitoring** The PLC bus is constantly monitored. Short circuits on the bus caused by defects or conductive pollution are immediately

**Expansion Test** MULTICONTROL systems expansion racks are also con-

stantly tested. A defect in an expansion rack or on a connection to an expansion rack such as a bus error will be detected.

### **Software Controlled Security and Diagnosis Functions**

The sense of software controlled diagnosis functions often comes into question since the proper operation of the CPU and the power supply module must be taken for granted. As described previously in the "Reliability" section, only 5 %of all errors in PLC controlled machines or devices are caused by the PLC itself. A closer look at the statistics of these PLC errors shows that approx. 10 % of the errors occur in the CPU or in the power supply module. The other 90 % occur in the other PLC components. That means the CPU and the power supply modules are some of the most reliable components of a PLC system. Therefore, it makes sense to place security and diagnosis functions in these components.

**Application Program** 

Checksum

The checksum of an application program is constantly monitored for defects in the application program memory.

Software Watchdog (Runtime Monitoring)

All B&R PLC systems provide a software watchdog, that checks the maximum permissible program scan time. The software watchdog recognizes a runtime error and executes a software reset if a program scan is not completed after a defined period of time (e.g. 100 msec). Endless loops are detected in an application program in this way.

**Trap Error Detection** 

If the processor encounters an unknown command when the application program is being executed, a trap error occurs, Trap errors are often caused by software errors in indexed

jump instructions.

**Stack Pointer Test** 

The system stack memory is checked at the end of every program scan to find software errors such as a subroutine that is not terminated with RTS or errors caused by using the system stack memory as data memory.

#### Summerv

The following table shows an overview of the B&R security and diagnosis

Function	Compact PLC	MINICONTROL	M264	IGIW	MULTI
Hardware Watchdog Hardware Reset Ready Relay	Mary!	· :	:	A STATE	•
Bus Monitoring Expansion Test			20	•	•
Checksum Test	•	• ×	3 ·	•	•
Software Watchdog	•	• ~	•	•	• 60
Trap Error Detection	•	•0,	•	•	×.
Stack Pointer Test	•	70°	•	• (	30.0

### SYSTEM SELECTION

To select the most appropriate PLC system, a good knowledge of the application is required. The following should be known:

- How many digital inputs/outputs are to be processed?
- How many analog inputs/outputs are to be processed?
- Is communication with superior/subordinate systems required?
- Are visualizations required?
- Is positioning required? If yes, which type?
- Are PID loops required? If yes, which type?
- Is data acquisition, data storage and data management required?

An overview of the PLC systems that are available is also required. This overview must contain:


- Performance data of individual systems (processing speed, available program and data memory, number of slots, etc.)
- Number of channels per module for digital input/output modules
- Slot restrictions (not all modules can be operated in every slot)

The overview on the following pages should help you select the most appropriate PLC system for your application. Also consider the software compatibility for all B&R PLC systems. This enables simple programming with a PC programming system for all systems and allows a simple and moderate change from one system to the next.



PLC SYSTEM
SYSTEM SELECTION

### **COMPACT PLC**



The Compact PLC is not a modular control system. However, it can be used universally due to it's concept and functionality.

### CPU CPU Type A

Processor	MOTOROLA 6303
Application Program Memory	16 KByte (RAM/EEPROM) max. 4.7 K inst.
Processing	approx. 4 msec / K inst.
Data Memory	
Register (8 bit)	7168
Flag (1 bit)	800
EEPROM Expansion Memory	
(for data)	16 KByte
Time/Date	Real time clock

### INPUTS/OUTPUTS

9	Digital Inputs	16	four of which can be used for counter inputs
	Digital Outputs	14	an additional relay expansion card with 16 extra outputs can be obtained
	Analog Inputs	2	0 - 20 mA / ±10 V / ±2.5 V / KTY10 (16 Bit)
	Analog Outputs	2	0 - 20 mA / ±10 V (12 Bit)

### SERIAL INTERFACES

X24.	
RS232	
RS232/RS485 (RS485 electrically isolated)	
PATA (controlling MINICONTROL operator panel,	
relay expansion card),	
SSI (absolute encoder connection)	
B&R On-line Interface	
CAN Bus (BRCOMP2-0)	
	RS232/RS485 (RS485 electrically isolated) PATA (controlling MINICONTROL operator panel, relay expansion card), SSI (absolute encoder connection) B&R On-line Interface

### NETWORKS / COMMUNICATION


B&R MININET	YES	
B&R NET2000	NO	
ARCNET	NO	
ETHERNET	NO	
CAN Bus	only BRCOMP2-0	
Communication Protocols	YES	

PLC SYSTEM SYSTEM SELECTION





### MINICONTROL SYSTEM



CPU CP30 CP32

Processor	MOTOROLA	MOTOROLA 6303 (CPU Type A)	
Application Program Memory	(RAM	16 KByte (RAM/PROM) max. 4.7 K inst.	
Processing Time	approx. 4 r	approx. 4 msec / K inst.	
Data Memory Register (8 bit) Flag (1 bit)	7.4.	168 300	
Parallel Processors	, i	NO	
Interface	TTY	TTY/RS485	
Time/Date	Software clock	Real time clock	
EEPROM Expansion Memory (for data)	<u>-</u>	32 KByte	

### INPUTS/OUTPUTS


max. 192	
max. 16	

### NETWORKS / COMMUNICATION

B&R MININET	YES	
B&R NET2000	NO	
ARCNET	YES	
ETHERNET	NO	
CAN Bus	NO	
Communication Protocols	YES	

### **MEASUREMENTS**

Measurements are given in mm. See conversion chart on the last page of the catalog for the corresponding measurement in inches.






PLC SYSTEM
SYSTEM SELECTION

### **MULTICONTROL SYSTEM**

### M264 SYSTEM



#### CPU CPU Type A CPU Type B MOTOROLA 6303 Processor MOTOROLA 6809 42 KByte (RAM/PROM) 16 KByte (RAM/PROM) Application Program Memory max. 4.7 K inst. max. 42 K inst Processing Time approx. 4 msec / K inst. approx. 2.5 msec / K inst. Data Memory Register (8 bit) Flag (1 bit) 7168 800 7168 Software clock Time/Date Real time clock Parallel Processors max. 4 max. 4

### INPUT/OUTPUT


Digital Input/Output	max. 264	
Analog Input/Output	max. 80	

### NETWORKS / COMMUNICATION


B&R MININET	YES	
B&R NET2000	NO	
ARCNET	YES	
ETHERNET (SINEC H1)	YES	
CAN Bus	YES	
Communication Protocols	YES	

### MEASUREMENTS

Measurements are given in mm. See conversion chart on the last page of the catalog for the corresponding measurement in inches.



### MIDI SYSTEM



CPU CPU Type A	CPU Type B	
Processor	MOTOROLA 6303	MOTOROLA 6809
Application Program Memory	16 KByte (RAM/PROM) max. 4.7 K inst.	42 KByte (RAM/PROM) max. 42 K inst.
Processing Time	approx. 4 msec / K inst.	approx. 2.5 msec / K inst.
Data Memory Register (8 bit) Flag (1 bit)	7168 800	7168 800
Time/Date	Software clock	Real time clock
Parallel Processors	max. 7	max. 7

### INPUT/OUTPUT


Digital Inputs/Outputs Analog Inputs/Outputs	max. 168 max. 112	

### NETWORKS / COMMUNICATION

B&R MININET B&R NET2000 ARCNET	YES NO YES	
ETHERNET (SINEC H1) CAN Bus Communication Protocols	YES YES YES	

### MEASUREMENTS

Measurements are given in mm. See conversion chart on the last page of the catalog for the corresponding measurement in inches.




PLC SYSTEM SYSTEM SELECTION





### **MULTI SYSTEM**



CPU CPU Type A	CPU Type B	
Processor	MOTOROLA 6303	MOTOROLA 6809
Application Program Memory	16 KByte (RAM/PROM) max. 4.7 K inst.	42 KByte (RAM/PROM) max. 42 K inst.
Processing Time	ca. 4 msec / K inst.	approx. 2.5 msec / K inst.
Data Memory Register (8 bit) Flag (1 bit)	7168 800	7168 800
Time/Date	Software clock	Real time clock
Parallel Processors	max. 16	max. 16

### INPUTS/OUTPUTS


ts/Outputs max. 1536 uts/Outputs max. 256	

### NETWORKS / COMMUNICATION

B&R MININET	YES	
B&R NET2000	NO	
ARCNET	YES	
ETHERNET (SINEC H1)	YES	
CAN Bus	YES	
Communication Protocols	YES	

### MEASUREMENTS

Measurements are given in mm. See conversion chart on the last page of the catalog for the corresponding measurement in inches.






# **SLOTS AND MODULES**

PLC SYSTEM
SYSTEM SELECTION


### MINICONTROL SYSTEM

### **SLOT OVERVIEW**



### **MULTICONTROL SYSTEM**

### M264 SYSTEM SLOT OVERVIEW



### MODULE OVERVIEW I/O MODULES

DIGIT	ΓAL I/	O MODULES	Slot	0	1	2	3	4	5
E10	6A	16 inputs 24 VDC		•	•	•	•	•	•
MA	EΑ	8 inputs 24 VDC, 6 transistor outputs 24 VDC / 0,5 A		•	•	•	•	•	•
MA	EB	16 inputs 24 VDC, 16 transistor outputs 24 VDC / 0,5 A		•	•	•	•	•	
A12	2A	12 relay outputs 220 VAC / 2 A		1)	1)	•	•	•	•
A12	2B	12 transistor outputs 24 VDC / 0,5 A		1)	1)	•	•	•	•
A12	2C	12 transistor outputs 24 VDC / 2 A		1)	1)	•	•	•	•

ANALOG	I/O MODULES	Slot	0	1	2	3	4	5
PEA4	4 inputs 0 - 10 V / 0 - 20 mA (10 Bit)		•	•			Š	io.
PEA8	4 inputs 0 - 10 V / 0 - 20 mA (10 Bit), 4 outputs 0 - 10 V / 0 - 20 mA (8 Bit)		•	•				
PT41	4 inputs for PT100 temp. (10 Bit, 3 or 4 c	conductor)	•	•				
PTA2	2 inputs for PT100 temp. sensors (10 Bit 2 outputs 0 - 10 V (8 Bit)	t, 3 conductor	),	•				
PTE6	6 inputs for thermal element (±50 mV, 16 (NiCrNi Typ K, FeCuNi Typ F and J)	6 Bit)	•	•				
PTE8	8 inputs for KTY10 temp. sensors (16 Bit	t)	•	•				
PRTA	4 inputs 0 - 10 V / 0 - 20 mA (10 Bit)		•	2)				
	124			-	-			

### MODULE OVERVIEW I/O MODULES

DIGITAL	I/O MODULES	Slot1	0 1 2 3 4 5 6 7 8 9 A
E161	16 inputs 24 VDC/AC		•••••
E162	16 inputs 220 VAC		•••••
E163	16 inputs 24 VDC		••••••
1164	16 inputs 120 VAC		<u></u>
E243	24 inputs 24 VDC		••••••
A161	16 relay outputs 220 VAC / 2	2 A	•••••
A162	16 transistor outputs 24 VD0	C/2A	•••••
A163	16 relay outputs 220 VAC / 2	2 A	•••••
A115	16 transistor outputs 24 VD0	C / 0.5 A	•••••
A244	24 transistor outputs 24 VD0	C / 0.5 A	••••••
A121	12 triac outputs 220 VAC / 2	Α	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
0125	12 triac outputs 120 VAC / 2	Α	•••••

AN	IALOG I	O MODULES	Slot	0 1 2	3 4 5 6 7 8 9 A	
5	PE42	4 inputs 0 - 10 V / 0 - 20 mA (10 E	Bit, 12 Bit)	•••	••	
-	PE82	8 inputs 0 - 10 V / 0 - 20 mA (10 Bit, 12 Bit)		•••	••	
-	PE84	8 inputs 0 - 10 V / 0 - 25 mA (16 E	Bit)	•••	••	
1	PE16	16 inputs 0 - 10 V / 0 - 50 mA / PT100 / NTC / PTC (16 Bit)			••	
-	PTE8	8 inputs for FeCuNi and NiCrNi temp. sensors		•••	•• 4	
	PT81	8 inputs for PT100 temp. sensors  ● ● ●			••	
1	PA42	4 outputs ±10 V / 0 - 20 mA (11, 13 Bit)				
ا	PA81	8 outputs $\pm 10$ V / 0 - 20 mA (11, 1	3 Bit)	•••	••	

The digital output modules A12A, A12B and A12C can also be operated in slots 0 and 1 in base unit A.

<sup>2)</sup> The analog input module PRTA can also be operated in slot 1, if slot 2 is not being used.


# **SLOTS AND MODULES**

PLC SYSTEM SYSTEM SELECTION






### MIDI SYSTEM SLOT OVERVIEW



### **MULTI SYSTEM SLOT OVERVIEW**



### MODULE OVERVIEW I/O MODULES

DIGITAL	I/O MODULES	Slot	0 1 2 3 4 5 6 7
E161	16 inputs 24 VDC/AC		·····
E162	16 inputs 220 VAC		0
E163	16 inputs 24 VDC		0
1164	16 inputs 120 VAC		·····
E243	24 inputs 24 VDC		0
A161	16 relay outputs 220 VAC / 2 A		0
A162	16 transistor outputs 24 VDC / 2 A		0
A163	16 relay outputs 220 VAC / 2 A		•••••
A115	16 transistor outputs 24 VDC / 0.5 A		
A244	24 transistor outputs 24 VDC / 0.5 A		
A121	12 triac outputs 220 VAC / 2 A		
0125	12 triac outputs 120 VAC / 2 A		0 • • • • • •
	27.4	27.5	

### MODULE OVERVIEW I/O MODULES


DIGITAL	I/O MODULES	Slot	0123456789ABCDEF
E161	16 inputs 24 VDC/AC		••••••
E162	16 inputs 220 VAC		<u> </u>
E163	16 inputs 24 VDC		•••••
I164	16 inputs 120 VAC		•••••
E243	24 inputs 24 VDC		•••••
A161	16 relay outputs 220 VAC	/ 2 A	•••••
A162	16 transistor outputs 24 VI	DC / 2 A	•••••
A163	16 relay outputs 220 VAC	/ 2 A	× •••••••
A115	16 transistor outputs 24 VI	OC / 0,5 A	e
A244	24 transistor outputs 24 VI	OC / 0,5 A	••••••
A121	12 triac outputs 220 VAC /	2 A	•••••
0125	12 triac outputs 120 VAC /	2 A	•••••

ANALOG	S I/O MODULES	Slot	0 1 2 3 4 5 6 7
PE42	4 inputs 0 - 10 V / 0 - 20 mA (10 Bit, 12 Bi	it)	0000000
PE82	8 inputs 0 - 10 V / 0 - 20 mA (10 Bit, 12 Bit	it)	0
PE84	8 inputs 0 - 10 V / 0 - 25 mA (16 Bit)		
PE16	16 inputs 0 - 10 V / 0 - 50 mA / PT100 / NTC / PTC (16 Bit)		<b>0</b>
PTE8	8 inputs for FeCuNi and NiCrNi temp. sen	sors	0
PT81	8 inputs for PT100 temp. sensors		<b>0000000</b>
PA42	4 outputs ±10 V / 0 - 20 mA (11, 13 Bit)		•••••
PA81	8 outputs ±10 V / 0 - 20 mA (11, 13 Bit)		••••••

ANALOG	I/O MODULES	Slot	0123456789ABCDEF
PE42	4 inputs 0 - 10 V / 0 - 20	mA (10 Bit, 12 Bit)	* • • • • • • • • • • • • • • • • • • •
PE82	8 inputs 0 - 10 V / 0 - 20	mA (10 Bit, 12 Bit)	••••••
PE84	8 inputs 0 - 10 V / 0 - 25	mA (16 Bit)	••••••
PE16	16 inputs 0 - 10 V / 0 - 5 NTC / PTC (16 Bit)	0 mA / PT100 /	••••••
PTE8	8 inputs for FeCuNi and	NiCrNi temp. sensors	•••••
PT81	8 inputs for PT100 temp	. sensors	••••••
PA42	4 outputs ±10 V / 0 - 20	mA (11, 13 Bit)	••••••
PA81	8 outputs ±10 V / 0 - 20	mA (11, 13 Bit)	••••••



PLC-SYSTEM B&R COMPACT PLC







A2	B&R COMPACT PLC		The state of the s	477		The state of the s
	CONTENTS					18
	GENERAL INFORMATION					
	100	NO.	N-	D."	10,	
	ACCESSORIES	70,	19%		70%	20
	TECHNICAL DATA					
	MEASUREMENTS					
	INSTALLATION GUIDELINES					
	MOUNTING					
	WIRING					
	GROUNDING / SHIELDING					
	CABLE SHIELD GROUNDING					
	PROTECTIVE ELEMENTS					
	STORAGE TEMPERATURES					
	ELECTROSTATIC DISCHARGE					-
	CPU					24
	X00 X0	Ö	:200		O.D.	700
	DIGITAL INPUTS					25
	DIGITAL OUTPUTS		637			(63.9)
	DIGITAL GOTT GTG		2,	40		Σ,
	ANALOG INPUTS					28
	ANALOG OUTPUTS					
	7.1.1.1.2.3.3.3.1.3.1.3.1.3.1.3.1.3.1.3.1	40.7		9.7	49.7	20
	IF1 - RS232 INTERFACE					30
	IF2 - RS232/RS485 INTERFACE					
	IF3 - PATA/SSI INTERFACE					( ) *
	IF5 - CAN BUS					
	11 0 0/11/200		(4)		)	02
	LITHIUM BATTERY					33
	EITHON BY TEXT		27	29		
	ADDITIONAL APPLICATION EEPROM.					33
	À	Α.		À	A	
	SUPPLY VOLTAGE			3×		33
	100	29/	10.		73,	
	RELAY EXPANSION CARD				Co.	34



# A2

# GENERAL INFORMATION, ACCESSORIES, TECHNICAL DATA

PLC-SYSTEM
B&R COMPACT PLC

### **GENERAL INFORMATION**

The Compact PLC is in the same category as the MINICONTROL. It was developed to be 100% software compatible to MINICONTROL. If you need to change to MINICONTROL because of advanced requirements, the work you have accomplished concerning software will not be lost.

Even though it is not modular, the Compact PLC is able to be used universally because of it's concept and design.

### **Features**

- Digital inputs/outputs
- Relay expansion card
- Analog inputs (voltage, current and temperature)
- Analog outputs (voltage and current)
- Event counter
- Interrupt input
- Reference input
- Channel A and B for positioning tasks
- 2 serial interfaces
- CAN Bus (BRCOMP2-0)
- B&R standard PATA interface (for MINICONTROL operator panel)
- SSI interface for connection of absolute encoders
- B&R on-line interface
- 16 KBytes EEPROM application memory
- 16 KBytes additional EEPROM
- RS485 network (B&R MININET)
- Operator panels: MINICONTROL operator panel

Compact MMI P120 and MMI P121 Other products from the PANELWARE family

The controller is described in detail in the "B&R Compact PLC User's Manual" (MABRCOMP1-E).

### ORDER INFORMATION

Compact PLC with 6303 processor, 16 KBytes application memory, approx. 4 msec / K instructions, 16 digital inputs, 14 digital outputs, 2 analog inputs, 2 analog outputs, channel A and B for positioning tasks, reference input, event counter, interrupt input, B&R on-line interface, RS232 interface (not electrically isolated), RS232/RS485 interface (RS485 electrically isolated), PATA interface

without CAN Bus BRCOMP1-0 with CAN Bus BRCOMP2-0

### **ACCESSORIES**

### **RELAY EXPANSION CARD**

A relay expansion card can be obtained for the Compact PLC. It is described at the end of section A2 "B&R Compact PLC".

### **Order Information**

16 relay outputs in 8 groups (2 x 4, 2 x 2 outputs, 4 x 1 output), switching current max. 3 A per output / 6 A per group, switching voltage 240 VAC / 30 VDC, status LED

BRADREL1-0

### STANDARD SOFTWARE

A diskette with the most important standard software is put together especially for the Compact PLC. The following software is saved on the diskette:

- General Utilities (Standard Software Package 1)
- Operator Panel Software
- B&R MININET

### **Model Number**

1751	
German English	SWSPSBRC01-0 SWPLCBRC01-0
~~~	

### TERMINAL BLOCKS

A PHOENIX terminal block set can be ordered as an accessory (BRTB0218-0).

Pieces	Terminal Block	
2	8 pin	9
2	10 pin	13.7

### **TECHNICAL DATA**

ECHNICAL DATA	12/2	
- 1/1/1	400	22
Processor	6303	
Processing Time	approx. 4 msec / K instructions	
Application Program Memory	16 KBytes RAM/EEPROM	
Expansion Memory	16 KBytes EEPROM (for data)	
Status LED	red	
Number of Registers Remnant Non-remnant	7168 7148 20	
Number of Flags Remnant Non-remnant	800 300 500	
Time/Date	Real time Clock	
Software Timer	64	
Clock Pulses	10 msec, 100 msec, 1 sec, 10 sec	
Digital Inputs	16 of which 4 can be used as counter inputs	
Digital Outputs	14	
Analog Inputs	2	
Analog Outputs	2	
Serial Interfaces IF1 IF2 IF3 IF4 IF5	RS232 RS232/RS485 (RS485 electrically isolated) PATA (MINICONTROL operator panel, relay expansion card), SSI (connecting absolute encoders) B&R on-line interface CAN Bus (BRCOMP2-0)	
CAN Bus	only BRCOMP2-0	
Supply Voltage	24 VDC ±25 %	
Max. Power Consumption without Operator Panels at 18 V at 24 V at 30 V	6 W 6.5 W 7.5 W	
Fuse	T 1.25 A / 250 V	
Software and Hardware Watch	ndog YES	11.
Battery Monitor	YES	
Operating Temperature	5 to 55 °C	
Operating remperature		

### **NETWORKS / COMMUNICATION**

B&R MININET	YES	Ì
B&R NET2000	NO	
ARCNET	NO	
ETHERNET	NO	
CAN Bus	only BRCOMP2-0	
From Other Manufacturers	YES	

Also see section C "Industrial Networks and Communication".


### GENERAL INFORMATION, ACCESSORIES, **TECHNICAL DATA**

**PLC-SYSTEM B&R COMPACT PLC** 





### **MEASUREMENTS**



**RELAY EXPANSION CARD** 

A relay expansion card can be obtained for the Compact PLC. The measurements can be found at the end of section A2 "B&R Compact PLC".

### **INSTALLATION GUIDELINES**

The Compact PLC can be mounted either horizontally or vertically. When mounting it vertically, make sure that the digital inputs/outputs groups are facing the upwards. The distance to the neighboring module caused by the fastening bracket is enough to ensure sufficient air circulation.

The area below the Compact PLC is to be kept below the maximum operating temperature of 55 °C. A fan is not required to cool the unit.

Make sure that devices that create heavy electromagnetic disturbances (e.g. frequency converter, transformer, motor controller etc.) are at a sufficient distance. The distance from these devices to the PLC should be as large as possible. If necessary, they are to be separated with a magnetic shielding partition (VACOPERM<sup>a</sup> 70).

### MOUNTING

### **Two Possibilities**

- directly on the back panel of the enclosure
- on mounting rail


### Directly on the Back Panel of the Enclosure

The chassis is to be screwed onto the back panel of the enclosure with the four mounting holes making sure there is good contact with the back panel.

M5 screws are to be used (distance between holes: 80 \* 270 mm).

### On Mounting Rail

In order to mount the chassis on mounting rail (DIN EN 50022-35), the two accompanying mounting rail fasteners (type: KSA10) must be screwed onto the Compact PLC.






A2

# INSTALLATION, WIRING

**PLC-SYSTEM B&R COMPACT PLC** 

Install relay expansion card on the mounting rail. The mounting rail must be grounded!

Install a grounding clamp left and right of the relay expansion card. Ground the relay expansion card with the blade terminal provided.



### **WIRING**

Only copper wires with a cross section of max. 2.5 mm<sup>2</sup> (AWG12) and at least 0.14 mm<sup>2</sup> (AWG26) may be connected to the terminal blocks. Aluminum wire may not be used.

### **Allowable Wire Cross Sections**


	Connecting digital I/O	typ. 0.75 mm² max. 2.5 mm²
	Connecting analog I/O	min. 0.14 mm² max. 2.5 mm²
à	Interface cable TTY/RS485	0.5 mm² for D type connections 0.5 to 2.5 mm² for screw terminals
	Interface cable RS232	min. 0.14 mm <sup>2</sup> max. 0.5 mm <sup>2</sup> for D type connections max. 2.5 mm <sup>2</sup> for screw terminals

### Cable Types / Cable Duct

Fundamentally, there are three different types of cables:

- Interface cables and analog or counter signal cables. These cables are shielded.
- Connections used for digital inputs.
- Connection used for digital outputs.

These three types of cables should be separated. That means that running cables of different types parallel to each other should be avoided. If cables of different types must be run in the same cable duct, they should be separated with a grounded metallic partition. Optimally, the three types of cables should be run in their own cable ducts that are separated sufficiently or shielded from each other with a partition:



# GROUNDING, SHIELDING, PROTECTION CIRCUIT

PLC-SYSTEM B&R COMPACT PLC





### **GROUNDING / SHIELDING**

In most applications, PLCs are installed in cabinets along with electromagnetic switching devices (relays, contactors), transformers, motor controllers, frequency converters, etc... As a consequence, the equipment is exposed to electromagnetic disturbances of various types. Although these disturbances can not generally be prevented, appropriate grounding, shielding and other protective steps can prevent negative effects on the PLC. These protective steps include control cabinet grounding, module grounding, cable shield grounding, protective elements for electromagnetic switching devices, correct wiring as well as consideration of cable types and their cross sections.

Basically grounding has two different functions:

- Protective grounding
- Surge protective grounding to prevent electromagnetic disturbances.

### **Protective Grounding:**

Protective grounding is required for any device with a conductive housing where a high voltage can occur. If a defect causes contact between a high voltage line and the housing, the protective ground cable will generate a short circuit to ground and the power supply will be broken by the appropriate safety device. Protective grounding is required in most countries by statutory regulation (e.g. UL, CSA, VDE).

### Surge Protective Grounding to prevent electromagnetic disturbances:

In order to prevent limitation of the PLC's functionality due to electromagnetic disturbances, cable shields are grounded (see section "Cable Shielding).


### **CABLE SHIELD GROUNDING**

The following connections have to be made with shielded cables:

- analog 1/0
- interface cables
- encoder cables

Grounding the Compact PLC is done with metal screws or metallic plug housings. That way the disturbances from the cable shield will be grounded to the housing of the Compact PLC.

The shield is to be connected directly to the plug housing.



If the potential difference between the PLC and the connected elements generate transient currents in the cable shield, the following steps are to be taken: The cable shield is separated and bridged by a high quality capacitor (ceramic or foil capacitor with at least 47 nF and low impedance at high frequency).

### **PROTECTIVE ELEMENTS**

External protective elements are generally required for the relay expansion card and can be required under certain circumstances for transistor outputs (see "B&R Compact PLC User's Manual").

Protective elements can be installed either on the load to be switched, on the output module, or on terminals between. Most manufacturers of relays and solenoids offer protective elements for the respective devices.

The following components can be used:

- RC elements: Can be used for AC and DC 1)
- Varistors: these are usually used for AC. Since varistors wear out, the use of RC combinations is preferred.
- Diodes: these are used for DC only.
- Diodes/Z Diodes: these are used for DC only. This type of protective element permits shorter cutoff times. Are used especially for transistor outputs.

### STORAGE TEMPERATURES

The Compact PLC is to be stored in a temperature range from 0 to +60 °C.

### **ELECTROSTATIC DISCHARGE**

The Compact PLC contains highly integrated CMOS components that are sensitive to electrostatic discharge. Before handling the unit with an open housing cover (e.g. changing battery), the user needs to be electrostatically discharged by touching grounded metal.

 $<sup>^{10}</sup>$  Typical values for RC elements (10 W inductive load) are: 22  $\Omega/250$  nF at 24 VDC/AC or 220  $\Omega/1~\mu\text{F}$  at 20 VAC.





### **CPU**

# PLC-SYSTEM B&R COMPACT PLC

### **CPU**

### **TECHNICAL DATA**

Processor	MOTOROLA 6303
Processing Time	approx. 4 msec / K instructions
Number of Registers Remanent Non-remanent	7168 7148 20
Number of Flags Remanent Non-remanent	800 300 500
Time/Date	Real Time Clock
Software Timer	64
Clock Pulses	10 msec, 100 msec, 1 sec, 10 sec

#### **ON-LINE INTERFACE**

The Compact PLC uses an on-line interface for the communication with the programming device. The on-line interface is a TTY interface with 62.5 kBaud that is used for the on-line operation with the programming device.

PIN ASSIGNMENTS	Pin	Assignment	
O siz D toss	1	TXD	10
9 pin D-type	2	Reserved	
(M)	3	RXD Ret	
J1	4	Reset Ret	
6	5	Reserved	
•:	6	TXD Ret	
::	7	RXD	
	8	Reset	
. 🔾 5	9	Reserved	

On-line Cable	for On-line Interface	Programming PC	Bus Type/Port
BRKAOL-0	BRIFPC-0 BRKAOL5-1	IBM AT Compatible PCs Notebooks	ISA (PC/AT) CENTRONICS

### **INSTRUCTION SET**

A 6303 processor is used as the CPU of the Compact PLC. That is the same processor that is used as the MINICONTROL CPU.

If you need to change to the next higher controller system because of advanced requirements, the work you have accomplished concerning software will not be lost.

### DATA MEMORY

Flags (1 bit) and registers (8 bit) have distinctive characteristics. The contents of remanent memory remains in tact when the PLC is turned off (backup battery). Non-remanent memory is automatically erased when the unit is turned on (power-on).

Registers total remanent	710 714	
Flags total remanent	80 30	

### MATHEMATICS ROUTINES


The CPU of the Compact PLC is standardly equipped with fast floating point mathematics routines. In addition to the basic functions such as addition, subtraction, multiplication, division and square root, many conversion and utility programs are provided. The standard 4 byte IEEE format is used to represent numbers. The mathematics routines can be used in the ladder diagram (standard function blocks) and in STL programs.

### FIRST SCAN FLAG

The first scan flag is a flag (R 0899 and T D64) that is set to 1 automatically by the operating system during the first program cycle, otherwise this flag is 0. The first scan flag is used for program initialization. In ladder diagrams, the first scan flag is connected to the enable input of function blocks that are only to be executed once during the first program cycle.

### TIME CYCLES, TIME PULSES, SOFTWARE TIMERS

Time cycles are flags that provide an on/off signal. Time pulses are flags that are set to 1 for defined time intervals for the duration of one program cycle.



Software timers are flags that function as delays. The delay time is definable by the user.

The CPU of the Compact PLC has four time cycles and four time pulses (10 msec, 100 msec, 1 secand 10 sec each) as well as over 64 software timers.

### **REAL TIME CLOCK**

The CPU of the Compact PLC has a time and date function:

Туре	14.	Real time clock	200
Nonvo	latile	YES	
Time		Hour, min., sec., 1/100 sec.	
Date	The state of the s	Day, month, year, weekday	

### SAFETY AND DIAGNOSIS FUNCTIONS

The CPU of the Compact PLC is equipped with extensive safety and diagnosis functions. A software watchdog is provided. The CP32 CPU also has a hardware watchdog that is able to put the system in a safe operation mode, even if the CPU fails

An overview of the safety and diagnosis functions can be found in section "A1 - System Selection".

Software Watchdog	YES	
Hardware Watchdog	YES	
Application Program Test at Power-on	YES	
Hardware Reset	YES	
Trap Error Detection	YES	
Stack Pointer Test	YES	

### CPU, DIGITAL INPUTS


# PLC-SYSTEM B&R COMPACT PLC





### **POWER-ON SEQUENCE**

The CPU of the Compact PLC has the following power-on sequence:



### **DIGITAL INPUTS**

The digital inputs convert the process binary signals to the binary values 0 and 1. The states of the inputs are shown on green LEDs.


The Compact PLC is equipped 16 digital inputs (I 040 - I 04F). The inputs I 04C - I 04F can also be used for special applications:

- Event Counter
- Interrupt Input
- Reference Input
- Channel A and B for Positioning Applications

#### **TECHNICAL DATA**

_!	ECHNICAL DATA	
	Amount	16
	Туре	Type 1 according to IEC 1131-2
	Status Display	16 green LEDs
4	Electrical Isolation Input ↔ PLC Input ↔ Input	NO NO
	Input Voltage <sup>1)</sup> minimum nominal maximum	15 VDC 24 VDC 30 VDC
	Input Resistance	4 kΩ
	Switching Threshold log. $0 \rightarrow 1$ log. $1 \rightarrow 0$	min. 15 VDC max. 5 VDC
4	Input Current at 24 VDC	approx. 5 mA
	Switching Response Time Inputs 0 - F (log. 0 $\rightarrow$ 1, log. 1 $\rightarrow$ 0)	18 V: max. 4 msec 24 V: max. 2 msec 30 V: max. 1.6 msec
	Input Frequency Inputs C - F	max. 20 kHz
	Transfer of Inputs to CPU	automatically when they change
	Maximum Peak Voltage	500 V for 50 msec, max. every 100 msec 2)

### **INPUT DIAGRAM**



 $<sup>^{9}</sup>$  When using inputs C - F as counter inputs, the input voltage should be in the range of 24 VDC  $\pm$  10 %, then the maximum input frequency of 20 kHz can be reached.

<sup>2)</sup> Standard Pulse 1.2/50 (IEC 60-2)




# A2

# **DIGITAL INPUTS**

# PLC-SYSTEM B&R COMPACT PLC

### WIRING SCHEME FOR DIGITAL INPUTS




### **COUNTER INPUTS AND INTERRUPT INPUT**

Inputs C - F can also be used for special applications:

- Event Counter
- Interrupt Input
- Reference Input
- Channel A and B for Positioning Applications

In the following sections, the functions of the inputs are described once in graphic form (overview) and once in table form.

### Overview of the Functions




### **Functions of the Inputs**

Input	Function	$T_{d_{j_{1}}}$	72
С		e of counter 0. Counter 0 can be used in two e with the function block input MODE or in the	
	1) Event Counter 4 byte counter	er (0 - 4 294 967 295)	
	2) HW Counter 2 byte count	er (0 - 65535)	
	The hardware counter can be use if the counter reaches the value 0	ed to generate an interrupt. The interrupt is caul.	used
D NATA	Is used as reference pulse input or in MODE function block input or in the	nterrupt input. The definition is made with the mode register.	
	1) Reference Pulse Input:		
	Used to set the counter to a certa	in preliminary value.	
	2) Interrupt Input	17/2	
E	Decrements counter 1 or is used as made with the MODE function block	input A for two channel counting. The definition input or in the mode register.	n is
	1) Event Counter 4 byte counter	er (0 - 4 294 967 295)	
	2) Input A		
	Two channel operation with quad applications. Input E is connected	ruple evaluation can be used for positioning to the first channel.	
F	Decrements counter 2 or is used as made with the MODE function block	nput B for two channel operation. The definition input or in the mode register.	on is
	1) Event Counter 4 byte counter	er (0 - 4 294 967 295)	
	2) Input B		
	Two channel operation with quad applications. Input F is connected	ruple evaluation can be used for positioning	

### Wiring Schematic

Wiring schematic with up to 12 digital inputs, 3 counter inputs and 1 interrupt input:



### **Counter Operation**

The operation is carried out either with the CMDC function block or with a call from an operating system routine from the STL. The two methods can also be mixed together.

# **DIGITAL OUTPUTS**

# PLC-SYSTEM B&R COMPACT PLC





### **DIGITAL OUTPUTS**


Digital outputs are used to control external loads (relays, motors, solenoids etc.). The state of the outputs is shown with orange status LEDs.

The Compact PLC is equipped with 14 transistor outputs (O 050 - O 05D).

### **TECHNICAL DATA**


ECHNICAL DATA	
Amount	14
Status Display	14 orange LEDs
Electrical Isolation Output ↔ PLC	NO
Output ← Output	NO NO
Supply Voltage	76
minimum	18 VDC
nominal	24 VDC
maximum	30 VDC
Switching Current	700
50 % simultaneousness	1.0 A <sup>1)</sup>
100 % simultaneousness	0.5 A
Switching Delay	2/2
log. 0 → 1	approx. 200 msec
$\log. 1 \rightarrow 0$	approx. 200 msec
Residual Voltage of the Transistors	<1 V at 1 A
Protective Circuit <sup>2)</sup>	provided internally
Sustained Short Circuit Protection	YES
Overload Protection	automatically cut off with thermal overload
	77.7

### **OUTPUT DIAGRAM**



### WIRING SCHEMATIC

Another wiring schematic is shown in section "Supply Voltage".



If 1 A current is flowing with 50 % simultaneousness, the ambient temperature may not exceed 40 °C

<sup>&</sup>lt;sup>2)</sup> An external protection circuit may be necessary under certain circumstances (see "B&R Compact PLC User's Manual").



# **A2**

# **ANALOG INPUTS**

# PLC-SYSTEM B&R COMPACT PLC

### **ANALOG INPUTS**


Analog inputs convert measured values (current, voltage or temperature) into numerical values that can be processed by the PLC.

### TECHNICAL DATA

FECHNICAL DATA	
Amount	2
Galvanic Isolation	Differential inputs, not galvanically isolated
Common Mode Voltage	±12 V
Input Resistance	min. 10 MΩ
Dielectric Strength	±30 V max.
Resolution A/D Converter	16 Bit
Addressing	Operating system
Precision at 25 °C	Software compensation to ±0.01 % (10 Hz Notch)
Temperature Drift	±10 V range: ±0.03 %/°C ±0.9LSB/°C°) ±2.5 V range: ±0.02 %/°C ±3.5LSB/°C
Hardware Filter Cutoff Frequency Rolloff Step Response	approx. 110 Hz approx. 20 dB/Dec. 63 % in 1.4 msec
Software Filter Cutoff Frequency (1. Not	tch) 10 Hz, 50 Hz, 250 Hz, 1 kHz, software selectable
Conversion Times	302 msec (10 Hz), 62 msec (50 Hz), 16.2 msec (250 Hz), 4.1 msec (1 kHz
Calibration Time	902 msec (10 Hz), 183 msec (50 Hz), 48 msec (250 Hz), 11.7 msec (1 kHz
Damping 1st Order Notch	>100 dB
Operating Mode	Trigger (a calibration is performed after every notch frequency change and after a reset. After a reset, a notch frequency of 50 Hz is set again)
Input Voltage	±10 V /±2.5 V software selectable
Resolution Voltage Input	appr. ±14 Bit (10 Hz and 50 Hz), appr. ±12 Bit (250 Hz), appr. ±8 Bit (1 kHz
Current Measurement	an internal shunt must be used (124 $\Omega$ )
Resolution for 0 - 20 mA	appr. 14 Bit (10 Hz and 50 Hz), appr. 12 Bit (250 Hz), appr. 8 Bit (1 kHz
KTY10 Temperature Sensor Range of Measurement Linearization Resolution	-50 to +150 °C hardware ±0.3 °C in range from -10 to +110 °C 0.01 °C
10.	10-7

PIN ASSIGNMENTS	Pin	Assignment	
9 pin D-type	1	+ Input 1	70°
A. X	2	- Input 1	
(F)	3	GND	
5	4	- Input 2	
° 7601	5	+ Input 2	
	6	KTY 1	
°°	7	Shunt 1	
6	8	Shunt 2	
X	9	KTY 2	


### **INPUT DIAGRAM**



### SHIELD GROUNDING


Full metal screws or metallic plug housings provide the simplest and most effective solution for grounding the disturbances from the cable shield to the housing of the Compact PLC.

The shield is to be connected directly to the plug housing.



### WIRING SCHEMATIC

### Voltage Source



<sup>1)</sup> LSB ... Least Significant Bit

<sup>2)</sup> No voltage dropout monitor is possible for this connection.


# ANALOG INPUTS, ANALOG OUTPUTS

PLC-SYSTEM B&R COMPACT PLC






### **Current Source**



### KTY10 Sensor



### **OPERATION OF THE ANALOG INPUTS**

The analog inputs are initialized with the AINJ function block. The converted values and the alarm bits for range exceeding and signal failures are sent to outputs.

### **ANALOG OUTPUTS**


Analog outputs are used to convert internal numerical values from the PLC into currents and voltages.

### **TECHNICAL DATA**

	ECHNICAL DATA		
	Amount	2	110
Š	Revision	Short circuit protected	
24	Addressing	Operating system	
	Voltage Output	±10 V / 10 mA	
	Current Output	0 - 20 mA, load 50 $\Omega$ (400 $\Omega$ max.)	
	Resolution D/A Converter	12 Bit	
	Offset at 25 °C	Software compensation to ±1 LSB 2)	
	Offset Drift	±0.02 % of full scale / °C (±0.8 LSB/°C) <sup>2)</sup>	
. 6	Gain Error at 25 °C	Software compensation to ±0.5 %	
	Gain Drift	±0.02%/°C	
	Gain Error Load	0.01 %/Ω	
	Linearity	±1 LSB <sup>2)</sup>	
	Response Time Constant	<1 msec	
	Maximum Output Level During Reset (or before initialization)	±50 mV or -0.3 mA	HORIE

PIN ASSIGNMENTS	Pin	Assignment	
Onio Damo	1	V Output 1	
9 pin D-type	2	I Output 1	
(F)	3	n.c.	
5	4	V Output 2	
° 601	5	I Output 2	
000	6	GND	
00	7	n.c.	
6	8	n.c.	
70	9	GND	

### **OUTPUT DIAGRAM**



<sup>1)</sup> No current dropout monitor is possible for this connection.

<sup>2)</sup> LSB ... Least Significant Bit



# A2


### ANALOG OUTPUTS, IF1 - RS232 INTERFACE

**PLC-SYSTEM B&R COMPACT PLC** 

### SHIELD GROUNDING


Full metal screws or metallic plug housings provide the simplest and most effective solution for grounding the disturbances from the cable shield to the housing of the Compact PLC.

The shield is to be connected directly to the plug housing.




### WIRING SCHEMATIC

### Voltage Output



### **Current Output**



### **OPERATION OF THE ANALOG OUTPUTS**

The initialization of the analog outputs is carried out with the AOTF function block. The digital values to be converted are given to the function block via the inputs OUT 0 and OUT 1.


### **IF1 - RS232 INTERFACE**

### **TECHNICAL DATA**

Interface	RS232	
Galvanic Isolation	NO	
Connection	9 pin D-type (male)	
Max. Distance	max. 15 m, shielded cable	
Handshake Lines 1)	DSR, RTS	
Baudrate	300 - 19200 Baud	
Data Format Data Bits Parity Configuration	5 to 8 yes / no / even / odd software	
Supply for Compact	+5 V / 500 mA	
MMI P120 and MMI P121	.36	

PIN ASSIGNMENTS	Pin	Assignment	-40
9 pin D-type	1	n.c.	1/2
	2	RXD	
(F)	3	TXD	
5	4	+5 V / 500 mA	
y 6001	5	GND	
	6	n.c.	
ا ه ها	7	RTS	
6	8	DSR	
-1 7/10	9	n.c.	

### WIRING SCHEMATIC



### SHIELDING AND GROUNDING

Shielded cables must be used for interface connections. The cable shield is to be grounded on both sides.

### **COMPACT MMI P120 AND MMI P121**

The Compact MMI P120 and MMI P121 operator panels are available for the Compact PLC. They are connected to the IF1 interface. The supply voltage is fed through pin 4.

### **Connection Cable**

From	To	Length	Model Number
Compact PLC Compact MMI	Compact MMI PC	1.5 m 2.5 m	BRACOMP1-0 0G0003.00-090
Compact WIVII	10	2.0 111	000003.00-030

The DTR signal can be built from RTS with the corresponding operation of the interface blocks.

# IF2 - RS232/RS485 INTERFACE

**PLC-SYSTEM B&R COMPACT PLC** 





### IF2 - RS232/RS485 INTERFACE


### **TECHNICAL DATA**

Interface	RS232	RS485	
Galvanic Isolation	NO	YES	
Max. Distance	max. 15 m, shielded cable	max. 1200 m, shielded twisted pair	
Handshake Line <sup>1)</sup>	DSR, RTS		
Connection	9 pin D-t	ype (female)	
Baudrate	300 - 1	9200 Baud	
Data Format Data Bits Parity Configuration	yes / no	5 to 8 / even / odd ffware	


PIN ASSIGNMENTS	Pin	RS	232	RS485
9 pin D-type	J 1	G	ND	27
	2	R	TS X	
(F)	3	T.	XD	
5	4	R	XD	
1/60	5			DATA
	6			Enable
	7			GND 2)
6	8			DATA
0	9	D	SR	

### WIRING SCHEMATIC

### **RS232 Interface**



### **RS485 Interface**



### SHIELDING AND GROUNDING

A shielded cable must be used for interface connections. The cable shield is to be grounded on both sides.

Pin 6 (Enable) must be connected with GND on pin 7 for RS485 operation. This is to be taken into consideration when wiring with a standard cable (standard: connect pin 6 with pin 1).



# A2

### IF3 - PATA/SSI INTERFACE, IF5 - CAN BUS

PLC-SYSTEMS
B&R COMPACT PLC

### **IF3 - PATA/SSI INTERFACE**

The IF3 interface is a modified RS422 interface. MINICONTROL operator panels (PATA interface) or absolute encoder (SSI interface) can be connected here.

PIN ASSIGNMENTS	Pin	Assignments	
9 pin D-type (F)	1 2 3 4 5 6 7 8	DATA IN DATA IN Reset GND +24 V DATA OUT DATA OUT CLK CLK	MANIGORIA

### SHIELDING AND GROUNDING

Shielded cables must be used for interface connections. The cable shield is to be grounded on both ends.

### **PATA INTERFACE**

The operation of the software for the MINICONTROL operator panel is described in "Operator Terminals User's Manual" (MATERM2-E).

The standard software package 2 SWSPSSTD02-0 (starting with rev. 00.31) is available from B&R for the control of the MINICONTROL operator panel. The operator panel software is also saved on the standard software diskette SWSPSBRC01-0 for the Compact PLC.

The operation is carried out with function blocks and by setting table parameters.

### SSI INTERFACE

The following conditions must be met in order to connect absolute encoders on the SSI interface:

- Absolute encoders with a monoflop time between 20 μsec and 260 μsec can be used
- Absolute encoders with a maximum 24 Bit (AG24) or 32 Bit (AG32) can be read.

The function blocks AG24 and AG32 are provided for the operation. They are contained in the standard software package 4 SWSPOS01-0 (starting with rev. 00.32).

### **IF5 - CAN BUS**

Also See Section C4 "CAN Bus".

The Compact PLC **BRCOMP2-0** (Operating System Version 4.1) is equipped with a CAN Bus interface according to ISO-DIS 11898. The connection assignments correspond to CiA DS 102-1.

PIN ASSIGNMENTS	Pin	Assignment	
9 pin D-type	1	747	
(M)	3	CAN L CAN GND	
6	4 5		
9	6 7 8	CAN H	
`5	9	Saga,	

### **CABLING**

The cabling is made in a bus structure. Both ends of the bus are to have a termination resistor. A node can be connected to the bus with a branch line. The length of the branch line may not be more than 30 cm.


A 4 wire twisted pair cable is to be used for the bus cable

### **CAN Signal**


CAN H	CAN High
CAN L	CAN Low
CAN GND	CAN Ground
CAN+	CAN Supply 8 - 15 V

Since all of the CAN interfaces from B&R are supplied internally, CAN+ is not connected.

### **Cabling Principle**



### **BLOCK DIAGRAM OF A NODE**



# IF5 - CAN BUS, LITHIUM BATTERY, APPLICATION-EEPROM, SUPPLY VOLTAGE

PLC-SYSTEMS
B&R COMPACT PLC





### **OPERATION OF THE CAN BUS**

The CAN Bus operates via the function blocks CNSW and CNCS. The function blocks are contained as standard software.

#### 3.5 "-Diskette(s)

German English	SWSPSCAN01-0 SWPLCCAN01-0	99/g.,
	ACV.	VC.

#### **CNSW - CAN Node Switch**

The function block reads the switch position of both of the Hex switches and gives them to the CAN Client/Server function block CNCS. Additionally, each switch position is output directly as a value between 0 - 15. The function block CNSW makes connecting the same program for different Client Stations easier. The switches can be found between the interface connector and the inputs.

### CNCS - CAN Client/Server

The function block makes communication over a standard CAN network (11 Bit-ID) possible via CAL/CMS utilities for transferring object data. No layer or network management utilities and no identifier distribution utilities are supported.

That means, it concerns an LMT/NMT/DBT class 0 slave with static CAN ID distribution that corresponds to CAL. The communication takes place via the CMS protocol for variables and for "uncontrolled events".

The Client/Server utilities for "Read-Only Access, Basic Variable" are not implemented. Only integers in multiples of bytes are supported from the CMS data types.

Transfer data (max. 8 Bytes) is transferred over the bus in incrementing byte order (LSB to MSB) (Little Endian).

#### Abbreviation

CAL	10	CAN Application Layer	
CMS		CAN Based Message Specification	
LMT		Layer Management	
NMT		Network Management	
DBT		Communication Object Distributor	

### LITHIUM BATTERY

The Compact PLC is equipped with a lithium battery. It is required to buffer the SRAM and the real time clock.

### **ADDITIONAL APPLICATION EEPROM**

The user is provided with 16 bytes of this EEPROM. It is divided into 8 2 Kbyte blocks.

Reading or writing data is carried out with the MCEE function block

### SUPPLY VOLTAGE

The DCOK LED shows that controller is being supplied with power. There are two possibilities for supplying power to the Compact PLC:

One Power Supply:

- Supply for all inputs and outputs

Two Power Supplies:


- One for the controller
- One for the digital outputs

#### ONE POWER SUPPLY

The standard procedure is to use one power supply for the Compact PLC (see section "Digital Outputs" for switching).

### **TWO POWER SUPPLIES**


Controller and outputs are supplied separately.



### FUSE

The Compact PLC is protected with a (250 V / 1.25 AT) fuse. The socket for the fuse can be found under the terminal block for the digital outputs.

The digital outputs are supplied separately. The feed must have it's own fuse (see sections "Supply Voltage" and "Digital Outputs").



<sup>1) 10</sup> A fuse (slow burn) to protect the connector in case of a short circuit or reverse polarization.



# A2

# **RELAY EXPANSION CARD**

**PLC-SYSTEMS B&R COMPACT PLC** 

### **RELAY EXPANSION CARD**

A relay expansion card is available for the Compact PLC which adds an additional 16 relay outputs to the 14 transistor outputs that already exist (O  $\,060$  -O 06F).

The Compact PLC and the relay expansion card can be mounted either beside each other or piggyback (one on top of the other).

The connection to the controller is made with the cable BRKA08-0 via the PATA interface. The cable must be ordered separately.

The DOUC function block transfers the output states to the relay expansion card.


### **RELAY GROUPS**

Group	Outputs	Type
1 (1)	4	N.O.
2	4	N.O.
3	2	N.O.
	2	N.O.
5		N.O.
6		N.O.
7	1	Switching
8	1	Switching

CHNICAL DATA	Kar.
Number	16
Туре	relay
Number of Groups	8
Switching Voltage	5 - 240 VAC, 50/60 Hz 5 - 30 VDC
Switching Current per Output per Group	max. 3 A max. 6 A
Switching Delay log. $0 \rightarrow 1$ log. $1 \rightarrow 0$	approx. 10 msec approx. 15 msec
Reverse Voltage Divider	external from user
Switching Play mechanical electrical	> 2 x 10° > 1 x 10°
Relay Supply	24 VDC ±15 %, max. 400 mA
Operating Temperature	0 to 55 °C
Relative Humidity	0 - 95 % non-condensing

PIN	ASSIGNMENTS	Pin	Assignment	
	"ulu.	1 2	GND (O 060 - O 063) Output 0	24
	<b>(10)</b>	3	Output 1	
	<b>□</b>    <b>⊘</b>    2	4	Output 2	
	<b>3</b>	5	Output 3	
	4   5	6	GND (O 064 - O 067)	
		7	Output 4	
		8	Output 5	
		9	Output 6	
	9 10	10	Output 7	
		11	GND (O 068 - O 069)	
	11	12	Output 8	
	12	13	Output 9	
	□ 3	14	GND (O 06A - O 06B)	
	<b>□</b> 14	15	Output A	
	15   0 16	16	Output B	
		17	GND (O 06C)	
	[S] 17	18	Output C	
	18	19	GND (O 06D)	
	20	20	Output D	
	21			
	22	21	GND (O 06E)	
	<b>□</b> 8 23	22	Output E - N.O.	
	24	23	Output E - N.C.	
	26	24	GND (O 06F)	
	-1470	25	Output F - N.O.	
		26	Output F - N.C.	

### MEASUREMENTS



# **RELAY EXPANSION CARD**

### PLC-SYSTEMS B&R COMPACT PLC





### **INSTALLATION GUIDELINES**

The relay expansion card can be mounted either horizontally or vertically. The distance to the neighboring module caused by the fastening bracket is enough to ensure sufficient air circulation.

The relay expansion card is to be kept below the maximum operating temperature of 55  $^{\circ}\text{C}$  . A fan is not provided in the housing.

### MOUNTING

### Two Possibilities

- directly on the back panel of the enclosure
- on mounting rail


### Directly on the Back Panel of the Enclosure

The chassis is to be screwed onto the back panel of the enclosure with the four mounting holes making sure there is good contact with the back panel.

M5 screws are to be used (distance between holes: 80 \* 270 mm).


### On Mounting Rail

In order to mount the chassis on mounting rail (DIN EN 50022-35), the two accompanying mounting rail fasteners (type: KSA10) must be screwed to the relay expansion card.



Install relay expansion card on the mounting rail. The mounting rail must be grounded!

Install a grounding clamp left and right of the relay expansion card. Ground the relay expansion card with the blade terminal provided.





# **RELAY EXPANSION CARD**

**PLC-SYSTEMS B&R COMPACT PLC** 

### **COMPACT PLC AND RELAY EXPANSION CARD**

The Compact PLC and the relay expansion card can be mounted either beside each other or piggyback (one on top of the other).


### 1. Beside Each Other

If the two housings are mounted next to each other, please follow installation and mounting instructions given.


### 2. Piggyback

With this type of installation, the relay expansion card is first mounted either directly on the back panel of the enclosure or on the mounting rail (see instructions). Then the Compact PLC is fastened to the relay expansion card with the two mounting plates.


The mounting plates are included with the delivery of the relay expansion card.



### **RELAY SUPPLY**



### **SWITCHING CIRCUIT**




### CONNECTION TO THE COMPACT PLC

The connection to the Compact PLC is made with the cable BRKA08-0 via the PATA interface. The cable must be ordered separately.

**PLC-SYSTEMS B&R COMPACT PLC**  **A2** 



NOTES:





PLC SYSTEMS
MINICONTROL SYSTEM



# **CONTENTS**

PLC SYSTEMS MINICONTROL SYSTEM





# A3 MINICONTROL SYSTEM

CONTENTS	192	122	43
GENERAL INFORMATION			
PERFORMANCE DATA			44
SLOTS	1000	X02*	44
MODULE OVERVIEW I/O MODULES			44
INSTALLATION GUIDELINES			45
WIRING	4,	4,	45
GROUNDING AND SHIELDING			46
CABLE SHIELD GROUNDING			46
PROTECTIVE ELEMENTS	.0.X		47
STORAGE TEMPERATURES			47
ELECTROSTATIC DISCHARGE			47





# GENERAL INFORMATION, PERFORMANCE DATA

PLC SYSTEMS
MINICONTROL SYSTEM

### **GENERAL INFORMATION**

System details can be found in the "MINICONTROL Hardware Manual".

The MINICONTROL system is designed for small to medium applications. Because of its network capabilities, it can also be applied in larger automation systems. The MINICONTROL is a very powerful and efficient PLC in spite of its compact size (W x H x D: 256 x 155.5 x 93.5 mm) providing logic functions as well as visualization, positioning, control and data management.

Programming is done with the B&R PROgramming SYStem.

### **PERFORMANCE DATA**

CPU	CP30	CP32
Microprocessor	MOTOROLA 6303	MOTOROLA 6303
Application Program Memory	16 KByte (RAM/EEPROM) Max. 4.7 K inst.	16 KByte (RAM/EEPROM) Max. 4.7 K inst.
EEPROM Expanded Memory	- 🔉	32 KByte
Processing Time	ca. 4 msec / K inst.	ca. 4 msec / K inst.
Data Memory 8 Bit Memory (Register) 1 Bit Memory (Flag)	7168 800	7168 800
Time/Date	Software Clock	Real-Time Clock
Interfaces	TTY	TTY/RS485


### INPUTS/OUTPUTS

Digital Inputs/Outputs	Max. 192	
Analog Inputs/Outputs	Max. 16	


### NETWORKS/ COMMUNICATION

B&R MININET	YES	
B&R NET2000	NO	
ARCNET	YES	
ETHERNET	NO	
CAN Bus	NO	
Other Connections	YES	

### DIMENSIONS



### **SLOTS**



### **MODULE OVERVIEW I/O MODULES**

[	DIGITAL I	O MODULES	Slots	0	1	2	3	4	5
	E16A	16 Inputs 24 VDC		•	•	•	•	•	•
	MAEA	8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A		•	•	•	•	•	•
	MAEB	16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A		10/10/	•	•	•	•	•
	A12A	12 Relay Outputs 220 VAC / 2 A		1)	1)	•	•	•	•
	A12B	12 Transistor Outputs 24 VDC / 0.5 A		1)	1)	•	•	•	•4
	A12C	12 Transistor Outputs 24 VDC / 2 A		1)	1)	•	•	•	•

A	NALOG I	O MODULES	Slots	0	1	2	3	4	5
	PEA4	4 Inputs 0 - 10 V / 0 - 20 mA (10 Bit)	, Š	· •	•				
	PEA8	4 Inputs 0 - 10 V / 0 - 20 mA (10 Bit), 4 Outputs 0 - 10 V / 0 - 20 mA (8 Bit)		•	•				
	PT41	4 Inputs for PT100 Sensor (10 Bit, 3/4	wire)	•	•				
	PTA2	2 Inputs for PT100 Sensor (10 Bit, 3 w 2 Outputs 0 - 10 V (8 Bit)	ire),	•	٠				
	PTE6	6 Inputs for Thermoelement (±50 mV, (NiCrNi Type K, FeCuNi Type F and J	,	OU OF	•				
	PTE8	8 Inputs for KTY10 Sensor (16 Bit)		•	•				
	PRTA	4 Inputs 0 - 10 V / 0 - 20 mA (10 Bit)	127.	•	2)				N

Digital output modules A12A, A12B and A12C can be operated in slot 0 of base unit A.

<sup>&</sup>lt;sup>2)</sup> Analog input module PRTA can also be operated in slot 1, if slot 2 is left empty.

# INSTALLATION GUIDELINES, WIRING

# PLC SYSTEMS MINICONTROL SYSTEM





### **INSTALLATION GUIDELINES**

The MINICONTROL rack may not be mounted vertically. At least 10 cm must be left free above and below the housing. The cooling vents must not be covered.

The maximum operating temperatures shown for each module in section "Technical Data" (usually 60 °C) must not be exceeded. No external ventilation fan is required.

For devices that cause heavier electromagnetic disturbances (e.g. frequency converter, transformers, motor regulators, etc.) should be situated as far away from the PLC as possible. Metal shielding (MU metal) may be required.

### Module Installation/Removal

The following guidelines apply for the installation or removal of all modules:

- Modules are generally not to be inserted or removed if the PLC is under power.
- Before removing modules, wired connectors should be removed.
- Terminations having lines carrying a voltage are not to be inserted or removed while under power.
- For safety reasons, you must wait a certain amount of time between disconnecting any terminations and removing the module. This is especially noted in the respective module description.

The following sequence is to be used when installing a module:

- Power down all incoming lines
- Remove all connectors
- Remove application memory module
- Remove fastening screws for the front cover
- Remove front cover
- Insert module
- Remove dummy cover from the front cover
- Insert pop-in module front into the front cover
- Fasten front cover again
- Insert application memory module
- Connect all lines

### Configuring the Module Rack

Slots 0 and 1 are suitable for operating P modules (analog I/O modules, counter modules) in MINICONTROL base unit<sup>1)</sup> C. Digital I/O modules and time modules can be operated in all 6 slots (possible exceptions are described in the respective module description).

When configuring the rack, a few standard configuration guidelines are to be kept in mind. Digital output modules which are sometimes under heavy load, are to be kept to the right in the rack. The recommended installation sequence is from left to right:

- Interface modules
- Analog I/O modules, counting and positioning modules
- Time modules
- Digital input modules
- Digital output modules

### **WIRING**

Only copper wire with a cross section of max  $2.5\,\text{mm}^2$  (AWG12)<sup>2)</sup> and min.  $0.14\,\text{mm}^2$  (AWG26) may be connected to the termination blocks. Aluminium wire is not to be used under in any circumstances.

#### **Permitted Wire Cross Sections**


typ. 0.75 mm <sup>2</sup> max. 2.5 mm <sup>2</sup>	
min. 0.14 mm² max. 2.5 mm²	and.
0.5 mm² for DSU 0.5 to 2.5 mm² fo	
min. 0.14 mm <sup>2</sup> max. 0.5 mm <sup>2</sup> for max. 2.5 mm <sup>2</sup> for	r DSUB connections r terminal blocks
	max. 2.5 mm² min. 0.14 mm² max. 2.5 mm² 0.5 mm² for DSL 0.5 to 2.5 mm² for min. 0.14 mm² max. 0.5 mm² for

#### Types of Cable / Cable Channels

Basically there are three different types of cable:

- Interface cable and cable that carries analog signals or counter signals. These cables are to be shielded.
- Lines carrying digital input signals.
- Digital output lines.

These three types of should be kept apart from one another. This means that running cables of different types in parallel is to be avoided. If different types of cable must be run in the same cable channel, an attempt should be made to separate the two types with a metallic ground partition. Ideally, each type should be run in its own channel apart from the others or separated with a partition:



<sup>1)</sup> Refer to section A4 - "MINICONTROL Components / Base Units"

<sup>&</sup>lt;sup>2</sup> Since 1991 terminal connectors suitable for a maximum of 2.5 mm<sup>2</sup> (AWG 12) wire cross section are delivered. Older models allowed wire cross sections of maximum 1.5 mm<sup>2</sup> (AWG 14). The maximum allowed wire cross section is printed on the terminal block.



# A3

# GROUNDING, SHIELDING

PLC SYSTEMS
MINICONTROL SYSTEM

### **GROUNDING AND SHIELDING**

In most applications, PLCs are installed in cabinets along with electromagnetic switching devices (relays, etc.) transformers, motor regulators, frequency converters among others. As a consequence, the equipment is exposed to electromagnetic disturbances of various types. Although these disturbances cannot generally be prevented, appropriate grounding, shielding and other protective steps can prevent negative effects on the PLC. These protective steps include control cabinet grounding, module grounding, cable shield grounding, protective elements for electromagnetic switching devices, correct wiring as well as consideration of cable types and their cross sections.

Basically grounding has two different functions:

- Protective grounding
- Rerouting electromagnetic disturbances


### **Protective Grounding**

Protective grounding is required for any device with a conductive housing where high voltages may exist. If a defect causes contact between a high voltage line and the housing, the protective ground cable will generate a short circuit to ground and the power supply will be broken by the appropriate safety device. Protective grounding is required in most countries by statutory regulation (e.g. UL, CSA, VDE).

Since the MINICONTROL rack is made of nonconductive ploadic, protective grounding is not required.

### Rerouting Electromagnetic Disturbance

Electromagnetic disturbance can cause restricted functionality of the PLC. In order to avoid this, cable shields and modules are grounded. A ground rail is run under the module rack in most cases. The ground rail should be conductively attached to the cabinet. All cable shields and module terminals that require grounding must be connected to the ground rail (e.g. analog modules, power supply modules):



The distance between the ground rail and the PLC module rack should be a short as possible, not exceeding 15 cm. No electromagnetic elements (relays, contacts, etc.) may be located between the rail and the rack. Normally a cable channel is mounted directly beneath the rack housing.

### **CABLE SHIELD GROUNDING**

The following connections are to be made with a grounded cable shield (any exceptions are noted in the description for the respective module):

- Analog I/O
- Interface Cables
- Encoder Cables
- Connections for external potentiometers for time modules

The cable shielding is to be well grounded at both ends. The cable shield is to be grounded to the ground rail under the housing on the PLC end:



If the potential difference between the PLC and the connected elements generate transient currents in the cable shield, the following steps are to be taken: the cable shield is separated and bridged with a high quality capacitor (ceramic or foil capacitor with at least 47 nF and low impedance at high frequency).

# PROTECTIVE ELEMENTS, ELECTROSTATIC DISCHARGE

PLC SYSTEMS
MINICONTROL SYSTEM





### **PROTECTIVE ELEMENTS**

External protective elements are generally required for a relay output module and recommended for transistor output modules.

Module	Туре	<b>External Protective Elements</b>
A12A	Relay Output	Generally Required
A12B	Transistor Output	Recommended
A12C	Transistor Output	Recommended
MAEA	Transistor Output	Recommended
MAEB	Transistor Output	Not Required

Protective elements can be installed either on the load to be switched, on the output module or on terminals in between. Most manufacturers of relays and solenoids offer protective elements for the respective devices.

The following can be used:

- RC combination: can be used for AC or DC. 1)
- Varistor: Usually used for AC. Since varistors wear out, the use of RC combinations is usually preferred.
- Inverse Diode: Only for DC use.
- Diodes/Z Diode combination: Only for DC use. This type of protection permits shorter cutoff times.

### STORAGE TEMPERATURES

Modules that are not backed with buffer batteries or rechargeable batteries can be stored between -20 and +80 °C. Modules with batteries may be stored under temperatures of 0 to +60 °C.

PLC modules contain highly integrated CMOS components that are sensitive to electrostatic discharge. Before handling modules, the user should be electrostatically discharged by touching grounded metal.

**ELECTROSTATIC DISCHARGE** 

Typical values for protective RC combinations (ca. 10 W inductive load) are: 22  $\Omega$ /250 nF at 24 VDC/AC or 220  $\Omega$ /1  $\mu$ F at 220 VAC.



## CONTENTS

PLC SYSTEMS
MINICONTROL COMPONENTS

# **CONTENTS**

PLC SYSTEMS
MINICONTROL COMPONENTS





# A4 MINICONTROL COMPONENTS

CONTENTS			48
SLOT OVERVIEW	<i></i>		50
I/O MODULE OVERVIEW			50
SLOTS AND MODULES			50
OPERATING TEMPERATURES / RELATIVE HUMIDITY			50
BASE UNITS			51
GENERAL INFORMATION			
CPUS			
HOUSING			
POWER SUPPLY MODULE			
APPLICATION PROGRAM MEMORY MODULE	0	700	54
		7/0	77.50
DIGITALE INPUT/OUTPUT MODULES		24	
E16A - 16 INPUTS 24 VDC			N
MAEA - 8 INPUTS 24 VDC, 6 OUTPUTS 24 VDC / 0.5 A			
MAEB - 16 INPUTS 24 VDC, 16 OUTPUTS 24 VDC / 0.5 A			
A12A - 12 RELAY-OUTPUTS 220 VAC			
A12B / A12C - 12 TRANSISTOR-OUTPUTS 24 VDC			
ANALOGE INPUT/OUTPUT MODULES			62
PEA4 - 4 INPUTS 0 - 10 V / 0 - 20 mA	<u> </u>		63
PEA8 - 4 INPUTS, 4 OUTPUTS 0 - 10 V / 0 - 20 mA			64
PT41 - 4 INPUTS FOR PT100 SENSOR	<u></u>		65
PTA2 - 2 INPUTS FOR PT100 SENSOR, 2 OUTPUTS 0 - 10 V	4,		66
PTE6 - 6 INPUTS FOR THERMOELEMENT ±50 mV			67
PTE8 - 8 INPUTS FOR KTY10 SENSOR			68
PRTA - 4 INPUTS 0 - 10 V / 0 - 20 mA, REAL-TIME CLOCK			69
INTERFACE MODULES			
PIFA - SERIAL RS232 INTERFACE			
PATA - MINICONTROL OPERATOR PANEL / SSI INTERFACE C	ONTROL		73
COUNTING AND POSITIONING MODULES			
PNC4 - COUNTER MODULE FOR POSITIONING APPLICATION			
PZL2 - COUNTER MODULE FOR EVENT COUNTING			
PSA2 - POSITIONING MODULE FOR STEPPER MOTORS			77
OTHER MODULES			
			70






# SLOTS, MODULES

PLC SYSTEMS
MINICONTROL COMPONENTS

### **SLOT OVERVIEW**




### **MODULE OVERVIEW I/O MODULES**

DIGITAL	I/O MODULES	Slot	0	1	2	3	4	5
E16A	16 Inputs 24 VDC		•	•	•	•	•	•
MAEA	8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A		•	•	•	•	•	•
MAEB	16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A		•	•	•	•	•	<u></u>
A12A	12 Relay Outputs 220 VAC / 2 A		1)	1)	•	٠	•	•
A12B	12 Transistor Outputs 24 VDC / 0.5 A		1)	1)	•	•	•	•
A12C	12 Transistor Outputs 24 VDC / 2 A		1)	1)	•	•	•	•


ANALOG	I/O MODULES	Slot	0	1	2	3	4	5
PEA4	4 Inputs 0 - 10 V / 0 - 20 mA (10 Bit)		•	•			Š	10,
PEA8	4 Inputs 0 - 10 V / 0 - 20 mA (10 Bit), 4 Outputs 0 - 10 V / 0 - 20 mA (8 Bit)		•	•				
PT41	4 Inputs for PT100 Sensor (10 Bit, 3/4)	wire)	•	•				
PTA2	2 Inputs for PT100 Sensor (10 Bit, 3 wi 2 Outputs 0 - 10 V (8 Bit)	re),	•	•				
PTE6	6 Inputs for Thermoelement (±50 mV, 1 (NiCrNi Type K, FeCuNi Type F and J)	,	•	•				
PTE8	8 Inputs for KTY10 Sensor (16 Bit)		•	•				
PRTA	4 Inputs 0 - 10 V / 0 - 20 mA (10 Bit)		•	2)	g.			

### **SLOTS AND MODULES**

The MINICONTROL system has two slots for a power supply module and a CPU as well as 6 slots for application modules.



The application slots are numbered 0 to 5 from left to right. These numbers can be seen on the front cover above the module slot.



Slot 0 is between the power supply module and the CPU. Slots 1 to 5 are to the right of the CPU. Shown below is an overview of MINICONTROL modules and the slots in which they can be operated:

				S	lot						
Module	Function	0	1	2	3	4	5				
E16A	Digital Input Module	•	3	•	•	•	•				
A12A	Digital Output Module	Α	Α	•	•	•	•				
A12B	Digital Output Module	Α	Α	•	•	•	•				
A12C	Digital Output Module	Α	Α	•	•	•	•				
MAEA	Digital Input/Output Module	С	•	•	•	•	25				
MAEB	Digital Input/Output Module	С	•	•	•	•	• 1				
PEA4	Analog Input Module	0	0								
PEA8	Analog Input/Output Module	0	0								
PT41	Analog Input Module (PT100)	0	0								
PTA2	Analog Input/Output Module	0	0								
PTE6	Analog Input Module	0	0								
PTE8	Analog Input Module	0	0								
PRTA	Analog Input/Real-Time Clock Module	0	0								
PIFA	Interface Module	0	0								
PATA	Interface Module		•	•	•	•	•				
PNC4	Counting/Positioning Module	0	0								
PSA2	Counting/Positioning Module	0	0								
PZL2	Counter Module	0	0								
MZEA	Digital Input/Timer Module	•	•	•	•	•	•				
MZEB	Digital Input/Timer Module	•	•	•	•	•	•				

- The module can be operated in all MINICONTROL base units
- The module can only be operated in base unit C
   The module can only be operated in base unit A and in this slot
- C The module can only be operated in base unit C and in this slot

### **OPERATING TEMPERATURE / RELATIVE HUMIDITY**

The following tasks apply to all MINICONTROL components as long as no other values are given in the "TECHNICAL DATA" section:

Operating Temperature	0 to 60 °C
Relative Humidity	0 to 95 %, non-condensing

<sup>1)</sup> The digital output modules A12A, A12B and A12C can also be operated in slots 0 and 1 of base unit A.


The analog input module PRTA can be operated in slot 1, if slot 2 is not being used.

# PLC SYSTEMS MINICONTROL COMPONENTS





### **GENERAL INFORMATION**



The components required for operating the MINICONTROL system are combined in what is called the base unit. This base unit consists of:

- The CPU
- The housing
- The power supply module
- The application program memory module

Three base units with two different CPUs exist for the MINICONTROL system:

Base Unit	Model Number	CPU
A	MCGE31-0	CP30
С	MCGE232-022	CP32
С	MCGE232-022M	CP32

### ORDER DATA

### MCGE31-0

MINICONTROL Base Unit A, consisting of housing, CPU CP30, power supply module NT33 and application program memory module (16 KByte RAM, 16 KByte EEPROM for 4.7 K instructions), 6 slots for digital I/O modules and timer module


### MCGE232-022

MINICONTROL Base Unit C, consisting of housing, CPU CP32, serial RS485/TTY application interface, real-time clock, 32 KByte EEPROM additional memory (data), power supply module NT33 and application program memory module (16 KByte RAM, 16 KByte EEPROM for 4.7 K instructions), 6 slots for digital I/O modules and timer module -2 of which are suitable for operating analog I/O modules, interface modules and counter modules

### MCGE232-022M

MINICONTROL Base Unit C, consisting of housing, CPU CP32, serial RS485/TTY application interface, real-time clock, 32 KByte EEPROM additional memory (data), power supply module NT33 and combination of network capable on-line interface modules with modem interface and application program memory module¹¹ (16 KByte RAM, 16 KByte EEPROM for 4.7 K instructions), 6 slots for digital I/O modules and timer modules - 2 of which are suitable for operating analog I/O modules, interface modules and counter modules

### **CPUS**



The most important technical data and points of interest for the two MINICONTROL CPUs are:

Technical Data	CP30	CP32
Application Program Memory	16 KByte 4.7 K Inst.	16 KByte 4.7 K Inst.
EEPROM Expansion Memory (Data)	41.ID.	32 KByte
Processing Time	4 msec/K Inst.	4 msec/K Inst.
8 Bit Data Memory Total Remnant	7168 7148	7168 7148
1 Bit-Data Memory Total Remnant	800 300	800 300
Microprocessor	MOTOROLA 6303	MOTOROLA 6303
Application Interface	<i>I</i> <sub>1</sub> ,	TTY/RS485 (Switchable)
Time/Date	Software Clock	Real-Time Clock
Software Timers	64	64
Digital I/O Modules Analog I/O Modules Interface Modules Counter/Positioning Modules	6 - - -	6 2 2 2
	4.	"Gli,

### **On-line Interface**

The CPU uses an on-line interface (9 pin D-type Male) for communication with the programming device (=on-line operation). The on-line interface is a TTY interface with 62.5 kBaud which can only be used for on-line operation with the programming device. The on-line interface is labelled PG on the front of the module. An on-line cable is required for on-line operation:

ħ.	On-line Cable	For On-line Interface	Programming PC	Bus Type/Port
	BRKAOL-0	BRIFPC-0	IBM AT compatible PCs	ISA (PC/AT)
		BRKAOL5-1	Notebooks	CENTRONICS

The combination of network capable on-line interface module with modem interface and application program memory module is described in section A7 "PLC Programming / On-line Networks and Diagnosis Over Modem".





# PLC SYSTEMS MINICONTROL COMPONENTS

#### **Application Interface**

The CP32 CPU is equipped with a user interface (application interface).

CPU	Interface	
CP32	RS485 or TTY, switched by means of software	

#### Command Set

A MOTOROLA 6363 processor is used in MINICONTROL CPUs. This is the same processor which is also used in the COMPACT controller as well as in the CP40 and NTCP33 CPUs. This guarantees full software compatibility to the other PLC systems.

#### Memory

Flags (1 Bit) and registers (8 Bits) have separate distinctive characteristics. The contents of remnant memory locations is not lost if the PLC is switched off (battery in the power supply module). Non-remnant memory locations are automatically deleted when the unit is switched on (power-on).

-279		
8 Bit Memory Locations (Re	egisters)	
Total	7168	
Remnant	7148	
1 Bit Memory Locations (Fl	ags)	
Total	800	
Remnant	300	

### Mathematics Instructions


MINICONTROL CPUs are standardly equipped with fast floating point mathematical instructions. Besides the basic calculations such as addition, subtraction, multiplication, division and square root, an abundance of conversion and utility programs are provided. 4 byte IEEE format is used for numerical display. Mathematic instructions can be used in ladder diagram (standard function blocks) and STL programs.

### First Scan Flag

The first scan flag is a memory location (R 0899 and T D64) that is set to 1 during the first program cycle automatically by the operating system, otherwise the flag is 0. The first scan flag is used for program initialization. In ladder diagram programming, the first scan flag can be linked to the "Enable" input of a function block that should be run one time only during the first program cycle.

### TIME CYCLES, TIME PULSES, SOFTWARE TIMERS

Time cycles are generated by the operating system. Four different time bases are available. Time pulses are flags that are set to 1 in defined intervals for the duration of one program cycle.



Software timers are flags which operate as initial delays. The time of the delay can be defined by the user.

MINICONTROL CPUs have four pulse generators and four cycle time generators (each for 10 msec, 100 msec, 1 sec and 10 sec) as well as 64 software timers.

#### Software Clock - Real-Time Clock

All MINICONTROL CPUs have a date/time function:

		CP30	CP32	
à	Туре	Software Clock	Real-Time Clock	
	Nonvolatile	NO	YES	
	Clock Time	Hrs., Min., Sec., 1/100 Sec.	Hrs., Min., Sec., 1/100 Sec.	
	Date	Day Counter	Day, Month, Year, Weekday	
_				10.7

### Safety and Diagnosis Functions


All MINICONTROL CPUs are equipped with extensive safety and diagnosis functions. Both CPUs have a software watchdog (runtime monitor). The CP32 CPU has an extra hardware watchdog which can bring the system back to a safe operational state, even if the CPU has failed completely.

A safety and diagnosis function overview can be found in section A1 " System Selection".

2,	CP30	CP32
Software Watchdog	YES	YES
Hardware Watchdog	NO	YES
Application Program Test at power-on	YES	YES
Hardware Reset	YES	YES
Trap Error Recognition	YES	YES
Stack Pointer Test	YES	YES

#### Power-On Sequence (power-on)

MINICONTROL CPUs follow this sequence when powered on:



# PLC SYSTEMS MINICONTROL COMPONENTS






### HOUSING

The MINICONTROL housing consists of the rack, the front cover and the modules or dummy fronts.


### Rack

The rack unit is equipped with guide rails to help with precision module insertion. The bus board containing the module connection slots is located at the back of the rack. All required bus connections are made by simply inserting the module into the respective slot on the bus.




#### Front Cover

The front cover is screwed onto the front of the rack after the modules have been inserted properly. The MINICONTROL may only be operated with the front cover in place.




### **Module Fronts**

Every module has a respective module front. This module front is clipped into place in the corresponding slot position in the front cover. For the E16A input module, for example:



All slots which do not contain a module are to be closed off with dummy fronts. The 6 application module slots are already equipped with dummy fronts when the unit is delivered. Replacement dummy fronts can be ordered with model number MCBL01-0.


### **Dimensions**



### All measurements are in mm (see last page of catalog for conversions)

Total Width	256	
Width without Angle Brackets	223.5	
Height	155.5	
Depth without Module Connections	93.5	
Distance Between Mounting Holes Horizontally	240	
Distance Between Mounting Holes Vertically	110	
Angle Bracket Thickness	2	
Diameter of Mounting Holes	7	

### Mounting Details in mm (see last page of catalog for conversions)








# PLC SYSTEMS MINICONTROL COMPONENTS

### **POWER SUPPLY MODULE**



The NT33 power supply module generates the required internal voltage from the input voltage (24V). The power supply module may only be operated in the system slot which was designed for it (leftmost slot in the rack).

#### Technical Data NT33

Input Voltage Nominal Min./Max. allowed	May.	24 VDC 18/32 VDC	
Galvanically Isolated		YES	
External Support Capacitor Single Phase Bridge Three Phase Bridge	Zalichai.	4700 μF -	Vallet.
Input Capacity		470 μF	
Fuse	2/21	2.5 A 250 V slow	

### Battery

The lithium battery in the power supply module supplies the memory of the CPU if the PLC is switched off.



Lithium batteries are not included in the delivery of the power supply module.

### DC LED Display

The MINICONTROL power supply module is equipped with a DC LED which displays whether the internal voltage is within the permitted range. If this LED is not lit, one of the internal voltages is not within the allowed limits. The cause of this can be a drop in input voltage to under the minimum voltage of 18 V or it could exceed 32 V. An internal voltage loss causes a hardware reset.

### **APPLICATION PROGRAM MEMORY MODULE**



The EE32 application program memory module is included in the delivery with the MINICONTROL base unit. The EE32 module is inserted into the CPU module. It can also be used in the CP40 CPU and the NTCP33.

### Transferring an Application Program to the CPU

The EE32 module has 16 KBytes RAM and 16 KBytes EEPROM. When transferring an application program from the programming device to the CPU (RUN), this program is saved in the RAM of the EE32 and then started, whether another program is stored in the EEPROM or not.

### **Programming the EEPROM Memory**

The "F1 - PROGRAM" command from the EEPROM menu of the programming device abandons the CPU in order to copy the application program from the RAM of the EE32 module to the EEPROM. During the programming of the EEPROM, the programming LED is lit. Programming the EEPROM can also be done when the application program is running. After the EEPROM has been programmed, the write protect switch (WE/WP) must be set to WP (=write protect). This prevents an accidental overwriting of the program in EEPROM. EEPROM memory doesn't have to be deleted. It is simply overwritten with the new program.

### Uninterrupted Transfer from Application Programs to the CPU

An application program can be transferred to the RAM memory of the EE32 with the programming system command "XFER", without interrupting or influencing the program running in the EEPROM. With another programming system command, you can switch between the programs in RAM and EEPROM. The switch is made synchronous to the program cycle. This enables program changes to be made without shutting down the system.

### Loading Application Programs from the CPU

Application programs can be loaded from the CPU back into the programming system. This can also be done while the application program is running. A program that is reloaded from the CPU runs with no problems but is reloaded without any comments, symbolic names or ladder diagram features.

### Power-On Sequence


This is described in the "CPUs" section

### **PLC SYSTEMS** MINICONTROL COMPONENTS

**A4** 



NOTES:







# DIGITAL INPUT/OUTPUT MODULES

PLC SYSTEMS
MINICONTROL COMPONENTS

### **GENERAL INFORMATION**

Digital input module are used for converting the binary signals of a process to the internal signal levels required for the PLC. Digital input status is displayed with status LEDs¹, Digital output modules are used for controlling external loads (relays, motors, solenoids, etc.). The status of digital outputs is displayed with yellow status LEDs.

MODULES	Slots	0	1	2	3	4	5
16 Inputs 24 VDC		•	•	•	•	•	•
8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5	A	-	•	•	•	•	•
16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5	5 A	•	•	•	•	•	•
12 Relay Outputs 220 VAC / 2 A		2)	2)	•	•	•	•
12 Transistor Outputs 24 VDC / 0.5	5 A	2)	2)	•	•	•	
12 Transistor Outputs 24 VDC / 2 /	4	2)	2)	•	•	•	•
	8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.3 12 Relay Outputs 220 VAC / 2 A 12 Transistor Outputs 24 VDC / 0.3	16 Inputs 24 VDC, 8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A 16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A	16 Inputs 24 VDC  8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A  16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A  12 Relay Outputs 220 VAC / 2 A  2)  12 Transistor Outputs 24 VDC / 0.5 A  2)	16 Inputs 24 VDC, 8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A  16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A  12 Relay Outputs 220 VAC / 2 A  2) 2)  12 Transistor Outputs 24 VDC / 0.5 A	16 Inputs 24 VDC, 8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A  16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A  12 Relay Outputs 220 VAC / 2 A  12 Transistor Outputs 24 VDC / 0.5 A  2) 2) 0	16 Inputs 24 VDC, 8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A  16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A  12 Relay Outputs 220 VAC / 2 A  12 Transistor Outputs 24 VDC / 0.5 A	16 Inputs 24 VDC, 8 Inputs 24 VDC, 6 Transistor Outputs 24 VDC / 0.5 A  16 Inputs 24 VDC, 16 Transistor Outputs 24 VDC / 0.5 A  12 Relay Outputs 220 VAC / 2 A  12 Transistor Outputs 24 VDC / 0.5 A

### **DIGITAL INPUTS**

#### Addressing

The designation (address) of an input consists of the address prefix "I" and a three character alphanumeric code beginning with 0:




Numbers 0 to 5 are permitted for MINICONTROL slot numbers. The channel number depends on the module:

Module	Channel Number	
E16A	0 to F	70
MAEA	0 to 7	
MAEB	0 to F	

### Timing

The changes in input status can be evaluated immediately by reading the respective I addresses in the application program. The state of an input can also change during a program cycle (asynchronous).



# DIGITAL OUTPUTS

### Addressing

The designation (address) of an output consists of the address prefix "O" and a three character alphanumeric code which begins with 0:

	O 0##	
Slot Number		Channel Numbe

Numbers 0 to 5 are permitted as slot numbers for the MINICONTROL. The channel number depends on the module:

Module	Channel Number	20,
A12A	0 to B	
A12B	0 to B	
A12C	0 to B	
MAEA	0 to 5	
MAEB	0 to F	

#### Timing

Output modules do not have temporary latch memory. Setting and resetting an output in the application program is effective immediately after the respective response time. These times are explained for each module in the respective "Technical Data" section (e.g. for relay modules, approx. 10 msec and for transistor modules, approx  $100 \, \mu sec.$ ).

#### **Protective Circuits**

An external protective circuit is required for relay output modules and for transistor output modules it is recommended.

Module	Туре	External Protective Elements
A12A	Relay Outputs	Required
A12B	Transistor Outputs	Recommended
A12C	Transistor Outputs	Recommended
MAEA	Transistor Outputs	Recommended
MAEB	Transistor Outputs	Not Required

The protective circuit can either be built into the load to be switched, the output module or terminations in between. Most manufacturers of these protective circuits and solenoids offer their own suitable protective elements for the respective element.

The following components are normally used:

- RC combination: Can be used for AC or DC. 3)
- Varistor: Mostly used for AC. Since varistors have a tendency to wear out, RC combinations are generally preferred.
- Inverse Diode: Can only be used for DC.
- Diodes/Z Diode Combination: Can only be used for DC. This type of protective circuit enables faster cutoff times.

The MAEB input/output module has 16 orange LEDs for displaying the status of inputs and outputs (car be switched with a button).

The digital output modules A12A, A12B and A12C can also be operated in slots 0 and 1 of base unit A.

Typical values for RC combination circuits (ca. 10 W inductive load) are: 22 Ω/250 nF at 24 VDC/AC or 220 Ω/1 μF at 220 VAC.

## DIGITAL INPUT/OUTPUT MODULES E16A - 16 INPUTS 24 VDC

PLC SYSTEMS MINICONTROL COMPONENTS







# **E16A**


- 16 Digital Inputs
- Input Voltage 24 VDC
- Input Delay ca. 1 msec or ca. 10 msec

SLOTS		Slot	0 1	2	3	4	5
E16A	Base Units A and C	The state of the s	• •	•	•	•	•

### ORDER DATA


MCE16A-0	Digital Input Module, 16 Inputs, Input Voltage 24 VDC, LED Status Display, Galvanically Isolated, Reference Potential GND, Power-on Delay ca. 10 msec
MCE16A-1	Digital Input Module, 16 Inputs, Input Voltage 24 VDC, LED Status Display, galvanically isolated, Reference Potential GND, Power-on Delay ca. 1 msec

### DIAGRAM




TECHNICAL DATA	E16A-0	E16A-1
Number of Inputs Total In Groups of	16	
Electrically Isolated Input - PLC Input - Input	YES (Opto-	
Input Voltage Nominal Minimal Maximal	24 VE 16 VE 30 VE	C
Input Resistance	ca. 2:2	kΩ
Switching Threshold log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	min. 16 max. 12	
Input Current at 24 VDC	ca. 10	mA
Switching Delay log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	ca. 10 msec ca. 20 msec	ca. 1 msec ca. 2 msec
Input Status Transfer Through CPU	With Ch	ange
Documentation German English French	Hardware Manual M MAHWM MAHWM MAHWM	IINI-0 IINI-E

### CONNECTIONS



### INPUT CIRCUIT





# DIGITAL INPUT/OUTPUT MODULES MAEA - 8 INPUTS, 6 OUTPUTS

PLC SYSTEMS
MINICONTROL COMPONENTS



# MAEA


- 8 Digital Inputs
- Input Voltage 24 VDC
- Input Delay ca. 10 msec
- 6 Digital Transistor Outputs
- Switching Voltage 24 VDC
- Switching Current Max. 0.5 A per Output

SLOTS	. J	Slot	0 1 2 3 4 5
MAEA	Base Unit A (CP30) Base Unit C (CP32)		0

### ORDER DATA


MCMAEA-0	Digital	Input/Output	Module,	8	Inputs,	Input	Voltage
		, LED Status Dis			,	. ,	
	•	g Voltage 24 VD	,				.3.3

### DIAGRAM




T	ECHNICAL DATA	MAEA	
I	Number of Inputs	8	200
3	Electrically Isolated Input - PLC Inputs - Outputs Input - Input Output - Output	YES (Optocoupler) YES NO NO	
	Input Voltage nom./min./max.	24 VDC / 16 VDC / 30 VDC	
	Input Resistance	ca. 2.2 kΩ	
ò	Switching Threshold $\log.~0 \rightarrow \log.~1/\log.~1 \rightarrow \log.~0$	min. 16 VDC / max. 12 VDC	
	Input Current at 24 VDC	ca. 10 mA	
	Switching Delay $\log. 0 \rightarrow \log. 1/\log. 1 \rightarrow \log. 0$	ca. 10 msec / ca. 20 msec	
	Input Status Transfer Through CPU	With Change	
ı	Outputs	6	
9	Output Switching Voltage nom./min./max.	24 VDC / 18 VDC / 30 VDC	
	Output Switching Current Per Output / Total	0.5 A / 3 A	
	Transistor Residue Voltage	< 1 V at 0.5 A	
Ó	Documentation German English French	Hardware Manual MINICONTROL MAHWMINI-0 MAHWMINI-E MAHWMINI-F	71 <sup>2</sup>

### CONNECTIONS



### INPUT/OUTPUT CIRCUITS



# DIGITAL INPUT/OUTPUT MODULES MAEB - 16 INPUTS, 16 OUTPUTS

PLC SYSTEMS MINICONTROL COMPONENTS







# **MAEB**


- 16 Digital Inputs
- Input Voltage 24 VDC
- Input Delay ca. 1 msec or ca. 5 msec
- 16 Digital Transistor Outputs
- Switching Voltage 24 VDC
- Switching Current max. 0.5 A per Output
- Short Circuit and Overload Protection
- 16 LED Status Display, either for inputs or outputs (switched with keys)

SLOTS		Slot	0	) 1	2	3	4	5	
MAEB	Base Unit A (CP30) Base Unit C (CP32)	True.						•	

### ORDER DATA


MCMAEB-0	Digital Input/Output Module, 16 Inputs, Input Voltage 24 VDC, LED Status Displays, Galvanically Isolated, Reference Potential GND, Switching Delay ca. 5 msec, 16 Transistor Outputs, Switching Voltage 24 VDC, Switching Current max. 0.5 A per Output
MCMAEB-1	Digital Input/Output Module, 16 Inputs, Input Voltage 24 VDC, LED Status Displays, Galvanically Isolated, Reference Potential GND, Switching Delay ca. 1 msec, 16 Transistor Outputs, Switching Voltage 24 VDC, Switching Current max. 0.5 A per Output

### DIAGRAM




TECHNICAL DATA	MAEB-0	MAEB-1
Number of Inputs		16
Electrically Isolated Input - PLC Inputs - Outputs Input - Input Output - Output	"IAKO""	ptocoupler) YES NO NO
Input Voltage nom./max.	24 VD0	C/30 VDC
Switching Threshold log. 0 → log. 1 / log. 1 —	→ log. 0 min. 16 VDC	C / max. 12 VDC
Input Current at 24 VDC	са	. 8 mA
Switching Delay log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	ca. 5 msec ca. 5 msec	ca. 1 msec ca. 1 msec
Outputs	1800	16
Protection	Short Circuit	and Overvoltage
Output Switching Voltage nom./min./max.	24 VDC / 18	S VDC / 30 VDC
Output Switching Current Per Output / Total	0.5	A/8A
Protective Circuit	On	Module
Operating Temperature	0 to	50 °C
Documentation German English French	MAH MAH	ual MINICONTROL WMINI-0 WMINI-E WMINI-F
- 1701	. 172	

### CONNECTIONS



### INPUT / OUTPUT CIRCUITS





## DIGITAL INPUT/OUTPUT MODULES A12A - 12 RELAY OUTPUTS

PLC SYSTEMS
MINICONTROL COMPONENTS



# **A12A**


- 12 Relay Outputs
- 3 Groups with Separate Reference Potential
- Switching Voltage 220 VAC or 24 VDC
- Switching Current max. 2 A per Output
- Two Outputs with Open Contacts

SLOTS	Sept.	Slot	0	1	2	3	4	5
A12A	Base Unit A (CP30) Base Unit C (CP32)		_	NT.	_	_	_	•

### ORDER DATA


MCA12A-0	Digital Output Module, 12 Relay Outputs, Switching Voltage 220VAC/24VDC, Switching Current max. 2 A per Output, LED Status
	Displays

### DIAGRAM



Т	ECHNICAL DATA	A12A	
à	Number of Outputs Total In Groups of	12 4	n
	Туре	Relay	
	Switching Voltage AC nom./max. DC nom./max.	220 VAC / 250 VAC 24 VDC / 30 VDC	
	Switching Current Per Output Per Group	max. 2 A max. 5 A	n
3	Switching Delay log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	ca. 10 msec ca. 15 msec	
	Protective Circuit	External by User, Required	
ı	Switching Procedure Mechanical Electrical (Resistive)	> 2 x 10 <sup>7</sup> > 1 x 10 <sup>5</sup>	11/2
	Voltage Resistance Contact - Coil	$2000\mathrm{V}_{\mathrm{eff}}$	
	Documentation German English French	Hardware Manual MINICONTROL MAHWMINI-0 MAHWMINI-E MAHWMINI-F	

### CONNECTIONS




# DIGITAL INPUT/OUTPUT MODULES A12B / A12C - 12 TRANSISTOR OUTPUTS

PLC SYSTEMS MINICONTROL COMPONENTS







# A12B / A12C


- 12 Transistor Outputs
- Switching Voltage 24 VDC
- Switching Current 0.5 A / 2 A per Output

SLOTS		Slot	0	1	2	3	4	5
A12B, A12C	Base Unit A (CP30) Base Unit C (CP32)	nun.	_	•	_	_	_	_

### ORDER DATA


MCA12B-0	Digital Output Module, 12 Transistor Outputs, Switching Voltage 24 VDC, Switching Current max. 0.5 A per Output, LED Status Displays, Galvanically Isolated
MCA12C-0	Digital Output Module, 12 Transistor Outputs, Switching Voltage 24 VDC, Switching Current max. 2 A per Output, LED Status Displays, Galvanically Isolated

### DIAGRAM




TECHNICAL DATA	A12B	A12C
Number of Outputs Total In Groups of	12	2
Туре	Trans	istor
Galvanic Isolation Output - PLC Output - Output	YE.	-
Switching Voltage nominal minimal maximal	24 V 18 V 30 V	DC
Switching Current Per Output Total	max. 0.5 A max. 6 A	max. 2 A max. 6 A
Switching Delay log. 0 → log. 1 log. 1 → log. 0	ca. 100 ca. 200	
Transistor Residue Voltage	< 1 V at	t 0.5 A
Protective Circuit	External l (Recomm	
Documentation German English French	Hardware Manual MAHWI MAHWI MAHWI	MINI-0 MINI-E

### CONNECTIONS



### **OUTPUT CIRCUIT**





# **ANALOG INPUT/OUTPUT MODULES**

# PLC SYSTEMS MINICONTROL COMPONENTS

### **GENERAL INFORMATION**

Analog inputs are used for converting measurement values (voltages, current, temperature) to numerical values that can be processed by the PLC. Analog outputs are used to convert PLC internal numerical values to current or voltage. The following table is an overview of the analog input / output modules for the MINICONTROL system. These modules can only be operated in base unit C (CP32).

,	ANALOG I/	O MODULE	Slot	0 1 2 3 4 5
S.	PEA4	4 Inputs 0 - 10 V / 0 - 20 mA		• 67
	PEA8	4 Inputs 0 - 10 V / 0 - 20 mA 4 Inputs 0 - 10 V / 0 - 20 mA		••
	PT41	4 Inputs for PT100 Sensor		• •
	PTA2	2 Inputs for PT100 Sensor, 2 Outputs 0 - 10 V		•• 📶
	PTE6	6 Inputs for Thermoelement (±50 mV	<b>'</b> )	•• %
	PTE8	8 Inputs for KTY10 Sensor		• • •
	PRTA	4 Inputs 0 - 10 V / 0 - 20 mA		• 1)

### **ANALOG INPUTS**

### **Utilization in the Application Program**

Converting the input signals to numerical values is controlled by standard function blocks. One function block exists for every module:

Module	Туре	Function Block
PEA4	4 Inputs 0 - 10 V / 0 - 20 mA	AINA
PEA8	4 Inputs 0 - 10 V / 0 - 20 mA, 4 Outputs 0 - 10 V / 0 - 20 mA	AINA
PT41	4 Inputs for PT100 Sensor	TINA
PTA2	2 Inputs for PT100 Sensor, 2 Outputs 0 - 10 V	TIND
PTE6	6 Inputs for Thermoelement (±50 mV)	TINF
PTE8	8 Inputs for KTY10 Sensor	TING
PRTA	4 Inputs 0 - 10 V / 0 - 20 mA	AINB

The following parameters are connected to the function block:

- The number of the first channel to be converted (CHAN)
- The number of channels to be converted (LENGTH)
- The slot number of the module
- The target address for the conversion results

With input modules used for temperature measurement, you can define whether the values should be stored in  ${}^{\circ}\text{C}$  or  ${}^{\circ}\text{F}$ . Different ranges of measurement can be switched between on some modules. A detailed description of the standard function blocks for analog input/output modules can be found in the "Standard Software User's Manual, Volume 1".

#### Resolution

A very important characteristic of analog input/output modules is the resolution. The resolution defines the number of steps that the range to be measured is divided by. The resolution is entered in bits. The number of divisions is a result of:

Number of Steps = 2 Resolution

The following table indicates the relationship between the resolution and the number of steps for the most common resolutions:

	Resolution	No. of Steps	Step Size with 0 - 10 V Range	Step Size with 0 - 20 mA Range	
ı	8 Bit	256	39.06 mV	78.13 µA	20
	10 Bit	1024	9.77 mV	19.53 µA	
	12 Bit	4096	2.44 mV	4.88 µA	
	16 Bit	65536	152.59 µV	305.18 nA	

### **Timing -Update Times**

Analog inputs are converted cyclically in most applications, which means that the channels are converted and saved, whether this data is required in the application program immediately or not. The update time is the period of time in which is required to update the results of the conversion. The update time depends upon three factors:

- The input filter on the module
- Conversion time of the A/D converter
- Program Cycle Time

#### Input Filter:

In order to obtain accurate measurements in an industrial atmosphere, all analog input modules are equipped with an input filter. This filter has a time constant which corresponds with the application. Filters with large time constants are used for temperature measurements (e.g. PT41), since temperature does not normally change very fast. Measurements that deal with rapid changes (e.g. voltage measurement with the PRTA) require a respectively small time constant that is suitable for the conversion time of the A/D converter.

Conversion Time:

The conversion time depends on the A/D converter used in the module. This is shown in the "Technical Data" section for each individual module.

Program Cycle Time:

Since one channel is converted per program cycle in most applications (e.g. Standard Function Blocks), the program cycle time fits within the update time. For example, : With a program cycle time of 30 msec and four channels to be converted, the update time (independent of the conversion time) cannot be under 120 msec.

### **ANALOG OUTPUTS**

### Utilization in the Application Program

Converting internal numerical values to voltage or current is controlled through standard function blocks. A function block exists for every module:

Module	Resolution	Function Block
PEA8	4 Inputs 0 - 10 V / 0 - 20 mA, 4 Outputs 0 - 10 V / 0 - 20 mA	AOTA
PTA2	2 Inputs for PT100 Sensor, 2 Outputs 0 - 10 V	AOTD

The following parameters are connected to the function block:

- The number of the channel to be converted first (CHAN)
- The number of channels to be converted (LENGTH)
- The slot number of the module
- The source address of the values to be output

The analog input module PRTA can also be operated in slot 1 if slot 2 is not used

# ANALOG INPUT/OUTPUT MODULES, PEA4 - 4 INPUTS 0 - 10 V / 0 - 20 mA

PLC SYSTEMS MINICONTROL COMPONENTS





# PEA4


- 4 Analog Inputs
- Input Signal 0 10 V or 0 20 mA
- 10 Bit Resolution
- Software Operated with Standard Function Blocks

TECHNICAL DATA	PEA4-1	PEA4-2
TECHNICAL DATA	FLA4-1	FLA4-2
Number of Inputs	4	4
Input Signal Nominal Maximal	0 to 10 V -0.3 V to +13 V	0 to 20 mA 70 mA
Input Resolution	10 Bit	10 Bit
Conversion Time per Channel	ca. 10 msec	ca. 10 msec
Input Current	< 250 nA	7470.
Load -	50	Ω
Voltage Drop at 20 mA	- 9	1 V
Input Precision  Basic Precision at 20 °C  Offset Drift  Gain Drift  Linearity	±0.3 % ±0.0025 % / ° C ±0.025 % / ° C 0.2 %	±0.3 % ±0.0055 % / °C ±0.03 % / °C 0.2 %
Documentation German English French	Hardware Manual MAHW MAHWI MAHWI	MINI-0 MINI-E


# SLOTS 0 1 2 3 4 5 PEA4 Base Unit C (CP32) • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • • •<

### ORDER DATA

MCPEA4-1	Analog Input Module, 4 Analog Inputs, Input Voltage 0 - 10 V, 10 Bit Resolution, Without Galvanic Isolation	
MCPEA4-2	Analog Input Module, 4 Analog Inputs, Input Current 0 - 20 mA, 10 Bit Resolution, Without Galvanic Isolation	



### CONNECTIONS



### **SOFTWARE OPERATION**

The AINA standard function block is used for software control of the analog inputs. This function block is a component of software package SWSPSSTD01-0 (see section A7 "PLC Programming").

The parameters of the AINA function block are:

- Number of the first channel to be converted (0 to 3)
- Number of channels to be converted (1 to 4)
- Slot number of the PEA4 module (0 or 1)
- Target address for the converted values

### RELATIONSHIP BETWEEN INPUT SIGNAL AND CONVERTER VALUE

The relationship between the input signal (Voltage 0 to 10 V or current 0 to 20 mA) and the converter value (0 to 1023) is linear:

Converter Value	Corresponds with Input Voltage (PEA4-1)	Corresponds with Input Current PEA4-2
0	0 V	0 mA
500	5 V	10 mA
1000	10 V	20 mA



# ANALOG INPUT/OUTPUT MODULES, PEA8 - 4 INPUTS, 4 OUTPUTS

PLC SYSTEMS
MINICONTROL COMPONENTS



## PEA8

- 4 Analog Inputs
- Input Signal 0 10 V or 0 20 mA
- 10 Bit Resolution
- 4 Analog Outputs
- Output Signal 0 10 V or 0 20 mA
- Software Operation with Standard Function Blocks

SLOTS		0 1 2 3 4 5
PEA8	Base Unit C (CP32)	• • •

### ORDER DATA


MCPEA8-1

Analog Input/Output Module, 4 Analog Inputs, Input Voltage 0 - 10 V, 10 Bit Resolution, 4 Analog Outputs, Output Voltage 0 - 10 V, Without Galvanic Isolation

MCPEA8-2


Analog Input/Output Module, 4 Analog Inputs, Input Current 0 - 20 mA, 10 Bit Resolution, 4 Analog Outputs, Output Current 0 - 20 mA, Without Galvanic Isolation

### DIAGRAM



TECHNICAL DATA	PEA8-1	PEA8-2
Number of Inputs	4	4
Input Signal Nominal Maximal	0 to 10 V -0.3 V to +13 V	0 to 20 mA 70 mA
Resolution der Inputs	10 Bit	10 Bit
Conversion Time per Channel	ca. 10 msec	ca. 10 msec
Input Current	< 250 nA	-
Load -	50	Ω
Voltage Drop at 20 mA		1 V
Input Precision Basic Precision at 20 °C Offset Drift Gain Drift Linearity	±0.3 % ±0.0025 % / ° C ±0.025 % / ° C 0.2 %	±0.3 % ±0.0055 % / ° C ±0.03 % / ° C 0.2 %
Number of Outputs	4	4
Output Signal	0 to 10 V	0 to 20 mA
Output Resolution	8 Bit	8 Bit
Output Precision Offset at 20 °C Offset Drift (0 to 60 °C) Gain Error at 20 °C Gain Drift Linearity	0.2 % ±0.05 % ±0.2 % ±0.012 % / ° C 0.2 %	0.3 % 0.08 % Load 50 Ω: 0.5 % Load 400 Ω: 3.5 % 0.05 % / °C 0.2 %
Max Output Load Per Channel	20 mA	
Load	Max.	400 Ω
Documentation German English French	MAHW	I MINICONTROL MINI-0 MINI-E MINI-F
- 27		

### CONNECTIONS



### SOFTWARE OPERATION

The analog inputs and outputs are controlled with standard function blocks AINA and AOTA. These function blocks are components of software package SWSPSSTD01-0 (see section A7 "PLC Programming" as well).

# ANALOG INPUT/OUTPUT MODULES, PT41 - 4 INPUTS FOR PT100 SENSORS

# PLC SYSTEMS MINICONTROL COMPONENTS







## **PT41**

- 4 Inputs for Direct Connection of PT100 Temperature Sensors
- Three or Four Wire Connection
- 10 Bit Resolution


SLOTS		0 1 2 3 4 5		
PT41	Base Unit C (CP32)	The state of	• •	


### ORDER DATA

Analog Input Module for temperature measurement, 4 inputs for direct connection of PT100 temperature sensors, 10 bit resolution, without galvanic isolation


MCPT41-0 Measurement Range -25 to +225 °C, for Three Wire Connections MCPT41-1 Measurement Range -25 to +225 °C, for Four Wire Connections

### DIAGRAM





#### CONNECTION



### **SOFTWARE OPERATION**

Analog input control is all handled through the TINA function block. This function block is a component of software package SWSPSSTD01-0 (see section A7 "PLC Programming" as well).

The parameters of the TINA function block are:

- Number of the first channel to be converted (0 to 3)
- Number of channels to be converted (1 to 4)
- Slot number of the PT41 module (0 or 1)
- Measurement range
- Desired units for the result (°C or °F)
- Target address for the converted values

The temperature in the defined units (°C or °F) is augmented by a factor of 10 and stored as a 2's complement number. e.g.:


Temperature	Result °C	Result °F
-25 °C (-13 °F)	-250	-130
0 °C (32 °F)	0	320
100 °C (212 °F)	1000	2120
225 °C (437 °F)	2250	4370

<sup>1)</sup> R ... Line Resistance



## ANALOG INPUT/OUTPUT MODULES, PTA2 - 2 INPUTS FOR PT100 SENSORS, 2 OUTPUTS

PLC SYSTEMS
MINICONTROL COMPONENTS



## PTA2

- 2 Inputs for Direct Connection of PT100 Temperature Sensors
- Three Wire Connection
- 10 Bit Resolution
- Measurement Range -25 °C to +475 °C
- 2 Analog Outputs
- Output Voltage 0 to 10 V


SLOTS	(April	0 1 2 3 4 5
PTA2	Base Unit C (CP32)	• • •

### ORDER DATA

MCPTA2-21


Analog Input / Output Module, 2 inputs, for direct connection of PT100 temperature Sensors, 10 bit resolution, measurement range - 25 to +475  $^{\circ}$ C, three wire connection, 2 analog outputs, output voltage 0 to 10 V, without galvanic isolation

### DIAGRAM



#### TECHNICAL DATA PTA2 Number of Inputs 2 Temperature Sensor / Norm PT100 / DIN 43760 Connection Type Three Wire Connection 10 Bit Input Resolution Conversion Time per Channel ca. 100 µsec Input Precision ±0.3 % + 110 ppm / R 1) Basic Precision at 20 °C Offset Drift ±0.039 % / °C ±170 ppm / °C Gain Drift Number of Outputs Output Signal 0 to 10 V Output Resolution 8 Bit Output Precision Offset at 20 °C 02% Offset Drift (0 to 60 °C) ±0.05 % +0.2 % Gain Error at 20 °C Gain Drift ±0.012 % / °C Linearity 0.2 % Maximum Output Load Per Channel 20 mA Hardware Manual MINICONTROL Documentation MAHWMINI-0 German English MAHWMINI-E MAHWMINI-F French

### CONNECTIONS



### SOFTWARE OPERATION

Software operation of the PT100 inputs is controlled with the standard function block TINE and the outputs are handled with the AOTE function block. Both of the function blocks are standard components of software package SWSPSSTD01-0 (see section A7 "PLC Programming" as well).

The temperature in the defined unit (°C or °F) is augmented by a factor of 10 and stored as a 2's complement number. e.g.:

Temp	erature	Result °C	Result °F
-25 °C	(-13 °F)	-250	-130
0 °C	(32 °F)	0	320
100 °C	(212 °F)	1000	2120
475 °C	(887 °F)	4750	8870

<sup>1)</sup> R ... Line Resistance

## ANALOG INPUT/OUTPUT MODULES, PTE6 - 6 INPUTS FOR THERMOELEMENTS

**PLC SYSTEMS** MINICONTROL COMPONENTS

**TECHNICAL DATA** 

Number of Inputs



PTE6





# PTE6

- 8 Analog Inputs for Temperature Sensors
- 6 Channels for FeCuNi- (Types F and J), NiCrNi Sensor (Type K), PtRh-Rt, PtRh-El etc.
- 2 Channels for KTY10 Sensors (Compensa-
- 2 Internal KTY10 Sensors (Compensation)
- Temperature Range -150 to +1800 °C (Depending on sensors)
- Resolution 16 Bit
- Conversion Time ca. 62 msec per Channel (User Definable)
- Software Linearization with TINF Function Block


SLOTS	(g)	0 1 2 3 4 5					
PTE6	Base Unit C (CP32)	'72 <sub>21</sub> • •					

### ORDER DATA

MCPTE6-0

 $Analog\,Input\,Module\,for\,temperature\,measurement,\,8\,channels$ (6 for temperature measurement, 2 for compensation), 16 bit resolution, measurement range -150 to +1800  $^{\circ}$  C (depending on the sensor), conversion time per channel- ca. 62 msec (user definable), without galvanic isolation

### DIAGRAM



#### 6 for Temperature Measurement (Thermoelement) 2 for Compensation (KTY10 or ±10 V) Temperature Sensor Sensor KTY NiCrNi FeCuNi FeCuNi Туре Temperature Range -150 to +1200 °C -100 to +850 °C -100 to +870 °C Precision 0.1°C 0.1°C 0.1 °C KTY10 Sensor -50 to +150 °C Measurement Range ±2°C 0.01°C Resolution Module Temperature Measurement over 2 Internal KTY10 Sensors -50 to +150 °C Measurement Range $\pm 5~^{\circ}\text{C}$ (compared to external KTY10 Sensor) $0.01~^{\circ}\text{C}$ Precision Resolution Comparison Voltage Resolution 1 mV (±10 V = ±100 °C) Measurement Range Precision ±10 V Offset Drift 100 μV/°C 0.025 %/°C Gain Drift Common Mode Error Common Mode Range 0.02 %/V = 0.02 °C ±10.5 V Thermoelement Input Resolution $2\mu V$ -65.536 mV to +65.534 mV Use half range only for disturbance suppression ( $\pm 35$ mV) Measurement Range ±10 µV (Environmental Temperature 22 °C) 2.5 µV/°C Precision Offset Drift Gain Drift 800 ppm/°C Common Mode Error 10 µV/V Common Mode Range Conversion Times 10 Hz Notch 302 msec 50 Hz Notch 62 msec

### CONNECTIONS

200 Hz Notch 1 kHz Notch Calibration Times<sup>1)</sup> 10 Hz Notch

50 Hz Notch


60 Hz Notch

1 kHz Notch

10 Hz Notch

50 Hz Notch

200 Hz Notch 1 kHz Notch



183 msec

48 msec

11.7 msec

(16 Bit)

(16 Bit) (15 Bit)

(10 Bit)

0.01 °C

0.01 °C 0.02 °C

### SOFTWARE OPERATION


The analog inputs are controlled through standard function block TINF. This function block is a standard component of software package SWSPSSTD01-0 (see section A7 "PLC Programming" as well).

The calibration is made automatically after a change in the notch frequency and after a reset. After a reset, the notch frequency is set to 50 Hz.



# ANALOG INPUT/OUTPUT MODULES, PTE8 - 8 INPUTS FOR KTY10 SENSORS

PLC SYSTEMS
MINICONTROL COMPONENTS



# PTE8

- 8 Analog Inputs for KTY10 Sensors
- Temperature Range -10 to 110 °C
- Resolution 16 Bit
- Conversion Time ca. 62 msec per Channel (User Definable)

	0 1 2 3 4 5
co Unit C (CD32)	■ ■1/4 ½

### ORDER DATA


**SLOTS** 

PTE8

MCPTE8-0


Analog Input Module for temperature measurement, 8 KTY10 sensor channels, 16 bit resolution, measurement range -10 to +110 °C, conversion time ca. 62 msec per channel, without galvanic isolation

### DIAGRAM



TECHNICAL DATA	PTE8	
Number of Inputs	8	25.
KTY10 Sensor Measurement Range Resolution Precision Max. Temperature Drift	-10 to +110 °C 0.01 °C ±0.3 °C (Environmental Temperature 20 °C) ±0.03 °C/°C Environmental Temperature	4
Hardware Filter Cutoff Frequency Steepness	ca. 5 Hz ca. 40 dB/Decade	
Conversion Times 10 Hz Notch 50 Hz Notch 200 Hz Notch 1 kHz Notch	302 msec 62 msec 16.2 msec 4.1 msec	ari
Calibration Times <sup>1)</sup> 10 Hz Notch 50 Hz Notch 60 Hz Notch 1 kHz Notch	902 msec 183 msec 48 msec 11.7 msec	
Resolution 10 Hz Notch 50 Hz Notch 200 Hz Notch 1 kHz Notch	0.01°C (16 Bit) 0.01°C (16 Bit) 0.02°C (15 Bit) 0.6°C (10 Bit)	nn'i

#### CONNECTIONS



### SOFTWARE OPERATION

The analog inputs are controlled with the standard function block TING. The function block is a component of software package SWSPSSTD01-0 (see section A7 "PLC Programming" as well).

the calibration is made automatically after a notch frequency change and a reset. After a reset, the notch frequency is set to  $50\,\mathrm{Hz}$ .

# ANALOG INPUT/OUTPUT MODULES, PRTA - 4 INPUTS, REAL-TIME CLOCK

# PLC SYSTEMS MINICONTROL COMPONENTS







# **PRTA**

- 4 Analog Inputs
- Voltage (0 to 10 V) or Current (0 to 20 mA) Definable for Every Channel
- 10 Bit Resolution
- Conversion Time 100 μsec / Channel
- Real-Time Clock
- 3 Keys for Setting Real-Time Clock
- Three Position LED Display


S	LOTS	,8¢°	'90,0	0	1	2	3	4	5
	PRTA	Base Unit C (CP32)	7747.	•	1)				
_								_	

### ORDER DATA

MCPRTA-0

Analog Input Module, 4 inputs for voltage or current (selected with jumper), input voltage 0 to 10 V or input current 0 to 20 mA, 10 bit resolution, real-time clock, 3 keys, three position LED display, without galvanic isolation

### DIAGRAM



TECHNICAL DATA	PRTA
Number of Inputs	4
Input Signal	Voltage or Current, Selected with jumper for each channel
Input Voltage Nominal Min. / Max.	0 to 10 V -5 V / +15 V
Input Current Nominal Max.	0 to 20 mA ±50 mA
Resolution	10 Bit
Conversion Time per Channel	ca. 100 µsec
Input Resistance	> 10 MΩ
Load	50 Ω
Voltage Drop at 20 mA	1V
Input Filter Cutoff Frequency	ca. 180 Hz
Input Precision Full Scale Error (at 20 °C) Offset Error Gain Drift Offset Drift	Voltage         Current           ±3 Bit         ±3 Bit           ±1 Bit         ±4 Bit           0.02 % / °C         0.03 % / °C           ±1 Bit (0 to 60 °C)         ±2 Bit (0 to 60 °C)
Real-Time	Year, Month, Day, Hours, Minutes, Seconds, 1/10 Seconds, 1/100 Seconds, Weekday
Documentation German English French	Hardware Manual MINICONTROL MAHWMINI-0 MAHWMINI-E MAHWMINI-F

### CONNECTIONS



- 0 Analog Input 01 Analog Input 1
- 2 Analog Input 2
- Reference potential for analog inputs

### SOFTWARE OPERATION

The analog inputs are controlled with standard function block AINB. This function block is a standard component of software package SWSPSSTD01-0 (see section A7 "PLC Programming").

The parameters of the AINB function block are:

- Number of the first channel to be converted (0 to 3)
- Number of channels to be converted (1 to 4)
- Slot number of the PRTA modules (0 or 1)
- Target address for the converted values

### **RELATIONSHIP BETWEEN INPUT SIGNAL - CONVERTER VALUE**

The relationship between the analog input size (Voltage 0 to 10 V or current 0 to 20 mA) and the converter value (0 to 1023) is linear.

Converter Value	Respective Voltage	Respective Current
0,0	0 V	0 mA
500	5 V	10 mA
1000	10 V	20 mA

The analog input module PRTA can also be operated in slot 1 if slot 2 is not being used.



## **INTERFACE MODULES**

# PLC SYSTEMS MINICONTROL COMPONENTS

### **GENERAL INFORMATION**

Interface modules allow the PLC to exchange data with other devices (as well as other PLCs):

- Parallel Interfaces
- Serial Interfaces

#### **PARALLEL INTERFACES**

The data is transferred a byte at a time. An entire byte is sent together over 8 separate data lines. The most important standardized parallel interfaces is the CENTRONICS interface which is normally used for printer data. CENTRONICS interfaces are not suitable for industrial use however.

#### **SERIAL INTERFACES**

The data is sent bit by bit and put back into word form by the receiver again. Serial interfaces are better suited to computer system communication because of the low cost wiring, less susceptibility to disturbance and worldwide standardization. The most important types of serial interfaces are:

RS232 (V24)

Communication is only established over a minimum of three lines (sender, receiver and reference to ground). Additional lines can be used as synchronization between sender and receiver (handshake). The communication distances that can be reached (about 10 meters) with RS232 interfaces are rather limited by the difficulties involved in separating electrical disturbances and the faults in galvanic isolation.

TTY

Communication is made through applied current (20 mA). The TTY interface is also called the current loop interface. Since TTY interfaces are galvanically isolated, a further communication distance is possible (up to 200 meters in industrial applications). The TTY interface requires four lines.

RS422

Send and receive lines and sometimes handshake lines are doubled with this interfaces (differential signals). Communication distances are further with the RS422 interfaces than with the RS232 interface. By using the proper cabling with B&R interface modules, the RS422 interface can also be used as an RS485 interface, if no handshake lines are used. All B&R RS422 interfaces can be switched to high resistance (tristate status) and are therefore network capable.

RS485

This type of interface is best suited for industrial applications. Differential signals are also used on the RS485 interface. The RS485 interface is normally galvanically isolated from the PLC and can be used in a network, which means that several senders and receivers can be run with the same medium (twisted pair cable). The communication distance with RS485 reaches up to 1200 meters.

### SYNCHRONIZING THE SENDER AND THE RECEIVER

In most cases, the sender can send data bytes faster as the receiver can process with asynchronous data transmission. Therefore a method of synchronization is required for almost all paths of transmission. This synchronization method is called a handshake. There are two different types of handshake:

- Hardware Handshake
- Software Handshake

### HARDWARE HANDSHAKE

An additional line, over which the receiver can inform the sender whether it is ready to receive more data bytes or not, is used for a hardware handshake. The parallel CENTRONICS interface also has a so-called busy line, through which the printer can inform the sender that its receive buffer is full for example. Two handshake lines are required for asynchronous data transmission.

Advantage: Handshake lines can be easily evaluated

with software

Disadvantage: More cabling required

#### SOFTWARE HANDSHAKE

Synchronization between the sender and receiver is done with control characters. The protocol which is best known is the standardized X-ON/X-OFF protocol which is also used on most printers around the world. The receiver sends a defined stop character (X-OFF; \$13) to the sender if it can't receive any more data. As soon as its receive buffer can take in more characters, it sends a start character (X-ON; \$11). Naturally there are other methods of synchronizing through software as well.

Advantage: Less cabling

Disadvantage: Normally more software required

#### POINT-TO-POINT CONNECTIONS/NETWORKS

Automation system communication can be done in different ways:

Point-to-Point Connections A system is connected to another system and exchanges data

with this other system. This means that the data transfer and also be done in both directions (= asynchronous).

Networks A number of systems are connected with a common medium

(at least a twisted pair line). A station can either send data only to a certain other station or to optional other stations depending on the network structure. A network capable serial interface (e.g. the RS485 interface) is required to set up a network.

# **INTERFACE MODULES**

### **PLC SYSTEMS** MINICONTROL COMPONENTS





### **SERIAL INTERFACES**

Characters that are sent over a serial interface are automatically split into individual bits by the interface module. The user defines the amount of data bits that the characters to be sent should have (5 to 8) during the initialization. The following diagram shows 8 data bits per character being sent.



A start bit which informs the receiver of the beginning of a character is then sent The individual data bits follow this start character.

### **PARITY TEST**

The parity test which can be switched on during the initialization, enables a simple security test. A so-called parity bit is generated in addition to the data bits:



This bit is generated by the interface module automatically, in order to make the sum of the transmitted data bits either even or odd.

EVEN Parity	ODD Parity
The parity bit is 1, if the sum of all data bits in uneven.	The parity bit is 1, if the sum of all data bits is even.
The parity bit is 0, if the sum of all data bits is even.	The parity bit is 0, if the sum of all data bits is uneven.

After a character has been received, the receiver checks whether the sum of bits corresponds with that set for the parity test. If, for example, the sum of received bits including the parity bit is even when parity checking is set to ODD, at least one of the bits in the received data has been inverted during the transmission. An error signal is generated in this case.

A stop bit is sent to terminate the sequence of bits. The user can define the length of this stop bits in the interface initialization. It can be exactly the same length as a data bit (1 stop bit; normally), it can be 1.5 times as long as a data bit or it can be twice as long as a data bit (2 stop bits):



### **POSSIBLE ERROR MESSAGES**

Three different error states can be shown with the error status bits:

- Parity Error (see above)
- Framing Error
- Overrun Error

Framing Error

A framing error occurs if the interface receiver doesn't recognize the stop bit at the end of a character, for example when strong line disturbances have influenced the stop bit.

Overrun Error

If a received character is not read from the receive data register, before the next character is received, an overrun error is generated. The received character is invalid

### **B&R INTERFACE MODULE**

B&R offers suitable hardware and software for almost all types of communication with other systems. For the B&R MINICONTROL system, the following interface modules are available for point to point connections from B&R PLCs to other B&R devices or to devices from other manufacturers:

Module	Interface
PIFA	Serial RS232 Interface
PATA	Serial interface for communication with MINICONTROL Operator Interface Panels or can be used as an SSI interface

#### **SLOTS**

INTERFAC	E MODULE	Slot	0 1 2 3 4			5			
PIFA	Base Unit C (CP32)	. NOT	•	•			3	Ō	_
PATA	Base Units A and C		•	•	•	•	•	•	

The CPU CP32 also has its own serial application interface (TTY, RS485).

### STANDARD SOFTWARE

B&R offers standard software for different types of communication. Point to point communication with B&R or other manufacturer systems and network connections are a couple. For more information see:

- Section A7 "PLC Programming / Standard Software"
- Section C5 "B&R MININET"
  Section C6 "Other Protocols"



## INTERFACE MODULES, PIFA - SERIAL RS232 INTERFACE

**TECHNICAL DATA** 

Galvanic Isolation Sender

Receiver

Handshake Lines

Connection Max. Distance

**Baudrates** Data Formats

Documentation German English

French

Interface





## **PIFA**

- 1 Serial Standard RS232 Interface
- Baudrate Software Definable up to 19200 Baud

PIN ASSIGNMENTS	Pin	R\$232
\$	1.08	GND
9 pin D-type	2	RXD
(M)	3	
1 10	4	DSR
6	5	DCD
	6	+5 VDC / 200 mA (Rev. 02.00 and higher)
	7	TXD
y ⇒ 5	8	RTS

PIFA

RS232

NO

NO

9 pin D-type (Male)

10 m

DSR, DTR, RTS

50 to 19200 Baud, software setting

5 to 8 Data Bits, Parity Yes/No/Even/Odd, 1/1.5/2 Stop Bits, Selected with software Hardware Manual MINICONTROL MAHWMINI-0

MAHWMINI-E MAHWMINI-F


DTR

SLOTS	779	0 1 2 3 4 5
PIFA	Base Unit C (CP32)	• •

### ORDER DATA

MCPIFA-2	Interface Module, 1 Serial RS232 Interface, 9 pin D-type Male

### CONNECTIONS



### STANDARD SOFTWARE

The following standard function blocks are available for the PIFA interface

FBK	Function	25
NDMA	Driver function block for connecting to a B&R MININET network (see section C5 - "B&R MININET")	
OPIB	Driver function block for controlling the BRRT360 operator panel BRRT360 (see section B2 "Visualization with Operator Panels")	
MCDA	Driver function block for controlling BRMEC mass memory device (see section A6 "MULTICONTROL Components")	

The function block OPIB (Operator Panel Driver) and MCDA (BRMEC Driver) are components of the standard software package SWSPSSTD02-0 (see section A7 "PLC Programming").

The NDMA function block (B&R MININET driver) is a component of the standard software package SWSPSCOM01-0 (see section A7 "PLC Programming").

A detailed description of the standard function blocks for the PIFA interface module shown above can be found in the "Standard Software User's Manual":

FBK	Volume	Chapter	
NDMA	2	Chap. 6 "B&R MININET"	20
OPIB	1	Chap. 4 "Operator Panels"	
MCDA	2	Chap. 11 "Device Driver"	

# INTERFACE MODULES, PATA - MINICONTROL OPERATOR PANELS / SSI

PLC SYSTEMS MINICONTROL COMPONENTS







# **PATA**

- 1 Serial Interface, Optional use as control for MINICONTROL operator panels or as SSI interface
- Can be used in all MINICONTROL base units
- Can be operated in all slots

SLOTS	77/02	Slot	0 1 2 3 4 5
PATA	Base Unit A and C	71/2	•••••

### ORDER DATA

MCPATA-0	Interface module for controlling MINICONTROL operator panels or can be used as an SSI interface
----------	-------------------------------------------------------------------------------------------------

PIN ASSIGNMENTS	Pin	Function
	1	DATA IN
9 pin D-type	2	DATA IN
(F)	3	Reset
_ ,5	4	GND
9 60	5	+24 VDC
	6	DATA OUT
, 60	7	DATA OUT
, 2 <sup>1</sup>	8	CLK
	9	CLK

### SSI INTERFACE

The following prerequisites must be met before connecting an absolute encoder to the SSI interface:

- Only absolute encoders with a monoflop time between 20 µsec and 260 µsec can be used
- Absolute encoders with up to maximum 24 bit (AG24) or 32 bit (AG32) can be read

Function blocks AG24 and AG32 are used. These are found in the standard software package 4 SWSPOS01-0 (Rev. 00.32 or higher).

## TECHNICAL DATA PATA

Interface	Synchronous Differential Signal Interface
Connection	9 pin D-type (F)
Max. Distance	100 m (see diagram)
Documentation German English French	Hardware Manual MINICONTROL MAHWMINI-0 MAHWMINI-E MAHWMINI-F

### MINICONTROL OPERATOR INTERFACE PANEL CONNECTIONS

Connection cable BRKA08-0 is required for the connection of a MINICONTROL operator panel to the PATA interface module.

#### **DISTANCE PATA - OPERATOR PANEL**

The connection cable between the PATA module and the MINICONTROL operator panel may be up to 100 meters long under certain conditions. The maximum distance depends on the wire cross-section of each line and the input voltage of the power supply module. The following diagram should make this relationship clear:



For distances over 30 meters, a twisted pair cable is to be used (e.g.  $5 \times 2 \times 0.14$  mm²). The pairs are to be twisted as follows:

DATA IN	with	DATA IN
DATA OUT	with	DATA OUT
CLK	with	CLK
+24 V	with	GND
RESET	with	GND

## STANDARD SOFTWARE

For communication with the MINICONTROL operator panel, standard function blocks are available. These are standard components of software package SWSPSSTD02-0 (see section A7 "PLC Programming/Standard Software").



# COUNTING AND POSITIONING, MODULES

PLC SYSTEMS
MINICONTROL COMPONENTS

### **GENERAL INFORMATION**

There are counter modules for positioning applications, counter modules for event counting and positioning modules:

Counter Modules for Positioning Applications This module has fast inputs and counters for actual position monitoring with incremental encoders and other hardware for positioning applications (analog outputs for motor control, fast digital inputs for end switches and reference switches, outputs for motor control enable). The positioning procedure is controlled by the application program in the CPU.

Counter Modules for Event Counting

The hardware is especially suited to event counting, i.e. these modules normally have several inputs and counters for monitoring events as fast as they can happen.

**Positioning Modules** 

In addition to the hardware components required for positioning applications, positioning modules have the respective firmware. That means that the application program in the CPU does not have to control the positioning procedure in detail, it just has to give commands (e.g. "Absolute Positioning" or "Positioning Relative to the Momentary Position"). The positioning module executes the respective command and sends "Position Reached" to the application program in the CPU.

There are a few different methods of positioning:

Dual Speed Positioning One or two motors with different speeds drive an axis. As long as the difference between set and actual positions is quite large, the faster motor is active. When the difference decreases enough, the slower motor kicks in and the faster motor drops out. This type of positioning inevitably leads to jumps in speed which causes unavoidable mechanical play.

Positioning with Stepper Motors The control electronics deliver pulses which turn the drive by a certain degree (one step). Since the angle of a single step is known, actual position monitoring is no longer required. The actual position is automatically identified by the number of pulses delivered. Stepper motors are used for small to medium sized applications.

Positioning with Servo Motors Analog signals are used for control  $(\pm 10~\text{V})$ , i.e. the speed of the motor can be controlled smoothly forwards and backwards. This type of positioning is preferred over dual speed positioning especially with larger masses, since the mechanics are not exposed to as much oscillation and shorter positioning times are possible.

PSA2

The following counter and positioning modules are available for the MINICONTROL system:

PNC4

P71 2

700	FNC4	FZLZ	FJAZ
Module Type	Counter Module	Counter Module	Positioning Module
Use	Positioning with Servo Motors or Dual Speed	Event Counting	Positioning with Stepper Motors
Counting Freq.	Max. 200 kHz	Max. 20 kHz	20 kHz <sup>1)</sup>
Axes/Counters	1	6	2

SLOIS	100	7(0)	0 1 2 3 4	5
PNC4	Base Unit C (CP32)		• •	M
PZL2	Base Unit C (CP32)		• •	
PSA2	Base Unit C (CP32)		• • 、	
0	0,		- 0	

#### STANDARD SOFTWARE

The respective standard function blocks are available for all counter and positioning modules of the MINICONTROL system:

Module	Functions Block	Use	Component of Software Package
PNC4	PNRC	Positioning with Servo Motors	SWSPSPOS01-0
PNC4	PNSC	Dual Speed Positioning	SWSPSPOS01-0
PZL2	CMDB	Counter Functions (Event Counting)	SWSPSSTD01-0
PSA2	PSA2	Positioning with Stepper Motors	SWSPSPOS01-0

See section A7 "PLC Programming/Standard Software" and section A8 "Positioning".

<sup>1)</sup> Maximal pulse frequency

# COUNTING AND POSITIONING MODULES, PNC4 - COUNTER MODULE (POSITIONING)

PLC SYSTEMS MINICONTROL COMPONENTS







# PNC4

- Fast Counter Module for Positioning Applications
- Counting Frequency Max. 200 kHz
- Counter Depth 24 Bit
- Analog Output for Control of Servo Motors (±10 V, 11 Bit)
- Supply of 5 V and 15 V Signal Encoders

See section A8 "Positioning" as well

SLOTS	77,07	7707	0 1 2 3 4 5
PNC4	Base Unit C (CP32)	350	• •

### ORDER DATA


MCPNC4-1

Counter module for positioning applications, binary 24 bit counter, counter frequency max. 200 kHz, 11 bit analog output ( $\pm$ 10 V), without galvanic isolation, supply of 5 V and 15 V signal encoders


### SIGNAL ENCODER

An optional 5 V or 15 V encoder can be connected to the PNC4 counter module. The PNC4 module provides power on the 9 pin D-type (F) for both types of encoder (15 V /max 300 mA on pin 3 and 5 V/max 500 mA on pin 9). Counter inputs A and B as well as reference pulse input Z are not galvanically isolated.

### Connection Diagram for the 15 V Encoder



### Connection Diagram for the 5 V Encoder



### TECHNICAL DATA PNC4

. A. I		13.5
7	Signal Encoder Connection	9 pin D-type (F)
	Signal Encoder Inputs Galvanically Isolated Nominal Input Voltage Min./Max. Input Voltage Input Current	NO 5 - 12 VDC 2.4 VDC / 15 VDC typ. 2 mA at 5 VDC typ. 5 mA at 15 VDC
1	Encoder Supply Supply Voltage Max. Load	From PNC4 Module 15 VDC 5 VDC 300 mA 500 mA
	Distance to Signal Encoder	Max. 50 meters when using signal encoders with square wave output signals
1	Input Frequency	Max. 50 kHz
	Counting Frequency With Single Evaluation With Double Evaluation With Four Fold Evaluation	Max. 50 kHz Max. 100 kHz Max. 200 kHz
2	Phase Shift between Counter Channels A and B	90°±30°
	Reference Pulse Delay	> 50 µsec
	Counting Depth	24 Bit Binary
2	Analog Output Output Voltage Resolution Quantification Error Offset Voltage	±10 V 10 Bit + Sign <1 Bit <1 mV
	Disturbance Resistance 1)	Grade 3
	Documentation German English French	Hardware Manual MINICONTROL MAHWMINI-0 MAHWMINI-E MAHWMINI-F
		40

PIN ASSIGNMENTS	Pin	Function
	1	Counter Channel B
Onio Damo	2	Counter Channel B
9 pin D-type (F)	3	+15 V Encoder Supply
(1)	4	Counter Channel A
9	5	Counter Channel A
o o	6	Ref. Potential for Encoder Supply
6	7 🔊	Reference Input Z
	8	Reference Input Z
	9	+5 V Encoder Supply
	27,0	120
± 10V	1	Analog Output ±10 V
	2	Analog Output ±5 V
	3	Analog Output ±5 V
4 🗐 🔘	4	Ref. Potential for Analog Output
10		

### STANDARD SOFTWARE

Software package SWSPSPOS01-0 contains, among other things, standard function blocks for positioning applications with servo motors and dual speed positioning (see section A7 "PLC Programming/Standard Software" as well for more information.

<sup>1)</sup> Signal encoder connections grounded on both sides according to DIN VDE 0843-4.



# COUNTING AND POSITIONING MODULES, PZL2 - COUNTER MODULE (EVENT COUNTING)

PLC SYSTEMS
MINICONTROL COMPONENTS



# PZL2

- Counter Module for Event Counting
- All Counter Channels are Galvanically Isolated
- Counting Frequency Max. 20 kHz
- Signal Voltage 24 V
- 6 Binary Decremental Counters
- 16 Bit Counter Depth

See section A8 "Positioning" as well

SLOTS		0 1 2 3 4 5
PZL2	Base Unit C (CP32)	•,•


### ORDER DATA

OKDEK DATA	~ Ø, ~ ~ Ø, ~ ~ Ø, ~ ~ ~ Ø, ~ ~ ~ ~ Ø, ~ ~ ~ ~	
MCPZL2-0	Counter Module for Event Counting, 6 bir input frequency max. 20 kHz, signal voltage 24	
	galvanically isolated	
V40		

### **FUNCTIONALITY**

The PZL2 module counters are decremental. They count from a defined value down to 0 and begin from the defined value again. Reaching 0 is indicated by setting a bit in the status register.

### INPUT CIRCUIT




1	ECHNICAL DATA	PZL2	
	Number of Counters	6	272
,5	Galvanic Isolation Channel - PLC Channel - Channel	YES YES	
	Input Voltage Nominal Maximum	24 V 30 V	
	Input Current	ca. 10 mA	
	Switching Threshold log. $0 \rightarrow \log 1$ log. $1 \rightarrow \log 0$	Max. 12.5 V Min. 6.5 V	21/2
8	Input Frequency	Max. 20 kHz	
ı	Counting Depth	16 Bit Binary	
	Documentation German English French	Hardware Manual MINICONTROL MAHWMINI-0 MAHWMINI-E MAHWMINI-F	415

### CONNECTIONS

Į 🗐 🤅	J.Co.	[	Counter Input 0 Reference Potential for Counter 0	
		[ 4	Counter Input 1 Reference Potential for Counter 1	
		2	Counter Input 2 Reference Potential for Counter 2	
		<u>{</u>	Counter Input 3 Reference Potential for Counter 3	
		4	Counter Input 4 Reference Potential for Counter 4	
5		5	Counter Input 5 Reference Potential for Counter 5	

### STATUS LEDs

The PZL2 module has two status LEDs per channel:



### STANDARD SOFTWARE


A standard function block for PZL2 module operation is included in software package SWSPSSTD01-0 (see section A7 "PLC Programming/Standard Software" as well).

# COUNTING AND POSITIONING MODULES, PSA2 - STEPPER MOTOR POSITIONING MODULE

PLC SYSTEMS MINICONTROL COMPONENTS







# PSA<sub>2</sub>

- Intelligent Positioning Module for Stepper Motors
- For Controlling Two Stepper Motors
- Pulse Frequency Max. 20 kHz
- 2 Potential Free Relay Contacts,
   8 Transistor Outputs, 10 Digital Inputs
- Faster Trigger Signal Input

See section A8 "Positioning" as well

 SLOTS
 0 1 2 3 4 5

 PSA2
 Base Unit C (CP32)

### ORDER DATA


MCPSA2-0

Positioning Module for Stepper Motors, for the control of two stepper motors, 1 potential free relay output per axis, 4 transistor outputs for stepper motor control, 5 digital inputs for end switches, reference switch, trigger switch and ready signals, pulse frequency max. 20 kHz

### **FUNCTIONALITY**

The PSA2 stepper motor control module is designed especially for positioning applications with stepper motors. Two axes can be controlled with a PSA2 module

## Diagram



The outputs of the PSA2 module for control electronics are: Pulse, Direction of Rotation, Enable and Booster (Current amplification during acceleration and deceleration phases). The control electronic inputs are: End Switch pos./neg., Reference Switch, Trigger Switch and Ready Signal.

### STANDARD SOFTWARE

A standard function block for PSA2 module operation is included in software package SWSPSPOS01-0 (see section A7 "PLC Programming/Standard Software" and section A8 "Positioning" for more information).

TECHNICAL DATA	199		PSA2	190.	
Axes 2					
Connections		Three 15	pin D-type (Fen	nale)	
Inputs End Switch Pos. End Switch Neg. Reference Switch Trigger Switch Ready Signal		2 2 2 24 V / 6 r	nically Isolated 4 V / 6 mA 4 V / 6 mA 4 V / 6 mA mA and 5 V / 4 18 V / ca. 5 mA	mA	
Transistor Outputs  Pulse Rotation Direction Enable Signal		N switchin 4 to 4 to	and Overload P g with active Pu 28 V, 50 mA 28 V, 50 mA 28 V, 50 mA		
Relay Output	30	V / 1 A, Internal	Protection Circ	cuit (Varisto	or)
Pulse Frequency		25 Hz to 20	kHz (Resolution	n 4 Hz)	
Acceleration Time from 25 (Start/Stop Frequency) to 2 (End Frequency)		60 m	nsec to 17 sec		
Modes of Operation		Linear Accelera	tion, Start/Stop	Operation	
Positioning Functions	Absolute, Rel	ative, Start at T	rigger Pulse, Er	ndless Pos	itioning
Resistance to Disturbance			/) for Inputs, VI st) 3 kV on all p		
Documentation German English French		M. M.	anual MINICON AHWMINI-0 AHWMINI-E AHWMINI-F	NTROL	

### CONNECTIONS

Inputs		Pin	Axis 0		Pin	Axis 1	
15	pin D-type		7/10			, i	100
	(M)	1	End Switch pos.		9	End Switch pos.	
	1	2	End Switch neg.		10	End Switch neg.	
9~	A	3	Reference Switch		11	Reference Switch	
	·	4	GND for Pin 1 to 3		12	GND for 9 to 11	
	•:	5	Trigger Signal 5 V		13	Trigger Signal 5 V	
		6	Trigger Signal 24 V	/	14	Trigger Signal 24 V	
		7	GND for 5 and 6		15	GND for 13 and 14	
45.4		8					
15*	≫'8						

Outputs Axis 0	Pin	Function	Pin	Function
15 pin D-type		73D		7. A.
(M)	1	Pulse	9	
1	2		10	
9	3	Direction of Rotation	11	Relay contact A
	4		12	Relay contact B
::	5	Enable	13	+ for Transistor Outp.
	6		14	Ready Signal
	7	Booster	15	GND for Transistor Outp.
	8			
12.				

Outputs Axis 1	Pin	Function	Pin	Function
15 pin D-type		1/200		. No.
(M)	1	Pulse	9	
1	2		10	
9	3	Direction of Rotation	11	Relay contact A
	4		12	Relay contact B
••	5	Enable	13	+ for Transistor Outp.
	6		14	Ready Signal
Sec. 1.	7	Booster	15	GND for Transistor Outp.
	8			
10.				



# OTHER MODULES, MZEA / MZEB - INPUT/TIMER MODULES

PLC SYSTEMS
MINICONTROL COMPONENTS



# MZEA / MZEB

- 4 Timers, 8 Digital Inputs
- Delay Time from 20 msec to 4 min
- 4 Time Ranges can be Set With Jumpers on the Module
- Fine Tuning with Potentiometer (Potentiometer on the MZEA Module, External Potentiometer connected to MZEB)
- Inputs are Galvanically Isolated
- Input Voltage 24 VDC
- LED Status Display for Inputs and Timers

	SLOTS			0	1	2	3	4	5
12	MZEA	Base Units A and C	27.	•	•	•	•	•	•

### ORDER DATA

Base Units A and C

MZEB

М	CN	17	ΕI	Δ.


Input/Timer Module, 8 digital inputs, input voltage 24 VDC, LED status display, galvanically isolated, reference potential GND, switching delay ca. 10 msec, four definable timers (on-delay), four time ranges set with jumpers, fine tuning with potentiometers on the module, times range from 20 msec to 4 min.

MCMZEB-0

Input/Timer Module, 8 digital inputs, input voltage 24 VDC, LED status display, galvanically isolated, reference potential GND, switching delay ca. 10 msec, four definable timers (on-delay), four time ranges set with jumpers, connections for external potentiometer, times range from 20 msec to 4 min.

### **FUNCTIONALITY**

By setting the Start/Stop address "O 0xy"  $^{-1}$ , the timer is started. When the defined time (T) has elapsed, the time address is "I 0xy"  $^{-1}$  = 1. It remains 1 until the "O" address is set. By resetting Start/Stop address "O", the timer is reset.



If Start/Stop address "O" is reset before the defined time has elapsed, the time begins at 0 again with a restart.


T	ECHNICAL DATA	MZEA	MZEB
	Inputs 8	8	25 <sup>2</sup>
3	Electrical Isolation Input - PLC Input - Input	YES (Optocoupler) NO	YES (Optocoupler) NO
	Input Voltage Nominal Minimal Maximal	24 VDC 16 VDC 30 VDC	24 VDC 16 VDC 30 VDC
	Input Resistance	ca. 2.2 kΩ	ca. 2.2 kΩ
	Switching Threshold log. 0 → log. 1 log. 1 → log. 0	Min. 16 VDC Max. 12 VDC	Min. 16 VDC Max. 12 VDC
	Input Current at 24 VDC	ca. 10 mA	ca. 10 mA
	Switching Delay log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	ca. 10 msec ca. 20 msec	ca. 10 msec ca. 20 msec
	Timers	4	4
	Timer Setting Normal Fine	With Jumpers With Pot. on Module	With Jumpers With External Pot. (1 M $\Omega$ )
	Time Range	See Table	See Table
ď	Repeatability	< 0.1 % 2)	< 0.1 % 2)
	Documentation German English French	Hardware Manual MAHWI MAHWI MAHWI	MINI-0 MINI-E

### TIME RANGE SETTINGS

Two jumpers exist for each channel. These are marked on the module as jumpers A and B. These jumpers are used to set the time range. They can be inserted and removed without any tools.

103	Jumper A	Jumper B	Time Range
	OPEN	OPEN	740 msec to 30 sec
Jumper Closed	OPEN	CLOSED	20 msec to 1 sec
	CLOSED	OPEN	90 msec to 4 sec
Jumper Open	CLOSED	CLOSED	6 sec to 4 min

### CONNECTIONS



 $<sup>^{1)}</sup>$  x is the slot number of the module (0 to 5), y is the timer number (0 to 3).


<sup>2)</sup> At constant environmental temperature

### **PLC SYSTEMS** MINICONTROL COMPONENTS

**A4** 



NOTES:





## CONTENTS

PLC SYSTEMS MULTICONTROL SYSTEM

# **CONTENTS**

PLC SYSTEMS
MULTICONTROL SYSTEM





# A5 SYSTEM MULTICONTROL

CONTENTS			80
GENERAL INFORMATION			82
THE B&R MULTIPROCESSOR TECHNOLOGY			82
RACKS			82
PERFORMANCE DATA			83
SLOT OVERVIEW			83
I/O MODULE OVERVIEW			84
EXPANSIONS			
INSTALLATION GUIDELINES			85
CABLING	4, 4	4	85
GROUNDING AND SHIELDING			
CABLE SHIELDING			87
ELECTROSTATIC DISCHARGE			
PROTECTIVE CIRCUIT			87
STOPAGE TEMPERATURES			87



# GENERAL INFORMATION, MODULE RACKS

PLC SYSTEMS
MULTICONTROL SYSTEM

### **GENERAL INFORMATION**

Communication

The system is described in detail in the "MULTICONTROL Hardware Manual".

The MULTICONTROL system is most powerful system in this range. The multiprocessor architecture in the MULTICONTROL system enables solutions for almost any automation problem. MULTICONTROL applications include:

Logic Control A MULTICONTROL system can have up to 1536 digital input/ outputs. The CPU has 42 KBytes of application program

memory. Control processing speed is 2.5 msec/K instructions.

The MULTICONTROL can also be integrated in a network -

Visualization This system provides visualization devices for every application - from single operator panels to high resolution full graphic

monitors. The visualization devices are described in section B.

with other B&R devices or with devices from other manufacturers. Networks such as ETHERNET (SINEC H1, FASTNET, TCP/IP), ARCNET, CAN Bus, B&R MININET as well as communication software packages are described in section C.

Industrial Computer

The B&R MAESTRO system can be integrated into the MULTICONTROL system. This enables the PLC to handle complex

automation tasks (CNC, Data storage and management). A complete description of the B&R MAESTRO system can be found in a solid part of the B&R MAESTRO system can be

ound in section D.

Positioning From simple single axis positioning tasks with servo motors or

stepper motors right up to complex CNC systems - the MULTICONTROL handles the job. See section A8 "Position-

ing".

PID Loop Control

Proven control algorithms, fast processors, powerful analog

inputs/outputs - for the MULTICONTROL System naturally

(see section A9 "PID Loop Control").

The B&R PROgramming SYStem is used to program the MULTICONTROL system.

### **MODULE RACK**


Three different racks exist for the MULTICONTROL system:

- MULTI
- MIDI
- M264

### **MULTI RACK**

With 16 slots, the MULTI rack is the largest of the three racks for PLC modules. There are three variations (0, 6 or 11 Slots for B&R MAESTRO Modules). Up to three expansion racks can be connected to the base rack using expansion modules (see section "Expansions").

### **Dimensions**



### THE B&R MULTIPROCESSOR TECHNOLOGY

When B&R started off the 80's with the predecessor of the MULTICONTROL system, a whole new multiprocessing concept was brought forth. Nobody could believe the success of the system. The idea was unheard of before and very good: Instead of the entire application program in a single processor (the CPU), multiple parallel processors (coprocessors) could be run in the same rack, each performing its own tasks. Each one of the coprocessors took care of its own part of the overall application. The CPU only had to control the communication between the other processors. This new concept brought about faster system reaction times and at the same time guaranteed that the system could be expanded at any time without slowing anything down.


In the period to follow, multiprocessor PLCs were developed by many other PLC manufacturers, but the efficiency and power of the MULTICONTROL remained on top. MULTICONTROL won the "Control Engineering" prize for innovation in 1988 for the best automation product of the year.

The next innovative step was also made by B&R. The B&R MAESTRO put the powers of PLC and industrial computer in one unit. The processors communicate over a common bus-faster and more secure than any network. Not enough. To perfect multiprocessor technology, B&R developed the B&R MAESTRO coprocessors. Several industrial computers (based on 680x0) on a common bus in the PLC, or in other words: A multiprocessing industrial computer in the multiprocessing PLC!

### MIDI RACK

With 7 slots, the MIDI rack is the smallest of the three racks.

### Dimensions



## PERFORMANCE DATA, SLOT OVERVIEW

# PLC SYSTEMS MULTICONTROL SYSTEM






### M264 RACK

The M264 rack has 11 slots for PLC modules.

#### Dimensions



### PERFORMANCE DATA

PU NTCP33	CP40 NTCP6#	CP60/CP70
Microprocessor	MOTOROLA 6303	MOTOROLA 6809
Application Program Memory	16 KByte (RAM/EEPROM) Max. 4.7 K Inst.	42 KByte (RAM/PROM) Max. 32 K Inst.
Processing Time	ca. 4 msec / K Inst.	ca. 2.5 msec / K Inst.
Data Memory 8 Bit Memory (Register) 1 Bit Memory (Flag)	7168 800	7168 800
Time/Date	Software Clock	Real-Time Clock

		RACK	
CPU	MULTI	MIDI	M264
CP40	•	• .ŏ	0
CP60/CP70	•	<ul><li>□ 1/2</li></ul>	0
NTCP33	0	0	•
NTCP6#	0	0	•

INPUT/OUTPUT	MULTI	RACK MIDI	M264	
Digital Inputs/Outputs Analog Inputs/Outputs	Max. 1536 Max. 256	Max. 168 Max. 112	Max. 264 Max. 80	

### NETWORK / COMMUNICATION

B&R MININET	YES	20
B&R NET2000	NO	
ARCNET	YES	
ETHERNET (SINEC H1) CAN BUS	YES YES	
Other Connections	YES	
Other Connections	ILO	70°0

### **SLOT OVERVIEW**

### **MULTI RACK**

The MULTI rack has 16 slots. In addition to the base rack<sup>1)</sup>, the number of slots can be increased to 64 with up to three expansion racks. Only digital input modules, digital output modules and timer modules can be operated in expansion racks.


	Base Rack	Expansion Rack
Digital I/O Modules	YES	YES
Timer Modules	YES	YES
Analog I/O Modules	YES	NO
Interface Modules	YES	NO
Peripheral Processors	YES	NO
Counting and Positioning Modules	YES	NO

### MIDI RACK

The MIDI rack has 7 equal slots. All MULTICONTROL system modules can be operated in these slots.

#### M264 RACK

The M264 rack has 11 slots. The first five slots (0 to 4) are for operating analog I/O modules, interface modules, NPO2 network processors and counting and positioning modules. Parallel processors can be operated in slots 1-4. Digital I/O modules and timer modules can be run in all slots.



<sup>1)</sup> The base rack is the rack in which the CPU is situated.





## I/O MODULE OVERVIEW, **EXPANSIONS**

**PLC SYSTEMS MULTICONTROL SYSTEM** 

### I/O MODULE OVERVIEW

#### **DIGITAL I/O MODULE**

E161 16 Inputs 24 VDC/AC E162 16 Inputs 220 VAC E163 16 Inputs 24 VDC I164 16 Inputs 120 VAC E243 24 Inputs 24 VDC A161 16 Relay Outputs 220 VAC / 2 A A162 16 Transistor Outputs 24 VDC / 2 A A163 16 Relay Outputs 220 VAC / 2 A A115 16 Transistor Outputs 24 VDC / 0,5 A A244 24 Transistor Outputs 24 VDC / 0,5 A A121 12 Triac Outputs 220 VAC / 2 A O125 12 Triac Outputs 120 VAC / 2 A			
E163 16 Inputs 24 VDC  I164 16 Inputs 120 VAC  E243 24 Inputs 24 VDC  A161 16 Relay Outputs 220 VAC / 2 A  A162 16 Transistor Outputs 24 VDC / 2 A  A163 16 Relay Outputs 220 VAC / 2 A  A115 16 Transistor Outputs 24 VDC / 0,5 A  A244 24 Transistor Outputs 24 VDC / 0,5 A  A121 12 Triac Outputs 220 VAC / 2 A	E161	16 Inputs 24 VDC/AC	
1164 16 Inputs 120 VAC  E243 24 Inputs 24 VDC  A161 16 Relay Outputs 220 VAC / 2 A  A162 16 Transistor Outputs 24 VDC / 2 A  A163 16 Relay Outputs 220 VAC / 2 A  A115 16 Transistor Outputs 24 VDC / 0,5 A  A244 24 Transistor Outputs 24 VDC / 0,5 A  A121 12 Triac Outputs 220 VAC / 2 A	E162	16 Inputs 220 VAC	
E243 24 Inputs 24 VDC  A161 16 Relay Outputs 220 VAC / 2 A  A162 16 Transistor Outputs 24 VDC / 2 A  A163 16 Relay Outputs 220 VAC / 2 A  A115 16 Transistor Outputs 24 VDC / 0,5 A  A244 24 Transistor Outputs 24 VDC / 0,5 A  A121 12 Triac Outputs 220 VAC / 2 A	E163	16 Inputs 24 VDC	
A161 16 Relay Outputs 220 VAC / 2 A  A162 16 Transistor Outputs 24 VDC / 2 A  A163 16 Relay Outputs 220 VAC / 2 A  A115 16 Transistor Outputs 24 VDC / 0,5 A  A244 24 Transistor Outputs 24 VDC / 0,5 A  A121 12 Triac Outputs 220 VAC / 2 A	I164	16 Inputs 120 VAC	
A162 16 Transistor Outputs 24 VDC / 2 A A163 16 Relay Outputs 220 VAC / 2 A A115 16 Transistor Outputs 24 VDC / 0,5 A A244 24 Transistor Outputs 24 VDC / 0,5 A A121 12 Triac Outputs 220 VAC / 2 A	E243	24 Inputs 24 VDC	
A163 16 Relay Outputs 220 VAC / 2 A  A115 16 Transistor Outputs 24 VDC / 0,5 A  A244 24 Transistor Outputs 24 VDC / 0,5 A  A121 12 Triac Outputs 220 VAC / 2 A	A161	16 Relay Outputs 220 VAC / 2 A	
A115 16 Transistor Outputs 24 VDC / 0,5 A  A244 24 Transistor Outputs 24 VDC / 0,5 A  A121 12 Triac Outputs 220 VAC / 2 A	A162	16 Transistor Outputs 24 VDC / 2 A	
A244 24 Transistor Outputs 24 VDC / 0,5 A A121 12 Triac Outputs 220 VAC / 2 A	A163	16 Relay Outputs 220 VAC / 2 A	
A121 12 Triac Outputs 220 VAC / 2 A	A115	16 Transistor Outputs 24 VDC / 0,5 A	
	A244	24 Transistor Outputs 24 VDC / 0,5 A	
0125 12 Triac Outputs 120 VAC / 2 A	A121	12 Triac Outputs 220 VAC / 2 A	
	0125	12 Triac Outputs 120 VAC / 2 A	The state of the s

#### **ANALOG I/O MODULES**

	. 170
PE42	4 Inputs 0 - 10 V / 0 - 20 mA (10, 12 Bit)
PE82	8 Inputs 0 - 10 V / 0 - 20 mA (10, 12 Bit)
PE84	8 Inputs 0 - 10 V / 0 - 25 mA (16 Bit)
PE16	16 Inputs 0 - 10 V / 0 - 50 mA / PT100 / NTC / PTC (16 Bit)
PTE8	8 Inputs for FeCuNi and NiCrNi Sensor
PT81	8 Inputs for PT100 Sensor
PA42	4 Outputs ±10 V / 0 - 20 mA (11, 13 Bit)
PA81	8 Outputs ±10 V / 0 - 20 mA (11, 13 Bit)

### **EXPANSIONS**

The MULTI base rack has 16 module slots. Up to three additional, so-called expansion racks can be connected to the base rack with expansion modules EXS2 and EXS3. The number of modules which can be operated in a MULTICONTROL system can be increased to 64.


An expansion unit requires:

- A MULTI Rack (e.g. ECR165-0)
   A MULTICONTROL Power Supply Module (NT43, NT44 or PS45)
- An Expansion Receiver Module EXE3
- An Expansion Cable (Model No. ECEXKA-1)

Only B&R standard cables (length 0.5 meters) may be used for connection of expansion senders and receivers. In addition to the above mentioned modules in the expansion unit, an expansion sender EXS2 is required in the base rack. Up to three expansion receivers can be connected to the expansion sender.

#### Slots and Their Functionality

The EXS2 expansion module is operated in the base rack in the slot between the power supply module and the CPU. Therefore, it doesn't require an application slot. The expansion receiver module EXE3 is operated in the expansion rack in the slot next to the power supply module. The slot to the right of the expansion receiver remains free and must be covered with a dummy cover. The two D-type (F) connectors on the expansion modules are run parallel to one-another. This means that the top one or the bottom one can be used. The expansion unit can be situated either over top of or underneath the base rack.



### Setting Up Several Expansion Units:

The following must be done in order to connect more expansion units to the base

- If the base rack is the top or the bottom rack in the system, then the second  $expansion \ unit is \ connected \ to \ the \ expansion \ receiver \ of \ the \ first \ expansion$ unit in this case.
- If the first two expansion units are above and below the base rack, then both expansion receivers must be connected to the expansion sender of the

## INSTALLATION GUIDELINES, CABLING

# PLC SYSTEMS MULTICONTROL SYSTEM





### **INSTALLATION GUIDELINES**

The MULTICONTROL rack may only be mounted horizontally. At least 10 cm must be left free above and below the rack in order to allow proper cooling.

The maximum operating temperature (normally 60 °C) which is indicated in the "Technical Data" section for every module must be kept underneath the rack. No external fans or ventilation is required.

Devices causing heavy electromagnetic disturbance (e.g. frequency converters, transformers, motor governors, etc..) must be situated a suitable distance away from the system. The distance between one of these devices and the PLC should be as large as possible. In certain cases a partition should be constructed between the two (MU metal).

#### Module Installation/Removal

To install or remove modules:

- A module may not be inserted or removed if power is applied to the PLC.
- Before removing modules, all terminations and cables must be unplugged
- Terminal blocks or connectors carrying current may not inserted or removed
- A delay time between disconnecting a terminal block and removing a module can be defined on certain modules. This is described in the respective module description.

In order to install a module, the following sequence is to be used:

- Disconnect any live lines
- Disconnect all terminal blocks and connectors
- Remove dummy front cover
- Insert module and secure it using the fastening bolts provided
- Connect the respective lines

### **Slot Assignments**

Although digital I/O modules can be operated in any slot, there are a few standard guidelines that should be followed. Digital output modules, that sometimes must switch heavy loads, should be located on the right-hand side of the rack. The recommended sequence is shown below (modules from left to right):

- Peripheral processors
- Interface modules
- Analog I/O modules, counting and positioning modules
- Timer modules
- Digital input modules
- Digital output modules

### **CABLING**

Only copper wire may with a cross-section of maximum 2.5 mm² (AWG12)¹ and minimum 0.14 mm² (AWG26) be connected to the terminal blocks. Aluminium wire is not allowed.

#### **Permitted Line Cross-Sections**


typ. 0.75 mm² max. 2.5 mm²	
min. 0.14 mm² max. 2.5 mm²	May.
0.5 mm² for D-type 0.5 to 2.5 mm² for	
min. 0.14 mm² max. 0.5 mm² for E max. 2.5 mm² for s	
	max. 2.5 mm² min. 0.14 mm² max. 2.5 mm² 0.5 mm² for D-type 0.5 to 2.5 mm² or to min. 0.14 mm² max. 0.5 mm² for E

### Cable Types / Cable Ducting

There are basically three different types of cable used:

- Interface cable and cable carrying analog signals or counter signals.
   These cables must be shielded.
- Lines carrying digital input signals
- Digital output lines.

These three types of cable must be separated from each other. That means that running cables parallel to one another is to be avoided. If different types of cable must be run in the same duct, the duct should be split with a grounded metal partition. Ideally, a separate duct should be used for each type of cable and these ducts should be kept apart from each other:



O Since 1991, only terminal blocks which are suitable for a line cross section of maximum 2.5 mm<sup>2</sup> (AWG12) are delivered. The maximum permitted line cross section is indicated on the terminal block itself.





# **GROUNDING, SHIELDING**

# PLC SYSTEMS MULTICONTROL SYSTEM

### **GROUNDING AND SHIELDING**

In most applications, the PLCs are built into cabinets that also have electromagnetic switching elements (relays, ...), transformers, governors, frequency converters, etc. Electromagnetic disturbance of some type is unavoidable in these cabinets. These disturbances cannot generally be avoided but negative influence to the PLC can be greatly reduced by suitable grounding, shielding and other protective measures. These protective measures include cabinet grounding, module grounding, cable shield grounding, proper cable laying procedures and cable cross-sections.

Grounding basically has two different functions:

- Protective ground
- Rerouting electromagnetic disturbance

#### **Protective Ground**

Protective grounding is a security measure for any device with a conductive housing if high voltages can occur within the device. If an error occurs causing a connection between a line carrying power and the housing, the protective ground causes a short to ground which in turn causes an especially suited security component or circuit (e.g. fuse, FI switch, ...) to break the contact to the power source. Protective grounding is subject to certain legal conditions in most countries (e.g. CSA, VDE, ...). The MULTICONTROL rack has a protective ground connection on the left side. The line used to ground the unit must be a cross-section of at least 2.5 mm²).


### **Rerouting Electromagnetic Disturbance**

Grounding the rack with the ground connector and relatively thin wire is only partially effective against electromagnetic disturbance. In order to effectively suppress this type of disturbance, a number of steps must be taken.


The next step is to properly connect the PLC rack with the ground potential. This is done by making a good contact with the grounded cabinet wall. A good contact is normally established by using contact washers on all four rack fastening screws:



The washers that are provided with the rack break through the coating of the rack and provide a good contact with the cabinet wall and the PLC. If the back wall is coated or painted, a proper ground can only be guaranteed if the unit is fastened with screws that threaded directly into the wall. If this is not the case, another contact washer must be used between the back wall and the nut on the fastening screw:



A ground rail is mounted underneath the rack, which is also fastened to the cabinet wall making a good contact. Cable shielding and module connections that must be grounded (e.g. ground connections for a PE82, power supply module, ...) are attached to this rail:



The distance between the ground rail and the PLC housing may be a maximum of 15 cm. No electromagnetic elements may be situated in between. Normally a cable duct is situated directly beneath the housing. Another ground rail is also to be mounted under the expansion rack if modules in the expansion rack are operating with shielded cables (e.g. timer modules with potentiometer fine tuning).

# ELECTROSTATIC, PROTECTIVE CIRCUITS, STORAGE TEMPERATURES

PLC SYSTEMS MULTICONTROL SYSTEM





### **CABLE SHIELDING**

The following connections are to be made with shielded cables (possible exceptions are indicated in the respective module description):

- Analog I/O
- Interface cable
- Pulse encoder cable
- Connection of external potentiometers with timer modules

The cable shielding is to be grounded on both ends. The ground connection for the PLC end is made to the grounding rail under the housing:



If possible potential shifting between the PLC and the connected element causes transient current over the cable shield (quite often connected with cable warming), there are some special measures to be taken: The cable shield is to be separated and bridged with a high quality high value capacitor (ceramic or gold foil capacitor higher or equal to 47 nF, less resistance at higher frequencies).

## **ELECTROSTATIC DISCHARGE**

PLC modules are equipped with integrated CMOS components which are sensitive to electrostatic discharge. Before handling modules, the user must discharge him/herself by gripping any grounded metal object immediately before touching the module.

### **PROTECTIVE CIRCUITS**

An external protective circuit is required for relay output modules and generally recommended for transistor output modules. No protective circuitry is required for triac output modules.

Module	Туре	External Protective Circuit
A161	Relay Outputs	Generally Required
A163	Relay Outputs	Generally Required
A162	Transistor Outputs	Recommended
A115	Transistor Outputs	Recommended
A244	Transistor Outputs	Recommended
A121	Triac Outputs	Not Required
O125	Triac Outputs	Not Required

Protective elements can be installed either on the load to be switched, on the output module, or on terminals between. Most manufacturers of relays and solenoids offer protective elements for the respective devices.

The following components can be used:

- RC elements: Can be used for AC and DC 1)
- Varistors: these are usually used for AC. Since varistors wear out, the use of RC combinations is preferred.
- Diodes: these are used for DC only.
- Diodes/Z Diodes: these are used for DC only. This type of protective element permits shorter cutoff times. Are used especially for transistor outputs.

### STORAGE TEMPERATURES

For modules that do not have battery buffers or rechargeables, storage temperatures between -20 to +80 °C are acceptable. Modules having battery buffers or rechargeable batteries may only be stored in temperatures from 0 to +60 °C.

Typical values for RC combinations for protective circuits (ca. 10 W inductive load) are: 22  $\Omega$ /250 nF at 24 VDC/AC or 220  $\Omega$ /1  $\mu$ F at 220 VAC.



# **CONTENTS**

# PLC SYSTEMS MULTICONTROL COMPONENTS

6	MULTICONTROL COMPONENTS				
300	CONTENTS	200	300	1900	0.0
	MODULE OVERVIEW				(5)
	BASE UNITS				
	OPERATING TEMPERATURE, RELATIVE HUMII				
	CPUS				91
	MULTI AND MIDI RACKS				
	M264				
	TECHNICAL DATA				_
	ON-LINE INTERFACE				
	APPLICATION INTERFACE				
	INSTRUCTION SET				
	DATA MEMORY				
	MATHEMATICS INSTRUCTIONS				
	FIRST SCAN FLAG				
	TIME CYCLES, TIME PULSES, SOFTWARE 1				
	SOFTWARE CLOCK, REALTIME CLOCK				
	SAFETY AND DIAGNOSIS FUNCTIONS				
	CP40 - MULTICONTROL CPUTYPE A				
	CP60 - MULTICONTROL CPUTYPE B				
	CP70 - MULTICONTROL CPUTYPE B				96
	NTCP33 - MULTICONTROL CPUTYPE A		<i>y</i>		97
	NTCP6# - MULTICONTROL CPU TYPE B				98
	RACKS				
	GENERAL INFORMATION				
	EXPANSION RACKS				
	SLOTS				
	INSTALLATION				
	SLOTS FOR INDUSTRIAL COMPUTER MOD	G-10 -			
	OVERVIEW				
	DIMENSIONS AND TECHNICAL DATA		<i>p</i> .		101
	DOWER OF DEATH OF THE PARTY OF				27
	POWER SUPPLY MODULES				
	GENERAL INFORMATION				
	M264 RACK				
	OVERVIEW				
	SLOTS				102
	STRUCTURE				102
	BATTERY				102
	FUSES				102
	READY RELAY	· · · · · · · · · · · · · · · · · · ·	A		103
	STATUS LEDS				103
	EXTENDED DIAGNOSIS FUNCTIONS				103
	SELECTING A POWER SUPPLY MODULE				
	NT43 - MULTICONTROL POWER SUPPLY M				
	NT44 - MULTICONTROL POWER SUPPLY M				
	PS45 - MULTICONTROL POWER SUPPLY M				
	NTCP#3 - MULTICONTROL POWER SUPPLY				
	NTCP64 - MULTICONTROL POWER SUPPLY				
	PSCP65 - MULTICONTROL POWER SUPPLY				
	4.0				
	APPLICATION PROGRAM MEMORY MODULES		-	24.	110
	APM MODULE FOR TYPE A PROCESSOR IN	MODULES			110
	APM MODULE FOR TYPE B PROCESSOR N	MODULES			110
	EE32 - TYPE A, 16 KBYTE EEPROM, 16 KBY				
	EE96 - TYPE B, 96 KBYTE EEPROM	76.,	75.,	<i>1</i> 0°,	112
	EP128 - TYPE B, 128 KBYTE EPROM	727		72,	113
	FP128 / FP384 - TVPF R 128 / 384 KRVTF F				114

# **CONTENTS**

# PLC SYSTEMS MULTICONTROL COMPONENTS





DIGITAL INFOT MIODOLLS	
GENERAL INFORMATION	
E161 - 16 INPUTS 24 VDC / AC	11
E162 - 16 INPUTS 220 VAC	118
E163 - 16 INPUTS 24 VDC	
I164 - 16 INPUTS 120 VAC	12 <sup>2</sup>
E243- 24 INPUTS 24 VDC	122
DIGITAL OUTPUT MODULES	124
GENERAL INFORMATION	
A161 - 16 RELAY OUTPUTS 220 VAC / 2 A	
A163 - 16 RELAY OUTPUTS 220 VAC / 2 A	
A162 - 16 TRANSISTOR OUTPUTS 24 VDC / 2 A	12
A115 - 16 TRANSISTOR OUTPUTS 24 VDC / 0.5 A	128
A244 - 24 TRANSISTOR OUTPUTS 24 VDC / 0.5 A	120
A121 / O125 - 12 TRIAC OUTPUTS 220 VAC / 120 VAC	
7.1217 G126 12 11.176 GG11 G1G 226 V.G7 126 V.G	
ANALOG INPUT MODULES	133
GENERAL INFORMATION	
PE42 / PE82 - 4 / 8 INPUTS 0 - 10 V / 0 - 20 mA (10, 12 BIT)	
PE84 - 8 INPUTS 0 - 10 V / 0 - 25 mA (16 / 15 BIT)	
PE16 - 16 INPUTS U, I, PT100, NTC, PTC (16 BIT)	
PTE8 - 8 INPUTS FOR FeCuni OR NICrNi TEMPÉRATURE SENSORS (10 BIT)	
PT81 - 8 INPUTS FOR PT100 TEMPERATURE SENSORS (10 BIT)	138
ANALOG OUTPUT MODULES	
GENERAL INFORMATION	
PA42 / PA81 - 4 / 8 OUTPUTS ±10 V / 0 - 20 mA (11, 13 BIT)	14
INTERFACE MODULES	140°
GENERAL INFORMATION	
SERIAL INTERFACES	
B&R INTERFACE MODULE	14
STANDARD SOFTWARE	
INTERFACE CONVERTER	
PIF1 - 1 SERIAL RS232/TTY OR 1 RS422 INTERFACE	
PIF3 - 2 SERIAL RS232/TTY AND 1 CENTRONICS INTERFACE	145
INT1 - RS232 / RS485 INTERFACE CONVERTER	146
PARALLEL PROCESSOR	
GENERAL INFORMATION	
PP60 - PARALLEL PROCESSOR TYPE B	150
PP60 MEM - PARALLEL PROCESSOR TYPE B WITH 128 KBYTE DATA MEMORY	15 <sup>2</sup>
COUNTING AND POSITIONING MODULES	15
GENERAL INFORMATION	152
STANDARD SOFTWARE	152
PNC3 - COUNTER MODULE FOR POSITIONING APPLICATIONS	
PSA2 - POSITIONING MODULE FOR 2 STEPPER MOTOR AXES	
PZL1 - COUNTER MODULE FOR EVENT COUNTING	
PNC8 - POSITIONING MODULE FOR 4 AXES	
PWP4 - ULTRASONIC TRANSDUCER MODULE	
	~95°
OTHER MODULES AND DEVICES	160
GENERAL INFORMATION	
EXS2 / EXE3 - EXPANSION SENDER / EXPANSION RECEIVER MODULES	
NP02 - COMMUNICATION PROCESSOR FOR OTHER PROTOCOLS	
PMV4 - PROPORTIONAL SOLENOID MODULE	
1 MIV 4 - 1 NOT ON HOUSE SOLEMOID MIODULE	103



# MODULES, BASE UNIT

### **PLC SYSTEMS MULTICONTROL COMPONENTS**

### **MODULE OVERVIEW**

The following table is an overview of all modules of the MULTICONTROL system described in this section.

•				5	_	64
Module	Function	Rack	-9.cg,	Σ	<u>E</u>	<u>M</u>
NT43	Power Supply Modul	e 24 VDC / 100 W	1	•	<b>A</b>	-,050
NT44	Power Supply Modul			<b>A</b>	_	
PS45	Power Supply Modul	e 120 VAC / 100 W		<b>A</b>	<u>*</u> >0	
NTCP33	Power Supply /CPU	Module 24 VDC / Ty	pe A			<b>A</b>
NTCP63	Power Supply /CPU	Module 24 VDC / Ty	ре В			<b>A</b>
NTCP64	Power Supply /CPU	Module 240 VAC / T	ype B			<b>A</b>
PSCP65	Power Supply /CPU	Module 120 VAC / T	уре В			<b>A</b>
CP40	CPU Module Type A			<b>A</b>	•	
CP60	CPU Module Type B			<b>A</b>	•	
CP70	CPU Module Type B			<b>A</b>	<b>A</b>	
EXS2	Expansion Sender M	lodule		<b>A</b>		
EXE3	Expansion Receiver	Module		<b>A</b>		
E161	Digital Input Module	16 x 24 VDC/AC		•	•	
E162	Digital Input Module	16 x 220 VAC		•	• //	•
E163	Digital Input Module	16 x 24 VDC		•		•
I164	Digital Input Module			20.0	•	•
E243	Digital Input Module	24 x 24 VDC		67.		
A161	Digital Output Modul	e 16 x 220 VAC / 2 A	(Relay)	•	•	
A162	Digital Output Modul			•	•	
A163	Digital Output Modul			•	•	
A115	Digital Output Modul			•	•	
A244	Digital Output Modul			•	•	•
A121	Digital Output Modul			•	•	- 50
0125	Digital Output Modul	e 12 x 120 VAC / 2 A	(Iriac)	•	•	110,
PE42	Analog Input Module	4 x 0-10 V / 0-20 m/	A (10, 12 Bit)		• 10	0
PE82	Analog Input Module	8 x 0-10 V / 0-20 m/	A (10, 12 Bit)		•	0
PE84	Analog Input Module	8 x 0-10 V / 0-25 m/	A (16 Bit)			0
PE16	Analog Input Module	16 x U, I, PT100, N	ΓC (16 Bit)		•	0
PTE8	Analog Input Module	8 x NiCrNi, FeCuNi	(10 Bit)		•	0
PT81	Analog Input Module				•	0
PA42	Analog Output Modu				•	0
PA81	Analog Output Modu	le 8 x ±10 V / 0-20 n	nA (11, 13 Bit)		•	О
PIF1	Interface Module 1 x				•	0
PIF3	Interface Module 2 x	RS232/TTY, 1 x CE	NTRONICS		•	0
PP60	Peripheral Processo	r Type B			•	- 10),
PP60 MEM	Peripheral Processo		RAM		•	<b>∂</b>
NP02	Network Processor C				*)	ာ
PNC3	Counting/Positioning	Module 1 Axis (Sen	(n Motors)	2.0	245	)
PNC8	Counting/Positioning				•	õ
PSA2	Counting/Positioning				•	ŏ
PZL1	Counter Module for E			_	•	ŏ
PWP4	Ultrasonic Transduce			ū	•	Ö
PMV4	Proportional Solenoi	d Module		٥	•	0

- The module can only be operated in certain assigned system slots. The module can be operated in all application module slots. The module can only be operated in slots 0 to 4 in the M264 rack.


- The module can only be operated in slots 1 to 4 in the M264 rack
  The module can be operated in all slots of a MULTI base rack

### **BASE UNIT**

 $The following \, components \, are \, required \, for \, running \, a \, MULTICONTROL \, system: \,$ 

- CPU
- Rack
- Power Supply Module
- Application Program Memory Module

These components are called the base unit, e.g. with the MULTI rack:



Base unit components of the MULTICONTROL system must be ordered

### **OPERATING TEMPERATURE, RELATIVE HUMIDITY**

The following applies to all MULTICONTROL components unless other values are indicated in the "Technical Data" sections for each module:

Operating Temperature	0 to 60 °C
Relative Humidity	0 to 95 %, non-condensing

# **CPUS**


### **PLC SYSTEMS MULTICONTROL COMPONENTS**





### **CPUS**

### **MULTI AND MIDI RACKS**



### CP40 / CP60

- Status LED
- Reset Button
- Status Display Application Program Memory Modules
- On-line Interface Programming LED

#### CP70

- Status LED
- Reset Button
- Status Display Application Program Memory Modules
- On-line Interface Programming LED


### M264 RACK

The power supply module and the CPU module have been combined into a single unit for the M264 rack. This module is available in different versions. The differences are the input voltage (24 VDC, 220 VAC or 120 VAC) and the CPU type (Type A with 6303 processor, Type B with 6809 processor). The following versions have been made from the possible combinations:

Input Voltage	CPU Type A	CPU Type B
24 VDC	NTCP33	NTCP63
240 VAC		NTCP64
120 VAC		PSCP65

Since the CPUs of the NTCP63, NTCP64 and PSCP65 modules all have the same functionality, they have been described together in this section:

For modules NTCP63, NTCP64 and PSCP65 NTCP6#



### NTCP33

- Status LED
- On-line Interface

### NTCP6#

- Status LED
- On-line/Application Interface Application Program Memory Module





# **CPUS**

# PLC SYSTEMS MULTICONTROL COMPONENTS

### **TECHNICAL DATA**

The most important data and differences in MULTICONTROL CPUs are:

		Тур	e A 👌		Type B	
		CP40	NTCP3x	CP60	CP70	NTCP6x
.0	Rack	MULTI, MIDI	M264	MU M	LTI, DI	M264
	Application Program Memory	16 K 4.7 K		-3	42 KByte 42 K Inst.	
	Processing Time	4 msec	/K Inst.	1.7 /	2.5 msec/	K Inst.1)
	8 Bit Data Memory Remnant		ig/ko:	7168 7148		
	1 Bit Data Memory Remnant	WILLIAM STATE		800 300		
	Microprocessor	63	03		6809	
	Application Interface on Module	NO	NO	RS232	RS232 RS485 TTY	RS485 TTY
	Status Display	YES	NO	YES	YES	NO
	Reset Button	YES	NO	YES	YES	NO
	Time/Date	Softwar	e Clock	Rea	al-Time Cl	ock

### **ON-LINE INTERFACE**

All CPU modules have an on-line interface for communicating with the programming device. The on-line interface is a TTY interface with a transmission rate of 62.5 kBaud which can only be used for on-line operation with the programming device. The on-line interface is situated on the front of the module and labeled "PG". An on-line cable is required for on-line operation:

4	On-line Cable	For On-line Interface	Programming PC	Bus Type/Port
2,5	BRKAOL-0	BRIFPC-0 BRKAOL5-1	IBM AT compatible PCs Notebooks	ISA (PC/AT) CENTRONICS

### **APPLICATION INTERFACE**

CPUs CP70 and NTCP6# both have application interfaces.

CPU	Interface	120
CP70 NTCP6#	RS232/RS485/TTY, Only one at any given time RS232/RS485/TTY, Only one at any given time	<sup>7</sup> ; <sub>O2</sub> ,

#### INSTRUCTION SET

The processor for the instruction set used in programming a CPU is very important. There are two different processors used:

- CPU with MOTOROLA 6303 Processor (Type A)
- CPU with MOTOROLA 6809 Processor (Type B)

CPU	Rack		Processor	
CP40	MULTI, MIDI	N	IOTOROLA 6303	
NTCP33	M264	N N	IOTOROLA 6303	
ODCO	MULTI MIDL	150 T	IOTODOL A COOO	
CP60	MULTI, MIDI		IOTOROLA 6809	
CP70	MULTI, MIDI	N	IOTOROLA 6809	
NTCP6#	M264	N	IOTOROLA 6809	

#### DATA MEMORY

Data memory is split into flag (1 bit memory locations) and registers (8 bit memory locations). The contents of remnant memory locations is also retained if the PLC is switched off. Non-remnant memory locations are automatically deleted when the unit is switched on. The MULTICONTROL CPU has the following data memory:

_			
	8 Bit Memory Locations (Registers)		
	Total	7168	
	Remnant	7148	
	1 Bit Memory Locations (Flags)		
	Total	800	
	Remnant	300	

#### **MATHEMATICS INSTRUCTIONS**


All CPUs are equipped with fast floating point mathematics instructions. In addition to basic mathematics calculations such as addition, subtraction, multiplication, division and square root, many conversion and utility programs are available. Numbers are displayed in the standard 4 byte IEEE format. The mathematics commands can be used in ladder diagram (standard function blocks) and in STL programs.

### **FIRST SCAN FLAG**

The First Scan Flag is a memory location (R 0899, T D64) which is automatically set to 1 by the operating system during the first program cycle, otherwise the flag is 0. The first scan flag is used for program initializations. The first scan flag can be connected to the enable input of function blocks which should only be run one time in the first program cycle.

### TIME CYCLES, TIME PULSES, SOFTWARE TIMERS

Time cycles are generated by the operating system. Four different time bases are available. Time pulses are flags that are set to 1 in defined intervals for the duration of one program cycle.



Software timers are flags which operate as initial delays. The time of the delay can be defined by the user.

All CPUs have four pulse generators and four cycle time generators (each for 10 msec, 100 msec, 1 sec and 10 sec) as well as 64 software timers.

With type B CPUs of revision 59.xx or above, the processing time can be switched from 2.5 msec/K to 1.7 msec/K instructions.

# PLC SYSTEMS MULTICONTROL COMPONENTS





### SOFTWARE CLOCK, REAL-TIME CLOCK

All CPUs have date and time functions:

	CP40 / NTCP33	CP60 / CP70 / NTCP6#
Туре	Software Clock	Real-Time Clock
Nonvolatile Memory	NO	YES
Time	Hrs., Min., Sec., 1/100 Sec.	Hrs., Min., Sec., 1/100 Sec.
Date	Day Counter	Day, Month, Year, Weekday

### SAFETY AND DIAGNOSIS FUNCTIONS

All CPUs are equipped with extensive safety and diagnosis functions. They have software watchdogs which can bring the system back to a safe operational state, even if the CPU has failed completely.

An overview of safety and diagnosis functions can be found in section A1 "System Selection".

	NTCP33	CP40 / CP60 / CP70	NTCP6#
Software Watchdog	• 28	•	
Hardware Watchdog	• 1/co.	•	7/2°
Application Program Test		•	<i>∞</i> •
Hardware Reset	~(C)	• 40	•
Trap Error Recognition	•	• 110	•
Stack Pointer Test	•	•.60	•
Bus Monitor	•	0	•
Expansion Test		O	

Standard

Only with power supply modules with expanded diagnosis functionality





## CPUS, CP40 - MULTICONTROL CPU TYPE A

PLC SYSTEMS MULTICONTROL COMPONENTS



# **CP40**

- 16 KByte Application Program Memory (4.7 K Instructions)
- Processing Time 4 msec/K Instructions
- 7168 Registers800 Flags
- MOTOROLA 6303 Microprocessor
- Hardware Watchdog
- Status Display, Reset Button, Status LED
- Date/Time Function (Software Clock)
- Software Compatible to all Type A CPUs

#### **SLOTS**


The CP40 CPU can be used in racks MULTI and MIDI1).

### ORDER DATA

ECCP40-01

MULTICONTROL CPU Type A, 16 KByte Application Program Memory for 4.7 K Instructions, Processing Time 4 msec/K Instructions, 7168 Registers, 800 1 Flags, No Application Program Memory Module

### **OPERATIONAL ELEMENTS**



т	ECHNICAL DATA	CP40	
	RackMULTI, MIDI¹)	- Trans	44
Ī	Processor	MOTOROLA 6303	
Ì	Processing Time	4 msec/K Instructions	
	Registers Remnant Non-Remnant	7168 7148 20	
	Flags Remnant Non-Remnant	800 300 500	
Ż	Application Program Memory (Not incl.)	EE32	
	Reset Button	YES	
	Status Display	YES	
	Time/Date	Software Clock, Volatile	
	Number of I/O Digital Analog	1536 256	
	Serial Interfaces On-line Interface Application Interface	TTY (62.5 kBaud) -	
	Hardware Timers	512	
	Software Timers	64	
	Timing Pulse/Timing Cycle	10 msec, 100 msec, 1 sec, 10 sec	27.20
100	Power Consumption At +8 V At +15 V At -30 V	5 W - -	
	Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL  MAHWMULTI-0  MAHWMULTI-E  MAHWMULTI-F  MAHWMULTI-I  MAHWMULTI-S	

### PROGRAMMING

Programming the CP40 is done with the B&R PROgramming SYStem. Powerful standard function blocks are used for creating the program. The B&R PROgramming SYStem and standard software packages are described in section A7 "PLC Programming".

The application program memory module is not included with the CP40 CPU and must be ordered separately. A description of the application program memory module for the CP40 CPU can be found in section "Application Program Memory Modules".

<sup>1)</sup> If the CP40 is to be operated in a MIDI rack, slot 0 cannot be used for an application module

# CPUS, CP60 - MULTICONTROL CPU TYPE B

# PLC SYSTEMS MULTICONTROL COMPONENTS







# **CP60**

- 42 KByte Application Program Memory (Max. 42 K Instructions)
- Optional Processing Time<sup>1)</sup>
   (1.7 or 2.5 msec/K Instructions)
- 7168 Registers 800 Flags
- MOTOROLA 6809 Microprocessor
- Hardware Watchdog
- Status Display, Reset Button, Status LED
- Date/Time Function (Real-Time Clock)
- Software is Compatible to all Type B CPUs and Parallel Processors

### **SLOTS**


The CP60 CPU can be used with racks MULTI and MIDI<sup>2)</sup>.

### ORDER DATA

ECCP60-01

MULTICONTROL CPU Type B, 42 KByte Application Program Memory for Max. 42 K Instructions, Processing Time¹) Optional (1.7 msec or 2.5 msec/K Instructions), 7168 Registers, 800 Flags, Real-Time Clock, No Application Program Memory Module

### **OPERATIONAL ELEMENTS**



# With revision 59.xx of type B CPUs, the processing time can be switched from 2.5 msec/K to 1.7 msec/K instructions.

TECHNICAL DATA	CP60	
RackMULTI, MIDI <sup>2)</sup>	No.	M.
Processor	MOTOROLA 6809	
Processing Time <sup>1)</sup> Optional 2 MHz 3 MHz	2.5 msec/K Instructions 1.7 msec/K Instructions	
Registers Remnant Non-Remnant	7168 7148 20	"Midporic
Flags Remnant Non-Remnant	800 300 500	
Application Program Memory	42 KByte RAM (for Max. 42 K Instr On Module, PROM Module Not In	
Reset Button	YES	
Status Display	YES	
Time/Date	Real-Time Clock, Non-Volati	le
Number of I/O Digital Analog	1536 256	
Serial Interfaces On-line Interfaces Application Interface	TTY (62.5 kBaud) -	Validation of the Control of the Con
Hardware Timers	512	"A'_{Q''
Software Timers	64	
Timing Pulse/Timing Cycle	10 msec, 100 msec, 1 sec, 10	sec
Power Consumption At +8 V At +15 V At -30 V	3,9 W 2.0 W -	
Documentation German English French Italian Spanish	Hardware Manual MULTICONT MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	ROL

### PROGRAMMING

Programming the CP60 is done with the B&R PROgramming SYStem. Powerful standard function blocks are used for creating the program. The B&R PROgramming SYStem and standard software packages are described in section A7 "PLC Programming".

The PROM application program memory module (EPROM, EEPROM or Flash-PROM) is not included with the CP60 CPU and must be ordered separately. A description of the application program memory module for the CP60 CPU can be found in section "Application Program Memory Modules".

<sup>&</sup>lt;sup>2)</sup> If the CP60 is run in a system with the MIDI rack, slot 0 cannot be used for application modules.





# CPUS, CP70 - MULTICONTROL CPUS TYPE B

PLC SYSTEMS MULTICONTROL COMPONENTS



# **CP70**

- 42 KByte Application Program Memory (max. 42 K Instructions)
- Processing Time<sup>1)</sup> Optional (1.7 or 2.5 msec/K Instructions)
- 7168 Registers
   800 Flags
- MOTOROLA 6809 Microprocessor
- Hardware Watchdog
- Status Display, Reset Button, Status LED
- RS232/RS485/TTY Application Interface
- Date/Time Function (Real-Time Clock)
- Software is Compatible to all Type B CPUs and Parallel Processors

### SLOTS


The CP70 CPU can be operated in the MULTI and MIDI<sup>2)</sup> racks.

### ORDER DATA

ECCP70-01

MULTICONTROL CPU Type B, 42 KByte Application Program Memory for Max. 42 K Instructions, Processing Time¹) Optional (1.7 msec or 2.5 msec/K Instructions), 7168 Registers, 800 Flags, Real-Time Clock, No Application Program Memory Module

### **OPERATING ELEMENTS**



With revision 59.xx of type B CPUs, the processing time can be switched from 2.5 msec/K to 1.7 msec/K instructions.

TECHNICAL DATA	CP70	
Rack MULTI, MIDI <sup>2)</sup>		55
Processor	MOTOROLA 6809	
Processing Time <sup>1)</sup> Optional 2 MHz 3 MHz	2.5 msec/K Instructions 1.7 msec/K Instructions	
Registers Remnant Non-Remnant	7168 7148 20	
Flags Remnant Non-Remnant	800 300 500	7/2
Application Program Memory	42 KByte RAM (for Max. 42 K Instructions) On Module, PROM Module Not Included	
Reset Button	YES	
Status Display	YES	
Time/Date	Real-Time Clock, Nonvolatile	200
Number of I/O Digital Analog	1536 256	
Serial Interfaces On-line Interface Application Interface	TTY (62.5 kBaud) RS232/RS485/TTY	
Hardware Timers	512	
Software Timers	64	200
Timing Pulse/Timing Cycle	10 msec, 100 msec, 1 sec, 10 sec	
Power Consumption At +8 V At +15 V At -30 V	8,9 W 0.9 W 0.8 W	
Documentation German English	MULTICONTROL CPU CP70 User's Manual MACP70KB-0 MACP70KB-E	

### **PROGRAMMING**

Programming the CP70 is done with the B&R PROgramming SYStem. Powerful standard function blocks are used for creating the programs. The B&R PROgramming SYStem and standard software packages are described in section A7 "PLC Programming".

The PROM application program memory module (EPROM, EEPROM or Flash-PROM) is not included with the CP70 CPU and must be ordered separately. A description of the application program memory module for the CP70 CPU can be found in section !Application Program Memory Modules".

<sup>2)</sup> If the CP70 is run in a system with the MIDI rack, slot 0 cannot be used for application modules.

# CPUS, NTCP33 - MULTICONTROL CPU TYPE A

PLC SYSTEMS MULTICONTROL COMPONENTS







# NTCP33

- 16 KByte Application Program Memory (4.7 K Instructions)
- Processing Time 4 msec/K Instructions
- 7168 Registers,
   800 Flags
- MOTOROLA 6303 Microprocessor
- Status LED
- Date/Time Function (Software Clock)
- Software is Compatible to all Type A

### SLOTS


The NTCP33 power supply / CPU module can only be operated in the assigned slot of the M264 rack.

### ORDER DATA

MULTICONTROL Power Supply / CPU Module Type A, 16 KByte Application Program Memory for 4.7 K Instructions, Processing Time 4 msec/K Instructions, 7168 Registers, 800 Flags, With EE32 Application Program Memory Module

M2NTCP33-0 For 24 VDC Input Voltage

### OPERATIONAL ELEMENTS



₹	ECHNICAL DATA	NTCP3#	0,
	RackM264	Mar.	
Ī	Processor	MOTOROLA 6303	
ı	Processing Time	4 msec/K Instructions	
	Registers Remnant Non-Remnant	7168 7148 20	
1	Flags Remnant Non-Remnant	800 300 500	0,
	Application Program Memory (incl.)	EE32	
	Reset Button	NO	
	Status Display	NO	Jion
J	Time/Date	Software Clock, Volatile	900
	Number of I/O Digital Analog	264 80	
	Serial Interfaces On-line Interface Application Interface	TTY (62.5 kBaud) -	
Ī	Hardware Timers	88	
	Software Timers	64	0
	Timing Pulse/Timing Cycles	10 msec, 100 msec, 1 sec, 10 sec	
	Power Consumption At +8 V At +15 V At -30 V	3.3 W - -	
	Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	'apariton'

### PROGRAMMING

Programming the NTCP33 is done with the B&R PROgramming SYStem. Powerful standard function blocks are used for creating the programs. The B&R PROgramming SYStem and standard software packages are described in section A7 "PLC Programming".

The EE32 application program memory module is included with the NTCP33 CPU. A description of the application program memory module can be found in section "Application Program Memory Module".





# CPUS, NTCP6# - MULTICONTROL CPU TYPE B

**TECHNICAL DATA** 

PLC SYSTEMS MULTICONTROL COMPONENTS



# NTCP6#

- 42 KByte Application Program Memory (Max. 42 K Instructions)
- Processing Time<sup>1)</sup> Optional (1.7 or 2.5 msec/K Instructions)
- 7168 Registers 800 Flags
- MOTOROLA 6809 Microprocessor
- Status LED
- RS485/RS232/TTY Application Interface
- Date/Time Function (Real-Time Clock)
- Software is Compatible to all Type B CPUs and Parallel Processors

#### **SLOTS**


The NTCP6# power supply/CPU module can only be operated in the assigned slot of the M264 rack

### ORDER DATA

MULTICONTROLPower Supply/CPU Module Type B, 42 KByte Application Program Memory for Max. 42 K Instructions, Processing Time<sup>1)</sup> Optional (1.7 msec or 2.5 msec/K Instructions), 7168 Registers, 800 Flags, Real-Time Clocks, RS485/RS232/TTY Application Interface

M2NTCP63-0for 24 VDC Input VoltageM2NTCP64-0for 220 VAC Input VoltageM2PSCP65-0for 120 VAC Input Voltage

### **OPERATING ELEMENTS**



	ECHNICAL DATA	NICPO#	
Ī	Rack M264	The state of the s	2525
Į	Processor	MOTOROLA 6809	
	Processing Time <sup>1)</sup> Optional 2 MHz 3 MHz	2.5 msec/K Instructions 1.7 msec/K Instructions	
	Registers Remnant Non-Remnant	7168 7148 20	
	Flags Remnant Non-Remnant	800 300 500	
	Application Program Memory	42 KByte RAM (for Max. 42 K Instructions) On Module, PROM Module Not Included.	
	Reset Button	NO	
	Status Display	NO	
	Time/Date	Real-Time Clock, Nonvolatile	
Ş	Number of I/O Digital Analog	264 80	
	Serial Interfaces On-line Interface Application Interface	TTY (62.5 kBaud) RS485/RS232/TTY	
	Hardware Timers	88	
ı	Software Timers	64	
7	Timing Pulse/Timing Cycle	10 msec, 100 msec, 1 sec, 10 sec	
	Power Consumption At +8 V At +15 V At -30 V	4,0 W 2.0 W	
Ó.	Documentation English English French Italian Spanish	Hardware-Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	

NTCP6#

### PROGRAMMING

Programming the NTCP6# is done with the B&R PROgramming SYStem. Powerful standard function blocks are used for creating programs. The B&R PROgramming SYStem and standard software packages are described in section A7 "PLC Programming".

The PROM application program memory module is not included with the NTCP6# CPU and must be ordered separately. A description of the PROM application program memory module can be found in section "Application Program Memory Modules".


With revision 59.xx of type B CPUs, the processing time can be switched from 2.5 msec/K to 1.7 msec/K instructions.

### **PLC SYSTEMS MULTICONTROL COMPONENTS**





NOTES:





# **MODULE RACKS**

# PLC SYSTEM MULTICONTROL COMPONENTS

### **GENERAL INFORMATION**

The module rack is a housing that is open at the front and is equipped with guide tracks (slots) in which the modules are inserted. The bus board is located at the back of the module rack along with connecting slots for modules. Inserting a module in the rack automatically makes all necessary connections.

#### **EXPANSION RACK**

The MULTICONTROL PLC system can be expanded with an expansion rack (only with MULTI rack). Up to three additional racks can be connected to the main rack via an expansion sender / receiver. The number of available slots is expanded to 64.

### SLOTS

A module rack provides a certain number of slots for PLC modules. These slots are designated - beginning with the slot directly next to the CPU - from left to right with hexadecimal numbers. The slot description is given on the top side of the rack.

Rack	Slot	Designation
MULTI	16	0 to F
MIDI	7	1 to 7
M264	11	0 to A

The system slots for the power supply module and the CPU are provided additionally and are labeled on the legend strips with "NT/PS" or "CPU". MULTICONTROL reserves the slot between the power supply module and The CPU for an expansion sender.

### MOUNTING


The sides of the module rack are equipped with mounting brackets. The mounting brackets are in the back (for panel mount installation). By reversing the sides, the module rack can also be installed in a mounting frame.

### INDUSTRIAL COMPUTER MODULE SLOTS

Differentiate between:


- a) Racks suitable for PLC modules
  - b) Racks suitable for PLC modules and industrial computer modules

### **OVERVIEW**




### ECR165-0

MULTICONTROL module rack, 16 slots for application modules, system slots for power supply module, CPU and expansion sender module




### HCR166-0

Same as ECR165-0, with 6 application slots for the operation of B&R MAESTRO industrial computer modules




#### HCR169-0

Same as ECR165-0, with 11 application slots for the operation of B&R MAESTRO industrial computer modules



### MDR085-1

MIDICONTROL module rack, 7 slotsforapplication modules, system slots for power supply module and CPU



### M2R111-0

M264 module rack, 11 slots for application modules, 5 of which are for the operation of analog I/O modules, interface modules, counter and positioning modules, system slots for power supply module and CPU

### ORDER DATA

ECR165-0	MULTICONTROL module rack, 16 slots for PLC modules
HCR166-0	MULTICONTROL module rack, 16 slots for PLC modules, 6 of which are for the operation of B&R MAESTRO industrial computer modules
HCR169-0	MULTICONTROL module rack, 16 slots for PLC modules, 11 of which are for the operation of B&R MAESTRO industrial computer modules
MDR085-1	MIDICONTROL module rack, 7 slots for PLC modules
M2R111-0	M264 module rack, 11 slots for PLC modules, 5 of which are for the operation of P modules (analog modules, interface modules, network processor NP02 etc.), 4 slots are for the operation of the PP60 parallel processor


# **MODULE RACKS**

PLC SYSTEM
MULTICONTROL COMPONENTS

A6



## **MEASUREMENTS AND TECHNICAL DATA**



	Size in mm / inch	ECR165-0 HCR166-0 HCR169-0	MDR085-1	M2R111-0
а	Width	482.6 / 19.0	279.4 / 11.0	355.6 / 14.0
b	Height	221.4 / 8.717	221.4 / 8.717	221.4 / 8.717
C	Depth	145 / 5.709	145 / 5.709	145 / 5.709
d	Cutout Width	446 / 17.559	243 / 9.567	319 / 12.559
е	Horizontal distance between holes	464.6 / 18.291	261.4 / 10.291	337.6 / 13.291
f	Vertical distance between holes	146.1 / 5.752	146.1 / 5.752	146.1 / 5.752
g	Distance to holes from top/bottom	37.65 / 1.482	37.65 / 1.482	37.65 / 1.482
h	Distance to holes from left/right	9 / 0.354	9 / 0.354	9 / 0.354
i	Thickness of the brackets	2 / 0.079	2/0.079	2/0.079

### **Technical Data**

### ECR165-0, HCR166-0, HCR169-0, MDR085-1, M2R111-0

V	10
Material	BI. ZINCOR (electrolytically galvanized sheet metal)
Surface Treatment	Pulverized, RAL 9005 fine structure
Grounding	Via side screws, contact washers and grounding clamps
Operating Temperature	0 to 60 °C
Relative Humidity	0 to 95 %, non-condensing



# **POWER SUPPLY MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

### **POWER SUPPLY MODULES**

### **GENERAL INFORMATION**

Power supply modules generate the internal voltages required by the PLC (+8 V, + 15 V and -30 V) from an input voltage of 24 VDC, 120 VAC or 240 VAC. Each rack requires a power supply module which operates in the far left slot in the rack (labeled "NT/PS").

### M264 MODULE RACK

The power supply and CPU are combined in one module for the M264 system. This module can be obtained in several versions. The differences are input voltage (24 VDC, 240 VAC or 120 VAC) and CPU type (type A with 6303 processor, type B with 6809 processor). The following module versions result from the possible combinations:

Input Voltage	CPU Type A	CPU Type B
24 VDC	NTCP33	NTCP63
240 VAC		NTCP64
120 VAC		PSCP65

Since the power supply for the NTCP33 and NTCP63 modules are the same, they are grouped in this section as follows:

NTCP#3	for the NTCP33 and NTCP63 modules	

#### **OVERVIEW**


Power supply modules are high efficiency electrically isolated switching power supplies. There is a power supply module for each module rack that is distinguished by its input voltage and power output:

Designation	PLC System	Input Voltage	Output Power
NT43	MULTI, MIDI	24 VDC	100 W
NT44	MULTI, MIDI	240 VAC	100 W
PS45	MULTI, MIDI	120 VAC	100 W
NTCP#3	M264	24 VDC	50 W
NTCP64	M264	240 VAC	60 W
PSCP65	M264	120 VAC	60 W

### SLOTS

Power supply modules can only be operated in the slot provided for them (far left slot). A labelling strip is attached to the top of the module rack. The system slot for the power supply module is labeled "NT/PS" on this strip.

#### CONSTRUCTION



#### **BATTERY**

The lithium battery in the power supply module is used to back up the memory of all processor modules if the PLC is turned off. It is not included in the delivery of the power supply module and must be ordered separately.



### **FUSES**

The power supply module inputs have fuses to protect against reverse polarity and overloading. Remove the supply voltage from the power supply module before changing a fuse.

Module	PLC System	Fuse	
NT43	MULTI, MIDI	10 A 250 V slow blow	. 6
NT44	MULTI, MIDI	2,5 A 250 V slow blow	
PS45	MULTI, MIDI	2,5 A 250 V slow blow	
NTCP#3	M264	6,3 A 250 V slow blow	
NTCP64	M264	2,5 A 250 V slow blow	
PSCP65	M264	2,5 A 250 V slow blow	

# **POWER SUPPLY MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

A6



#### READY RELAY


The ready relay is closed if an application program is running in the main CPU. The ready relay LED is lit as long as the ready relay is closed. The ready relay function is only available in power supply modules with extended diagnostics functions. The LED and relay are always off for power supply modules without extended diagnostics functions.

Possible reasons for opening the ready relay:

- Diagnostics error
- Application program not running
- Watchdog time out
- Internal supply voltage outside the valid range

#### STATUS LEDS

Power supply modules provide LEDs that show certain operating modes:



... the LED is provided on the power supply module

### **EXTENDED DIAGNOSTICS FUNCTIONS**

"Extended Diagnostics Functions" are available in addition to the elementary diagnostics functions provided with all B&R PLC systems. These diagnostics functions include:

- 1 bit bus test
- 8 bit bus test
- Hardware watchdog
- Permanent application program checksum test
- Expansion rack test (only with MULTICONTROL systems)
- Ready relay test

Module	PLC System	<b>Extended Diagnostics Functions</b>
NT43	MULTI, MIDI	OPTIONAL
NT44	MULTI, MIDI	OPTIONAL
PS45	MULTI, MIDI	YES
NTOD#O		V=0.200
NTCP#3	M264	YES
NTCP64	M264	YES
PSCP65	M264	YES

If a module rack connected to a MULTICONTROL system with expansion units uses a power supply module with extended diagnostics functions, then the power supply modules in all of the other racks must have extended diagnostics functions.

### SELECTING A POWER SUPPLY MODULE

The total power consumption of all modules in a rack is the criteria used for selecting a power supply module. The power consumption for each module is listed under "Technical Data". The power specifications of all modules are separated according to voltage (+8 V, +15 V and -30 V). The power specifications for each voltage are to be added together for all modules in a rack and may not exceed the maximum power rating for that voltage specified in the technical data for the power supply module. Also, the sum of the power consumption for all voltages may not exceed the maximum power specifications of the power supply module.

If a M264 system is used, the maximum power for +8 V and -30 V are to be multiplied by 2 when calculating the total power. The total power consumption of all modules calculated with the following formula may not exceed the maximum power of the power supply module.

$$P_{ges} = 2 * P_{8V} + P_{15V} + 2 * P_{-30V}$$

#### Sizing Example

The main rack of the MULTICONTROL system contains the following modules:

- 1 CP60 CPU
- 2 PP60 Parallel Processor
- 2 PE82 Analog Input Modules
- 1 PNC3 Counter Module
- 2 PIF3 Interface Module
- 1 PTE8 Analog Input Module 1 PA81 Analog Output Module
- 2 E 161 Input Modules
- 3 A 161 Output Modules

This configuration results in the following power requirements:

Module	at +8 V	at +15 V	at -30 V	Sum	
1 x CP60	3.9 W	2.0 W	-	5.9 W	
2 x PP60	14 W	3.0 W	1.0 W	18.0 W	
2 x PE82	0.8 W	0.8 W	0.6 W	2.2 W	
1 x PNC3	1.2 W	0.4 W	0.6 W	2.2 W	
2 x PIF3	4.4 W	1.6 W	2.6 W	8.6 W	
1 x PTE8	1.4 W	1.0 W	1.9 W	4.3 W	
1 x PA81	0.5 W	3.3 W	4.4 W	8.2 W	
2 x E 161	0.4 W	1.6 W	-	2.0 W	
3 x A 161	0.6 W	9.9 W	-	10.5 W	
Sum	27.2 W	23.6 W	11.1 W	61.9 W	

The maximum load for the MULTICONTROL power supply modules are:

Module	at +8 V	at +15 V	at -30 V	Sum	
NT43	65 W	100 W	30 W	100 W	
NT44	65 W	100 W	30 W	100 W	
PS45	65 W	100 W	30 W	100 W	

None of the maximum rating are exceeded in this example. Any of the power supply modules can be used.



# POWER SUPPLY MODULES NT43 - 24 VDC / 100 W

**TECHNICAL DATA** 

Power Output

PLC SYSTEMS MULTICONTROL COMPONENTS



# **NT43**

- Electrically Isolated Switching Power Supply
- Input Voltage 24 VDC
- Large Input Voltage Range (18 to 32 VDC)
- Current Requirement Max. 7 A
- Power Output 100 W
- No External Protective Capacitor Required for Three Phase Bridge
- Expanded Diagnostics Functions if Required
- Ready Relay

### **SLOTS**


The NT43 power supply module can be used in MULTICONTROL and MIDICONTROL systems.

### ORDER DATA

MULTICONTROL Power Supply Module, input voltage 24 VDC, power output 100 W, ready relay

ECNT43-0 with extended diagnostics functions ECNT43-1 without extended diagnostics functions

## OPERATION ELEMENTS



#### MULTICONTROL, MIDICONTROL PLC System Input Voltage 24 VDC Nominal Min./Max. 18 / 32 VDC External Protective Capacitor Single Phase Bridge $6800\,\mu\text{F}\,/\,35\,\text{V}$ Three Phase Bridge Current Requirement max. 7 A Input Capacitance 6000 μF Fuse 10 A 250 V slow blow **Extended Diagnostics Functions** Optional Ready Relay Max. Load on Contacts 2000 VA / 150 W Transient Voltage 250 V<sub>ms</sub> 4000 V<sub>ms</sub> Breakdown Voltage Protection Varistor **Output Voltages** +8 V, +15 V, -30 V

**NT43** 

at +8 V at +15 V at -30 V	65 W 100 W 30 W
Total	100 W
Documentation	MULTICONTROL Hardware Manual
German	MAHWMULTI-0
English	MAHWMULTI-E
French	MAHWMULTI-F
Italian	MAHWMULTI-I
Spanish	MAHWMULTI-S

## POWER SUPPLY MODULES NT44 - 240 VAC / 100 W

# PLC SYSTEMS MULTICONTROL COMPONENTS

Spanish







# **NT44**

- Electrically Isolated Switching Power Supply
- Input Voltage 240 VAC
- Large Input Voltage Range (187 to 288 VAC)
- Input Voltage Frequency 47 to 63 Hz
- Current Requirement Max 1 A
- Power Output 100 W
- Expanded Diagnostics Functions if Required
- Ready Relay

#### SLOTS


The NT44 power supply module can be used in MULTICONTROL and MIDICONTROL systems.

#### ORDER DATA

MULTICONTROL Power Supply Module, input voltage 240 VAC, power output 100 W, ready relay

ECNT44-0 with extended diagnostics functions ECNT44-1 without extended diagnostics functions

### **OPERATION ELEMENTS**



#### **TECHNICAL DATA** NT44 MULTICONTROL, MIDICONTROL PLC System Input Voltage 240 VAC Nominal 187 / 288 VAC Min./Max Input Voltage Frequency 47 to 63 Hz Current Requirement max. 1 A Fuse 2.5 A 250 V slow blow **Extended Diagnostics Functions** Optional Ready Relay Max. Load on Contacts 2000 VA / 150 W 250 V<sub>rms</sub> 4000 V<sub>rm</sub> Transient Voltage Breakdown Voltage Varistor Protection **Output Voltages** +8 V, +15 V, -30 V Power Output at +8 V 65 W at +15 V 100 W at -30 V 30 W 100 W Total MULTICONTROL Hardware Manual MAHWMULTI-0 Documentation German MAHWMULTI-E English MAHWMULTI-F French MAHWMULTI-I Italian

MAHWMULTI-S





# POWER SUPPLY MODULES PS45 - 120 VAC / 100 W

PLC SYSTEMS MULTICONTROL COMPONENTS



# **PS45**

- Electrically Isolated Switching Power Supply
- Input Voltage 120 VAC
- Large Input Voltage Range (96 to 144 VAC)
- Input Voltage Frequency 47 to 63 Hz
- Current Requirements Max. 2 A
- Power Output 100 W
- Extended Diagnostics Functions
- Ready Relay

### SLOTS


The PS45 power supply module can be used in MULTICONTROL and MIDICONTROL systems.

### ORDER DATA

ECPS45-0

MULTICONTROL Power Supply Module, Input Voltage 120 VAC, Power Output 100 W, Ready Relay, with Extended Diagnostics Functions

### **OPERATION ELEMENTS**



### TECHNICAL DATA PS45

PLC System	MULTICONTROL, MIDICONTROL	-51-25
Input Voltage Nominal Min./Max.	120 VAC 96 / 144 VAC	
Input Voltage Frequency	47 to 63 Hz	
Current Requirement	max. 2 A	
Fuse 2,5 A 250 V slow blow		.5
Extended Diagnostics Functions	YES	
Ready Relay Max. Load on Contacts Transient Voltage Breakdown Voltage Protection	2000 VA / 150 W 250 V <sub>rms</sub> 4000 V <sub>rms</sub> Varistor	
Output Voltages	+8 V, +15 V, -30 V	
Power Output at +8 V at +15 V at -30 V Total	65 W 100 W 30 W 100 W	ni
Documentation German English French Italian Spanish	MULTICONTROL Hardware Manual MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	
	Input Voltage Nominal Min./Max.  Input Voltage Frequency  Current Requirement  Fuse 2,5 A 250 V slow blow  Extended Diagnostics Functions  Ready Relay Max. Load on Contacts Transient Voltage Breakdown Voltage Protection  Output Voltages  Power Output at +8 V at +15 V at -30 V Total  Documentation German English French Italian	Input Voltage Nominal Min./Max.  120 VAC Min./Max.

# POWER SUPPLY MODULES NTCP33, NTCP63 - 24 VDC / 50 W

PLC SYSTEMS MULTICONTROL COMPONENTS







# NTCP#3

- Electrically Isolated Switching Power Supply
- Input Voltage 24 VDC
- Large Input Voltage Range (18 to 32 VDC)
- Current Requirements Max. 4,5 A
- Power Output 50 W
- No External Protective Capacitor Required
- Extended Diagnostics Functions
- Ready Relay

### **SLOTS**

The NTCP#3 CPU / Power Supply Module can only be used in the specified system slot in the M264 system.

#### ORDER DATA

M264 CPU / Power Supply Module, Input Voltage 24 VDC, Power Output 50 W, Ready Relay, with Extended Diagnostics Functions


M2NTCP33-0 CPU Type A, 16 KByte Application Program Memory for 4.7 K

Instructions, Process Time approx. 4 msec / K Instructions

M2NTCP63-0 CPU Type B, 42 KByte Application Program Memory for max.
42 K Instructions, Process Time approx. 2.5 msec / K Instruc-

tions, Real Time Clock, RS485/RS232/TTY User Interfaces

### **OPERATION ELEMENTS**



#### **TECHNICAL DATA** NTCP33, NTCP63 PLC System M264 Input Voltage 24 VDC Nominal 18 / 32 VDC Min./Max. **External Protective Capacitor** One Phase Bridge Three Phase Bridge Current Requirement max. 4.5 A Input Capacitance 6000 μF Fuse 6.3 A 250 V slow blow **Extended Diagnostics Functions** YES Ready Relay Max. Load on Contacts 2000 VA / 150 W $250 \, V_{ms} \\ 4000 \, V_{ms}$ Transient Voltage Breakdown Voltage Protection Varistor Output Voltages +8 V, +15 V, -30 V Power Output at +8 V 25 W 50 W at +15 V 24 W at -30 V 50 W Total Documentation MULTICONTROL Hardware Manual MAHWMULTI-0 German MAHWMULTI-E English MAHWMULTI-F French MAHWMUI TI-I Italian MAHWMULTI-S Spanish



# **A6**

## POWER SUPPLY MODULES NTCP64 - 240 VAC / 60 W

PLC SYSTEMS MULTICONTROL COMPONENTS



# NTCP64

- Electrically Isolated Switching PS
- Input Voltage 240 VAC
- Large Input Voltage Range (187 to 288 VAC)
- Input Voltage Frequency 47 to 63 Hz
- Current Requirement Max. 1 A
- Power Output 60 W
- Extended Diagnostics Functions
- Ready Relay

### SLOTS

The NTCP64 CPU / Power Supply Module can only be used in the specified system slot in the M264 system.


#### ORDER DATA

M264 CPU / Power Supply Module, Input Voltage 240 VAC, Power Output 60 W, Ready Relay, with Extended Diagnostics Functions

M2NTCP64-0

CPU Type B, 42 KByte Application Program Memory for max. 42 K Instructions, Process Time approx. 2.5 msec / K Instructions, Real time Clock, RS485/RS232/TTY User Interface

### **OPERATION ELEMENTS**



#### TECHNICAL DATA NTCP64 PLC System M264 Input Voltage 240 VAC Nominal Min./Max 187 / 288 VAC Input Voltage Frequency 47 to 63 Hz Current Requirement max. 1 A Fuse 2.5 A 250 V slow blow **Extended Diagnostics Functions** YES Ready Relay 2000 VA / 150 W Max. Load on Contacts 250 V<sub>rms</sub> 4000 V<sub>rms</sub> Transient Voltage Breakdown Voltage Varistor Protection Output Voltages +8 V, +15 V, -30 V Power Output at +8 V at +15 V 30 W 60 W 30 W at -30 V 60 W Total MULTICONTROL Hardware Manual MAHWMULTI-0 Documentation German MAHWMULTI-E English French MAHWMULTI-F MAHWMULTI-I Italian MAHWMULTI-S Spanish

## POWER SUPPLY MODULES PSCP65 - 120 VAC / 60 W

PLC SYSTEMS MULTICONTROL COMPONENTS







# PSCP65

- Electrically Isolated Switching PS
- Input Voltage 120 VAC
- Large Input Voltage Range (96 to 144 VAC)
- Input Voltage Frequency 47 to 63 Hz
- Current Requirement Max. 2 A
- Power Output 60 W
- Extended Diagnostics Functions
- Ready Relay

#### SLOTS

The PSCP65 CPU / Power Supply Module can only be used in the specified system slot in the M264 system.


#### ORDER DATA

M264 CPU / Power Supply Module, Input Voltage 240 VAC, Power Output 60 W, Ready Relay, with Extended Diagnostics Functions

M2NTCP65-0

CPU Type B, 42 KByte Application Program Memory for max. 42 K Instructions, Process Time approx. 2.5 msec / K Instructions, Real time Clock, RS485/RS232/TTY User Interface

#### **OPERATION ELEMENTS**



ď	TECHNICAL DATA	PSCP65	70,
	PLC System	M264	Trans.
	Input Voltage Nominal Min./Max.	120 VAC 96 / 144 VAC	
	Input Voltage Frequency	47 to 63 Hz	
ĺ	Current Requirement	max. 2 A	Naille .
A	Fuse 2.5 A 250 V slow blow		
	Extended Diagnostics Functions	YES	n,
	Ready Relay Max. Load on Contacts Transient Voltage Breakdown Voltage Protection	2000 VA / 150 W 250 V <sub>rms</sub> 4000 V <sub>rms</sub> Varistor	
	Output Voltages	+8 V, +15 V, -30 V	
2	Power Output at +8 V at +15 V at -30 V Total	30 W 60 W 30 W 60 W	WHILES.
	Documentation German English French Italian Spanish	MULTICONTROL Hardware MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	Manual



# APPLICATION PROGRAM MEMORY MODULES

PLC SYSTEMS MULTICONTROL COMPONENTS

#### **APPLICATION PROGRAM MEMORY MODULES**

Basically, there are two groups of application program memory modules (APM Module):

- APM Module for Type A CPUs (e.g. CP40)
- APM Module for Type B CPUs (e.g. CP60) or Type B parallel processors (PP60)

#### **APM MODULE FOR TYPE A PROCESSOR MODULE**

Type A CPU:

Module	System / Rack	
CP30	MINICONTROL	
CP32	MINICONTROL	
CP40	MULTI, MIDI	
NTCP33	M264	

The following application program memory modules are available for these type A processor modules:

APM Module	Description
EE32	EEPROM/RAM Module, 16 KByte EEPROM, 16 KByte RAM for 4.7 K Instructions, Standard Module for Program Develop ment and nonvolatile storage of application programs.
EE32MP <sup>1)</sup>	Combination of network capable on-line interface module with modern interface and application program memory module (16 KByte EEPROM, 16 KByte RAM for 4.7 K instructions).

#### APM MODULES FOR TYPE B PROCESSOR MODULES

Type B CPUs and Type B Peripheral Processors:

	Module	Rack
Ò.	CP60	MULTI, MIDI
	CP70	MULTI, MIDI
	NTCP6#	M264
	PP60	Peripheral Processor for MULTI-/MIDI <sup>2)</sup>

Type B processor modules have internal RAM application program memory (42 KByte for max. 42 K instructions). This memory is supplied by two batteries (power supply module and CPU) which retains the memory if the PLC is switched off. Therefore, no PROM application program memory module is required during program development.

A PROM module is required for nonvolatile storage of application programs if the battery buffer fails. The following PROM application program memory modules are available for type B processor modules:

APM Module	Description
EP128	EPROM Module. 128 KByte EPROM for max. 42 K instructions.
EE96	EEPROM Module. 96 KByte EEPROM for max. 42 K inst.
FP128	Flash PROM Module. 128 KByte Flash PROM for max. 42 K instructions and 52 KByte application data memory.
FP128MP¹)	Combination of network capable on-line interface module with modern interface and application program memory module (128 KByte Flash PROM for max. 42 K instructions and 52 KByte application data memory).
FP384	Flash PROM Module. 384 KByte Flash PROM for max. 42 K instructions and 308 KByte application data memory.

The combination of network capable on-line interface module with modern interface and application program memory module is described in section A7 "PLC Programming / On-line Networks and Modern Diagnosis".

All functions of the PP60 peripheral processor are the same as the PP60 MEM peripheral processor.

# APPLICATION PROGRAM MEMORY MODULES, EE32 - 16 KBYTE EEPROM, 16 KBYTE RAM

PLC SYSTEMS MULTICONTROL COMPONENTS







# **EE32**

- EEPROM/RAM Application Program Memory Module for Type A CPUs
- 16 KByte EEPROM + 16 KByte RAM for 4.7 K Instructions
- Standard Module for Program Development and Nonvolatile Storage of Application Programs
- Fast and Simple Programming
- No Deletion Required

#### ORDER DATA

ECEE32-0	EEPROM/RAM Application Program Memory Module, 16 KByte EEPROM, 16 KByte RAM for 4.7 K Instructions
ECEE32MP-0 <sup>1)</sup>	Combination of Network Capable On-line Interface Module with Modern Interface and Application Program Memory Module (16 KByte EEPROM, 16 KByte RAM for 4.7 K Instructions)

#### **TECHNICAL DATA**

#### EE32

Used	d with	CP30, CP32, CP40, NTCP33	
Mem Meth	nory Capacity and nod	16 KByte EEPROM + 16 KByte RAM	
Prog	gramming	In processor module with a command from the Programming Device	
Dele	te	Zalico Zalico	
Secu	urity	Write Protect Switch protects against accidentally overwriting a program	
Statu	us LED	PGM LED (Programming indicator)	
Docu	umentation German English French Italian Spanish	Hardware Manual MULTICONTROL  MAHWMULTI-0  MAHWMULTI-E  MAHWMULTI-F  MAHWMULTI-I  MAHWMULTI-S	

#### **Downloading an Application Program**

When an application program is transferred from the programming device to the processor module (RUN), this program is loaded to RAM in the EE32 and started whether another program is stored in the EEPROM or not.

#### **Programming the EEPROM Memory**

By giving the "F1 PROGRAM" command from the EEPROM menu of the programming device, the processor module is abandoned in order to copy the application program from EE32 RAM to the EEPROM. During the EEPROM programming, the programming LED is lit. Programming the EEPROM can also be done when an application program is still running. After the programming procedure is finished, the write protect switch (WE/WP) is to be set to WP (Write Protected). This ensures that the program will not be accidentally overwritten from EEPROM memory. EEPROM memory is not deleted, it is simply overwritten with a new program.

#### **Uninterrupted Application Program Transferal**

An application program can be downloaded into the RAM of the EE32 with the programming command "XFER" and without any influence on the program running in the EEPROM. The program in RAM and the one in the EEPROM can be switched between with a command on the programming device. The switch is made synchronous to the program cycle.

#### Loading Application Programs from the EE32 Module

Application programs can be loaded back to the programming device from the EE32 module. This can also be done with the application program running. A program which has been reloaded from the EE32 module can still be run but it no longer has any comments, ladder diagram pictures or symbols.

#### Power-On Behavior

A finished program must be stored in the EEPROM when the PLC system is powered on with CPUs. If a complete runnable program is not stored in the EEPROM, the status LED lights and the CPU remains in HALT state until a program is transferred from the programming device.

The combination of network capable on-line interface module with modern interface and application program memory module is described in section A7 "PLC Programming / On-line Networks and Modern Diagnosis".





# APPLICATION PROGRAM MEMORY MODULES, EE96 - 96 KBYTE EEPROM

PLC SYSTEMS MULTICONTROL COMPONENTS

TECHNICAL DATA

Security



# **EE96**

- EEPROM Application Program Memory Module for Type B CPUs and Type B Parallel Processors
- 96 KByte EEPROM for Max. 42 K Instructions and 34 KByte System Module
- Fast and Simple Programming
- No Deleting Necessary
- Write Protect Switch
- Programming LED

#### ORDER DATA

ECEE96-0	EEPROM Application Program Memory Module, 96 KByte EEPROM
	for Max, 42 K Instructions

# Utilized with CPUs Peripheral Processors CP60, CP70, NTCP6# PP60, PP60 MEM Memory Capacity and Type 96 KByte EEPROM Programming in the Processor Module, with a command from the programming device Deleting -

EE96

Write Protect Switch as protection against

	Accidentally Overwill	ng the Flogram

Status LED	PGM LED (Programming Indicator)
Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I

#### **Downloading an Application Program**

When an application program is transferred from the programming device to the processor module (RUN), the program is stored in the internal RAM of the processor module and then started whether another program is stored in the EE96 module or not and even if an EE96 module doesn't exist.

#### **Programming the EEPROM Memory**

By giving the "F1 PROGRAM" command from the EEPROM menu of the programming device, the processor module is abandoned in order to copy the application program from EE96 RAM to the EEPROM. During the EEPROM programming, the programming LED is lit. Programming the EEPROM can also be done when an application program is still running. After the programming procedure is finished, the write protect switch (WE/WP) is to be set to WP (Write Protected). This ensures that the program will not be accidentally overwritten from EEPROM memory. EEPROM memory is not deleted, it is simply overwritten with a new program.

#### **Uninterrupted Application Program Transferal**

An application program can be downloaded into the RAM of the EE96 with the programming command "XFER" and without any influence on the program running in the EEPROM. The program in RAM and the one in the EEPROM can be switched between with a command on the programming device. The switch is made synchronous to the program cycle.

#### Loading Application Programs from the EE96 Module

Application programs can be loaded back to the programming device from the EE96 module. This can also be done with the application program running. A program which has been reloaded from the EE96 module can still be run but it no longer has any comments, ladder diagram pictures or symbols.

#### Power-On Behavior

Since type B processor modules have internal RAM, no PROM module is necessary. If no EE96 module is in the processor module when the system is powered on, the program is tested and started in internal RAM.

If there is an EE96 module in the processor module, it must have a valid program stored in it. If the EE96 module is blank or the program in it has a problem, the processor module remains in HALT state and the status LED lights. CPUs that have status displays also show an error number.

### APPLICATION PROGRAM MEMORY MODULES, EP128 - 128 KBYTE EPROM

PLC SYSTEMS MULTICONTROL COMPONENTS







# **EP128**

- EPROM Application Program Memory Module for Type B CPUs and Type B Parallel Processors
- 128 KByte EPROM for Max. 42 K Instructions and 34 KByte System Module
- Programming in the Processor Module
- Write Protect Switch
- Programming LED

#### ORDER DATA

ECEP128-0 EPROM Application Program Memory Module, 128 KByte EPROM for Max. 42 K Instructions and 34 KByte System Module

#### **TECHNICAL DATA**

#### **EP128**

2.	Utilized with CPUs Peripheral Processors	CP60, CP70, NTCP6# PP60, PP60 MEM
	Memory Capacity and Type	128 KByte EPROM
	Programming	in the Processor Module, with a command from the programming device
	Deleting	With UV Light
2	Security	Write Protect Switch as protection against Accidentally Overwriting the Program
	Status LED	PGM LED (Programming Indicator)
	Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I MAHWMULTI-S
0		

#### **Downloading an Application Program**

When an application program is transferred from the programming device to the processor module (RUN), the program is stored in the internal RAM of the processor module and then started whether another program is stored in the EE128 module or not and even if an EE128 module doesn't exist.

#### **Programming the EPROM Memory**

By giving the "F1 PROGRAM" command from the EEPROM menu of the programming device, the processor module is abandoned in order to copy the application program from EE128 RAM to the EEPROM. During the EEPROM programming, the programming LED is lit. Programming the EEPROM can also be done when an application program is still running. After the programming procedure is finished, the write protect switch (WE/WP) is to be set to WP (Write Protected). This ensures that the program will not be accidentally overwritten from EEPROM memory. EEPROM memory is not deleted, it is simply overwritten with a new program.

#### **Uninterrupted Application Program Transferal**

An application program can be downloaded into the RAM of the EE128 with the programming command "XFER" and without any influence on the program running in the EEPROM. The program in RAM and the one in the EEPROM can be switched between with a command on the programming device. The switch is made synchronous to the program cycle.

#### Loading Application Programs from the EP128 Module

Application programs can be loaded back into the programming device from the EP128 module. This can also be done if an application program is running. A program that is loaded from the EP1128 module can be run but it no longer has any comments, ladder diagram pictures or symbols.

#### Power-On Behavior

Since type B processor modules have internal RAM no PROM module is required. If no EP128 module is in the processor module when the system is switched on, then the program is tested and started in internal RAM.

If there is an EP128 module in the processor module, it must contain a valid program. If the EP128 module is blank or if the program that is stored on it has an error, the processor module remains in HALT state and the status LED lights. CPUs with a status display also show an error number.



# APPLICATION PROGRAM MEMORY MODULES, FP128 / FP384 - 128 / 384 KBYTE FLASHPROM

PLC SYSTEMS MULTICONTROL COMPONENTS



# FP128 / FP384

- FlashPROM Application Program Memory Module for Type B CPUs and Type B Parallel Processors
- 128/384 KByte FlashPROM for Max. 42 K Instructions, 34 KByte System Module and 52/308 KByte Application Data
- Programming and Deleting in Processor Module
- Write Protect Switch
- Programming LED

#### ORDER DATA

ECFP128-0	FlashPROM Application Program Memory Module, 128 KByte FlashPROM for Max. 42 K Instructions, 34 KByte System Module and 52 KByte Application Data
ECFP128MP-0 <sup>1)</sup>	Combination of Network Capable On-line Interface Module with Modem Interface and Application Program Memory Module (128 KByte FlashPROM for Max. 42 K Instructions, 34 KByte System Module and 52 KByte Application Data).
ECFP384-0	FlashPROM Application Program Memory Module, 384 KByte FlashPROM for Max. 42 K Instructions, 34 KByte System Module and 308 KByte Application Data

#### **General Information**

The technology used in FlashPROM memory is similar to that in EPROM memory. The main difference is that erasing the FlashPROM can be done in the processor module instead of with UV light as is the case with EPROM memory.

#### **Application Data Memory**

The FlashPROM memory has 52 KByte (FP128) or 308 KByte (FP384) data memory for the user. Programming this application memory is done from the application program, the same as erasing or comparing.

The FP128 module has a memory block of 128 KByte. Areas in memory cannot be deleted. The entire chip is always erased. If the application data area should be deleted, then the application program and the system module must also be reprogrammed because they are all in the same block.

The FP384 module is equipped with three memory blocks, each with 128 KBytes. You can erase a certain block without affecting the other two. The data in the second and third 128 KByte block can be deleted without affecting the application program or the system module. If the application data in the first 128 KByte block should be deleted, then the application program and the system module must be reprogrammed because they are in the same block.

|--|

#### FP128, FP384

Utilized with CPUs Peripheral Processors	CP60, CP70, NTCP6# PP60, PP60 MEM
Memory Capacity and Type	128/384 KByte Flash PROM
Programming	In the Processor Module with a Command From the Programming Device
Deleting	In the Processor Module
Security	Write Protect Switch as protection against Accidentally Overwriting a Program
Status LED	PGM LED (Programming Display)
Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-O MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I

#### **Downloading an Application Program**

When transferring an application program from a programming device to the processor module (RUN), this program is stored in the internal RAM of the processor module and started whether another program is stored in the FlashPROM module or not and even if a FlashPROM module doesn't exist.

#### **Programming the Flash PROM Memory**

By giving the "F1 PROGRAM" command from the PROM menu of the programming device, the processor module is abandoned in order to copy the application program from internal RAM to the FlashPROM module. During the FlashPROM programming, the programming LED is lit. After the programming procedure is finished, the write protect switch (WE/WP) is to be set to WP (Write Protected). This ensures that the program will not be accidentally overwritten.

#### **Uninterrupted Application Program Transferal**

An application program can be downloaded into the internal RAM of the processor module with the programming command "XFER" and without any influence on the program running in the FlashPROM module. The program in RAM and the one in the FlashPROM can be switched between with a command on the programming device. The switch is made synchronous to the program cycle.

#### Loading Application Programs from the FlashPROM Module

Application programs can be loaded back into the programming device from the FlashPROM. This can also be done when an application program is running. A program that is loaded back into the programming device from the FlashPROM module can be run again but no longer has any comments, ladder diagram pictures or symbol assignments.

#### Power-On Behavior

Since type B processor modules have internal RAM, no PROM module is required. If no FlashPROM is in the processor module when the system is powered on, then the program is tested and started in internal RAM.

If there is a FlashPROM module in the processor module, then it must contain a valid program. If the FlashPROM module is blank or if the program that is stored on it has an error, the processor module remains in HALT state and the status LED lights. CPUs with a status display also show an error number.


The combination of network capable on-line interface module with modern interface and application program memory module is described in section A7 "PLC Programming / On-line Networks and Modern Diagnosis".

#### **PLC SYSTEMS MULTICONTROL COMPONENTS**





NOTES:





# **DIGITAL INPUT MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

#### **GENERAL INFORMATION**

Digital input modules are used for converting the binary signals of a process into the internal signal levels required in the PLC. The status of each input is indicated by means of status LEDs.

#### **OVERVIEW**

The following digital input modules are available for the MULTICONTROL PLC system:

	Number of	Nom. Input	Input	
Module	Inputs	Voltage	Delay	Latch
E161-0 E161-1	16 16	24 VDC/AC 24 VDC/AC	10 msec 1 msec	YES YES
E162-3	16	220 VAC	40 msec	YES
E163-0 E163-1	16 16	24 VDC 24 VDC	10 msec 1 msec	NO NO
1164-0	16	120 VAC	25 msec	YES
E243-0 E243-1	24 24	24 VDC 24 VDC	10 msec 1 msec	NO NO

#### SLOTS

Digital input modules can be used in all application slots of the MULTICONTROL PLC system.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack MIDI M264		0	•	• • • •	•	•	•	•	•	•	•	•	•					

#### ADDRESSING DIGITAL INPUTS

The address code (address) of an input consists of the address preselection code "I" and a three character alphanumeric combination:



The rack number is always 0 for the MIDI and M264 racks. This number can be from 0 to 3 with a MULTI rack.

The slot number is a hexadecimal number. Possible slot numbers are:

Rack	Permissible Slot Numbers	
MULTI	0 to F	
MIDI	1 to 7	
M264	0 to A	

The channel number is also hexadecimal. This number depends on the module:

Module	Permissible Slot Numbers	
E161, E162, E163, I164	0 to F	
E243	0 to N	

# If using power supply modules which are equipped with extended diagnostic functions, slot F in the third expansion rack may not be used.


#### TIMING

There are two different types of modules as far as timing is concerned.

- Modules with Input Latches
- Modules without Input Latches


#### a. Modules without Input Latches

The change of input status can be determined immediately by reading the respective input address in the application program. The status of an input can also change during a program cycle (asynchronous).



#### b. Modules with Input Latches

The input states are transferred to the input addresses by means of a latch pulse which is sent at the end of each program cycle (EOP). The input states cannot change during a program cycle (synchronous).



Input signals can be delayed by up to 100 msec (maximum permitted program cycle time) on input modules with input latches. If this delay will cause problems in certain applications, a special function exists for triggering the latch pulses in shorter intervals:


Setting flag S D99 to 1 causes the CPU module to trigger the latch pulse with each timer interrupt routine (every 10 msec). Note that the status of an input can change during a program cycle (asynchronous).

# DIGITAL INPUT MODULES, E161 - 16 INPUTS 24 VDC / AC

# PLC SYSTEMS MULTICONTROL COMPONENTS







# E161

- 16 Digital Inputs
- Galvanically Isolated
- Input Voltage 24 VDC/AC
- Optional Input Delay 10 msec or 1 msec
- With Input Latching
- PNP or NPN Switching

#### SLOTS


 $E161\,input\,modules\,can\,be\,operated\,in\,all\,application\,slots\,of\,racks\,MULTI, MIDI\,and\,M264.$ 

Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
	•	•	•	•	•	•	•	•	•	•	•	•					
	Slot	•	• •	000	0000	0000	00000	000000	000000	0000000	0000000	••••••		••••••	••••••	••••••	• • • • • • • • • • • • • • • • • • • •

#### ORDER DATA

Memory,	t Module, 16 Input Galvanically	, i	,	LED Status Di Potential	isplays, L GND	atch or
+24 VDC ECE161-0	Switching	Delay ca. 10 r	nsec			
ECE161-1		Delay ca. 1 m				


#### DIAGRAM




If using power supply modules which are equipped with extended diagnostic functions, slot F in the third expansion rack may not be used.

CHNICAL DATA	E161-0	E161-1
Number of Inputs Total In Groups of	11 -	6
Electrical Isolation Input - PLC Input - Input	YES (Opt	
Input Voltage Nominal Minimal Maximal	24 VD 14 VDC / 30 VDC /	19 VAC
AC Input Frequency	47 to	63 Hz
Input Resistance	ca. 2.	2 kΩ
Switching Threshold log. $0 \rightarrow \log$ . 1 log. $1 \rightarrow \log$ . 0	min. 14 VD max. 9 V	
Input Current At 24 VDC At 24 VAC	ca. 1: ca. 1	
Switching Delay $\log. 0 \rightarrow \log. 1$ $\log. 1 \rightarrow \log. 0$	ca. 10 msec ca. 20 msec	ca. 1 msec ca. 2 msec
Transfer of Input Status through CPU	With Software	Latch Pulse at Program End (EOP)
Maximum Peak Voltage	500 V for 50 μsec, m	ax. every 100 msec 2)
Galvanic Isolation Input - Logic Input - Housing	250 150	
Power Consumption At +8 V At +15 V	0.2 0.8	
Documentation German English French Italian Spanish	Hardware Manual MAHWN MAHWN MAHWN MAHWN MAHWN	NULTI-0 NULTI-E NULTI-F NULTI-I

#### CONNECTIONS






<sup>2)</sup> Standard Pulse 1.2/50 (IEC 60-2)



### DIGITAL INPUT MODULES, E162 - 16 INPUTS 220 VAC

TECHNICAL DATA

PLC SYSTEMS MULTICONTROL COMPONENTS



### E162

- 16 Digital Inputs in 4 Groups
- Galvanic Isolation Between Individual Groups and to the PLC
- Input Voltage 220 VAC
- Input Delay ca. 40 msec
- With Latch Memory
- With Varistor Overvoltage Protection
- Conforms to EN 61131-2:1994

#### SLOTS

The E162 input module can be operated in all application slots of racks MULTI, MIDI and M264.


Rack	Slot	0	1	2	3	4	5	6	7	8	9	A	В	C	D	Ε	F
MULTI Base Rack	77,4			•													
MULTI Expansion Rack		•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	1)
MIDI		0	•	•	•	•	•	•	•								
M264		•	•	•	•	•	•	•	•	•	•	•					

#### ORDER DATA

ECE162-3

Digital Input Module, 16 Inputs, Four Galvanically Isolated Groups, Input Voltage 220 VAC, LED Status Displays, Latch Memory, Galvanic Isolation, Switching Delay ca. 40 msec, Varistor Overvoltage Protection, Conforms to EN 61131-2:1994

#### DIAGRAM



If using power supply modules which are equipped with extended diagnostic functions, slot F in the third expansion rack may not be used.

#### Number of Inputs 16 In Groups of Electrical Isolation Input - PLC YES Group - Group YES Input - Input NO Input Voltage Nominal 220 VAC Maximal 250 VAC AC Input Frequency 45 to 55 Hz 0 to 70 V $_{\rm eff}$ / 0 to 2 mA 70 to 164 V $_{\rm eff}$ /typ. 120 V $_{\rm eff}$ with Hysteresis 164 to 250 V $_{\rm eff}$ / 4.6 to 7.8 mA LOW Range Switching Range HIGH Range Switching Delay $\begin{array}{c} \log. \ 0 \rightarrow \log. \ 1 \\ \log. \ 1 \rightarrow \log. \ 0 \end{array}$ Max. 40 msec, typ. 33 msec max. 30 msec, typ. 15 msec Transfer of Input Status through CPU With Software Latch Pulse at Program End (EOP) Application Class 4 3) Input Type Digital Inputs Type 1 4) Resistance to Disturbance 15 kV (Max. Surge Energy C = 150 pF, Min. Source Impedance 150 Ω) Electrostatic Discharge ESD-B Interference Resistance Asymmetrical, Fast Transients 10 V / m 4 kV (max. Surge Energy 4 mJ / Peak at 2 kV, min. Source Impedance $50\,\Omega$ ) Symmetrical Attenuated Oscillation and Parallel Coupling 2 kV (min. Source Impedance 200 $\Omega$ )

E162

2 5)

0.6 W
Hardware-Manual MULTICONTROL
MAHWMULTI-0

MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S

#### CONNECTIONS


Contamination

Power Consumption

German English

French

Italian



- <sup>2)</sup> See section "Characteristic Curve" for more information
- 3) Equipment for use in extra high voltage areas (conforms to DIN 57 109 / VDE 0109).
- 4) Digital inputs suited for signals originating from electromagnetic switching devices such as relay contacts, push buttons, switches, etc. This type is not necessarily suitable for connecting semiconductor switches, proximity switches, ... (Conforms to EN 61131-2:1994).
- Most contamination is nonconductive. However, conductivity caused by moisture must be taken into consideration (Conforms to DIN 57 109 / VDE 0109). For printed circuit boards with a lacquer coating, grade 2 is the highest of the four grades.


## DIGITAL INPUT MODULES, E162 - 16 INPUTS 220 VAC

PLC SYSTEMS MULTICONTROL COMPONENTS






#### INPUT CIRCUIT




#### **PHASE WIRING**

The potential difference between the individual groups must not exceed 400 V. The potential difference between two adjacent terminals must not exceed 250 V. For example:



#### CHARACTERISTIC CURVE




The areas of the characteristic curve which are shown in the background of the diagram (ON Range, Switching Range and OFF Range) are specified in standard EN 61131-2:1994.



## DIGITAL INPUT MODULES, E163 - 16 INPUTS 24 VDC

PLC SYSTEMS MULTICONTROL COMPONENTS



# E163

- 16 Digital Inputs
- Galvanic Isolation
- Input Voltage 24 VDC
- Optional Input Delay 10 msec or 1 msec

#### **SLOTS**

The E163 input module can be operated in all application slots of racks MULTI, MIDI and M264.


	Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	E	F	
Ī	MULTI Base Rack	44	•																
	MULTI Expansion Rack		•	_	_	_	_	_	_	_	_	•	•	•	•	•	•	1)	
	MIDI		0	•	•	•	•	•	•	•									
	M264		•	•	•	•	•	•	•	•	•	•	•						

#### ORDER DATA

Digital Input Module, 16 Inputs, Input Voltage 24 VDC, LED Status Displays, Galvanically Isolated, Reference Potential GND

MDE163-0Switching Delay ca. 10 msec MDE163-1Switching Delay ca. 1 msec


#### DIAGRAM




If using power supply modules which are equipped with extended diagnostic functions, slot F in the third expansion rack may not be used.

Т	ECHNICAL DATA	E163-0	E163-1
	Number of Inputs Total In Groups of	16 -	N <sub>1</sub>
Ś	Electrical Isolation Input - PLC Input - Input	YES (Optocou NO	ipler)
	Input Voltage Nominal Minimal Maximal	24 VDC 18 VDC 30 VDC	
	Input Resistance	ca. 2.2 kΩ	2
	Switching Threshold	min. 10 VDC, typ. 12 VD0	C, max. 14 VDC
3	Input Current at 24 VDC	ca. 10 mA	9
	Switching Delay $\log. 0 \rightarrow \log. 1$ $\log. 1 \rightarrow \log. 0$	ca. 10 msec ca. 15 msec	ca. 1 msec ca. 1.5 msec
	Transfer of Input Status Through CPU	With Change (without I	atch function)
	Maximum Peak Voltage	500 V for 50 μsec, max. e	very 100 msec 2)
_	Galvanic Isolation Input - Logic Input - Housing	2500 V 1500 V	7 2,
	Power Consumption At +8 V	0.2 W	The same
	Documentation German English French Italian Spanish	Hardware Manual MUL MAHVMULT MAHVMULT MAHVMULT MAHVMULT MAHVMULT	TI-0 FI-E FI-F TI-I

#### CONNECTIONS






<sup>2)</sup> Standard Pulse 1.2/50 (IEC 60-2)

# DIGITAL INPUT MODULES, 1164 - 16 INPUTS 120 VAC

# PLC SYSTEMS MULTICONTROL COMPONENTS







# **I164**

- 16 Digital Inputs in 4 Groups
- Galvanic Isolation Between Individual Groups and to PLC
- Input Voltage 120 VAC
- Input Delay ca. 25 msec
- With Latch Memory

#### SLOTS


The I164 input module can be operated in all application slots of racks MULTI, MIDI and M264.

Rack Slot	0 1	2	3	4	5	6	1	ŏ	9	Α	В	C	ט	E	F
MULTI Base Rack MULTI Expansion Rack MIDI M264	00	•	•	•	•	•	•	•	•	•	•				

#### ORDER DATA

ECI164-0	Digital Input Module, 16 Inputs, Four Galvanically Isolated Groups, Input Voltage 120 VAC, LED Status Displays, Latch Memory, Galvanic Isolation, Switching Delay ca. 25 msec
----------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------


#### DIAGRAM




1)	If using power supply modules which are equipped with extended diagnostic functions, slot F in the third	
	expansion rack may not be used.	

TECHNICAL DATA	I164
Number of Inputs Total In Groups of	16 4
Electrical Isolation Input - PLC Group - Group Input - Input	YES YES NO
Input Voltage Nominal Minimal Maximal	120 VAC 102 VAC 144 VAC
AC Input Frequency	47 to 63 Hz
Input Current at 120 VAC	ca. 3.5 mA
Input Resistance	typ. 15 kΩ
Switching Threshold log. 0 → log. 1 log. 1 → log. 0	85 VAC 55 VAC
Switching Delay log. $0 \rightarrow \log 1$ log. $1 \rightarrow \log 0$	< 25 msec < 25 msec
Transfer of Input Status Through CPU	With Software Latch Pulse at Program End (EOP)
Peak Voltage	1500 V for max. 10 μsec
Power Consumption At +8 V	0.5 W
Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S

#### CONNECTIONS








# DIGITAL INPUT MODULES, E243- 24 INPUTS 24 VDC

PLC SYSTEMS MULTICONTROL COMPONENTS



# **E243**

- 24 Digital Inputs in Two Groups
- Galvanic Isolation Between Groups and to PLC
- Input Voltage 24 VDC
- Optional Input Delay 10 msec or 1 msec

#### SLOTS

The E243 input module can be operated in all application module slots of racks MULTI, MIDI and M264.


	Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
Π	MULTI Base Rack	May	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	Ī
	MULTI Expansion Rack		•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	1)	
	MIDI		0	•	•	•	•	•	•	•									
	M264		•	•	•	•	•	•	•	•	•	•	•						

#### ORDER DATA

Digital Input Module, 24 Inputs, Input Voltage 24 VDC, LED Status Displays, Galvanic Isolation, Reference Potential GND

ECE243-0 Switching Delay ca. 10 msec ECE243-1 Switching Delay ca. 1 msec


#### DIAGRAM




If using power supply modules which are equipped with extended diagnostic functions, slot F in the third expansion rack may not be used.

ECHNICAL DATA	E243-0	E243-1
Number of Inputs Total In Groups of	24 12	49
Electrical Isolation Input - PLC Group - Group Input - Input	YES (Optoco YES NO	upler)
Maximum Voltage Difference Between the two Groups	160 VDC	;
Input Voltage Nominal Minimal Maximal	24 VDC 18 VDC 30 VDC	
Input Resistance	ca. 2.2 ks	2
Switching Threshold	min. 9 VDC, typ. 11 VD0	C, max. 13 VDC
Input Current at 24 VDC	ca. 10 m	A
Switching Delay log. 0 → log. 1 log. 1 → log. 0	ca. 10 msec ca. 10 msec	ca. 1 msec ca. 1 msec
Transfer of Input Status Through CPU	With Change (without	latch function)
Maximum Peak Voltage	250 V for 50 μsec, max.	every 100 msec
Galvanic Isolation Input - Logic Input - Housing	2500 V 1500 V	
Power Consumption at +8 V	0.35 W	
Documentation German English French Italian Spanish	Hardware Manual MU MAHWMUL MAHWMUL MAHWMUL MAHWMUL MAHWMUL	TI-0 TI-E TI-F .TI-I

#### CONNECTIONS






#### **PLC SYSTEMS MULTICONTROL COMPONENTS**





NOTES:





# **DIGITAL OUTPUT MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

#### **GENERAL INFORMATION**

Digital output modules are used to control external loads (relays, motors, solenoids, etc.). The status of the digital outputs is displayed with orange status LEDs. The following types exist:

- Relay Output Module
- Transistor Output Module
- Triac Output Module

#### OVERVIEW

The following digital output modules are available fort the MULTICONTROL PLC system:

Module	No. of Outputs	Туре	Nom. Switching Voltage	Switching Current
A161	16	Relay	At 220 VAC	2 A
A163	16	Relay	At 220 VAC	2 A
A162	16	Transistors	24 VDC	2 A
A115	16	Transistors	24 VDC	0.5 A
A244	24	Transistors	24 VDC	0.5 A
A121 O125	12 12	Triacs Triacs	220 VAC 120 VAC	2 A 2 A
0125	12	macs	120 VAC	Z A

#### SLOTS

Digital output modules can be operated in all application module slots of the MULTICONTROL PLC system.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	A	В	С	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack MIDI M264		0	•	• • • •	•	•	•	•	•	•	•	•	•				1)	

#### ADDRESSING DIGITAL OUTPUTS

The address of an output is made up of the designation code "A" and a three character number / letter combination:



The rack number is always 0 for MIDI and M264 racks. It can be from 0 to 3 for MULTI racks.

The slot number is a hexadecimal number. Possible slot numbers:

Rack	Permitted Slot Numbers	
MULTI	0 to F	
MIDI	1 to 7	
M264	0 to A	
- 10	10	

The channel number is also a hexadecimal number. It depends on the module:

Module	Permitted Channel Numbers	
A161, A162, A163, A115	0 to F	
A244	0 to N	
A121, O125	0 to B	

#### When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

#### TIMING

Output modules do not have latch temporary memory. Setting or resetting an output in the application program is effective immediately after the respective rising or falling edge. These times are described in the "Technical Data" section for each module (e.g. approx. 10 msec for relay modules, approx. 100 msec for transistor modules).

#### PROTECTIVE CIRCUITS

External protective circuits are required for relay output modules, for transistor output modules, they are recommended and for triac output modules no protective circuit is required.

Module	Туре	<b>External Protective Circuit</b>	
A161	Relay	Required	
A163	Relay	Required	
A162	Transistors	Recommended	
A115	Transistors	Recommended	
A244	Transistors	Recommended	
A121	Triacs	Not Required	
O125	Triacs	Not Required	

The protective circuit can either be placed on the load to be switched, on the output module or on the terminal block. Most solenoid and contactor manufacturers offer protective circuits for the respective components.

The following elements can be used:

- RC element: Can be used for AC or DC. 2)
- Varistor: This is normally used for AC voltage. Varistors have a relatively short life span and therefore RC elements are usually preferred.
- Diode: Can only be used for DC.
- Diode/Z Diode Combination: Can only be used for DC. This type of protection circuit allows faster cutoff times.


Typical values for RC circuit combinations (ca. 10 W load) are: 22  $\Omega$ /250 nF at 24 VDC/AC or 220  $\Omega$ /1  $\mu$ F at 220 VAC.

# DIGITAL OUTPUT MODULES, A161 - 16 RELAY OUTPUTS 220 VAC / 2 A

PLC SYSTEMS MULTICONTROL COMPONENTS







# A161

- 16 Digital Relay Outputs
- 4 Groups with Separate Reference Potential;
   A different potential can be used with every group
- Maximum Switching Voltage 250 VAC or 30 VDC
- Switching Current Max. 2 A per Output

#### SLOT


The A161 output module can be operated in all application module slots of the MULTI, MIDI and M264 racks.

Rack	Slot	0	1 2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F
MULTI Base Rack			• •													
MULTI Expansion Rack		•	• •	•	•	•	•	•	•	•	•	•	•	•	•	1)
MIDI		0	•	•	•	•	•	•								
M264			•	•	•	•	•	•	•	•	•					

#### ORDER DATA

ECA161-01	Digital Output Module, 16 Relay Outputs, Switching Voltage 220 VAC/24 VDC, Switching Current Max. 2 A per Output, LED Status Displays
-----------	---------------------------------------------------------------------------------------------------------------------------------------


#### DIAGRAM



When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

TECHNICAL DATA		A161	
Number of Outputs Total In Groups of	n <sub>th</sub>	16 4	
Type Relay			
Switching Voltage AC DC		Max. 250 VAC Max. 30 VDC	
Switching Current Per Output Per Group	"Midpag	Max. 2 A Max. 5 A	'iqp <sub>anr</sub>
Switching Delay log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	Na.	ca. 10 msec ca. 10 msec	
Protection Circuit		External by the user, require	ed
Contact Resistance at Maximum L	Load	ca. 6 mΩ	
Switching Procedure Mechanical Electrical		> 5 . 10 <sup>7</sup> > 2 . 10 <sup>5</sup>	
Dielectric Strength Contact Contact - Coil	Mary .	1200 V <sub>eff</sub> 3750 V <sub>eff</sub>	Dr.
Power Consumption At +8 V At +15 V Output 0 / Ou	utput 1 / Output 0 ⇒ 1	0,2 W 0 / 3.3 / 5.3 W	
Documentation German English French Italian Spanish		Hardware Manual MULTICON' MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	FROL
	N.	- 17	


#### CONNECTIONS





# DIGITAL OUTPUT MODULES, A163 - 16 RELAY OUTPUTS 220 VAC / 2 A

PLC SYSTEMS MULTICONTROL COMPONENTS



# A163

- 16 Digital Relay Outputs
- 4 Groups with Separate Reference Potential;
   A different potential can be used for each group
- Maximum Switching Voltage 250 VAC or 30 VDC
- Switching Current Max. 2 A per Output

#### SLOTS


The A163 output module can be operated in all application module slots of the MULTI, MIDI and M264 racks.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack	1/4		•														1)	
MIDI		0	•	•	•	•	•	•	•									
M264		•	•	•	•	•	•	•	•	•	•	•						

#### ORDER DATA

MDA163-0	Digital Output Module, 16 Relay Outputs, Switching Voltage 220 VAC / 24 VDC, Switching Current max. 2 A per Output, LED
r.	Status Displays


#### DIAGRAM



When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

Т	ECHNICAL DA	TA	A163	
	Number of Outputs Total In Groups of	4	16 4	200
1	Type Relay			
	Switching Voltage AC DC	ionida.	max. 250 VAC max. 30 VDC	
	Switching Current Per Output Per Group	58 <sup>5</sup>	max. 2 A max. 5 A	.6
	Switching Delay $\log. 0 \rightarrow \log.$ $\log. 1 \rightarrow \log.$		ca. 10 msec ca. 15 msec	712
	Protective Circuits		External by the user. Required	
	Switching Procedure Mechanical Electrical	, Itelijas	> 2 . 10 <sup>7</sup> > 1 . 10 <sup>5</sup>	
	Dielectric Strength Contact - Coil		2000 V <sub>eff</sub>	
	Power Consumption At +8 V At +15 V	Output 0 / Output 1 / Output 0 ⇔ 1	0.2 W 0 / 4.2 / 10.3 W	212
2	Documentation German English French Italian Spanish	altotaghe a	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I	
		7		

#### CONNECTIONS




# DIGITAL OUTPUT MODULES, A162 - 16 TRANSISTOR OUTPUTS 24 VDC / 2 A

PLC SYSTEMS MULTICONTROL COMPONENTS







# A162

- 16 Digital Transistor Outputs
- Current Monitor for Each 4 Outputs
- Switching Voltage 24 VDC
- Switching Current Max. 2 A per Output
- Short Circuit Protected
- Cutoff for Overload

#### SLOTS


Output module A162 can be operated in all application slots of the MULTI, MIDI and M264 racks.

Rack	Slot	0	1	2	3 4	5	6	7	8	9	Α	В	С	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack MIDI M264		•	•	• • • • • • • • • • • • • • • • • • • •			•	•	•	•	•	•					

#### ORDER DATA

ECA162-01	Digital Output Module, 16 Transistor Outputs, Switching Voltage 24 VDC, Switching Current max. 2 A per Output, LED Status Displays,
	Current Monitor, Short Circuit Protection, Overload Cutoff


#### DIAGRAM




When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

TECHNICAL DATA	A162
Number of Outputs Total In Groups of	16 4 <sup>2</sup>
Type Transistors	
Switching Voltage Nominal Minimal Maximal	24 VDC 18 VDC 30 VDC
Continuous Current Per Output Per Group Module	max. 2 A max. 2 A max. 8 A
Current Monitor	4 A per Group
Switching Delay After Overload Cutoff	ca. 10 msec
Switching Delay log. $0 \rightarrow \log . 1$ log. $1 \rightarrow \log . 0$	ca. 100 μsec ca. 200 μsec
Protection Circuit	External by User (Recommended)
Transistor Residual Voltage	< 1 V at 1 A
Power Consumption At +8 V	0.5 W
Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S

#### CONNECTIONS



#### **OUTPUT CIRCUIT**



<sup>&</sup>lt;sup>2)</sup> Groups only for current monitoring. No galvanic group - group isolation.



# DIGITAL OUTPUT MODULES, A115 - 16 TRANSISTOR OUTPUTS 24 VDC / 0.5 A

PLC SYSTEMS MULTICONTROL COMPONENTS



# A115

- 16 Digital Transistor Outputs
- Switching Voltage 24 VDC
- Switching Current Max. 0.5 A per Output

#### **SLOTS**


The output module A115 can be operated in all application slots of the MULTI, MIDI and M264 racks.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack	M			•													1)	
MIDI		0	•	•	•	•	•	•	•									
M264		•	•	•	•	•	•	•	•	•	•	•						

#### ORDER DATA

MDA115-0	Digital Output Module, 16 Transistor Outputs, Switching Voltage 24
	VDC, Switching Current max. 0.5 A per Output, LED Status Displays


#### DIAGRAM




When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

TECHNICAL DATA	A115
Number of Outputs Total In Groups of	16 -
Type Transistors	
Galvanic Isolation Output - PLC Output - Output	YES NO
Switching Voltage Nominal Minimal Maximal	24 VDC 18 VDC 30 VDC
Switching Current Per Output Module	max. 0,5 A max. 6 A
Switching Delay log. $0 \rightarrow \log. 1$ log. $1 \rightarrow \log. 0$	ca. 100 µsec ca. 200 µsec
Protective Circuit	External by User (Recommended)
Transistor Residual Voltage	< 1 V at 0.5 A
Power Consumption At +8 V	0.8 W
Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-1 MAHWMULTI-S
	70

#### CONNECTIONS



#### **OUTPUT CIRCUIT**



# DIGITAL OUTPUT MODULES, A244 - 24 TRANSISTOR OUTPUTS 24 VDC / 0.5 A

PLC SYSTEMS MULTICONTROL COMPONENTS







# A244

- 24 digital Transistor-Outputs
- Switching Voltage 24 VDC
- Switching Current max. 0,5 A per Output

#### SLOTS


The A244 output module can be operated in all application slots of racks MULTI, MIDI and M264.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
MULTI Base Rac MULTI Expansio MIDI M264		•	•	•	•	•	•	•	•	•	•	•	•					

#### ORDER DATA

ECA244-0	Digital Output Module, 24 Transistor-Outputs, Switching Voltage 24
	VDC, Switching Current max. 0.5 A per Output, LED Status Displays


#### DIAGRAM




When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

24 - YES NO 24 VDC 18 VDC
NO 24 VDC
NO 24 VDC
30 VDC
Max. 0.5 A Max. 6 A
ca. 100 µsec ca. 200 µsec
External by User (Recommended)
< 1 V at 0.5 A
0.3 W
Hardware-Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I MAHWMULTI-S

#### CONNECTION




#### **OUTPUT CIRCUIT**





# DIGITAL OUTPUT MODULES, A121 / O125 - 12 TRIAC OUTPUTS

PLC SYSTEMS MULTICONTROL COMPONENTS



# A121 / O125

- 12 Digital Triac Outputs in Three Groups
- Switching Voltage 220 VAC / 120 VAC
- Switching Current Max. 2 A per Output
- Galvanic Isolation between the Groups and to the PLC
- No External Protection Circuit Required

#### SLOTS


The A121 and O125 output modules can be operated in all slots of the MULTI, MIDI and M264 racks.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	Ε	F	
MULTI Base Rack	77,4																•	
MULTI Expansion Rack		•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	1)	
MIDI		0	•	•	•	•	•	•	•									
M264		•	•	•	•	•	•	•	•	•	•	•						

#### ORDER DATA

Digital Output I Displays	Module, 12 Triac Outputs, Three Galvanicall	y Isolated Groups, LED Status
ECA121-0 ECO125-0	Switching Voltage 220 VAC Switching Voltage 120 VAC	


#### DIAGRAM



When using power supply modules with extended diagnostic functions, slot F in the third expansion rack may not be used.

TECHNICAL DATA	A121	Eggs.	O125
Number of Outputs Total In Groups of	na	12 4	£4
Туре		Triac	
Galvanic Isolation Output - PLC Group - Group Output - Output	Uggk.	YES YES NO	
Switching Voltage Nominal Minimal Maximal	220 VAC 90 VAC 250 VAC	<sup>1</sup> 120,	120 VAC 90 VAC 144 VAC
Switching Voltage Frequency	у	47 to 63 Hz	
Switching Current	Se	ee Section "Switching Curre	ent"
Maximum Switching Current	per Group	3 A <sup>2)</sup>	
Leakage Current	Max. 7 mA (w/load, 50 Hz, 220		ax. 5 mA ) Hz, 120 VAC) <sup>3)</sup>
Maximum Power-on Current (Non-repeating) For 100 msec For 10 msec	12 A 25 A	ig.	7 A 12 A
Minimum Holding Current At 0 °C At 60 °C		2 mA 2 mA	
Voltage Drop	1 V at 2.4 A 0.85 V at 0.7		/ at 2.4 A V at 0.5 A
Switching Delay	Max. 20 msec at	50 Hz Max. 19	msec at 60 Hz
Switching Procedure	Switched Switched	ON with change in voltage OFF with change in currer	e potential nt direction
Transient Voltage	150	0 V for Max. 2 msec (at 22	0 Ω)
Electric Isolation Output - PLC Group - Group Output - Housing	1500 \	occupler, Distance betweer / (Distance between lines - (Distance between lines -	- 3 mm)
Grade		4	
Protection Circuit	No Ext	ernal Protective Circuitry R	tequired
Power Consumption At +8 V		1.8 W	
Documentation German English French Italian Spanish	Hard	ware Manual MULTICONT MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	FROL
- 10		100	

#### CONNECTIONS



Unless restricted by the max. power loss of the triac (see section "Switching Current")

<sup>3)</sup> Check engaging current and hold current when controlling relays!


### DIGITAL OUTPUT MODULES, A121 / O125 - 12 TRIAC OUTPUTS

# PLC SYSTEMS MULTICONTROL COMPONENTS

A6




#### **OUTPUT CIRCUIT**



#### **SWITCHING CURRENT**

The switching current of the outputs depends on the number of outputs used and on the ambient temperature. The power loss of the triacs must be calculated using the following diagram to get the desired switching current for the outputs:



The power loss of all triacs is added together and may not exceed the result of the following formula:

$$\begin{split} P_0 + P_1 + P_2 + ... + P_9 + P_A + P_B &\leq \frac{(105 - \vartheta_v) - P_{max}^{--- *} \cdot 4.2}{\vartheta_u^{--- *} \cdot 0.09 + 3.6} \\ P_0^0 & Power Loss at Output 0 \\ P_1^0 & Power Loss at Output 1 \\ \vdots \\ P_B & Power Loss at Output B \\ \vartheta_u^- & Ambient Temperature [^{\circ}C] \\ P_{max}^- & Maximum Power Loss of One Output (P_0 to P_B) \end{split}$$

Example

The 12 channels of the A121 output module are loaded with the following:

The graph shows that the following power losses apply to the individual outputs below:

 Outputs 0 to 5
 per 0.78 W

 Output 6
 1.72 W

 Outputs 9 to B
 per 0.36 W

When these power losses are put into the formula, the total power loss can be calculated as shown here:

$$P_0 + P_1 + ... + P_n + P_n = (6 * 0.78) + 1.72 + (3 * 0.36) = 7.48 \text{ W}$$

This total may not exceed the right-hand expression of the formula. An ambient temperature  $(\vartheta_u)$  of  $40^{\circ}$ C is assumed. The greatest power loss of an output ( $P_{\text{max}}$ ) is 1.72 W (output 6):

$$\frac{(105 - \vartheta_{u}) - P_{\text{max}} * 4.2}{\vartheta_{u} * 0.09 + 3.6} = \frac{(105 - 40) - 1.72 * 4.2}{40 * 0.09 + 3.6} = 8.02 \text{ W}$$

7.48 W ≤ 8.02 W

The load on the outputs is also within the permissible range. Please note that an increase in ambient temperature to 45  $^{\circ}$ C causes the maximum power loss of 6.9 W. Therefore, the load on the outputs is too high.

#### Permissible Output Current with the Same Load on All Channels

If the outputs are all loaded with the same output current, the maximum permissible loss per output is only dependent on the ambient temperature of the unit:

$$P_x = \frac{105 - \vartheta_u}{(0.09 * \vartheta_u + 3.6) * n + 4.2}$$

- P<sub>x</sub> Maximum permissible power loss of an output
- naximam permissisie
- n Number of outputs used

The maximum permissible current per output can be determined as shown in the diagram above. Below is an example of a surrounding ambient temperature of  $60\,^{\circ}\text{C}^{\circ}$ 

	Number of Outputs Used	Max. Current per Output	Number of Outputs Used	Max. Current per Output	
П	1	3 A 1)	7	0.9 A	
	2	2.25 A	8	0.8 A	
	3	1.7 A	9	0.7 A	
	4	1.35 A	10	0.65 A	
	5	1.15 A	11	0.55 A	
	6	1 A	12	0.5 A	

Example

We must determine whether each of a total of 10 outputs can be loaded with 0.8 A at an ambient temperature of 50 °C. The maximum power loss attained from the formula above is:

$$P_x = \frac{105 - 50}{(0.09 * 50 + 3.6) * 10 + 4.2} = 0.65 \text{ W}$$

The power loss diagram indicates that each of the outputs is allowed to be loaded with 0.85 A with a power loss of 0.65 W. A load of 0.8 A on the outputs is also allowed. Please not that an increase in the ambient temperature to 55  $^{\circ}\mathrm{C}$  causes the maximum permissible power loss of 0.56 W. This corresponds with a maximum current per output of 0.75 A. The load on the outputs is too high in this case.

<sup>1)</sup> Limited by the fuse



# **ANALOG INPUT MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

#### **GENERAL INFORMATION**

Analog inputs are used to convert measurement values (voltage, current, temperatures) into numerical values that can be processed in the PLC.

#### **OVERVIEW**

The following analog input modules are available for the MULTICONTROL PLC system:

	Number of	Input	
Module	Inputs	Signal	Resolution
PE42	4	0 - 10 V or 0 - 20 mA	10 or 12 Bit
PE82	8	0 - 10 V or 0 - 20 mA	10 or 12 Bit
PE84	8	0 - 10 V or 0 - 25 mA	16 or 15 Bit
PE16	16	U, I, PT100, NTC, PTC	16 Bit
PTE8	8	FeCuNi or NiCrNi Sensor	10 Bit
PT81	8	PT100 Sensor	10 Bit

#### SLOTS

Analog inputs modules can be operated in the following MULTICONTROL PLC system slots.

Rack Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F
MULTI Base Rack	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•
MULTI Expansion Rack	0	0	0	O	0	0	0	0	0	0	0	0	0	0	0	0
MIDI	0		•	•	•			•								
M264			•		•	0	0	0	0	0	0					
<ul> <li>The module can be operated in this slot</li> <li>The module cannot be operated in this slot</li> </ul>																

#### UTILIZATION IN AN APPLICATION PROGRAM

Converting the input signal to a numerical value is controlled with standard function blocks. One function block exists for every module:

Module	Туре	Function Block
PE42	4 Inputs 0 - 10 V / 0 - 20 mA	AINB, AINF
PE82	8 Inputs 0 - 10 V / 0 - 20 mA,	AINB, AINF
PE84	8 Inputs 0 - 10 V / 0 - 25 mA	AIND
PE16	16 Inputs U, I, PT100, NTC, PTC	AINE
PTE8	8 Inputs NiCrNi Sensor	TINC
PTE8	8 Inputs FeCuNi Sensor	TIND
PT81	8 Inputs PT100 Sensor	TINB

The following parameters are connected to the function block:

- The number of the first channel to be converted (CHAN)
- The number of the channel to be converted (LENGTH)
- The slot number of the module
- The source address for the conversion result

Analog input modules that are used for temperature measurement, can also be set to save the measured values in °C or in °F. The two measurement ranges can be switched between with software on some modules. A detailed description of the standard function blocks for analog input modules can be found in the "Standard Software User's Manual, Volume 1".

#### RESOLUTION

An important performance characteristic of analog input/output modules is the resolution. The resolution defines the amount of steps that the area to be converted is split into. The resolution is defined in bits. The number of steps is determined with:

Number of Steps = 2 Resolution

The following table shows the relationship between the resolution and the number of steps for the most popular resolutions:

Resolution	Number of Steps	Steps Size at 0 - 10 V Range	Steps Size at 0 - 20 mA Range
10 Bit	1024	9.77 mV	19.53 μΑ
12 Bit	4096	2.44 mV	4.88 µA
16 Bit	65536	152.59 μV	305.18 nA

#### **TIMING - UPDATE TIMES**

The analog inputs are converted cyclically in most applications, i.e. the channels are converted and saved whether the data is required in the application program immediately or not. The update time is the period of time that it takes for the conversion result to be renewed. This update time depends on three factors:

- Input filter on the module
- Conversion time of the A/D converter
- Program Cycle Time

Input Filter

In order to get reliable measurements in an industrial environment as well, all analog input modules are equipped with an input filter. This filter has a time constant which corresponds to the application. For temperature measurement (e.g. PT81), filters with higher time constants are used, since temperature measurements do not change very fast. Measurements that deal with rapid changes (e.g. voltage measurement with the PE82) require a respectively small time constant that is suitable for the conversion time of the A/D converter.

**Conversion Time** 

The conversion time depends on the A/D converter used in the module. This is shown in the "Technical Data" section for every analog input module.

Program Cycle Time


Since one channel is converted per program cycle in most applications (e.g. standard function block), the program cycle time fits within the update time. For example,: With a program cycle time of 30 msec and four channels to be converted, the update time (independent of the conversion time) cannot be under 120 msec.

## ANALOG INPUT MODULES PE42 / PE82 - 4 / 8 INPUTS 0 - 10 V / 0 - 20 mA

PLC SYSTEMS MULTICONTROL COMPONENTS







# PE42 / PE82

- 4 or 8 Analog Inputs (Two Module Versions)
- Input Signal 0 10 V or 0 20 mA (Two Module Versions)
- 10 Bit or 12 Bit Resolution (Two Module Versions)
- Status LED for exceeding upper and lower limits
- Software Operation with Standard Function Block

#### SLOTS


The analog input modules PE42 and PE82 can be operated in the following slots of racks MULTI, MIDI and M264:

Rad	ck		Slot	0	1	2	3	4	5	6	7	8	9	A	В	С	D	E	F
		Rack		0	0	0	0	0	0	0	0		Ó	Ó	Ó			•	
	The module ca		ed in this slot erated in this slot																

#### ORDER DATA


True.	0 to	0 to 10 V 0 to							
Resolution 10 Bit		ECPE42-1 ECPE82-1	4 Channels 8 Channels	ECPE42-2 ECPE82-2					
Resolution 12 Bit		ECPE42-11 ECPE82-11	4 Channels 8 Channels						

#### DIAGRAM



Ž	ECHNICAL DATA		PE42-1, PE42-11 PE82-1, PE82-11		PE42-2, PE42-21 PE82-2, PE82-21
	Number of Inputs ECPE42-x ECPE82-x	20,		4 8	14
	Galvanic Isolation			NO	
	Input Signal Nominal Min./Max.		0 to 10 V ±22 V		0 to 20 mA 70 mA
Š	Resolution ECPEx2-1, ECPEx2-2 ECPEx2-11, ECPEx2-21			10 Bit 12 Bit	
	Conversion Time per Channel		ca. 100 μ	sec per	Channel
	Differential Input Resistance		400 kΩ		-
	Load		-7K3-4		50 Ω
	Voltage Drop at 20 mA		Mar.		1 V
	Input Filter Cutoff Frequency		640 Hz	, 6 dB/D	Pecade
15	Input Precision Basic Precision at 20 °C Offset Drift Gain Drift Linearity	MAN, CO	±0.3 % ±0.0025 % / °C ±0.025 % / °C 0.2 % / V		±0.3 % ±0.0055 % / °C ±0.03 % / °C 0.45 % / V
	Power Consumption At +8 V At +15 V At -30 V		0.7 W 0.4 W 0.3 W		0.7 W 0.5 W 0.5 W
	Documentation German English French Italian Spanish		MAI MAI MAI MA	nual MUI HWMUL HWMUL HWMUL HWMUL HWMUL	TI-E TI-F TI-I

#### CONNECTIONS




#### SOFTWARE OPERATION

Standard function blocks AINB (10 bits) or AINF (12 bits) are used to control the analog inputs. These function blocks are both standard components of software package SWSPSSTD01-0 (see section A7 "PLC Programming" for more information).



# ANALOG INPUT MODULES PE84 - 8 INPUTS 0 - 10 V / 0 - 25 mA

PLC SYSTEMS MULTICONTROL COMPONENTS



# **PE84**

- 8 Analog Inputs
- Input Signal 0 10 V or 0 25 mA (Two Module Versions)
- Resolution 16 Bit (at 0 10 V) or 15 Bit (at 0 - 20 mA)
- Galvanically Isolated from PLC
- Individual Channels Galvanically Isolated
- Automatic Calibration
- Software Operation with Standard Function Blocks

#### **SLOTS**

The analog input module PE84 can be operated in the following slots of racks MULTI, MIDI and M264:

Rack Slot	0 1 2 3 4 5 6 7 8 9 A B C D E F
MULTI Base Rack	•••••
MULTI Expansion Rack	000000000000000
MIDI	0 • • • • • •
M264	•••••00000
The module can be operated in this slot     The module cannot be operated in this slot	


#### ORDER DATA

Analog Input Module, 8 channels, galvanic isolation between PLC and channels and individual channels are isolated, automatic calibration

**ECPE84-0**0 - 10 V, Resolution 16 Bit **ECPE84-2**0 - 25 mA, Resolution 15 Bit

Т	ECHNICAL DATA	ECPE84-0	ECPE84-2
	Number of Inputs	8	_C <sup>2</sup>
6	Galvanic Isolation Inputs - PLC Channel - Channel	YES YES	
	Input Signal Nominal Min./Max.	0 to 10 V ±22 V	0 to 25 mA ±70 mA
	Resolution	16 Bit	15 Bit
	Data Updates	Min. 3.9 msec / Max. 6.3	msec for all 8 Channels
	Calibration Time	Min. 0.7 sec, N	Max. 1.1 sec
	Input Resistance	40 kΩ ±0.1 %	50 $\Omega$ ±0.1 %
Ş,	Input Filter Cutoff Frequency (-3 dB)	6 Hz ±2	20 %
	Filter Response TIme (to $\pm 79~\rm ppm$ or 1/2 LSB with maximum input signal change)	145 msec	±20 %
	Linearity Error	±2 L	SB
	Measurement Precision	see section "Measur	rement Precision"
6	Galvanic Isolation Galvanic Isolation Channel - PLC Isolation Resistance Channel - PLC Galvanic Isolation Channel - Channel Isolation Resistance Channel - Channel	270 V > 5 N 270 V > 5 N	ν <u>π</u>
	Grade	4	A.
	Power Consumption At +8 V At +15 V	0.9 V 2.8 V	• •
6	Documentation German English French Italian Spanish	Hardware Manual M MAHWMI MAHWMI MAHWMI MAHWMI MAHWMI	ULTI-0 ULTI-E ULTI-F IULTI-I

#### CONNECTIONS



#### SOFTWARE OPERATION

The analog inputs are controlled with standard function block AIND. This function block is a standard component of software package SWSPSSTD01-0 (see section A7 "PLC Programming" for more information).


## ANALOG INPUT MODULES PE84 - 8 INPUTS 0 - 10 V / 0 - 25 mA

PLC SYSTEMS MULTICONTROL COMPONENTS






#### **ATTENUATION**




#### STEP-FUNCTION RESPONSE



#### MEASUREMENT PRECISION


#### a. Voltage Measurement (ECPE84-0, 0 to 10 V)

The measurement precision depends on the ambient temperature. The maximum measurement error can be calculated with the following formula.



#### b. Current Measurement (ECPE84-2, 0 to 25 mA)


The measurement precision depends on the ambient temperature. The maximum measurement error can be determined from the following diagram.





# ANALOG INPUT MODULES PE16 - 16 INPUT U, I, PT100. NTC, PTC

PLC SYSTEMS MULTICONTROL COMPONENTS



# **PE16**

- 16 Analog Inputs
- Voltage Measurement (0 to 10 V or 0 to 2.5 V)
- Current Measurement (0 to 50 mA)
- Temperature Measurement (PT100)
- Resistance Measurement (NTC, PTC)
- Resolution 16 Bit
- Software Set Digital Filter (-50 dB, -85 dB, -120 dB)
- Software Operation with Standard Function Block

#### **GENERAL INFORMATION**

The analog input module PE16 is used for current, voltage and resistance measurements. It has 16 analog 16 bit inputs for voltage measurement (0 to 10 V or 0 to 2.5 V), current measurement, PT100 temperature sensors (2 or 3 wire) as well as NTC and PTC temperature sensors. Different types of sensors can be connected to the individual channels. All channels have adjustable filters. Sensor type, measurement type and filter time can be defined by writing to control registers and jumper settings.

#### SLOTS

The analog input module PE16 can be operated in the following slots of the MULTI, MIDI and M264 racks.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	A	В	C	D	E	F
MULTI Base Rack	17	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•
MULTI Expansion Rack		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
MIDI		0	•	•	•	•	•	•	•								
M264		•	•	•	•	•	0	0	0	0	0	0					
<ul> <li>The module can be operated.</li> <li>The module cannot be operated.</li> </ul>																	

#### ORDER DATA

ECPE16-0	Analog Input Module, 16 Channels, current, voltage and resistance measurement, resolution 16 bit, without galvanic isolation, software adjustable digital filter for every channel

T	ECHNICAL DATA	PE16	
	Number of Inputs	16	22
	Galvanic Isolation	NO	-
9	Input Signal, Sensor Types	$\label{eq:Voltage} \begin{array}{ll} \text{Voltage (0 to 10 V / 0 to 2.5 V)} \\ \text{Current (0 to 50 mA)} \\ \text{PT100 (2 wire , 3 wire)} \\ \text{NTC Resistance Measurement (1 to 50 k$\Omega$)} \\ \text{PTC Resistance Measurement (0 to 2 k$\Omega$)} \end{array}$	
	Measurement Precision For Voltage Measurement For Current Measurement For PT100 Measurement For NTC Measurement For NTC Measurement For PTC Measurement	±0.5 % ±2.5 % ±1.0 % ±1.0 % (to 10 kΩ) ±1.0 %	
Ì	Digital Filter Level 1 Level 2 Level 3	-50 dB with 50 Hz (-60 dB with 60 Hz) -85 dB with 50 Hz (-95 dB with 60 Hz) -120 dB with 50 Hz (-125 dB with 60 Hz)	
	Conversion Time With Filter Level 1 With Filter Level 2 With Filter Level 3	ca. 200 msec per Channel ca. 400 msec per Channel ca. 800 msec per Channel	
	Power Consumption At +8 V At +15 V At -30 V	0.4 W 0.7 W 0.8 W	200
Ş	Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	

#### CONNECTIONS



Voltage or current signals, resistance or temperature sensors can be connected to both connections of a channel. Either two wire or three wire connections can be utilized with PT100 temperature sensors. The sense line requires its own channel for a three wire connection.

#### SOFTWARE OPERATION

The analog inputs are operated with standard function block AINE. This function block is a standard component of software package SWSPSSTD01-0 (see section A7 "PLC Programming" for more information).

The name of a configuration table is connected to the AINE function block. The following information is entered in this table:


- Method of measurement (Current, Voltage, PT100, NTC, PTC)
- Input Filter (200 msec, 400 msec, 800 msec)
- Scaling
- Linearizatio

# ANALOG INPUT MODULES PTE8 - 8 INPUTS FOR TEMPERATURE SENSORS

# PLC SYSTEMS MULTICONTROL COMPONENTS







# PTE8

- 8 Analog Inputs for Temperature Sensors
- Optional FeCuNi or NiCrNi Sensor (Type J, K, L) conforming to DIN 43710 or DIN IEC 584
- Temperature Ranges 0 to 400 °C, 0 to 500 °C, 0 to 600 °C, 0 to 1200 °C
- Resolution 10 Bit
- Conversion Time ca. 300 μsec per Channel
- Software Operation with Standard Function Blocks

#### **SLOTS**

The analog input module PTE8 can be operated in the following slots of racks MULTI, MIDI and M264.

Rac	k Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F
MUL	TI Base Rack									•							
	TI Expansion Rack									0	0	0	0	0	0	0	0
MID						•					_	_					
M26	4	٥,	•	•	•	•	O	O	J	0	J	0					
•	The module can be operated in this slot																
0	The module cannot be operated in this slot																

#### ORDER DATA

Analog Input module for Temperature Measurement, 8 Channels, 10 Bit Resolution, for direct connection of temperature sensors, not galvanically isolated

ECPTE8-0 FeCuNi Temperature sensors conforming to DIN 43710 (Type L), Measurement Range 0 to 400 °C


ECPTE8-1 NiCrNi Temperature sensors conforming to DIN IEC 584 (Type K), Measurement Range 0 to 600 °C

ECPTE8-2 NiCrNi Temperature sensors conforming to DIN IEC 584 (Type K), Measurement Range 0 to 1200 °C

ECPTE8-3 FeCuNi Temperature sensors conforming to DIN IEC 584 (Type J), Measurement Range 0 to 500 °C

ECHNICAL DATA	PTE8-0	PTE8-1	PTE8-2	PTE8-3
Number of Inputs	2200		8	120
Galvanic Isolation		1	NO	
Sensor Type	FeCuNi	NiCrNi I	NiCrNi K	FeCuNi K .I
Standard	DIN 43710	DIN IEC 584	DIN IEC 584	DIN IEC 584
Measurement Range	0 - 400 °C	0 - 600 °C	0 - 1200°C	0 - 500 °C
Resolution		11	0 Bit	
Conversion Time		ca. 300 µse	c per Channel	
Measurement Precision Basic Precision at 20 °C Offset Drift Gain Drift Linearity	±0.6 % ±0.062 % / °C ±0.052 % / °C ±0.7 % / V		±0.6 % ±0.046 % / °C ±0.052 % / °C ±0.7 % / V	
Linearization	Hardware	Software	Software	Hardware
Terminal Block Temp. Compensation		Y	'ES	Mallo.
Power Consumption At +8 V At +15 V At -30 V		1.	4 W 0 W 9 W	
Documentation German English French Italian Spanish		MAHW MAHW MAHW MAHW	NULTICONTRO MULTI-0 MULTI-E MULTI-F VMULTI-I MULTI-S	DL

#### CONNECTIONS



#### **SOFTWARE OPERATION**


The analog inputs are controlled with standard function blocks TINC and TIND. These function blocks are standard components of software package SWSPSSTD01-0 (see section A7 "PLC Programming" for more information). Either TINC or TIND is used depending on the module version:

<b>Module Version</b>	Sensor Type	Measurement Range	Function Block
PTE8-0	FeCuNi	0 to 400 °C	TIND
PTE8-1	NiCrNi	0 to 600 °C	TINC
PTE8-2	NiCrNi	0 to 1200 °C	TINC
PTE8-3	FeCuNi	0 to 500 °C	TIND



# ANALOG INPUT MODULES PT81 - 8 INPUTS FOR PT100 TEMPERATURE SENSORS

PLC SYSTEMS MULTICONTROL COMPONENTS



# **PT81**

- 8 Analog Inputs for PT100 Temperature Sensors
- Direct connection to DIN 43760 Standard Temperature Sensors
- Temperature Range optionally -25 to +75 °C or -25 to +475 °C (software adjustable)
- Resolution 10 Bit
- Conversion Time ca. 3 msec per Channel
- Automatic Linearization (Hardware)
- Optional Three Wire or Four Wire Connection (Two Module Versions)
- Software Operation with Standard Function Blocks

#### **SLOTS**

The analog input module PT81 can be operated in the following slots of racks MULTI, MIDI and M264.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack MIDI M264	My.	0	0		0	0	0	0	0	Ó	0	0	Ó				•	
<ul> <li>The module can be operate</li> <li>The module cannot be operate</li> </ul>																		


#### ORDER DATA

Analog Input Module for Temperature Measurement, 8 Channels, 10 Bit Resolution, For Direct Connection of PT100 Temperature Sensors, Measurement Range -25 to +475 °C, Not Galvanically Isolated

ECPT81-0	Three Wire Connection
ECPT81-1	Four Wire Connection

ECHNICAL DATA	PT81-0	PT81-1
Number of Inputs	7274	8
Galvanic Isolation	4.	NO
Sensor Type Standard		PT100 DIN 43760
Type of Connection	Three Wire	Four Wire
Measurement Range	-25 to +75 °C or -25 to	o +475 °C (software adjustable)
Resolution	.4.º	10 Bit
Conversion Time	ca. 3 m	nsec per Channel
Measurement Precision in range -25 to +475 °C Basic Precision at 20 °C Offset Drift Gain Drift	±0.3 % + 0.011 % / R <sup>-1</sup> ) ±0.039 % / °C + 0.0008%/R.°C ±0.017 % / °C	±0.5 % + 0.00022 % / R <sup>1)</sup> ±0.039 % PC + 0.00008 %/R. <sup>1</sup> ±0.017 % / °C
Measurement Precision in Range -25 to +75 °C Basic Precision at 20 °C Offset Drift Gain Drift	±0.5 % + 0.055 % / R <sup>-1</sup> ) ±0.2 % / °C + 0.0004 % / R . °C ±0.022 % / °C	±0.5 % + 0.0006 % / R <sup>1)</sup> ±0.2 % / °C + 0.0004 % / R . ° ±0.022 % / °C
Linearization	YE	S / Hardware
Measurement Current		2 mA
Power Consumption At +8 V At +15 V At -30 V	<sup>9</sup> G <sub>V</sub> o <sub>'2,</sub>	1.4 W 0.9 W 1.5 W
Documentation German English French Italian	MA MA MA	inual MULTICONTROL IHWMULTI-0 IHWMULTI-E IHWMULTI-F AHWMULTI-I

#### CONNECTIONS



#### SOFTWARE OPERATION

The analog inputs are controlled with standard function block TINB. This function block is a standard component of software package SWSPSSTD01-0 (see A7 "PLC Programming" for more information).


<sup>1)</sup> R ... Line Resistance

#### **PLC SYSTEMS MULTICONTROL COMPONENTS**





NOTES:





# **ANALOG OUTPUT MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

#### **GENERAL INFORMATION**

Analog outputs are used to convert PLC internal numerical values to current or voltage .

#### **OVERVIEW**

The following analog output modules can be obtained for the MULTICONTROL PLC system:

Module	Number of Outputs	Output Signal	Resolution
PA42-0	4	±10 V	10 Bit + Sign
PA42-01	4	±10 V	12 Bit + Sign
PA81-0	8	±10 V	10 Bit + Sign
PA81-01	8	±10 V	12 Bit + Sign
PA42-2	4	0 to 20 mA	11 Bit
PA42-21	4	0 to 20 mA	12 Bit
PA81-2	8	0 to 20 mA	11 Bit
PA81-21	8	0 to 20 mA	12 Bit

#### **SLOTS**

Analog output modules can be operated in the following MULTICONTROL PLC system slots.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	E	F	
MULTI Base Rack MULTI Expansion Rack MIDI M264	MAN TO	• 0 0 •	0	0	0	0	0	0	0	o	Ó	0	0					
<ul><li>The module can be ope</li><li>The module cannot be</li></ul>																		

#### **UTILIZATION IN AN APPLICATION PROGRAM**

The conversion of the internal numerical values to output current or voltage is controlled with standard function blocks AOTB and AOTD. These function blocks are standard components of software package SWSPSSTD01-0 (see section A7 "PLC Programming"). The following parameters are connected to the function block:

- The number of the first channel to be converted (CHAN)
- The number of channels to be converted (LENGTH)
- The module slot
- The source address of the data to be output

#### RESOLUTION

An important performance characteristic of analog input/output modules is the resolution. The resolution defines the amount of steps that the area to be converted is split into. The resolution is defined in bits. The number of steps is determined with:

Number of Steps = 2 Resolution

Analog output modules for voltage ( $\pm 10~V$ ) and current (0 to 20 mA) are available for the MULTICONTROL system.

#### **OUTPUT VOLTAGE ±10 V**

The  $\pm 10~V$  modules are available in two versions (10 bit + Sign or 12 bit + Sign). The voltage range of  $\pm 10~V$  is divided into 1024 or 4096 steps. The digital value must be a twos complement number. The following table indicates the relationship between the digital value and the voltage that is output:

D	igital Value	PA42-0, PA81-0 (10 Bit + Sign)	PA42-01, PA81-01 (12 Bit + Sign)
(4)	-4095	(0)	-10.238 V
	-4000		-10.000 V
	-2000		-5.000 V
	-1023	-10.23 V	-2.558 V
	-1000	-10.00 V	-2.500 V
	-500	-5.00 V	-1.250 V
	0	0 V	0 V
	500	5.00 V	1.250 V
	1000	10.00 V	2.500 V
	1023	10.23 V	2.558 V
	2000		5.000 V
	4000		10.000 V
.20	4095	30%	10.238 V
Resolution		9.77 mV / Bit	2.44 mV / Bit

#### **OUTPUT CURRENT**

The 0 - 20 mA versions are also available with two different resolutions (11 bit or 12 bit). The current range of 0 to 20 mA is split into 2048 or 4096 steps. The following table shows the relationship between digital values and the current that is output:

		PA42-2, PA81-2	PA42-21, PA81-21
-177	Digital Value	(11 Bit)	(12 Bit)
	0	0 mA	0 mA
	250	2.50 mA	1.250 mA
	500	5.00 mA	2.500 mA
	1000	10.00 mA	5.000 mA
	1500	15.00 mA	7.500 mA
	2000	20.00 mA	10.000 mA
	2047	20.47 mA	10.235 mA
	3000		15.000 mA
	4000		20.000 mA
	4095		20.475 mA
Resolution	(0)	10 μA / Bit	5 µA / Bit

# ANALOG OUTPUT MODULES, PA42 / PA81 - 4 / 8 OUTPUTS ±10 V / 0 - 20 mA

PLC SYSTEMS MULTICONTROL COMPONENTS







# PA42 / PA81

- 4 or 8 Analog Outputs (Two Module Versions)
- Output Signal ±10 V or 0 20 mA (Two Module Versions)
- Resolution 11 bit or 13 bit with Voltage Output (±10 V)
- Resolution 11 bit or 12 bit with Current Output (0 to 20 mA)
- Software Operation with Standard Function Blocks

#### SLOTS


The analog output modules PA42 and PA81 can be operated in the following slots of racks MULTI, MIDI and M264.

Ra	ck		Slot	0	1	2	3	4	5	6	7	8	9	A	В	С	D	Ε	F
	LTI Base Rack	Rack																•	
MII M2	DI .	ruon		0	•	•	•	•	•	•	•					•	7	\ \	•
	The module ca																		

#### ORDER DATA

Neg.	4 Channels	8 Channels
±10 V / 10 Bit + Sign	Model No. ECPA42-0	Model No. ECPA81-0
±10 V / 12 Bit + Sign	Model No. ECPA42-01	Model No. ECPA81-01
0 to 20 mA / 11 Bit	Model No. ECPA42-2	Model No. ECPA81-2
0 to 20 mA / 12 Bit	Model No. ECPA42-21	Model No. ECPA81-21

#### DIAGRAM



TECHNICAL DATA	ECPA42-0, ECPA42-01 ECPA81-0, ECPA81-01	ECPA42-2, ECPA42-21 ECPA81-2, ECPA81-21
Number of Outputs ECPA42-x ECPA81-x	4 8	1/2
Galvanic Isolation	NO	1
Output Signal	±10 V	0 to 20 mA
Max. Load on Outputs Per Channel Sum of All Channels	±20 mA -80 mA / +160 mA	(Aparito)
Load		Max. 560 Ω
Resolution	10 Bit + Sign or 12 Bit + Sign	11 Bit or 12 Bit
Precision Offset (at 20 °C) Offset Drift (0 to 60 °C) Gain Error (at 20 °C) Gain Drift Linearity	±0.1 % ±0.05 % ±0.2 % ±0.12 % / ° C 0.2 %	$\begin{array}{c} \pm 0.2 \ \% \\ \pm 0.08 \ \% \\ \text{Load } 50 \ \Omega: \ \ \pm 0.5 \ \% \\ \text{Load } 500 \ \Omega: \ \ \pm 3.5 \ \% \\ \pm 0.04 \ \% \ / \ ^{\circ}\text{C} \\ 0.2 \ \% \\ \end{array}$
Power Consumption At +8 V At +15 V At -30 V	PA42-0 / PA81-0 0.5 W / 0.5 W 1.7 W / 3.3 W 3.0 W / 4.4 W	PA42-2 / PA81-2 0.5 W / 0.5 W 1.7 W / 3.3 W 3.0 W / 4.4 W
Documentation German English French Italian Spanish	Hardware-Manual M MAHWM MAHWM MAHWM MAHWM	ULTI-0 ULTI-E ULTI-F MAHWMULTI-I

#### SOFTWARE OPERATION

The analog outputs are operated with standard function blocks AOTB and AOTD. These function blocks are standard components of software package SWSPSSTD01-0 (see section A7 "PLC Programming" for more information).



### **INTERFACE MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

#### **GENERAL INFORMATION**

Interface modules enable the PLC to transfer data with other devices (also other PLCs). Two types of interfaces:

- Parallel Interfaces
- Serial Interfaces

#### **PARALLEL INTERFACES**

The data is transferred parallel. 8 data lines are available for the simultaneous transmission of an entire byte. The standard parallel interface is the CENTRONICS interface, which is usually used for printers. The CENTRONICS interface is not suited for industrial applications.

#### **SERIAL INTERFACES**

The data is transferred bit by bit and reassembled into data words by the receiver. Because of low cable costs, high resistance to interference and world wide standardization, serial interfaces are better suited for computer system communication than parallel interfaces. The most important types are:

RS232 (V24)

The communication is carried out over at least 3 lines (sender, receiver and GND). Addition lines can be used for synchronization of the sender and receiver (handshake). The length of an RS232 interface cable in an industrial environment is rather limited (ca. 10 m) because of its low signal to noise ratio and that fact that it is not electrically isolated.

TTY

The communication takes place via an induced current (20 mA). For this reason, the TTY interface is also known as the current loop interface. Since TTY interfaces are electrically isolated, a greater distance can be bridged (up to 200 m in an industrial environment). The TTY interface requires four lines.

RS422

This interface has dual transmit, receive and when needed also handshake lines (differential signals). An RS422 interface cable can be longer than an RS232 interface cable. The RS422 interface can also be used as RS485 interface for B&R interface modules if it is wired accordingly and the handshake lines are not used. All RS422 interfaces from B&R can be operated in tristate mode and are therefore network capable.

RS485

This type of interface is best suited for industrial applications. The RS485 interface also uses differential signals. The RS485 interface is standardly electrically isolated from the PLC and network capable, that means multiple transmitters and receivers can operate on the same medium (twisted pair). A distance of up to 1200 m can be bridged with an RS485 interface.

#### SYNCHRONIZATION OF TRANSMITTER AND RECEIVER

In most cases, asynchronous data is transferred faster than it can be processed by the receiver. Therefore, almost all data transfer requires synchronization of the transmitter and receiver (handshake). Two types of handshake:

- Hardware Handshake
- Software Handshake

#### HARDWARE HANDSHAKE

A hardware handshake requires an additional line with which the receiver informs the transmitter it is ready to receive additional data. The parallel CENTRONICS interface also has a busy line, with which e.g. a printer can say that the input buffer is full. Asynchronous data transfer requires 2 handshake lines

Advantage: Handshake lines are easily evaluated

by the software

Disadvantage: Higher cable costs

#### SOFTWARE HANDSHAKE

The synchronization of transmitter and receiver takes place with control characters. The standardized X-ON/X-OFF protocol is the best known and most used and is used for most printers. The receiver sends a defined stop character (X-OFF; \$13) to the transmitter, if it cannot receive any more data. As soon as the receiver buffer can accept characters again, it sends a start character (X-ON; \$11). Naturally, other methods of software synchronization are also possible.

Advantage: Low cabling costs

Disadvantage: Usually higher software costs

#### POINT TO POINT CONNECTION / NETWORK

Automation system communication can use:

Point to Point Connection A system is connected with one other system and they

exchange data. Data can be transferred in both directions

simultaneously (= asynchronous).

Network Several stations are connected to a common medium (e.g.

twisted pair cable). According to the network structure, a station can only send data to certain stations or to all stations desired. A network capable serial interface is required (e.g.

RS485 interface).

#### SERIAL INTERFACES

Characters transferred via a serial interface are automatically split into bits by the interface modules. During initialization, the user defines how many data bits the characters should contain (5 to 8). The following illustration corresponds to 8 data bits per character.



A start bit is sent which indicates the beginning of the character to the receiver. The individual data bits follow.

#### **PARITY TEST**

The parity test, that which can be turned on during initialization, provides a simple safety test. A parity bit is generated in addition to the data bits:



The parity bit is generated automatically by the interface modules in order to make the sum of the data bits sent even or odd.

Odd Parity
The parity bit is 1 if the sum of the bits is even.
The parity bit is 0 if the sum of the bits is odd.

The receiver checks the parity after receiving a character to see if the sum corresponds to the type of parity test being used (even or odd). If odd parity is being used and the sum of the bits received incl. parity bit is even, then a transfer error has caused at least one bit of the data word to be inverted. In this case, an error signal is generated.

# **INTERFACE MODULES**

# PLC SYSTEMS MULTICONTROL COMPONENTS

A6



A stop bit is sent to terminate the bit sequence. During the interface initialization, the user defines the length of the stop bit. It can be the same length as a data bit (1 stop bit; most common case), 1.5 times as long as a data bit (1.5 stop bits) or twice as long as a data bit (2 stop bits):



#### **POSSIBLE ERROR MESSAGES**

The error status bits indicate three possible error conditions:

- Parity Error (see above)
- Framing Error
- Overrun Error

Framing Error

A framing error occurs if the interface receiver does not detect the stop bit at the end of a character, e.g. because strong disturbances on the line have effected the stop bit.

Overrun Error

An overrun error is generated when a received character is not read from the data register before the next character is received. The character received is not valid.

#### **B&R INTERFACE MODULES**

B&R offers hardware and software for almost all types of communication with other systems. The following MULTICONTROL system interface modules are available for point to point connection of B&R PLCs with other B&R devices or devices from other manufacturers:

Module	Description	
PIF1	One RS232/TTY or RS422 Serial Interface (two Module Versions)	
PIF3	Two RS232/TTY Serial Interfaces, One Parallel CENTRONICS Interface	

The following CPUs and parallel processors provide their own serial interfaces:

Module	Description	Interfaces
CP70	CPU (MULTI, MIDI Rack)	Optionally RS232/RS485/TTY (software setting)
NTCP6#	CPU (M264 Rack)	Optionally RS232/RS485/TTY (software setting)
PP60	Parallel Processor	Optionally RS232/RS485/TTY (software setting)

#### SLOTS

Interface modules can be operated in the following slots in MULTI, MIDI and M264 racks.

Module Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F
MULTI Maine Rack	25	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•
<b>MULTI Expansion Rack</b>		0	o	0	0	o	0	0	0	0	o	o	o	0	0	0	o
MIDI .		0	•	•	•	•	•	•	•								
M264		•	•	•		•	O	0	0	0	0	0					

#### STANDARD SOFTWARE

B&R offers standard software for different types of communication, such as point to point communication with B&R systems or systems from other manufacturers and network communication. Refer to:

- Section A7 "PLC Programming / Standard Software"
- Section C "Industrial Networks and Communication"

#### INTERFACE CONVERTER

In many applications, devices must be connected with different types of interfaces. In this case, an interface converter is required. The following interface converter is offered by B&R:


Designation	Converts from / to	Application
INT1	RS232 / RS485	Coupling a network module with an RS232 interface (e.g. NP02 or PIF3)



# **INTERFACE MODULES** PIF1 - 1 SERIAL RS232/TTY OR 1 RS422

MULTICONTROL COMPONENTS





- 1 Serial User Interface
- RS232/TTY or RS422 (two module versions)
- Software Selectable Baudrate up to 19200 Baud

#### **SLOTS**


The PIF1 interface module can be operated in the following slots in MULTI, MIDI and M264 racks.

Module Rack Slo	730	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	E	F
MULTI Main Rack MULTI Expansion Rack MIDI M264	La.	0	•	0	0	0	0	0	0	Ó	o	0	Ó	-	-	-	-
<ul><li>the module can be operated in this</li><li>the module cannot be operated in</li></ul>																	

#### ORDER DATA

MDPIF1-0	Interface module, 1 Serial RS232/TTY Interface, 25 Pin D-Type Connector (F)
MDPIF1-1	Interface module, 1 Serial RS422 Interface, 9 Pin D-Type Connector (M)

#### CONNECTION



TECHNICAL DATA	PIF1-0 TTY	PIF1-0 RS232	PIF1-1 RS422	
-76	-27	27- 110-0-		100
Electrical Isolation				
Transmitter	NO	NO	NO	
Receiver	YES	NO	NO	
Input Filter	NO	NO	YES	
Protection Circuit	YES	NO	NO	
Connector	25 pin	25 pin	9 pin	
	D-type connector (F	) D-type connector (F)	D-type connector (M	1)
Max. Range	200 m	10 m	50 m	
Handshake Lines	- 3	DTR, DSR,	DTR, DSR	
		RTS, DCD		
Baudrates	50 to1	9200 Baud, software sel	ectable	
Data Format	5 to 8 c	lata bits, parity yes/no/e	ven/odd,	
	1/1.5/	2 stop bits, software sele	ectable	
Power Consumption				
at +8 V	1.4 W	1.4 W	1.1 W	
at +15 V	0.5 W	0.5 W		
at -30 V	0.6 W	0.6 W	-	
Documentation	MUL1	CICONTROL Hardware	Manual	
German		MAHWMULTI-0		
English		MAHWMULTI-E		
French		MAHWMULTI-F		
Italian		MAHWMULTI-I		
Spanish		MAHWMULTI-S		
	20		0	

PIN O		MDPIF1-	0		ME	OPIF1-1
ASSIGNMENTS	Pin	INTERFACE	Function		Pin	Function
25 pin D-type	2	RS232	RXD	7	1	GND
(F)	3	RS232	TXD		2	RXD
(1)	5	5 RS232 RTS	_			
- 13	6	RS232	DTR	9 pin D-type	3	RXD
25	7		GND		4	DSR
	8	RS232	DCD	(M)	5	DSR
%	9	TTY	RXD	6 2	6	TXD
6 0	10	TTY	TXD Ret			
	11		+8 V	1.0	7	TXD
0 0	12	TTY	RXD Ret		8	DTR
	13	TTY	TXD	9	9	DTR
	20	RS232	DSR	20. 2		
ا ٥ م	23		-30 V			
14	24		+12 V			
200	25		+15 V			

#### STANDARD SOFTWARE

Many standard function blocks are available for interface modules. See Section A7 "PLC Programming".

# INTERFACE MODULES PIF3 - 2 SERIAL RS232/TTY, 1 CENTRONICS

PLC SYSTEMS
MULTICONTROL COMPONENTS







## PIF3

- 2 Serial, 1 Parallel User Interface
- 2 x RS232/TTY
   1 x CENTRONICS
- Software Selectable Baudrate
   19200 Baud

## **SLOTS**


The PIF3 interface module can be operated in the following slots in MULTI, MIDI and M264 racks.

Module Rack Slot	0	1	2	3	4	5	6	7	8	9	A	В	С	D E	F
MULTI Main Rack	•	•	•	•	•	•	•	•	•	•	•	•	•	• •	•
MULTI Expansion Rack	0	0	0	0	0	0	0	0	0	0	0	0	0	<b>o</b> c	0
MIDI		•													
M264		•	•	•	•	0	0	0	0	0	0				
<ul><li>the module can be operated in this slot</li><li>the module cannot be operated in this slot</li></ul>															

## ORDER DATA


ECPIF3-0	Interface Module, 2 Serial RS232/TTY Interfaces (25 pin D-type	
	female connector), 1 Parallel CENTRONICS Interface	
	(flat plug connection)	

## CONNECTION



#### **TECHNICAL DATA** Electrical Isolation RS232 NO TTY YES (only receiver) Protection Circuit RS232 NO TTY RS232/TTY CENTRONICS Two 25 pin D-type connector (F) Flat plug connection Max. Range RS232 10 m TTY 200 m Handshake Lines RS232 TTY DSR, DCD Baudrates 50 to 19200 Baud, software selectable 5 to 8 data bits, parity yes/no/even/odd, 1/1.5/2 stop bits, software selectable Data Format Power Consumption at +8 V 2.2 W at +15 V 0.8 W 1.3 W at -30 V MULTICONTROL Hardware Manual Documentation MAHWMULTI-0 MAHWMULTI-E German English French MAHWMULTI-F Italian Spanish MAHWMULTI-I MAHWMULTI-S

PIN			PIF3		
ASSIGNMENTS	Pin	Interface	IF2	IF3	
	2	RS232	TXD	RXD	
25 pin D-type	3	RS232	RXD	TXD	
(F)	4	RS232	RTS		
13	5	RS232		RTS	
25 713	6	RS232	DSR	DTR	
100	7		GND	GND	
60	8	RS232	DCD	DCD	
	9	TTY	TXD	RXD	
	10	TTY	TXD Ret	TXD Ret	
	11		+8 V	+8 V	
	12	TTY	RXD Ret	RXD Ret	
0 0	13	TTY	RXD	TXD	
	20	RS232	DTR	DSR	
14 0	23		-30 V	-30 V	
17	24		+12 V	+12 V	
	25		+15 V	+15 V	




## STANDARD SOFTWARE

Many standard function blocks are available for interface modules. See Section A7 "PLC Programming".



# INTERFACE CONVERTER INT1 - RS232 / RS485 CONVERTER

PLC SYSTEMS MULTICONTROL COMPONENTS



## INT1

- RS232/RS485 Interface Converter
- Electrical Isolation
- Tristate Switching
- Network Capable

### **GENERAL INFORMATION**


The INT1 interface converter converts the RS232 interface signal to the RS485 signal level. It is used if:

- Data must be transferred further than the range of a RS232 interface.
- Electrical isolation of the interface is required.
- A PLC is to be connected via the RS232 interface.

The INT1 interface converter can be connected to all modules with RS232 interfaces. Example:

Designation	Description	
PIF3	Interface Module, 2 x RS232/TTY	
PIF1-0	Interface Module, 1 x RS232/TTY	
NP02	Communication Processor for Other Protocols	

## **BASIC STRUCTURE**



The distance between two stations can be a max. 5000 m when using a shielded RS485 cable.

## **Terminals**

×	Terminal No.		Signal	7000
(22)	1	TXD	9	410
	2	TXD		
	3	RXD		
	4	RXD		
	5	DTR	RS485	
	6	DTR —		
	7	DSR		
	8	DSR		
	9	RXD	-91/10	
	11	DSR		
	13	DTR	RS232	
	15	TXD		
	17	GND		
	18	Earth Ground		

### **SWITCHES**

The INT1 RS232/RS485 interface converter can be used either for point to point connections or for twisted pair network connections switch ("MODE" switch). The cable must be terminated at the first and last station with a 120  $\Omega$  resistor. This is carried out with the "R $_{\tau}$ " switch.

### **LEDs**

Transmitting and receiving on the RS232 interface is displayed with the "TXD" and "RXD" LEDs. The "DTR" and "DSR" LEDs show the state of the RS232 handshake lines. The "DC ON" LED is lit if an input voltage is connected. The "Active" LED shows if the INT1 RS485 transmitter is switched to bus or tristate mode. This LED is always lit for point to point connections.

## SUPPLY

The INT1 interface converter requires an external 24 VDC supply voltage. The current requirement is a max. 400 mA.


## ORDER INFORMATION

	nverter RS232/RS485, electrically isolate o an RS485 twisted pair network	led, for coupling RS232
without lightning protect		ECINT1-1 ECINT1-11
Connection Cable F	PP60/NP02/PIF3/PIF1 - INT1	BRKA05-0

## PLC SYSTEMS MULTICONTROL COMPONENTS









## PARALLEL PROCESSORS

## PLC SYSTEMS MULTICONTROL COMPONENTS

## **GENERAL INFORMATION**

Parallel processors are used to relieve the CPU from time consuming tasks. e.g.:

- Communication with other systems
- Controlling operator panels
- Controlling operator interface terminals
- Controlling other parallel devices (e.g. BRMEC)
- Executing complex calculations
- Data storage and management

All of the above functions can be handled directly in the CPU module. In many cases, this can lead to an unacceptable program scan time. The user must evaluate the size and complexity of the application and distribute tasks among multiple processors.

A parallel processor provides its own application program memory. Its application program runs parallel to the program in the CPU. The programs in the CPU and in the parallel processor are processed asynchronously. They are independent of each other. The cycle times can be different. The parallel processor cannot access the CPU memory or other PLC modules. However, the CPU can read and write to parts of the parallel processor memory. B&R offers the PP60 Parallel Processor with the 6809 processor (type B).

Parallel Processor	Processor	Application Program Memory	Registers	Processing Time
PP60	6809	42 KByte for max. 42 K instructions	11264	approx. 2.5 msec per K instructions

B&R offers the PP60 MEM Parallel Processor for managing large amounts of data. It is equipped with an additional 128 KByte data memory.


Designation	Module	Application	Slot
PP60 MEM	128 KByte data memory (RAM)	Data storage and management	1

### ONLINE INTERFACE

All parallel processors are equipped with an online interface for communication with the programming device. The online interface is a TTY interface with 62.5 kBaud which can only be used for online operation with the programming device. An online cable is required for online operation:

	Online Cable	Online Interface	Programming PC	Bus Type/Port
Ī	BRKAOL-0	BRIFPC-0 BRKAOL5-1	IBM AT Compatible PCs Notebooks	ISA (PC/AT) CENTRONICS

The parallel processor online interface is connected to the user interface with a 25 pin D-type connector (F) marked "PG/IF". An online adapter (model no. ECPAD1-0) is required for online operation.



The online adapter is plugged into the 25 pin D-type connector (F) of the parallel processor. The online cable is plugged into the 9 pin D-type connector (M) of the online adapter. The online cable shield is wired to the top module mounting screw.

## **USER INTERFACE**

The parallel processor provides its own user interface.

Designation	Interface	
PP60	RS232/RS485/TTY, as desired	277

## INSTRUCTION SET

The PP60 Parallel Processor is equipped with a 6809 processor (type B).

## PARALLEL PROCESSORS

## PLC SYSTEMS MULTICONTROL COMPONENTS





#### DATA MEMORY

PP60 Parallel Processors provide 11264 registers. There are remnant and nonremanent registers. The contents of remanent memory remains in tact when the PLC is turned off. Non-remanent memory is automatically cleared when the power is turned on.

Registers	90	19,
Total	1126	64
Remanent	1124	14

The registers are divided in local and global memory:

Global G 0000 to G 4095
-------------------------

The CPU can access a some of the registers in the parallel processor, i.e. it can read and write to these registers.

Registers	50,	10	
Local		R 0000 to R 0511	
Global	- 10°	G 0000 to G 4095	

### **MATH ROUTINES**

All parallel processors are standardly equipped with fast floating point math routines. Numerous conversion and utility programs are provided in addition to the basic operations such as addition, subtraction, multiplication, division and square root. Numbers are represented in the standard 4 Byte IEEE format. The math routines can be used in ladder diagrams (standard function blocks) and in STL programs.

## FIRST SCAN REGISTER

The first scan register is a register (R 0899) which is automatically set to 1 by the operating g system during the first program cycle, otherwise it is 0. Thew first scan register is used for program initialization. In a ladder diagram, the first scan register can be connected to the enable input of a function block which is only be used once during the first program cycle.

## TIME PULSES

Unlike CPUs, parallel processors do not have time cycles, time pulses or software timers. The prescaler registers R 0991 to R 0993 permit generation of time cycles and time pulses. The prescalers count from 10 to 1 in the specified time interval and then begin again with 10:

R 0991	T = 10 msec
R 0992	T = 100 msec
R 0993	T = 1 sec

The function block PULS generates time pulses from these prescalers. It provides three registers which are set high 1 for the duration of one program scan every n milliseconds, otherwise it is low 0 (n = 10, 100 and 1000). The function block PULS is included in the software package SWSPSSTD01-0 (see Section A7 "PLC Programming / Standard Software").

#### SOFTWARE CLOCK

The parallel processor provide time and date functions

	PP60	
Туре	Software clock	
Nonvolatile	NO	
Time	Hr., Min., Sec., 1/100 Sec.	
Date	Day counter	

#### **SOFTWARE WATCHDOG**

Parallel processors provide software monitoring of the maximum program cycle time. This safety feature is called software watchdog or runtime monitoring. Unlike CPU modules, the default setting of the software watchdog in parallel processors is off, it can be activated by the user when required.

If the software watchdog is active and a program cycle is not completed within the specified cycle time, a software reset will occur. That means that the application program is interrupted.

The software watchdog is an absolutely necessary safety feature for the CPU, however it is only useful in certain circumstances in parallel processors. The software watchdog should only be activated if it is required for safety reasons.

### **APS MODULES FOR PP60 PARALLEL PROCESSORS**

The PP60 parallel processor is a type B processor module

Module	Module Rack	
CP60	MULTI, MIDI	
CP70	MULTI, MIDI	
NTCP6#	M264	
PP60	Parallel Processor for MULTI/MIDI	

Type B processor modules provide internal RAM application program memory (42 KByte for max. 42 K instructions). This memory is supplied by two batteries (power supply module and CPU), the contents remains in tact if the PLC ids turned off. A PROM application program memory module is not required during program development.

A PROM module is required for nonvolatile storage of the application program if the battery supply fails. The following PROM application program memory modules are available for type B processor modules:

	APS Module	Description	
, S	EP128	EPROM Module 128 KByte EPROM for max. 42 K instructions.	
	EE96	EEPROM Module 96 KByte EEPROM for max. 42 K instructions.	
	FP128	Flash PROM Module 128 KByte Flash PROM for max. 42 instructions and 52 KByte data memory.	K
	FP128MP <sup>1)</sup>	Combination of network capable online interface module wit modem interface and application program memory modul (128 KByte Flash PROM for max. 42 K instructions an 52 KByte data memory).	le
	FP384	Flash PROM Module 384 KByte Flash PROM for max. 42 instructions and 308 KByte data memory.	K

The combination of network capable online interface module with modern interface and application program memory module is described in Section A7 "PLC Programming / Online Network and Modern Remote Diagnosis".





## PP60 - PARALLEL PROCESSOR TYPE B

PLC SYSTEMS MULTICONTROL COMPONENTS



## **PP60**

- Parallel Processor Type B
- 42 KByte Application Program Memory for
   42 K Instructions
- Processing Time is approx. 2.5 msec per K Instructions
- 11264 Registers
- Serial RS485/RS232/TTY User Interface
- Software Cloc

## **SLOTS**

The PP60 parallel processor can be operated in MULTICONTROL and MIDICONTROL module racks in the following slots.

Module Rack Slot	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	E	F
MULTI Main Rack MULTI Expansion Rack MIDI	Ċ		Ó	Ó	Ó	Ó	Ó	Ó	Ó							
M264		•								0	0					
<ul> <li>the module can be operated in this slot</li> <li>the module cannot be operated in this slot</li> </ul>																

## ORDER DATA

ECPP60-01	Parallel Processor Type B, 6809 processor, 42 KByte applica-
	tion program memory for 42 K instructions, processing time
	approx. 2.5 msec per K instructions, 11264 registers, serial
	RS485/RS232/TTY user interface, without application program
	memory module
	1.0

Т	ECHNICAL DATA	PP60	
	Module Rack	MULTI, MIDI	2525
	Processor	6809	
9	Processing Time	2.5 msec/K instructions	
	Registers Remanent Non-remanent	11264 11244 20	
	Application Program Memory	42 KByte RAM (internal), PROM Module (EPROM, EEPROM, FlashPROM) not incl. for 42 K instructions	
À	Time / Date	Software clock, volatile	
	Serial Interfaces Online Interface User Interface	TTY (62.5 kBaud) RS485/RS232/TTY (19.2 kBaud)	
	Power Consumption	700	
	at +8 V at +15 V at -30 V	7 W 1.5 W 0.5 W	
9.	Documentation German English French Italian Spanish	MULTICONTROL Hardware Manual MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I	

## **PROGRAMMING**

Programming the PP60 parallel processor is carried out with the B&R PROgramming SYStem. Efficient standard function blocks are available. The B&R PROgramming SYStem and standard software package are described in Section A7 "PLC Programming".

The application program memory module is not included with the delivery of the PP60 parallel processor, it must be ordered separately. A description of the application program memory module can be found in Section "Application Program Memory Module".

# PP60 MEM - PARALLEL PROCESSOR TYPE B WITH 128 KBYTE DATA MEMORY

PLC SYSTEMS MULTICONTROL COMPONENTS







## PP60 MEM

- Parallel Processor Type B with 128 KByte
   Data Memory
- 42 KByte Application Program Memory for 42 K Instructions
- Processing Time approx. 2.5 msec per K Instructions
- 11264 Registers
- Serial RS485/RS232/TTY Interface
- Software Clock

### **SLOTS**

The PP60 MEM parallel processor can be operated in the MULTICONTROL and MIDICONTROL module racks in the following slots.

Module Rack Slot	0 1 2 3 4 5 6 7 8 9 A B C D E F
MULTI Main Rack	•••••
MULTI Expansion Rack	000000000000000
MIDI	0000000
M264	00000000
<ul> <li>the module can be operated in this slot</li> <li>the module cannot be operated in this slot</li> </ul>	

## ORDER DATA

ECPP60MEM-01	Parallel Processor Type B, 6809 processor, 42 KByte applica tion program memory for 42 K instructions, processing time approx. 2.5 msec per K instructions, 11264 registers, serial
	RS485/RS232/TTY user interface, without application program memory module, 128 KByte data memory (RAM)

## ADDITION DATA MEMORY

The parallel PP60 MEM processor provides 128 KByte data memory (static RAM) in addition to the functions of a PP60 parallel processor. This memory area is buffered by the battery in the power supply module and by the battery in the parallel processor. It is also nonvolatile if the module is removed from the PLC.

## Addressing

The parallel processor accesses the 128 KByte data memory via P addresses. Then desired memory location (\$0000 to \$FFFF) is addressed with a 16 bit address register. The selected memory location is read or written to with an access register. Access can also be performed with an auto-increment access register. That means the address register is automatically incremented after the access. Auto-increment access registers are very useful for copy loops.

TECHNICAL DATA	PP60 MEM
Module Rack	MULTI, MIDI
Processor	6809
Processor Time	2.5 msec/K instructions
Registers Remanent Non-remanent	11264 11244 20
Application Program Memory	42 KByte RAM (internal), PROM Module (EPROM, EEPROM, FlashPROM) not incl. for 42 K instructions
Time /Date	Software clock, volatile
Serial Interfaces Online Interface User Interface	TTY (62.5 kBaud) RS485/RS232/TTY (19.2 kBaud)
Power Consumption at +8 V at +15 V at -30 V	7 W 1.5 W 0.5 W
Documentation German English French Italian Spanish	MULTICONTROL Hardware Manual MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-I MAHWMULTI-S

### **PROGRAMMING**

Programming the PP60 MEM parallel processor is carried out with the B&R PROgramming SYStem. Efficient standard function blocks are available. The B&R PROgramming SYStem and standard software package are described in Section A7 "PLC Programming".

The application program memory module is not included with the delivery of the PP60 MEM parallel processor, it must be ordered separately. A description of the application program memory module can be found in Section "Application Program Memory Module".

## STANDARD FUNCTION BLOCKS

Data can be read from data memory or written to data memory with the standard function blocks GETM and PUTM. The function block GETM can copy up to 1024 Bytes from data memory into the register area of the PP60 MEM. The function block PUTM can copy up to 1024 Bytes from the register area of the PP60 MEM into the data memory.



## **COUNTER/POSITIONING MODULES**

## PLC SYSTEMS MULTICONTROL COMPONENTS

## **GENERAL INFORMATION**

This section explains the differences between counter modules for positioning applications, counter modules for event counting and positioning modules:

Counter Modules for Applications These modules have fast inputs and counters for actual position monitoring with incremental encoders as well as other hardware necessary for positioning tasks (analog outputs for controlling motors, fast digital inputs for end switches and reference switches, outputs for motor governor control). The positioning task is controlled from the user program in the CPU.

Counter Modules for Event Counting The hardware is especially suited to event counting, i.e. these modules have inputs and counters (normally several) for rapid event monitoring.

**Positioning Modules** 

Positioning modules are equipped with the respective firmware for positioning applications as well as those hardware components that are required. This means that the CPU does not have to control all of the details involved in a positioning task, it only has to give instructions (e.g. "Absolute Positioning" or "Move Relative to Current Position". The positioning module executes the respective command and informs the application program in the CPU that "Position Reached".

Some different positioning methods are:

Dual Speed Positioning Two motors with different RPM drive one axis. As long as the difference between the set and actual positions is relatively large, the faster motor is active. When the set position is closer, the slower motor is switched on and the faster is deactivated. This type of positioning inevitably leads to jumps in acceleration which can cause mechanical play.

Positioning with Stepper Motors The control electronics send pulses which turn the motor by a certain angle (one step). Since the angle of a single pulse is known, the actual position does not have to be monitored. The actual position is determined automatically by the number of pulses that are output. The current consumption of stepper motors is relatively high for fast positioning procedures. Therefore, this type of positioning is only suitable for small to medium size applications.

Positioning with Servo Motors Positioning is controlled through analog signals ( $\pm 10\,$  V), i.e. the speed of the motor can be regulated smoothly in both directions. Compared with dual speed positioning, this method of positioning is especially preferred for large masses since the mechanics are not as subject to jolts.

The following positioning modules are available for the MULTICONTROL system:

	PNC3	PZL1	PSA2	PNC8	
Module type	Counter	Counter	Positioning	Positioning	
	Module	Module	Module	Module	
Use	Positioning	Event	Positioning with	Positioning	
	with Servo Motor Governors or	Counting	Stepper Motors	with Servo Motor Governors or	
	Dual Speed Pos.			Dual Speed Pos.	
	Dual opocu i co.			Dual Opcour oc	
Counting Freq.	Max. 200 kHz	max. 20 kHz	20 kHz <sup>1)</sup>	max. 400 kHz	
Axes / Counter	1	15	2	4	0

#### SLOT

Counting and positioning modules can be operated in the following slots of racks MULTI, MIDI and M264.

Rack Slot	0	1	2	2	3	4	5	6	7	8	9	A	В	С	D	E	F
MULTI Base Rack	•	•		•	•	•	•	•	•	•	•	•	•	•	•	•	•
MULTI Expansion Rack	0	0	(	)(	)	0	0	0	0	0	0	0	0	0	0	0	0
MIDI	0		•	•		•	•	•	•								
M264	•		•	•	•	•	0	0	0	0	0	0					
The module can be operated in this slot     The module cannot be operated in this slot																	

## STANDARD SOFTWARE

There are respective standard function blocks for all counting and positioning modules:

For Module	Function Block	Use	Component of Software Package
PNC3	PNRC	Positioning with Servo Motor Governors	SWSPSPOS01-0
PNC3	PNSC	Dual Speed Positioning	SWSPSPOS01-0
PZL1	CMDA	Counting Functions (Event Counting)	SWSPSSTD01-0
PSA2	PSA2	Step Motor Positioning	SWSPSPOS01-0
PNC8	PNRD	Positioning with Servo Motor Governors	SWSPSPOS01-0

See sections A7 "PLC Programming/Standard Software" and A8 "Positioning".


maximum pulse frequency

# COUNTING AND POSITIONING MODULES, PNC3 - COUNTER MODULE (POSITIONING)

PLC SYSTEMS MULTICONTROL COMPONENTS







## PNC3

- Fast Counter Module for Positioning Applications
- Counter Frequency Max. 200 kHz
- Counting Range 24 Bit
- Analog Output for Controlling Servo Motors (±10 V, 11 Bit)
- Encoder Inputs for 24 VDC (Galvanically Isolated) or 5 - 15 V

See section A8 "Positioning" as well.

#### SLOTS

The PNC3 counter module can be operated in the following slots of racks MULTI, MIDI and M264.

Rad	ck	Slot	0	1	2	3	4	5	6	7	8	9	A	В	С	D	E	F
	ILTI Base Rack		-	-	-	-	-	-	-	-	-	-	-	-	-	-	•	-
MU	ILTI Expansion Rack DI		0								O	O	O	O	O	O	0	0
M2	M264				•	•	•	0	0	0	0	0	0					
	The module can be of The module cannot	perated in this slot be operated in this slot																

## ORDER DATA

	Counter Module for Positioning Applications, Binary 24 Bit Counter, Counter	unting Frequency
Ma	Х.	
	200 kHz, 11 Bit Analog Output (±10 V)	
	With Galvanic Isolation, For Connection of Externally	
	Supplied 24 VDC Encoders (Asymmetric Input)	ECPNC3-0
	Without Galvanic Isolation, For the Connection of Internally or	
	Externally Supplied 5 - 15 VDC encoders (Symmetric input)	ECPNC3-1

## SIGNAL ENCODER

The PNC3-0 counter module is designed for externally supplied 24 VDC encoders. The supply voltage is connected to the terminals. It is internally connected directly to the 9 pin D-type (F) of the encoder connection (see Pinouts). Counter inputs A and B and the reference pulse input R are galvanically isolated from the signal encoder with an optocoupler. It can be used with positive switching, negative switching or push-pull switching encoders.

With the PNC3-1 module, the user can select internal and external encoder supply with a jumper. With internal encoder supply, the encoder is supplied by the PNC3 module. A 5V and a 15V supply voltage are available. With external supply, the supply voltage is connected to two terminals. It is then fed directly to the 9 pin D-type (F) of the encoder connection (see pin-outs). Counter inputs A and B as well as reference pulse input R are not galvanically isolated.

CHNICAL DATA	PNC3-0	PNC3-1
Signal Encoder Connection	9 pin D-type (F)	9 pin D-type (F)
Signal Encoder Inputs	`	1,0
Galvanically Isolated	YES	NO
Input Voltage - Nominal	24 VDC <sup>1)</sup>	5 - 12 VDC
Input Voltage Min./Max.	18 VDC / 30 VDC	2.4 VDC / 15 VDC
Input Current	typ. 10 mA	typ. 2 mA at 5 VDC
- 1900 - 1900		typ. 5 mA at 15 VDC
Encoder Supply	24 VDC	Optional from PNC3 2)
100	Fed Externally	or Fed Externally
	100	5 VDC/250 mA or
		15 VDC/500 mA
	477	13 VD0/300 IIIA
Distance from Signal Encoder	Max. 50 m	Max. 50 m
Input Frequency	Max. 50 kHz	Max. 50 kHz
Counting Frequency		
With Single Evaluation	Max. 50 kHz	Max. 50 kHz
With Double Evaluation	Max. 100 kHz	Max. 100 kHz
With Four Fold Evaluation	Max. 200 kHz	Max. 200 kHz
Willi Four Fold Evaluation	IVIdX. 200 KTIZ	IVIAX. 200 KHZ
Phase Shift between		
Counter Channels A and B	90°±30°	90 ° ±30 °
Reference Pulse Duration	> 50 µsec	> 50 µsec
Counting Range	24 Bit Binary	24 Bit Binary
Analog Output		
Output Voltage	+10 V	±10 V
Resolution	10 Bit + Sign	10 Bit + Sign
Quantization Error	< 1 Bit	< 1 Bit
-,	< 1 mV	< 1 mV
Offset Voltage	< 1 mV	< 1 mv
Resistance to Disturbance 3)	Grade 3	Grade 4
Power Consumption		
At +8 V	1.2 W	1.6 W
At +15 V	0.4 W	0.4 W
At -30 V	0.6 W	0.6 W
At -50 V	0.0 **	0.0 W
Documentation	Positioning Use	
German	MAPOS	
English	MAPOS	SI-E
	1200	
- 125	Hardware Manual MULTICONTI	
French	MAHWMU	ILTI-F
	A A A L IVA A A I	II TI I
Italian	MAHWMU	JL I I-I

PIN ASSIGNMENT	Pin	ECPNC3-0	ECPNC3-1
	1	Counter Channel B	Counter Channel B
9 pin D-type	2	Counter Channel B Ret	Counter Channel B
(F)	3	Encoder Supply +	+15 V (Max. 500 mA)
5	4	Counter Channel A	Counter Channel A
3 60	5	Counter Channel A Ret	Counter Channel A
	6	Ref. Potential Encoder Sup.	Ref. Potential Encoder Sup.
6	7	Reference Signal R	Reference Signal R
0	8	Reference Signal R Ret	Reference Signal R
	9	-7 <sub>12</sub> ,	5 V (Max. 250 mA)

## STANDARD SOFTWARE

Software Package SWSPSPOS01-0 contains standard function blocks for positioning applications with servo applications with servo motors and dual speed positioning (see section A7 "PLC Programming/Standard Software" and section A8 "Positioning" as well).

Positive switching (PNP), negative switching (NPN) or push-pull

<sup>2)</sup> Jumper selectable

<sup>3)</sup> Conforms to DIN VDE 0843-4, Signal encoder connection grounded at both ends



# COUNTING AND POSITIONING MODULES, PSA2 - FOR STEPPER MOTOR POSITIONING

PLC SYSTEMS
MULTICONTROL COMPONENTS



## PSA<sub>2</sub>

- Intelligent Positioning Module for Stepper Motors
- Controlling Two Stepper Motors
- Pulse Frequency Max. 20 kHz
- 2 Potential Free Relay Contacts, 8 Transistor Outputs, 10 Digital Inputs
- Fast Trigger Signal Input

See section A8 "Positioning" as well

## **SLOTS**

The PSA2 positioning module can be operated in the following slots of racks MULTI, MIDI and M264.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	A	В	C	D	Ε	F
MULTI Base Rack	Ma	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•
MULTI Expansion Rack		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
MIDI		0	•	•	•	•	•	•	•								
M264		•	•	•	•	•	0	0	0	0	0	0					
The module can be operated.  The module can be operated.																	

## ORDER DATA


## ECPSA2-0

Positioning Module for Stepper Motors, For Controlling 2 Stepper Motors, 1 Potential Free Relay Output per Axis, 4 Transistor Outputs for Stepper Motor Control, 5 Digital Inputs for End Switches, Reference Switch, Trigger Switch and Ready Signals, Pulse Frequency Max. 20 kHz

## **FUNCTIONALITY**

The stepper motor controller module PSA2 is used for positioning applications with stepper motors. Two axes can be controlled with a PSA2 module.

## Diagram



The Outputs of the PSA2 Module for Power Electronics are: Pulse, rotation direction, enable and booster (current amplification during the acceleration phase). The Inputs: End switch pos./neg., reference switch, trigger switch and ready signal of the power electronics.

T	ECHNICAL DATA	PSA2
	Axes 2	
Ī	Controller	8031
Ì	Connections	Three 15 pin D-type (F)
	Inputs End Switch Pos. End Switch Neg. Reference Switch Trigger Switch Ready Signal	24 V / 10 mA 24 V / 10 mA 24 V / 10 mA 24 V / 10 mA and 5 V / 7 mA 5 to 24 V / ca. 5 mA
	Transistor Outputs Pulse Rotational Direction Enable Signal	Short Circuit and Overload Protected 5 to 24 V, Push-Pull Driver, Pull:50 mA 5 to 24 V, Push Current 3 mA stat./80 mA dyn., (0.2 msec) 5 to 24 V, Push Current 3 mA stat./80 mA dyn., (0.2 msec)
Ġ,	Relay Output	30 V / 1 A, Internal Protection Circuit (Varistor)
	Pulse Frequency	25 Hz to 20 kHz (Resolution - 4 Hz)
	Acceleration Time From 25 Hz Start/Stop Frequency To 20 kHz End Frequency	From 60 msec to 17 sec.
	Operation Modes	Linear Acceleration, Start/Stop Operation
Ī	Positioning Functions	Absolute, Relative, Start at Trigger Pulse, Endless Positioning
	Resistance to Disturbance	NEMA (1,5 kV) for Inputs, VDE 0843 ( Burst Test) 3 kV on all Pins
	Documentation German English	Positioning User's Manual MAPOSI-0 MAPOSI-E
	French Italian Spanish	Hardware Manual MULTICONTROL, MIDICONTROL, M264 MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S

## **CONNECTIONS (3 \* 15 PIN MALE D-TYPES)**

Inputs	Pin	Axis 0	Pin	Axis 1	
-2 <sup>1</sup>	N 1	End Switch pos.	9	End Switch pos.	
9	2	End Switch neg.	10	End Switch neg.	
.: 19	3	Reference Switch	<b>11</b>	Reference Switch	
2,50	4	GND for Pin 1 to 3	12	GND for 9 to 11	
30.	5	Trigger Signal 5 V	13	Trigger Signal 5 V	
₹1.:	6	Trigger Signal 24 V	14	Trigger Signal 24 V	
15	7	GND for 5 and 6	15	GND for 13 and 14	
15 38	8	- 2			
Outputs Axis 0	Pin	Function	Pin	Function	
	- A (	)-		20	

Pin	Function	Pin	Function
_100	Pulse	9	-500
2		10	
3	Rotation Direction	11	Relay Contact A
4		12	Relay Contact B
5	Enable	13	+ For Transistor Output
6		14	Ready Signal
7	Booster	15	GND for Transistor Output
8			
	1 2 3 4 5 6 7	1 Pulse 2 3 Rotation Direction 4 5 Enable 6 7 Booster	1 Pulse 9 2 10 3 Rotation Direction 11 4 12 5 Enable 13 6 14 7 Booster 15

Outputs Axis 1	Pin	Function	Pin	Function
	1	Pulse	9	"The
9	2		10	
•:	3	Rotation Direction	11	Relay Contact A
	4		12	Relay Contact B
:•	5	Enable	13	+ for Transistor Output
·:   20	6		14	Ready Signal
15	7	Booster	15	GND for Transistor Output
13 38	8			

## STANDARD SOFTWARE


A standard function block for operating the PSA2 module is included in the SWSPSPOS01-0 software package (see sections A7 "PLC Programming/ Standard Software" and A8 "Positioning" as well).

# COUNTING AND POSITIONING MODULES, PZL1 - COUNTER MODULE (EVENT COUNTING)

PLC SYSTEMS MULTICONTROL COMPONENTS







## PZL1

- Fast Counter Module for Event Counting
- All Counter Channels Galvanically Isolated
- Counting Frequency Max. 5 kHz
- Signal Voltage 24 V
- 15 Binary Decremental Counters
- Counting Range 16 Bit

See section A8 "Positioning"

#### SLOTS

The PZL1 counter module can be operated in the following slots of racks MULTI, MIDI and M264.

Rac	k		Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
	-	Rack		0	0	0	0	0	0	0	0	0	0	0	0			•		
	The module ca		ed in this slot erated in this slot																	


## ORDER DATA

ECPZL1-0 Counter Module for Event Counting, 15 Binary 16 Bit Counter, Input Frequency Max. 5 kHz, Signal Voltage 24 V, All Channels are Galvanically Isolated

## **FUNCTIONALITY**

The counters of the PZL1 module are decremental. They count from a predefined value down to 0 and start again from the predefined value. When the counter status reaches 0, a bit is set in the status register.

## INPUT CIRCUIT



TECHNICAL DATA	PZL1	
Number of Counters	15	
Galvanic Isolation Channel - PLC Channel - Channel	YES YES	
Input Voltage Nominal Max. Permitted	24 V 30 V	allion o
Input Current	ca. 10 mA	
Signal Encoder Supply	External	
Switching Threshold log. $0 \rightarrow \log$ . 1 log. $1 \rightarrow \log 0$	Max. 13 V Min. 2.5 V	
Input Frequency	Max. 5 kHz	10Kg
Counting Range	16 Bit Binary	3/1
Documentation German English French Italian Spanish	Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E MAHWMULTI-F MAHWMULTI-I MAHWMULTI-S	

PIN	SV1	SV2	SV3	SV4
1	76/0	-	-	77,65
2	Ref.Pot. Z4	Ref.Pot. Z8	Ref.Pot. Z12	Total -
3	Ref.Pot. Z3	Ref.Pot. Z7	Ref.Pot. Z11	Ref.Pot. Z15
4	Ref.Pot. Z2	Ref.Pot. Z6	Ref.Pot. Z10	Ref.Pot. Z14
5	Ref.Pot. Z1	Ref.Pot. Z5	Ref.Pot. Z9	Ref.Pot. Z13
6	Counter 4	Counter 8	Counter 12	-
7	Counter 3	Counter 7	Counter 11	Counter 15
8	Counter 2	Counter 6	Counter 10	Counter 14
9	Counter 1	Counter 5	Counter 9	Counter 13
	1 2 3 4 5 6 7 8	1 Ref.Pot. Z4 3 Ref.Pot. Z3 4 Ref.Pot. Z2 5 Ref.Pot. Z1 6 Counter 4 7 Counter 3 8 Counter 2	1 Ref.Pot. Z4 Ref.Pot. Z8 Ref.Pot. Z7 Ref.Pot. Z7 Ref.Pot. Z7 Ref.Pot. Z6 Ref.Pot. Z6 Ref.Pot. Z1 Ref.Pot. Z5 Ref.Pot. Z1 Ref.Pot. Z5 Counter 4 Counter 8 Counter 3 Counter 7 Ref.Pot. Z6 Counter 2 Counter 6 Ref.Pot. Z6 Ref.Pot. Z6 Counter 2 Counter 3 Counter 6 Ref.Pot. Z6 Ref.Pot. Z7 Ref.Pot. Z6 Ref.Pot. Z7 Ref.Pot. Z6 Ref.Pot. Z	1 2 Ref.Pot. Z4 Ref.Pot. Z8 Ref.Pot. Z12 Ref.Pot. Z3 Ref.Pot. Z7 Ref.Pot. Z11 4 Ref.Pot. Z2 Ref.Pot. Z6 Ref.Pot. Z10 Ref.Pot. Z1 Ref.Pot. Z1 Ref.Pot. Z1 Ref.Pot. Z9 Ref.Pot. Z9 Ref.Pot. Z9 Ref.Pot. Z9 Ref.Pot. Z9 Ref.Pot. Z9 Counter 4 Counter 8 Counter 12 Counter 3 Counter 7 Counter 11 Ref.Pot. Z9 Counter 2 Counter 2 Counter 6 Counter 10


## STANDARD SOFTWARE

A standard function block for operating the PZL1 module is included in software package SWSPSSTD01-0 (see section A7 "PLC Programming/Standard Software" as well).



# COUNTING AND POSITIONING MODULES, PNC8 - POSITIONING MODULE

PLC SYSTEMS
MULTICONTROL COMPONENTS



## PNC8

- Fast Positioning Module for Positioning Applications
- Four Axes Control
- Counting Frequency Max. 400 kHz
- Counting Range 32 Bit
- Analog Output for Control of Servo Motors (±10 V, 12 Bit)
- Encoder Inputs are Optional Incremental or Absolute
- Event Counting (Eight Channels)

See section A8 "Positioning" as well

#### **SLOTS**

The PNC8 positioning module can be operated in the following slots of racks MULTI, MIDI and M264.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	A	В	С	D	Ε	F	
MULTI Base Rack MULTI Expansion Rack	14,															•		
MIDI		Ó	•	•	•	•	•	•	•			-		•		J	•	
M264		•	•	•	•	•	0	0	0	0	0	0						
<ul><li>The module can be operated</li><li>The module cannot be open</li></ul>																		

## ORDER DATA

Positioning module for Positioning Applications, Four Axes, Four Binary 32 Bit Counters, Counting Frequency Max. 400 kHz at Four Fold Evaluation, For Direct Connection of Incremental Encoders or Absolute Encoders, 8 Event Counters, 12 Digital Inputs,

With 16 digital transistor outputs ECPNC8-13

With four analog outputs ( $\pm 10$  V, 12 Bit) for controlling servo motors, 4 relay outputs e.g. Controller Enable)

ECPNC8-23

D-type adapter from 37 pin D-type (F) to four 15 pin D-type (F)

BRADPNC8E-0

## GENERAL INFORMATION

The PNC8 positioning module is available in two different versions. The PNC8-13 has 16 digital transistor outputs. Version PNC8-23 is equipped with four analog outputs for controlling servo motors. Both modules have four counter inputs for incremental encoders, four binary counters (32 bit), inputs for absolute encoders and 12 digital inputs.

TI	ECHNICAL DATA	PNC8-13	PNC8-23
	Signal Encoder Connection	37 pin D-type (F)	37 pin D-type (F)
ì	Signal Encoder Inputs	5 to 24 V, Single and Differential, Not Galvanically Isolated, Input Filter 1 µsec or 10 µsec (Software Selectable)	5 to 24 V, Single and Differential, Not Galvanically Isolated, Input Filter 1 µsec or 10 µsec (Software Selectable)
	Encoder Supply	5 to 24 V, External	5 to 24 V, External
Π	Input Frequency	Max. 100 kHz	Max. 100 kHz
	Counter Frequency At Four Fold Evaluation	Max. 400 kHz	Max. 400 kHz
	Phase Shift Between Counter Channels A and B	90°±45°	90°±45°
	Counter Operating Mode	32 Bit Binary Absolute, Incremental, Inc./Dec. Counter, Event Counter	32 Bit Binary Absolute, Incremental, Inc./Dec. Counter, Event Counter
	Digital Inputs Input Voltage Switching Threshold Input Current Switching Delay	12, Galvanically Isolated 24 VDC Min. 7 V, typ. 10 V, Max. 14 V ca. 6 mA at 24 VDC ca. 10 msec	12, Galvanically Isolated 24 VDC Min. 7 V, typ. 10 V, Max. 14 V ca. 6 mA at 24 VDC ca. 10 msec
	Analog Outputs Output Voltage Resolution	9	4 ±10 V 11 Bit + Sign
	Digital Outputs Output Voltage Output Current	16 Transistor Outputs Nom. 24 VDC, Max. 30 VDC Max. 400 mA	4 Relay Outputs Nom. 24 VDC, Max. 30 VDC Max. 1.5 A
	Power Consumption At +8 V At +15 V At -30 V	3.9 W - -	4.6 W 2.7 W
	Documentation German English	Positioning User MAPOS MAPOSI	I-0


## **COUNTER OPERATION MODES**

The following modes of operation can be switched between for each of the four channels:

- Incremental Encoder Signal Counting
- Absolute Encoder Signal Counting
- Incremental / Decremental Counter
- Event Counter

## a. Incremental Encoder Signal Counting

This mode of operation is used for positioning applications with incremental actual position monitoring. The signal encoder puts out two square wave signals (A and B). The counter is either incremented or decremented respectively with each positive and negative edge of both signals. Both square wave signals are phase shifted by 90 degrees. The counting direction is determined in this way.



## COUNTING AND POSITIONING MODULES, PNC8 - POSITIONING MODULE

## PLC SYSTEMS MULTICONTROL COMPONENTS

A6




## b. Counting Absolute Encoder Signals

The PNC8 module puts out 32 pulses for absolute encoders and receives the incoming serial data.


#### c. Incremental / Decremental Counter

In this mode of operation the counter is incremented or decremented at input A with each positive and negative edge. Input B determines the counting direction. If input B is 0, the counter is incrementing and if it is logic 1, it is decrementing.




## d. Event Counting

In the event counting mode of operation, two independent counters exist for each counting channel (a total of 8 counters). A counter is incremented with each positive and negative edge on input A and the second counter with each edge on input B.



## PIN-OUTS

DIGITAL INPUTS	Pin	Function	Pin	Function
15 pin D-type (F)	1 2 3 4 5 6 7 8	Neg. End Switch Channel 1 Reference Switch Channel 1 Pos. End Switch Channel 1 GND GND Neg. End Switch Channel 0 Reference Switch Channel 0 Pos. End Switch Channel 0	9 10 11 12 13 14 15	Neg. End Switch Channel 3 Reference Switch Channel 3 Pos. End Switch Channel 3 GND Neg. End Switch Channel 2 Reference Switch Channel 2 Pos. End Switch Channel 2



SIGNAL ENCODER	Pin	Channel	Function
	1	1	Pulse Neg. Absolute Encoder
	2	1	Pulse pos. Absolute Encoder
	3	1	Reference Pulse (incr.) or Data of Absolute Encoder Neg.
	4	1	Reference Pulse (incr.) or Data of Absolute Encoder Pos.
	5	1	Counter Input B (incr.) Neg.
	6	1	Counter Input B (incr.) Pos.
	7	1	Counter Input A (incr.) Neg.
	8	1	Counter Input A (incr.) Pos.
37 pin D-type	9		Encoder Supply Neg.
20.3	10		700
(F)	11		Encoder Supply Pos.
	12	0	Pulse Neg. Absolute Encoder
37	13	0	Pulse Pos. Absolute Encoder
	14	0	Reference Pulse (incr.) or Data of Absolute Encoder Neg.
	15	0	Reference Pulse (incr.) or Data of Absolute Encoder Pos.
60	16	0	Counter Input B (incr.) Neg.
	17	0	Counter Input B (incr.) Pos.
%	18	Ö	Counter Input A (incr.) Neg.
000	19	0	Counter Input A (incr.) Pos.
000	20	3	Pulse Neg. Absolute Encoder
00	21	3	Pulse Pos. Absolute Encoder
000	22	3	Reference Pulse (incr.) or Data of Absolute Encoder Neg.
	23	3	Reference Pulse (incr.) or Data of Absolute Encoder Pos.
	24	3	Counter Input B (incr.) Neg.
	25	3	Counter Input B (incr.) Pos.
20	26	3	Counter Input A (incr.) Neg.
<b>○</b> \1	27	3	Counter Input A (incr.) Pos.
	30	2	Pulse Neg. Absolute Encoder
	31	2	Pulse Pos. Absolute Encoder
	32	2	Reference Pulse (incr.) or Data of Absolute Encoder Neg.
	33	2	Reference Pulse (incr.) or Data of Absolute Encoder Neg.
	34	2	Counter Input B (incr.) Neg.
	35	2	Counter Input B (incr.) Neg. Counter Input B (incr.) Pos.
	36	2	Counter Input A (incr.) Neg.
	37	2	Counter Input A (incr.) Pos.

## STANDARD SOFTWARE

A standard function block for the operation of the PNC8 module is included in software package SWSPSPOS01-0 (Rev. 00.30 and higher) (see sections A7 "PLC Programming/Standard Software" and A8 "Positioning" as well).



# COUNTING AND POSITIONING MODULES, PWP4 - ULTRASONIC TRANSDUCER MODULE

PLC SYSTEMS MULTICONTROL COMPONENTS



## PWP4

- Up to Four UWS Connections
- Resolution to 0.01 mm
- Measurement lengths to 12.8 m
- Galvanic Isolation: UWS PLC PLC PLC

See section A8 "Positioning"

### SLOTS


The PWP4 ultrasonic transducer module can be operated in the following slots of racks MULTI, MIDI and M264.

Rack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	C	D	Ε	F
MULTI Base Rack MULTI Expansion Rack MIDI M264	Alan.	0		0	0	0	0	0	0	Ó	Ó	0	Ó	•			•
<ul> <li>The module can be opera</li> <li>The module cannot be of</li> </ul>																	

## ORDER DATA

Distance Measurement Module for Ultrasonic Transducer, Systems, Galvanically Isolated	Four Distance Measurement
Without Distance Processor (Socket Available)	ECPWP4-0
Two Distance Processors	ECPWP4-2
Four Distance Processors	ECPWP4-4

## DIAGRAM



TECHNICAL DATA	PWP4-0	PWP4-2	PWP4-4
Number of Distance Processors	-	2	4
Connections		Four 9 pin D-type (F)	
Galvanic Isolation UWS - PLC UWS - UWS		YES YES	
Resolution		0.01 mm to 1.2 m measurement ler 0.1 mm to 12.8 m measurement ler	
Reproducibility		Better than 0.01 mm	
Maximum Measurement Length		12.8 m (at 0.1 mm resolution)	
Output Voltage for UWS		±15 VDC (±5 %)	27,
Output Current per UWS		+15 V / 70 mA -15 V / 50 mA	
Documentation	PW	Short Description P4 - Ultrasonic Transducer Controlle	r Module
German English		MAPWP4KB-0 MAPWP4KB-E	

PIN	-OUTS	Pin	Function	
		1	+15 V / 70 mA	
	9 pin D-type	2	Init	
	(F)	3	GND	
	5	4	Stop	
	168	5	-15 V / 50 mA	
		6	Init	
	ر الفال	7	GND	
	1/40.	8	Termination Resistance <sup>1)</sup>	
		9	Stop	

## STANDARD SOFTWARE

A standard function block for operating the PWP4 module is included in the SWSPSSTD01-0 software package (see section A7 "PLC Programming/Standard Software" as well).


For sensors with RS485 interfaces, the termination resistance must be bridged (Pin 8 with Pin 9).

## PLC SYSTEMS MULTICONTROL COMPONENTS





NOTES:





## OTHER MODULES AND DEVICES

PLC SYSTEMS MULTICONTROL COMPONENTS

## **GENERAL INFORMATION**

Modules and devices which cannot be assigned to a specific section are described in this section. They are:

Module / Device	Function
EXS2	Expansion sender module for connection of up to 3 MULTICONTROL expansion units.
EXE3	Expansion receiver module for connecting MULTICONTROL expansion units to the main rack.
NP02	Communication processor for other protocols (S 3964, L1, Allen Bradley Data Highway, Modbus, Honeywell CIM620, B&R MININET)
PMV4	Proportional solenoid module
BRMEC	Mass memory

# **EXS2 - EXPANSION SENDER MODULE, EXE3 - EXPANSION RECEIVER MODULE**

## PLC SYSTEMS MULTICONTROL COMPONENTS









### ORDER DATA

EXS2 - Expansion sender module for the main rack, for connection of up to three expansion racks	ECEXS2-1
EXE3 - Expansion receiver module to connect an expansion rack to the main rack	ECEXE3-0
Expansion cable for connecting an expansion rack to the a main rack, Length 0.5 m	ECEXKA-1

## GENERAL INFORMATION

The MULTI main rack has 16 module slots. With the expansion modules EXS2 and EXE3, up to three extra expansion racks can be connected to the main rack. Therefore, the number of modules that can be used in the MULTICONTROL system can be raised to 64.

Required for an expansion unit:

- MULTI main rack (e.g. ECR165-0)
- MULTICONTROL power supply module (NT43, NT44 or PS45)
- Expansion receiver module EXE3
- Expansion cable (Model No. ECEXKA-1)


A standard B&R cable (length 0.5 m) must be used to connect expansion senders and receivers. An EXS2 expansion sender is required in the main rack in addition to the modules shown above in the expansion unit. Up to three expansion receivers can be connected to the expansion sender.

TECHNICAL DATA	EXS2	EXE3
Name Expansion	Expansion Sender Module	Receiver Module
LED Display	3	4
Connections	Two 25 Pin D-Type Connectors (F)	Two 25 Pin D-Type Connectors (F)
Power Consumption at +8 V	1.7 W	1.7 W
Documentation German English French Italian Spanish	MAHWI MAHWI MAHWI MAHW	. Hardware Manual MULTI-0 MULTI-E MULTI-F MULTI-I MULTI-1 MULTI-S

## **SLOTS AND CONFIGURATIONS**

The EXS2 expansion sender module is used in the main rack in the slot between the power supply module and the CPU. The EXE3 expansion receiver module is used in the expansion unit in the slot immediately next to the power supply module. The slot to the right of the expansion receiver is to remain free, it is to be covered with dummy front.

Both female D-type connectors on the expansion modules are wired parallel. That means either the top or the bottom connector can be used. The expansion units can also either be places over or under the main rack. e.g.:



## **Configuration of Multiple Expansion Units**

The following configurations are possible when using more than one expansion unit on the main rack:

- a) The main rack is either the top or bottom rack in the configuration. In this case, the second expansion unit is connected to the expansion receiver of the first expansion unit.
- b) The first two expansion units are situated above and below the main rack. In this case, both expansion receivers are connected to the expansion sender on the main rack.



# NP02 - COMMUNICATION PROCESSOR FOR OTHER PROTOCOLS

PLC SYSTEMS MULTICONTROL COMPONENTS



## SLOTS

The communication processor NP02 can be operated in the MULTI, MIDI and M264 rack in the following slots.

R	ack	Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F
М	ULTI Main Rack	.44	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•
M	ULTI Expansion Rack		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
M	IDI .		0	lacktrian	•	•	•	•	•	•								
M	264		•	•	•	•	•	0	0	0	0	0	0					

## ORDER DATA

NP02 - Communication Processor for Other Protocols, without EPROM Memory Module	ECNP02-0
EPROM Memory Module with Modbus Protocol EPROM Memory Module with S3964(R) Protocol (RK512) EPROM Memory Module with Honeywell CIM620 Protocol EPROM Memory Module with A+B Data Highway Protocol EPROM Memory Module with L1 Protocol EPROM Memory Module with B&R MININET Protocol	SWNP02DP01-0 SWNP02DP02-0 SWNP02DP03-0 SWNP02DP04-0 SWNP02DP05-0 SWNP02DPMN-0

## **GENERAL INFORMATION**

An application program memory module is not contained in the delivery of the NP02 communication processor. The software for the other protocols shown above are delivered on EPROM memory. The NP02 is always to be ordered together with one of the EPROM memory modules.

## NP<sub>0</sub>2

- Communication Processor for Other Protocols
- Serial RS232 Interface
- For MULTI, MIDI and M264 Racks
- S3964 (R) (RK512), L1, Modbus, Allen Bradley Data Highway, Honeywell CIM 620, B&R MININET Protocols are Supported

## TECHNICAL DATA NP<sub>02</sub> Designation Communication Processor for Other Protocols S3964(R) (RK512), Modbus, L1, Allen Bradley Data Highway, Honeywell CIM620, B&R MININET Interface RS232/TTY Connection to an RS485 Twisted Pair Bus via INT1 (RS232/RS485 Interface Converter) Hardware Manual MULTICONTROL MAHWMULTI-0 MAHWMULTI-E Documentation German English MAHWMULTI-F MAHWMULTI-I Italian Spanish

## PMV4 - PROPORTIONAL SOLENOID MODULE

## PLC SYSTEMS MULTICONTROL COMPONENTS







## PMV4

- Controlling Proportional Solenoids (4 channels) and Adjustable Pumps (2 channels)
- Controlled by Processor on the Module
- Communication with PLC via 2 KBytes Dual Port RAM
- Four Analog Inputs (0 10 V)
- Four Analog Inputs (0 20 mA)
- Two Digital Inputs (24 V)
- RS232/TTY Interface

#### SLOTS

The proportional solenoid module PMV4 can be operated in the following slots on the MULTI, MIDI and M264 racks.

Rad	ck		Slot	0	1	2	3	4	5	6	7	8	9	Α	В	С	D	Ε	F	
MU	LTI Main Rack			•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	П
MU	LTIExpansion	Rack														õ				
MIE	)I			0	•	•	•	•	•	ullet	•									
M20	64			•	lacktriangle	•	•	•	0	0	0	0	0	0						
•	the module ca		ed in this slot erated in this slot																	

## ORDER DATA

ECPMV4-4	Proportional Solenoid Module for controlling proportional solenoids (4 channels) and adjustable pumps (2 channels), 4 analog inputs 0 - 10 V,
	4 analog inputs 0 - 20 mA, 2 digital inputs, 1 RS232/TTY interface

## GENERAL INFORMATION

The PMV4Proportional Solenoid Moduleis used for controlling proportional solenoids (4 channels) and adjustable pumps (2 channels). It is controlled by a processor on the module which lightens the load on the CPU. The communication with the CPU takes place via 2 KBytes of dual port RAM.

The module is supplied with  $9-36\ VDC$ . The module provides four analog inputs  $0-10\ V$ , four analog inputs  $0-20\ mA$  and two digital inputs with period evaluation for measuring motor speed.

The module is equipped with am RS232/TTY interface. This interface is required for the development software. During operation, it can be used to control an operator panel.

TECHNICAL DATA	PMV4
Processor	MC68332
Frequency	16.78 MHz
PROM	128 KByte
SRAM	286 KByte
Flash PROM	100° - 100°
Serial Interface Type Electrical Isolation	RS232 / TTY (MCOx - IF1 compatible) NO
PMV Outputs	7274
Function Principle	Pulse width modulation with software current control
Supply Voltage	with software current control
Nominal	24 VDC
Minimum	9 VDC
Maximum	36 VDC
Amount Output Current 4 Channel Operation	4 on Max. 1.5 A
Output Current 2 Channel Operation	
Short Circuit Protection	Automatic cutoff
Overload Protection	Software
Voltage Drop at 2 A	Max. 1 V at 100 %
Switching Frequency	3 kHz
Switching State (off, control area, o	
Idle Current Precision at 25 °C -	Max. 1 mA
for 2 A Maximum Current	±0.5%
	1/30
Analog Inputs (voltage)	200
Amount Voltage Range	4 0 - 10 V
Resolution	10 Bit
Precision	70°
Precision at 25 °C	±0.2 %
Offset Drift	±12 ppm/°C
Gain Drift	±75 ppm/°C
Compensation	Software controlled by correction value in the EEPROM
Analog Inputs (current)	
Amount	4 0 - 20 mA
Current Range Resolution	10 Bit
Precision	10 Bit
Precision at 25 °C	±0.2 %
Offset Drift	±60 ppm/°C
Gain Drift	±155 ppm/°C
Compensation	Software controlled by correction value in the EEPROM
Digital Inputs	
Amount	2
Input Voltage	
Minimum	15 VDC
Nominal Movimum	24 VDC
Maximum Maximum Peak Voltage	36 VDC ±500 V for 50 µsec, every 100 msec (IEC60-2)
Input Resistance	Approx. 10 k $\Omega$
Input Current at 24 VDC	Approx. 2.4 mA
Switching Threshhold	Min. 4.2 VDC, typ. 6.6 VDC, Max. 9 VDC
Electrical Isolation	YES
Switching Delay	70,0
$\log. 1 \rightarrow \log. 0$	Min. 20 µsec, typ. 55 µsec, Max. 90 µsec
log. 0 → log. 1	Min. 18 µsec, typ. 54 µsec, Max. 90 µsec
Other Information	Inputs are controlled by the TPU



## PMV4 - PROPORTIONAL SOLENOID MODULE

## PLC SYSTEMS MULTICONTROL COMPONENTS


## **RS232/TTY INTERFACE**

Pin Assignments	Pin A	RS232	TTY	
9 pin D-type	1	GND DTR		
(F)	3	TXD		
, <u>Col</u>	5	RXD	TXD	
000	6 7		TXD Ret RXD	
6	8 9	DSR	RXD Ret	20175

## ANALOG AND DIGITAL INPUTS

Pin Assignments	Pin	Function	Pin	Function
15 pin D-typ	e	80	Tho	
(F)	1	Digital Input 1 (TPU1)	9	Digital GND
(I.)	2	Digital Input 0 (TPU0)	10	Analog GND
15.	3	Analog GND	11	Analog GND
To a	4	Analog GND	12	Analog Input U (Input 3)
	5	Analog Input I (Input 7)	13	Analog Input U (Input 2)
	6	Analog Input I (Input 6)	14	Analog Input U (Input 1)
	7	Analog Input I (Input 5)	15	Analog Input U (Input 0)
اا ٥ م ا	8	Analog Input I (Input 4)		
, -				

## **PMV OUTPUTS**



## STANDARD SOFTWARE

A standard function block for the operation of the PMV4 module is included in the software package SWSPSSTD01-0 (also see Section A7 "PLC Programming / Standard Software").

## **BRMEC MASS MEMORY**

## PLC SYSTEMS MULTICONTROL COMPONENTS





## **BRMEC**

- Mass Memory Device with Memory Card
- Memory Capacity 8 to 512 KByte
- EEPROM or RAM Cards
- For all PLC Systems and for the B&R MAESTRO System
- Network Capable (B&R MININET)



## ORDER DATA

BRMEC Mass Memory, for memory cards (Typ BN), two serial interfaces (1 x RS232/RS485, 1 x RS232/TTY), network capable (RSMININET), standard housing (DIN 43700), protection IP54 (dust and spray protection

BRMEC-0

BRMEC Memory Card, 32 KByte RAM BRMEC Memory Card, 128 KByte RAM BRMEC Memory Card, 8 KByte EEPRON

BRMCR032-0 BRMCR128-0 BRMCEE008-0

TECHNICAL DATA	BRMEC
Designation	Mass memory device
Memory Medium	Memory cards type BN
Interfaces	1 x RS232/RS485 1 x RS232/TTY
Baud Rates	600 to 19200 Baud
B&R MININET Connection	Direct (RS485)
Supply Voltage	10 to 60 VDC/AC
Housing	DIN 43700 for Control Panel or Operator Panel Installation
Protection	IP54 Installed (dust and spray protection)
Measurements (Metric to English Conversions Width Cutout Width Height Cutout Height Depth	s can be found at the back of this catalog) 96 mm 90 mm 48 mm 43 mm 117 mm
Documentation German English	BRMEC Short Description MABRMECKB-0 MABRMECKB-E

## **GENERAL INFORMATION**

The BRMEC mass memory is an independent system for fast and secure data storage. Memory cards (type BN) with a capacity of 8 to 512 KByte are used as memory media. The mass memory is connected to the PLC or PC via a serial interface. The BRMEC mass memory device can be integrated into a B&R MININET network.

The data is divided into logic blocks. The blocks can be divided into records. The length and number of blocks and records can be defined by the user during the format procedure in order to guarantee optimal adaption to the application data structure.

Possible applications for mass memory are data transfer between computer system and PLC without a direct connection, data acquisition, data storage for PLC systems, program and recipe storage for PLC controlled devices, etc.

## INTERFACES

The BRMEC mass memory device provides two interfaces: an RS232/RS485 interface and an RS232/TTY interface. Both interfaces (IF1 and IF2) can operate as command interface or as slave interface. The communication with the PLC is carried out via the command interface. An additional device can be accessed (e.g. terminal, operator panel, printer) by the slave interface. The interface to be used as the command interface can be selected with the node number switch on the back of the device.

## NODE NUMBER SWITCH

The node number switch is a 16 step BCD rotary switch. It is used to set the node number in a B&R MININET network and to select the command interface.





## **BRMEC MASS MEMORY**

## PLC SYSTEMS MULTICONTROL COMPONENTS

### **LEDS**

Seven status LEDs which display the operation mode are situated on the front of the BRMEC mass memory device.

LE	D Designation	Function
	DC	DC supply (yellow). Is on when the device is turned on and the supply voltage is in the valid range.
	ERR	Error (red). If an error occurs, the ERROR LED is on continuously until the error is cleared (e.g.: incorrect baudrate setting).
	RT1	Receive / Transmit (yellow). On when there is activity on interface IF1.
	RT2	Receive / Transmit (yellow). On when there is activity on interface IF2.
	Busy	Device busy (yellow). On when the card is being accessed.
	WP	Write protect (yellow). On if the memory card in the BRMEC is write protected.
	CA	Card accepted (green). On briefly if the device has accepted the memory card. This LED can also be turned on and off with control commands. The CA LED is on continuously for approx. 2 - 3 seconds during the boot procedure.

### **CARD WRITE PROTECTION**

The memory card can be write protected to prevent it from being unintentionally deleted or formatted. Data can be read from a write protected card, but it is not possible to write data to a write protected card. A memory card is write protected by applying a write protect adhesive label to a certain location.

## **SOFTWARE OPERATION**

One of the interfaces can be defined as the command interface and the other as the slave interface with a switch on the back of the BRMEC mass memory device

## **Command Interface**

The operation of the device is carried out via the command interface. Communication takes place with a protected protocol. The following commands are available for reading and writing memory cards:

- Format card
- Write name and date
- Read record(s)
- Write record(s)
- Search for record
- Insert and delete records
- request status
- Read directory

## Slave Interface

The BRMEC mass memory device offers the possibility to control an additional terminal, operator panel or a printer via the second interface (slave). The following commands are available for controlling the second interface:

- Send string
- Send frame with protected protocol
- Read and send data from the card
- Send command to another network participant

### COMMUNICATION VIA B&R MININET NETWORK

The B&R MININET network functions on a master / slave basis. The master is assigned station number zero. The master is mostly a PLC. Only the master has the right to give commands. The command is always sent in a frame. The participant effected by the command carries out the command and sends an answer. The master must evaluate the answer and continue correspondingly.

All frames that are sent over the network are provided with an index. The index serves to identify related commands and answers. The command index is repeated in every answer. In normal operation, the master distributes increasing indexes for its commands.

Broadcasts are possible on the network. A broadcast is always valid for a device group. The device name is set in the node number of the broadcast frame, the station number is zero. Only certain commands can be sent in the broadcast frame. A command sent as a broadcast does not receive an answer, even if an error occurs.

#### COMMUNICATION WITHOUT A NETWORK

If thew BRMEC mass memory device is not included in a network, the communication is carried out with the same protocol. In this case, commands that only apply to a network have no effect.


A detailed description of the B&R MININET network can be found in Section C "Industrial Networks and Communication".

## **PLC SYSTEMS MULTICONTROL COMPONENTS**





NOTE:





## CONTENTS

PLC SYSTEMS
PLC PROGRAMMING

## **CONTENTS**

PLC SYSTEMS
PLC PROGRAMMING





## A7 PLC PROGRAMMING

CONTENTS	10	168
GENERAL INFORMATION	90	170
PROGRAMMING DEVICE	<u> </u>	170
ONLINE PROGRAMMING		171
GENERAL INFORMATION		
CENTRONICS / ONLINE - CONVERTER		
B&R ONLINE INTERFACE MODULE	A	171
ONLINE NETWORK AND MODEM REMOTE DIAGNOSIS		172
BRADOL - ONLINE / MODEM CONVERTER		173
ONLINE ADAPTER	70.	174
ONLINE CABLE	70,	174
THE B&R PROGRAMMING SYSTEM		0.00
GENERAL INFORMATION		175
PERSONAL COMPUTER		175
STATEMENT LIST PROGRAMMING (STL)		
FUNCTION BLOCK PROGRAMMING (FBK)		175
LADDER DIAGRAM PROGRAMMING (LAD)		175
LOGIC PLAN PROGRAMMING (LP)		176
FBK EDITOR		176
TABLES		176
SYMBOL ASSIGNMENT (SYMB)	<u> </u>	176
PROGRAM DOCUMENTATION		177
DEBUGGING		177
ORDER DATA		177
STANDARD SOFTWARE	7, 7,	178
STANDARD SOFTWARE PACKAGE 1		179
STANDARD SOFTWARE PACKAGE 2		181
STANDARD SOFTWARE PACKAGE 3	X	185
STANDARD SOFTWARE PACKAGE 4	122	186
STANDARD SOFTWARE PACKAGE 5	V. V.	187





## GENERAL INFORMATION, **PROGRAMMING DEVICE**

**PLC SYSTEMS** PLC PROGRAMMING

## **GENERAL INFORMATION**


In this section, all hardware and software components are described that are required to program B&R PLC systems. They are:

- Programming Device (PG)
  Interface Modules for Communication PG PLC
- Interface Modules for online networks and remote diagnosis (modem)
- Connection Cable PG PLC
- B&R PROgramming SYStem
- Standard Software

Programming the B&R MAESTRO Co-Processor as well as the B&R MAESTRO software package are described in section D "Industrial Computer".

## PROGRAMMING DEVICE

A standard personal computer (PC) is used as programming device for the Compact Control PLC system, MINICONTROL and MULTICONTROL.



The PC must meet the following requirements:

- Completely compatible to IBM AT or IBM XT PCs
- IBM compatible color or monochrome monitor
- Hard disk with at least 2 MByte of available memory
- 3.5" disk drive (720 KByte or 1.44 MByte)
- 640 KByte RAM
- MS-DOS with version 2.11 or higher or PC-DOS

## **ONLINE PROGRAMMING**

PLC SYSTEMS PLC PROGRAMMING





## **GENERAL INFORMATION**

All CPUs communicate with the programming device via an online interface. There are several possibilities for creating an online connection from the programming device to the PLC:

- With a CENTRONICS / Online Converter on the PC parallel interface
- With an B&R Online Interface Module built into the PC
- Programming via online network and/or remote diagnosis via modem

## **CENTRONICS / ONLINE - CONVERTER**



The CENTRONICS / Online Converter is connected to the PC parallel printer interface. On the right side of the housing is a male 9 pin D-type connector. The PLC connection is made with the online cable BRKAOL-0. The online cable is contained in the delivery of the CENTRONICS / Online Converter.

## ORDER DATA

CENTRONICS / Online Converter for online operation of a PLC processor (CPU or peripheral processor) via the PC parallel interface, incl. online cable (BRKAOL-0)

BRKAOL5-1

## SUPPLY VOLTAGE

When using battery operated laptop PCs, the converter voltage must be supplied separately. This can be done either with a normal power supply (8 to 30 VDC, 250 mA) or with the B&R power supply device (Model No. BRPS220904-0).

Most other PCs supply the required voltage on the CENTRONICS interface. In this case, a converter voltage does not have to be supplied separately.

## **B&R ONLINE INTERFACE MODULE**



The B&R Online Interface Module is built into the PC. It provides two online interfaces in order to program two PLC processors at the same time (CPU or peripheral processors). The connection to the PLC processor is made with an online cable. The online cable is not included with the delivery of the Online Interface Module.

### ORDER DATA

Online Interface module for online operation of two PLC processors (CPU or peripheral processors) without online Cable.

For AT compatible PCs or PCs with AT / XT compatible slots

BRIFPC-0

Online cable for BRIFPC-0

BRKAOL-0





# ONLINE NETWORKS AND REMOTE DIAGNOSIS

PLC SYSTEMS
PLC PROGRAMMING

## ONLINE NETWORK AND REMOTE DIAGNOSIS WITH MODEM


Normally, the programming device (PC) has to be close to the PLC. The cable length is relatively limited. However, some applications require remote diagnostics or programming of several PLC processors from a central location. The B&R remote online interface module provides both network and modem programming / diagnostics.



The remote online interface module combines application memory and the online interface in one unit. It is used in the PLC processor module (CPU or parallel processor) in place of the application memory module. One of two modules is used depending on the type of processor module (A or B):

Processor Module(s)	Designation / Type	PLC System, PLC System	Interface Module
CP30, CP32	Type A CPU	MINICONTROL	ECEE32MP-0
CP40	Type A CPU	MULTI, MIDI	ECEE32MP-0
CP60, CP70	Type B CPU	MULTI, MIDI	ECFP128MP-0
NTCP33	Type A CPU	M264	ECEE32MP-0
NTCP63, NTCP64, PSCP65	Type B CPU	M264	ECFP128MP-0
PP60, PP60 MEM	Type B Parallel Processor	MULTI, MIDI	ECFP128MP-0

The remote online interface provides three interfaces:



### ONLINE INTERFACE

The connection to the processor module (CPU or parallel processor) is made via the online interface. One of the two online cables can be selected for this purpose:

Model No.	Length	Description
BRKAOL-0	2.5 m	Standard online cable for online interface module
BRKAOL-1	0.2 m	Only for operation with ECEE32MP-0 and ECFP128MP-0

### **RS485 INTERFACE**

The online network connection can be made via the RS485 interface. Several processor modules (max. 16) can be connected together with twisted pair cable. The length of the online network can be a max. of 1200 m. Only one station must be connected to a programming device (PC). All stations on the online network can be programmed by this programming device.

### **RS232 INTERFACE**

The remote online interface module is connected to the programming device (PC) or a modem via the RS232 interface.

### CONFIGURATION


There are two basic configurations:

- Local Online Network without Modem
- Remote Diagnostics with Modem

## a. Local Online Network without Modem

This configuration consists of a programming device connected to a processor module via the RS232 interface of the remote online interface module. Up to 15 other processor modules can be coupled to the first processor module via the online network (RS485) and programmed by the central programming device.

## Diagram:



Local online networks are especially useful when programming PLC processors that are difficult to access. Since RS232 only uses TXD, RXD and GND, conversion to almost any medium (e.g. twisted pair, fiber optics) can be made easily with the appropriate converter. Therefore, the distance between the PC and the PLC can be greatly increased (several km).

# BRADOL ONLINE / MODEM CONVERTER

PLC SYSTEMS
PLC PROGRAMMING






### b. Remote Diagnostics with Modem

A station in the online network (site A) is connected to a modem. At site B, the programming device is linked to a second modem.

#### Diagram:



### SECURITY MEASURES

The system described above operates over public telephone lines. In order to protect against unauthorized access to the PLC, the following security measures have been installed:

- Password
- Call Back
- User Levels

### a. Password:

The programming device is only allowed to access the PLC after the operator has entered a password. After a specified number of incorrect entries (user definable), the connection is broken.

## b. Call Back:

When this security feature is activated, the PLC automatically breaks the connection and calls back a specified number which is stored in the PLC. This assures that only one site (telephone) can access the PLC. The possibility of storing two different numbers is also provided. The caller determines if the first or second number stored in the PLC should be called back.

## c. User Levels:

PLC modem access rights are divided into two levels. Level 1 only allows reading from memory and has no influence on the PLC. Level 2 provides all debugger functions (reading and writing to memory, starting and stopping the program, up/downloading program, breakpoints, single step operation, ladder diagram debugging etc.). The user levels can be given different passwords.

## PLC ALARM

If a previously defined event occurs, the PLC can place a call to a stored number and leave an alarm message. The alarm message can have a max. of 80 characters. This maintains the operational security of unattended PLC stations by informing the user or maintenance personnel of possible failures.

## **BRADOL - ONLINE / MODEM CONVERTER**



### **GENERAL INFORMATION**

- The BRADOLRemote Online / Modern Converter can be used with the B&R PROgramming SYStem for remote diagnostics of PLC processors (CPUs or parallel processors).
- This make online programming of up to 16 PLC processors (CPUs or parallel processors) which are connected with a RS485 twisted pair network possible via the COM1 interface of the PC (directly or with a modem).
- The online / modem converter is contained in a housing together with a power supply. It is not inserted in the CPU or PP like the application program memory module with modem interface. Therefore, the user is provided with the entire pallet of B&R application memory. The converter can be mounted in the panel as desired.
- The online / modem converter can be used as a **mobile** online interface. It is connected between the PG interface of the PLC and the COM1 port on the PC. Therefore, the PC does not have to be equipped with a B&R online interface.

## SOFTWARE OPERATION

The software operation of the online / modem converter is identical to the application program memory module with modem interface.

A PROgramming SYStem starting with Version 5.4 is required for the operation of the online / modem converter. A description can be found in Chapter 11 "Online Programming via Modem" in the "User's Manual B&R PROgramming SYStem".





## BRADOL - ONLINE / MODEM CONVERTER, ONLINE ADAPTER, ONLINE CABLE

**PLC SYSTEMS** PLC PROGRAMMING

BRADOL **Technical Data** 

i ecililicai Da	·u	DIADOL (S)
Power Supply	Input Voltage	The state of the s
	AC 110 V	Voltage Selector Switch (220/110 VAC) 93 - 121 V
	220 V	187 - 242 V
- S	max. Input Curre	8 - 30 V
-00	8 V	270 mA
	24 V 30 V	110 mA 95 mA
(A)	Protection Circuit	·(C), 34/C),
	AC	2 fuses 100 mA quick 2 varistors 150 V
	DC	Reverse polarity protection for supply voltage Multifuse 300 mA
		Over voltage protection (IEC801-4): 4 kV (Burst)
	LED	Power On LED
Interfaces	Туре	RS232 and RS485 are electrically isolated from the device not electrically isolated between each other
	RS232	76
	Baudrate Max. cable length	max. 19.2 kBaud (set with PROgramming SYStem) 10 m (expandable to over 5 km with INT1)
	RS485	0010
	Baudrate Max. cable length	9.6 kBaud 1.2 km
	Protection Circuit for Interfaces	Over voltage protection (IEC801-4) 1 kV (Burst)
	LEDs	RxD, TxD
700		AV

## ORDER DATA

BRADOL Online / Modem Converter for connecting HAYES modems, an RS232 and an RS485 interface, the interfaces are electrically isolated from the device - but not from each other, station number switch, status LEDs

BRADOL-0

BRKAOL-0 BRKAPC-8


- Online Cable (Online / Modem Converter  $\leftrightarrow$  PLC Processor) PC Cable  $\leftrightarrow$  Online / Modem Converter
- - ... in German ... in English

MABRADOLKB-0 MABRADOLKB-E

- Cable and plug for 24 V supply 5 pin PHOENIX terminal block Mounting brackets for panel installation Mounting stencil for panel installation

## **ONLINE ADAPTER**

The online interface is connected to the user interface with a space saving 25 pin female D-type connector for the M264 CPUs NTCP63, NTCP64 and PSCP65 as well as for all parallel processors. Programming these modules requires an online adapter (Model No. ECPAD1-0).



## **ONLINE CABLE**

Online cables described in the last section:

Description / Application	Model No.	Length	27.
Standard Online Cable for B&R Online			
Interface Module BRIFPC-0	BRKAOL-0	2.5 m	
Online Cable for Remote Online Interface			
Modules with Modern Interface			
(ECEE32MP-0 and ECFP128MP-0)	BRKAOL-1	0.2 m	

## THE B&R PROGRAMMING SYSTEM

## PLC SYSTEM PLC PROGRAMMING





## **GENERAL INFORMATION**

The performance of a PLC system is enhanced with a user friendly programming system and readily available standard software. B&R offers a software package for MS-DOS computers that live up to these requirements, the B&R PROgramming SYStem.



The Compact Control as well as the MINICONTROL and MULTICONTROL PLC systems are programmed with the B&R PROgramming SYStem. In this way, the user has a free hand when choosing the programming language. Whether a problem should be solved with ladder diagrams (LAD), logic plans (LP), function blocks (FBK) or statement lists (STL), or if these programming languages should be mixed inside of a program - the B&R PROgramming SYStem knows no bounds.


A easy to use FBK editor allows the user to create application specific function blocks. The B&R PROgramming SYStem speaks many languages: German, English, Italian, Spanish or French can be installed for dialog.

## PERSONAL COMPUTER

The B&R PROgramming SYStem can be run on all IBM XT/AT compatible personal computer with an MS-DOS operating system starting with version 2.11. The B&R Online-Interface Module ensures fast online operation, CENTRONICS/Online Converter or Online Network (see Section "B&R Online Interface Module" and "Online Network and Remote Diagnostics").

## STATEMENT LIST PROGRAMMING (STL)


Statement list programming allows complex programming problems to be solved - either with B&R specific, German command abbreviations or with original MOTOROLA mnemonics.



STL is more than assembler programming. The commands range from elementary processor commands (6303, 6809) up to complex floating point math routines that are standardly integrated into all B&R systems.

## **FUNCTION BLOCK (FBK)**


Function blocks allow a structured type of programming. Program sections are displayed on the screen as rectangles, the user only has to connect the input and outputs parameters of the function blocks to correspond to the application.



A collection of over 400 standard function blocks e.g. for processing analog values, math functions, general data processing, communication and hardware support is available from B&R (see Section "Standard Software"). In addition, the B&R PROgramming SYStem allows you to create your own application specific function blocks.

## LADDER DIAGRAM PROGRAMMING (LAD)

Ladder diagram programming is especially useful for logic control. The LAD editor's menu technique allows ladder diagram entries to be made easily.



In the LAD debugger, the program can be monitored and contacts can be forced "online". Contacts that are set are displayed as the inverse. Naturally, the ladder diagram can be displayed and printed with comments.






## THE B&R PROGRAMMING SYSTEM

PLC SYSTEM
PLC PROGRAMMING

## LOGIC PLAN PROGRAMMING (LP)


Logic plan programming is an extension to the ladder diagram. AND/OR/EXOR connections are drawn out with logic blocks that are very similar to logic gates used in digital engineering.



The size and number of inputs can be determined arbitrarily. Logic plan symbols can be easily combined with LAD elements and function blocks.

## **FBK EDITOR**

The FBK editor allows you to create your own, problem specific function blocks. The form of the function block is determined in the first step, i.e. the number of inputs and outputs.



The function blocks are then programmed with a statement list program.

## **DATA TABLES**

Data tables are constant data records that the application program can access. The entries are made in a table editor. Decimal, binary, hexadecimal and ASCII number formats can be mixed within a table and even within a line of a table as desired.

Data tables are components of the application program and are stored in nonvolatile application memory.

## SYMBOL ASSIGNMENTS (SYMB)

Symbol assignments are names that are assigned to an input, output or a memory location. The user can either use the physical address of the memory location or the symbolic name. The B&R PROgramming SYStem provides the missing information automatically and interactively.

```
PASSIGNMENTS: PROGRAMMO1 95.08.09 09:01 0012/1998
R0063
R0064
R0065
R0066 FBK SRC 0
R0067
R0068 PBK DEST 0
R0069
FBK L. 0 R0070 FBK LENGTH 0
FBK L. 1 R0071 FBK LENGTH 1
FBK PTR.0 R0072 FBK POINTER 0
R0073
R0073
R0075
FBK SRC 1 R0076
R0077
R0077
R0077
R0078
FBK DATA0 R0080 FBK DATA 00
FBK DATA1 R0081 FBK DATA 01
FBK DATA2 R0082 FBK DATA 01
FBK DATA3 R0083 FBK DATA 04

138045644
R0084 FBK DATA 04
```

The SYMB list can be displayed or printed completely or selectively for a group of memory locations.

## THE B&R PROGRAMMING SYSTEM


PLC SYSTEM PLC PROGRAMMING





## PROGRAM DOCUMENTATION


Particular attention has been given to the documentation capabilities of the B&R PROgramming SYStem. Comments can be written at any location in a program, in STL programs as well as in LAD/FBK/LP.



The program printout already contains the complete program documentation, including cross references, symbol tables, function blocks and symbol assignments

## **DEBUGGING**

A number of powerful tools are available to aid in locating errors. The STL debugger permits single step execution of STL programs and the setting of breakpoints or trace functions. The LAD debugger displays the inverse of set contacts and superimposes active values into function blocks.



 $Windows\, techniques\, allow\, the\, simultaneous\, monitoring\, of\, multiple\, processors.$ 

## **ORDER DATA**

German	SWPIC-0
German	
English	SWPIC-3
Spanish	SWPIC-4
French	SWPIC-5
PROSYS Update German	SWPROSUP1C-0
PROSYS Update English	SWPROSUP1C-E





## STANDARD SOFTWARE

## PLC SYSTEMS PLC PROGRAMMING

## STANDARD SOFTWARE

This section explains B&R PLC system standard software  $^{\circ}$ . The B&R standard software includes a number of user oriented software packages with the following model number codes:

SW	aaa	abbbcc-0		
SW		B&R internal model	number c	ode for software products
aaa		Language:		Documentation and comments in German Documentation and comments in English
bbb		Package:	PID POS	Standard utility programs PID loop control software Positioning software Communication software (network)
CC		Extension number (	(00, 01, 02	,)
0	~ <sup>3</sup>	Diskette format (3.5	5")	
e.g.:		Standard software to printers and other do German: Model No.	levices, pa	
e.g.:		Standard software t English: Model No.		ing applications, part 1, documentation OS01-0
e.g.:		Standard software to German: Model No.		sed loop controller, part 1, documentation ID01-0

Following is an overview of available software packages:

Package No.	Model No.2)	Contents	
1	0-10DT8CCCW8	Function blocks for analog I/O operation modules, counter modules etc., utility programs (comparator, number conversions, memory management etc.), function blocks for math functions (basic operations, compare, number conversions)	
2	SWOOSTD02-0	Package 1 plus function blocks for communication with operator panels, terminals, printers and other devices (e.g. BRMEC)	
3	SWOODPID01-0	Package 1 plus standard software for loop control application (PID loop control)	
4	SWOODPOS01-0	Package 1 plus standard software for positioning applications (positioning with PNC3, PNC4, PNC8, PSA2)	
5	SWOOOCOM01-0	Package 1 plus B&R MININET Software	
6	SWOODRV01-0	Package 1 plus communication protocol (Modbus)	
7	SWOODRV02-0	Package 1 plus communication protocol (Siemens 3964 (R) RK512)	
8	SWOODRV03-0	Package 1 plus communication protocol (Honeywell CIM620)	
9	SWOODRV04-0	Package 1 plus communication protocol (Allen Bradley Data Highway)	
12	SWOODARC01-0	Package 1 plus ARCNET Software (PLC/PLC, OS-9 Net Server, SPECTO Server, PC Routines for DOS)	
15	SWOOOCAN01-0	Package 1 plus CAN Bus Software	

Every software package has a "Standard Software User's Manual" included in the delivery (English or German). The manual comes in two volumes.

The software for the B&R MAESTRO system is described in section D3 "Industrial Computer Software"

The model number locations shown with  $\bigcirc$  are variable. tzhey refer to the language of the documentation (SPS = German, PLC = English).

## STANDARD SOFTWARE PACKAGE 1, UTILITY PROGRAMS

PLC SYSTEMS PLC PROGRAMMING





## **STANDARD SOFTWARE PACKAGE 1**

The standard software package 1 contains standard utility programs. It is also a part of software packages 2 to 10.

## ORDER DATA

Standard software package 1, standard utility programs (comparator, counter, timers, system functions, number conversions, analog I/O module operation, arithmetic programs etc.).

## 3.5 " Diskette(s)

German	SWSPSSTD01-0	
English	SWPLCSTD01-0	

The Standard Software Package 1 is divided into three groups:

- Utility
- Hardware
- Operating System Routines

The following abbreviations are used in the overview table:

Abbreviation	Description	
PRG FBK	Program Function Block	
TAB	Table	
MSL	STL Makro	
SPG	B&R System Data	

		UTILITY
ADDA	FBK	ADDITION 1 BYTE
ADDB	FBK	ADDITION 2 BYTE
ALIN	FBK	LINEARIZATION FOR ANALOG VALUES
ARCH	FBK	ANALOG RESOLUTION CHANGE
BCDU	FBK	CONVERT BINARY TO BCD
BINA	FBK	CONVERT BINARY TO ASCII
BINU	FBK	CONVERT BCD TO BINARY
BTOR	FBK	PACK BITS INTO REGISTER
CLIM	FBK	UP/DOWN COUNTER WITH LIMIT
СМРН	FBK	COMPARE 2 BYTE VALUES INC. HYSTERESIS
CMPW	FBK	COMPARE 2 BYTE VALUES
CNTR	FBK	UP/DOWN COUNTER
COMA	FBK	COMMUNICATION PLC — MCO
СОМС	FBK	COMMUNICATION PLC — MAESTRO / MCO
CPRT	FBK	COMPARE REGISTER TABLE
DEFF	FBK	DEFINE FLAGS
DFPP	FBK	DIAGNOSTIC FUNCTIONS OF PP40 / 1
DIVA	FBK	DIVISION 2 BYTE / 1 BYTE
DIVB	FBK	DIVISION 3 BYTE / 2 BYTE
DIVC	FBK	DIVISION 4 BYTE / 2 BYTE
DRET	FBK	DRUM + EVENT + TIMER
DTAL	FBK	DATA TABLE ADDRESS & LENGTH
DTAO	FBK	DATE AND TIME ASCII OUTPUT
DTBI	FBK	DATE AND TIME BINARY INPUT
ETSF	FBK	EVENT/TIME SEQUENCE FUNCTION
FIOR	FBK	RING BUFFER FOR REGISTER TABLE
FPRG	FBK	TRANSFER PROGRAM/SYSTEM TO FP128 OR FP384
FPRM	FBK	FP384 RECIPE STORE/RETRIEVE
FSCA	FBK	FIRST SCAN (OP. SYS. V1.x)
GETR	FBK	GET DATA BLOCK FROM REGISTER TABLE
HSEL	FBK	HIGH / LOW SELECTOR

	LD##	FBK	LOAD REGISTER WITH CONSTANT	(4)
P	LIMA	FBK	LIMIT & ALARM	
	LZIN	FBK	LIVE / ZERO CONVERSION FOR ANALOG INPUT	
	LZOU	FBK	LIVE / ZERO CONVERSION FOR ANALOG OUTPUT	
	MCEE	FBK	RD/WR FILES TO CP32 EEPROM	
	MULA	FBK	MULTIPLICATION 1BYTE * 1BYTE = 2BYTE	
	MULB	FBK	MULTIPLICATION 2BYTE * 2BYTE = 4BYTE	
	MULC	FBK	MULTIPLICATION 3BYTE * 2BYTE = 5BYTE	
	MVME	FBK	MOVE MEMORY EQUAL	
à	MVMI	FBK	MOVE MEMORY INVERTED	
	MVML	FBK	MOVE MEMORY EQUAL LONG	
	OSGE	FBK	ONE SHOT GENERATOR FOR REGISTERS	
	PIAA	FBK	PHYSICAL INTERF. ADAPTER FOR CP32 (RS485/TTY)	
	PUTR	FBK	PUT DATA BLOCK TO REGISTER TABLE	
	RTOB	FBK	UNPACK REGISTER TO BITS	
	RWTC	FBK	READ / WRITE TO CPU	
	RWTP	FBK	READ / WRITE TO PPU	
s	SCAL	FBK	SCALING	
	SCVA	FBK	SEARCH FOR DEFINED VALUE	
	SETF	FBK	SET FLAGS	
	SHBL	FBK	SHIFT BITS LEFT	
	SHBR	FBK	SHIFT BITS RIGHT	
	SUBA	FBK	SUBTRACTION 1 BYTE	
	SUBB	FBK	SUBTRACTION 2 BYTE	
	TOFF	FBK	OFF DELAY TIMER	
	TOND	FBK	ON DELAY TIMER	
è	VINT	FBK	VALUE INTEGRATOR AND FILTER	
	VSEL	FBK	SELECT 2 BYTE VALUE	
	DRTE	TAB	EVENT DEFINITION TABLE FOR DRUM EVENT TIMER	
	DRTO	TAB	OUTPUT TABLE FOR DRUM EVENT TIMER	
	DRTT	TAB	TIME DEFINITION TABLE FOR DRUM EVENT TIMER	
	DTOT	TAB	DEFINITION DATA TABLE FOR DTAO	
	FIOT	TAB	DATA TABLE FOR FIOM, FIOR	
	SEQT	TAB	CONFIGURATION DATA TABLE FOR ETSF	
	TLIN	TAB	CONFIGURATION DATA TABLE FOR ALIN	
	TSCL	TAB	CONFIGURATION DATA TABLE FOR SCAL	

	SIGHT	HARDWARE	-3
AINA	FBK	ANALOG INPUT PEA	100
AINB	FBK	ANALOG INPUT PE82 & PE42	
AINC	FBK	ANALOG INPUT PE83	
AIND	FBK	ANALOG INPUT PE84	
AINE	FBK	ANALOG INPUT FOR PE16	
AINF	FBK	ANALOG INPUT PE82 & PE42 (12 BIT)	
AING	FBK	ANALOG INPUT PM88	
AINH	FBK	ANALOG INPUT MINI PE82 (16 BIT)	
AINJ	FBK	ANALOG INPUT COMPACT CONTROL	
AOTA	FBK	ANALOG OUTPUT PEA	
AOTB	FBK	ANALOG OUTPUT PA81 & PA42	
AOTC	FBK	ANALOG OUTPUT PEA. (12 BIT)	
AOTD	FBK	ANALOG OUTPUT PA81 (12 BIT)	
AOTE	FBK	ANALOG OUTPUT PTA2	
AOTF	FBK	ANALOG OUTPUT COMPACT CONTROL	
CLCK	FBK	REAL TIME CLOCK FOR PRTA/PRTS	
CMDA	FBK	COUNTER MODULE DRIVER A	
CMDB	FBK	COUNTER MODULE DRIVER B	





# STANDARD SOFTWARE PACKAGE 1, UTILITY PROGRAMS

PLC SYSTEMS
PLC PROGRAMMING

DINA FBK DIGITAL INPUT FOR E243  DOUA FBK DIGITAL OUTPUT FOR A244  DOUB FBK CYCLIC PULSE GENERATOR FOR PM88  DOUC FBK DIGITAL OUTPUT COMPACT CONTROL FOR RELAY EXPANSION OF PMV4 FBK PROPORTIONAL SOLENOID MODULE CONTROL PMV4  PWPA FBK ULTRASONIC TRANSDUCER IF, (PWP4/1 CHANNEL)  PWPB FBK ULTRASONIC TRANSDUCER IF, / SW-LIMIT SWITCH  TINA FBK TEMPERATURE INPUT PT41	
DOUB FBK CYCLIC PULSE GENERATOR FOR PM88  DOUC FBK DIGITAL OUTPUT COMPACT CONTROL FOR RELAY EXPANSION OF PMV4 FBK PROPORTIONAL SOLENOID MODULE CONTROL PMV4  PWPA FBK ULTRASONIC TRANSDUCER IF. (PWP4/1 CHANNEL)  PWPB FBK ULTRASONIC TRANSDUCER IF. SW-LIMIT SWITCH	
DOUC FBK DIGITAL OUTPUT COMPACT CONTROL FOR RELAY EXPANSION OF PMV4 FBK PROPORTIONAL SOLENOID MODULE CONTROL PMV4  PWPA FBK ULTRASONIC TRANSDUCER IF. (PWP4/1 CHANNEL)  PWPB FBK ULTRASONIC TRANSDUCER IF. SW-LIMIT SWITCH	
PMV4 FBK PROPORTIONAL SOLENOID MODULE CONTROL PMV4 PWPA FBK ULTRASONIC TRANSDUCER IF. (PWP4/1 CHANNEL) PWPB FBK ULTRASONIC TRANSDUCER IF./ SW-LIMIT SWITCH	
PWPA FBK ULTRASONIC TRANSDUCER IF.(PWP4/1 CHANNEL) PWPB FBK ULTRASONIC TRANSDUCER IF./ SW-LIMIT SWITCH	ARD
PWPB FBK ULTRASONIC TRANSDUCER IF/SW-LIMIT SWITCH	
THE SELECTION OF THE SE	
TINA FBK TEMPERATURE INPUT PT41	
TINB FBK TEMPERATURE INPUT PT81	
TINC FBK TEMPERATURE INPUT PTE8 (NiCrNi - TYPE K)	
TIND FBK TEMPERATURE INPUT PTE8 (FeCuNi - TYPE L & J)	
TINE FBK TEMPERATURE INPUT PTA2	
TINF FBK TEMPERATURE INPUT PTE6	
TING FBK TEMPERATURE INPUT PTE8 KTY 10 ELEMENTS	
AITC TAB INITIALIZATION DATA TABLE FOR AINC	
AITE TAB INITIALIZATION DATA TABLE FOR AINE	
TITF TAB INITIALIZATION DATA TABLE FOR TINF	
TPMV TAB PARAMETER DATA TABLE FOR PMV4	

OPERATING SYSTEM ROUTINES						
CAF	FBK	CONVERT ASCII TO FLOATING POINT				
CBCD	FBK	CONVERT TO BCD				
CBIN	FBK	CONVERT TO BINARY				
CBP	FBK	CONVERT BINARY TO PHYSICAL UNITS				
CBPP	FBK	CONVERT BINARY TO PHYSICAL UNITS-PARAMETERS				
CBPQ	FBK	CONVERT BINARY TO PHYSICAL UNITS QUICK				
CFA	FBK	CONVERT OPERAND 1 TO ASCII				
CFA0	FBK	CONVERT OP1 TO ASCII (WITH LEADING ZEROS)				
CFEA	FBK	CONVERT FLOATING EXPONENT TO ASCII				
CIA	FBK	CONVERT INTEGER TO ASCII (NO LEADING ZEROS)				
CIA0	FBK	CONVERT INTEGER TO ASCII WITH LEADING ZEROS				
CIM	FBK	CONVERT INCH TO METRIC				
CMI	FBK	CONVERT METRIC TO INCH				
CPB	FBK	CONVERT PHYSICAL UNITS TO BINARY				
CPBQ	FBK	CONVERT PHYSICAL UNITS TO BINARY QUICK				
FCLR	FBK	FUNCTION CLEAR MEMORY				
FCOP	FBK	FUNCTION COPY				
FM2B	FBK	FUNCTION MULTIPLY 2 BYTE BY 2 BYTE				
FM3B	FBK	FUNCTION MULTIPLY 3 BYTE BY 2 BYTE				
FM4B	FBK	FUNCTION MULTIPLY 4 BYTE BY 2 BYTE				
FSMB	FBK	FUNCTION SET MEMORY BYTE				
FSMW	FBK	FUNCTION SET MEMORY WORD				
LAL1	FBK	LOAD ABSOLUTE LONG TO OPERAND 1				
LAL2	FBK	LOAD ABSOLUTE LONG TO OPERAND 2				
LAW1	FBK	LOAD ABSOLUTE WORD TO OPERAND 1				
LAW2	FBK	LOAD ABSOLUTE WORD TO OPERAND 2				
LF1 _c	FBK	LOAD FLOATING POINT INTO OP1				
LF2	FBK	LOAD FLOATING POINT INTO OP2				
LIL1	FBK	LOAD INTEGER LONG INTO OP1				
LIL2	FBK	LOAD INTEGER LONG INTO OP2				
LIW1	FBK	LOAD INTEGER WORD INTO OP1				
LIW2	FBK	LOAD INTEGER WORD INTO OP2				
MADD	FBK	ADDITION FLOATING POINT				

	MCMP	FBK	COMPARE OPERAND 1 WITH OPERAND 2	
I	MCOP	FBK	COPY OPERAND 1 TO OPERAND 2	- 25
I	MDIV	FBK	DIVISION FLOATING POINT	20
I	MEXG	FBK	EXCHANGE OPERAND 1 WITH OPERAND 2	
١	MHIL	FBK	HIGH LIMIT OF OPERAND 1	
I	MLOL	FBK	LOW LIMIT OF OPERAND 1	
I	MMUL	FBK	MULTIPLICATION FLOATING POINT	
I	MSGN	FBK	CHANGE SIGN OF OPERAND 1	
I	MSQR	FBK	SQUARE ROOT FLOATING POINT	
I	MSUB	FBK	SUBTRACTION FLOATING POINT	3
I	RFM1 <	FBK	RECALL MEMORY 1 TO OPERAND 2	272
I	RFM2	FBK	RECALL MEMORY 2 TO OPERAND 2	
١	RFM3	FBK	RECALL MEMORY 3 TO OPERAND 2	
l	SAL	FBK	STORE ABSOLUTE LONG	
I	SAW	FBK	STORE ABSOLUTE WORD	
I	SFM1	FBK	STORE OPERAND 1 TO MEMORY 1	
I	SFM2	FBK	STORE OPERAND 1 TO MEMORY 2	
I	SFM3	FBK	STORE OPERAND 1 TO MEMORY 3	
I	SFX	FBK	STORE FLOATING POINT - OPERAND 1	22
I	SIL	FBK	STORE INTEGER LONG - OPERAND 1	
I	SIW	FBK	STORE INTEGER WORD - OPERAND 1	

### STANDARD SOFTWARE PACKAGE 2, OPERATOR PANEL, PRINTER, PROVIT

# PLC SYSTEMS PLC PROGRAMMING





### **STANDARD SOFTWARE PACKAGE 2**

The standard software package 2 contains package 1 and standard software for:

- Operator Panels
- Printers
- BRMEC Mass Storage Device
- Operator Terminals (PROVIT 600 and 700)

### ORDER DATA

Standard software package 2, standard utility programs (comparators, counters, timers, system functions, number conversions, analog I/O module operation, arithmetic programs etc.), control of operator panels, printers, BRMEC and PROVIT.

3.5 " Diskette(s

	_(()	50
German	SWSPSSTD02-0	
English	SWPLCSTD02-0	
English	3WFL031D02-0	

### STANDARD SOFTWARE FOR OPERATOR PANELS

### a. Driver Function Blocks and Configuration Tables

A driver function block and a configuration data table is required for each operator panel:

	OPIA	FBK	PANEL INTERFACE DRIVER A (PATA)
	OPIB	FBK	PANEL INTERFACE DRIVER B (PIF1, PIF3)
	OPIC	FBK	PANEL INTERFACE DRIVER C (CP32 INTERFACE)
	OPID	FBK	PANEL INTERFACE DRIVER D (PIF1, PIFA)
	OPIE	FBK	PANEL INTERFACE DRIVER E (CP32 INTERFACE)
	OPIF	FBK	PANEL INTERFACE DRIVER F (CP70, PP60, NTCP6#)
	OPIG	FBK	PANEL INTERFACE DRIVER G (CP70, PP60, NTCP6#)
ς			
	OPTA	TAB	KEY DECODER TABLE FOR MINICONTROL PANEL
	OPTB	TAB	KEY DECODER TABLE FOR BRRT360

The driver function block initializes the interface, defines the data protocol between the PLC and the operator panel, receives the key codes and sends the issued characters to the operator panel. The key codes are defined in the configuration data table.

The driver function block and the configuration data table used depends on which operator panel and which interface module is being utilized:

Operator Panel	Module / Controller	Driver FBK	Configuration Table
MINICONTROL Panels	MCPATA-0 Compact Control	OPIA	OPTA
BRRT360	MDPIF1-0, ECPIF3-0, MCPIFA-0	OPIB	ОРТВ
	CP32	OPIC	ОРТВ
	M2NTCP63-0, M2NTCP64-0, M2PSCP65-0, ECPP60-01, ECCP70-01	OPIF	ОРТВ
	M2NTCP63-0, M2NTCP64-0, M2PSCP65-0, ECPP60-01, ECCP70-01	OPIG	ОРТВ

### b. Message Display




The following software is required to display messages on an operator panel:

OPDM	FBK	MESSAGE DISPLAY	
OPKS	FBK	KEY SELECTOR AND DECODER	
	600	A. C.	
OPTM	TAB	MESSAGE DEFINITION DATA TABLE	7/10/

The OPDM function block is used to display messages on the operator panel. The message text is entered in the OPTM table. The message display can be controlled by keys or PLC internal memory locations.

Since the OPDM function block is independent from the operator panel being used but the individual panels have different keyboards, the keyboard has to be selected previously with the OPKS function block.

### Diagram:







### STANDARD SOFTWARE PACKAGE 2, OPERATOR PANEL, PRINTER, PROVIT

PLC SYSTEMS
PLC PROGRAMMING

### c. Display Process Variables with Message




The following software components are required when displaying a process variable with message on the operator panel:

OPDV	FBK	DISPLAY PROCESS VARIABLE WITH MESSAGE	2
OPKS	FBK	KEYBOARD SELECTOR AND DECODER	10,
7000		258	72/20
OPTM	TAB	MESSAGE DEFINITION DATA TABLE	'4' <sub>1</sub> O.
OPTV	TAB	VALUE DEFINITION DATA TABLE	24

The OPDV function block displays a process variable with message on the operator panel (e.g. "PRINT = 100.0"). The message text is entered in the OPTM table, the data format for the value to be displayed (number of digits, position of the decimal points) is specified in the OPTV table. The value / message display can be controlled by keys or from an internal PLC memory location.

Since the OPDV function block is independent from the operator panel being used but the individual panels have different keyboards, the keyboard has to be selected previously with the OPKS function block.

Schematic:



### d. Value Input with Message




The following software components are required to display value inputs with message:

OPIN	FBK	INPUT NUMERICAL	d
OPIO	FBK	INPUT OPEN	
OPKS	FBK	KEYBOARD SELECTOR AND DECODER	
80.		7:0,	
OPTI	TAB	VALUE INPUT DEFINITION DATA TABLE	
OPTM	TAB	MESSAGE DEFINITION DATA TABLE	

The OPIO function block displays a message on the operator panel (e.g. "VALUE=") and initializes the input field. The message text entered in the OPTM data table, the data format for the entry (number of digits, position of the decimal points) is defined in the OPTI table. Processing characters entered from the keyboard is carried out by the OPIN function block, i.e. updating the displayed value when a key is pressed and checking high and low limits etc.

Since the OPIN function block is independent from the operator panel being used but the individual panels have different keyboards, the keyboard has to be selected previously with the OPKS function block.

#### Diagram:



### STANDARD SOFTWARE FOR PRINTER CONTROL

The standard function block used fro printer control contains the following functions:

- Initialization of the Printer Interface
- Header Definition
- Printing Messages
- Printing Messages with Process Variables
- Printing Reports
- Printing Event Protocols

### a. Initialization, Header

A driver function block is used to initialize the interface between the PLC and the printer. The baudrate, data format and header are defined in the configuration table:

2	PRNA	FBK	PRINTER DRIVER A (PIF3 - CENTRONICS)	
Ì	PRNB	FBK	PRINTER DRIVER B (PIFA/PIF1/PIF3) HW HS	
	PRND	FBK	PRINTER DRIVER D (PIFA/PIF1/PIF3) SW HS	
	PRNF	FBK	PRINTER DRIVER F (NTCP6#/CP70/PP60) HW HS	
	PRNG	FBK	PRINTER DRIVER G (NTCP6#/CP70/PP60) SW HS	
		cò		
	PRTI	TAB	PRINTER DEFINITION DATA TABLE	J.
	PRTM	TAB	MESSAGE DATA TABLE	27.

The driver function block used depends on the interface module and the type of handshake (hardware or software handshake):

Module	Interface	PLC System / Rack	Handshake	Driver FBK
ECPIF3-0	CENTRONICS	MULTI, MIDI, M264	Hardware	PRNA
MCPIFA-2	RS232	MINICONTROL	Hardware	PRNB
MDPIF1-0, ECPIF3-0	RS232	MULTI, MIDI, M264	Hardware	PRNB
MCPIFA-2	RS232	MINICONTROL	Software	PRND
MDPIF1-0, ECPIF3-0	RS232	MULTI, MIDI, M264	Software	PRND
M2NTCP63-( M2NTCP64-( M2PSCP65-( ECPP60-01	0,	M264	Hardware	PRNF
ECCP70-01, ECPP60-01	RS232	MULTI, MIDI	Hardware	PRNF
M2NTCP63-( M2NTCP64-( M2PSCP65-( ECPP60-01	0,	M264	Software	PRNG
ECCP70-01, ECPP60-01	RS232	MULTI, MIDI	Software	PRNG

# STANDARD SOFTWARE PACKAGE 2, OPERATOR PANEL, PRINTER, PROVIT

PLC SYSTEMS PLC PROGRAMMING






#### b. Header

A header can be defined in the PRTI table that is connected to the driver function block and will be printed on at the beginning of each page. Two variables can be defined for the header:

- ?P ... Prints the page number in the desired position
- ?D  $\,\,\dots\,\,$  Prints the date and time in the desired position

#### Example:



#### c. Printing Messages

All message text to be printed is defined in the PRTM data table which is connected to the driver function block. e.g.:

```
000

001 * PRINTER FUNCTION BLOCKS - MESSAGE DEFINITION TABLE

002

003 * Message must be terminated with < 000 >.

004 * The data table can contain up to 100 messages.

005 * The length of the individual messages can may very.

006 * control Characters: Lf ... 10 Line Feed

007 * FF ... 12 Form Feed

008 * CR ... 13 Carriage Return

009

010 *

011 'EMERGENCY HALT PERFORMED !',13,10,000, * Message #1

012 'END LIMIT A DEFECTIVE !',13,10,000, * Message #2

013 'EMD LIMIT B DEFECTIVE!',13,10,000, * Message #3

014 'TEMPERATURE IN VAT 1:',000, * Message #4

015 'DEGREE C',13,10,000, * Message #4

016 'PRESSURE 1 TOO HIGH!',13,10,000, * Message #6


017 'PRESSURE 1 TOO HIGH!',13,10,000, * Message #6

018 'USER INITIALIZATION I',13,10,000, * Message #8

019 'INITIALIZATION DONE!',13,10,000, * Message #8

020 *
```

Messages are printed with the PRNM function block. The number of the message to be printed is connected to the function block. e.g. Message 3 and Message 8:



### d. Printing Messages with Process Variables

Messaged defined in the PRTM data table are printed together with process variables by means of the PRNV function block. The data format for the process variables to be printed (number of characters, source address) is defined in the PRTV value definition data table.


### Example

If a maximum value is exceeded, the following message will be printed:

Temperature in VAT 1 too high: ±xxx.x degrees C


In this case " $\pm xxx.x$ " is the format for the process variable (four characters, a decimal point, subject to preceding sign). The value comes from registers R 0200 and R 0201.

An entry with the following data is required in the PRTV value definition data table:



- a ... Number of the message that should be printed before the process variables
- b ... Number of spaces between message and process variable
- Source address of the process variables (offset to R 0000)
- d ... With/without preceding sign: '+' without, '-' with
  - ... Source data format: 'S' short (2 Byte), 'L' long (4 Byte)
- f ... Number of digits without preceding sign and decimal point
- g ... Number of digits after the decimal point
- ... Number of the message that is printed after the process variable

The output looks like this:




### e. Report Output

A report can be printed using the PRNR function block. A report is an arrangement of messages and process variables. The individual process variables are entered in the PRTV value definition data table and the message text in the PRTM message definition data table. The report format is defined in the PRTR data table. The report table utilizes a simple language interpreter with the following commands:

'M',001,000,	'M' Instruction code "print message"
	001 Number of the message (defined in PRTM)
	000 Space character (always 0)
'X',080,'-',	'X' Instruction code "repeat character"
	080 Number of repetitions
	'-' Character to be printed
'V',001,000,	'V' Instruction code "print message with process variable"
	001 Number of the process variable (defined in PRTV)
	000 Space character (always 0)

### Example

The following report is to be printed:







### STANDARD SOFTWARE PACKAGE 2, OPERATOR PANEL, PRINTER, PROVIT


PLC SYSTEMS
PLC PROGRAMMING

The following message text is to be defined in the PRTM message data table:

The process variables come from the following registers:

Temperature VAT 1	R 0100, R 0101
Pressure VAT 1	R 0102, R 0103
Temperature VAT 2	R 0104, R 0105
Pressure VAT 2	R 0106, R 0107
Temperature VAT 3	R 0108, R 0109
Pressure VAT 3	R 0110, R 0111
Temperature VAT 4	R 0112, R 0113
Pressure VAT 4	R 0114, R 0115

The 8 process variables are defined in the PRTV value definition data table:



The report format is specified in the PRTR data table:


### f. Event Logging

Simple event logging can be carried out with the PRNS function block. The function block monitors up to 16 memory locations and prints a corresponding message with each status change. The text to be printed is defined in the PRTS data table.

### Example


The 8 valves are to be monitored. Changes are to be logged. The message text is entered in the PRTS data table:

The following printout could be made:



### STANDARD SOFTWARE FOR BRMEC MASS MEMORY

The BRMEC mass memory is an independent system for saving data on interchangeable memory cards with a capacity of 8 KBytes to 512 KBytes.



The BRMEC mass memory communicates with the PLC or a printer via two serial interfaces. One of the two interfaces is a network capable RS485 interface with which the BRMEC can be connected to a B&R MININET network (also see Section C5 "B&R MININET").

The following function blocks and configuration tables are used for software operation:

MCDA	FBK	MEMORY CARD DRIVER A (PIF1,PIF3,)	
MCDB	FBK	MEMORY CARD DRIVER B (CP32)	
MCDC	FBK	MEMORY CARD DRIVER C (CP70,PP60,NTCP6#)	
		1997.	
TMCD	TAB	DEFINITION TABLE FOR BRMEC DRIVER	

# STANDARD SOFTWARE PACKAGE 2 - PROVIT, STANDARD SOFTWARE PACKAGE 3 - PID LOOPS

PLC SYSTEMS PLC PROGRAMMING





### STANDARD SOFTWARE FOR PROVIT TERMINALS

The standard software supports PROVIT 600, PROVIT 700 terminals and the operator panel BRRTEL45.

### **Driver Function Block**

A driver function block is required for each terminal:

		A 2
PRDB	FBK	PROVIT DRIVER B (PIFA,PIF1,PIF3)
PRDC	FBK	PROVIT DRIVER C (CP70,PP60,NTCP6#)
PRDF	FBK	PROVIT DRIVER F (PP60)
PVTC	TAB	KEY DECODER TABLE FOR BRRTEL45 PANEL

These driver function blocks initialize the interface, define the data protocol between PLC and terminal, receive key codes and send the issued characters to the terminal.

The driver function block required depends on the interface module used:

Module	PLC System / Rack	Driver FBK
MCPIFA-2	MINICONTROL	PRDB
MDPIF1-0, ECPIF3-0	MULTI, MIDI, M264	PRDB
ECPP60-01	MULTI, MIDI	PRDC
NTCP63-0, NTCP64-0, PSCP65-0	M264	PRDC
ECCP70-01	MULTI, MIDI	PRDC
ECPP60-01	MULTI, MIDI	PRDF

### Other Function Blocks

The PRVT function block is used for the communication between the parallel processor and CPU if the PROVIT terminal is to be operated by a parallel processor.

A screen is selected with the PRVS function block and displayed with the PRVR function block.

PRVR	FBK	PROVIT SCREEN DRIVER	
PRVS	FBK	PROVIT SCREEN SELECTION	
PRVT	FBK	PROVIT TRANSFER CPU - PPU	

### **Configuration Data Table**

Screen masks, input and display fields and key functions are defined with the configuration table PRTD, PRTI, PRTK, PRTM and PRTT:

	PVTD	TAB	OUTPUT VALUE DATA TABLE	9
N	PVTI	TAB	INPUT VALUE DATA TABLE	Ka.x
Ş	PVTK	TAB	KEY DEFINITION DATA TABLE	1979.
	PVTM	TAB	DATA TABLE FOR SCREEN MASKS	,O <sup>C</sup>
	PVTT	TAB	MESSAGE DATA TABLE	70gDz

### **STANDARD SOFTWARE PACKAGE 3**

 $Standard\,software\,package\,3\,contains\,package\,1\,and\,standard\,software\,for\,PID\,loop\,control\,applications.$ 

### ORDER DATA

Standard software package 3, standard utility programs (comparators, counters, timers, system functions, number conversions, analog I/O modules operations, arithmetic programs etc.), Standard software for PID loop control applications.

	44.	3.5 "-Diskette(s)	May .
German English		SWSPSPID01-0 SWPLCPID01-0	

Standard software package 3 contains the following components in addition to package 1:

7/10.		PID Loop Controller
LAPP_P60	PRG	PID ALGORITHMS FOR PP60 (32 CONTROLLERS)
LCCL	FBK	PID LOOP CONFIGURATION FOR CP/PLC
LCPC	FBK	PID LOOP CONFIGURATION FOR PP/PCS
LCPL	FBK	PID LOOP CONFIGURATION FOR PP/PLC
LECL	FBK	PID LOOP EXT I/O DEFINITION FOR CP/PLC
LEPC	FBK	PID LOOP EXT I/O DEFINITION FOR PP/PCS
LEPL	FBK	PID LOOP EXT I/O DEFINITION FOR PP/PLC (PP60)
LICL	FBK	PID LOOP I/O DEFINITION FOR CP/PLC
LIPC	FBK	PID LOOP I/O DEFINITION FOR PP/PCS
LIPL	FBK	PID LOOP I/O DEFINITION FOR PP/PLC (PP60)
LPCL	FBK	PID LOOP PARAMETER DEFINITION FOR CP/PLC
LPPL	FBK	PID LOOP PARAMETER DEFINITION FOR PP/PLC (PP60)
LSCP	FBK	PID LOOP SELECTOR FOR CP
LSPP	FBK	PID LOOP SELECTOR FOR PP (PP60)
500		70,1
LPAD	TAB	RACK ASSIGNMENT FOR LOOP PP
LPAR	TAB	PARAMETER DATA TABLE FOR PID LOOP

A detailed description of the PID loop controller software can be found in Section A9 "PID Loop Controller".





# STANDARD SOFTWARE PACKAGE 4, POSITIONING

PLC SYSTEMS
PLC PROGRAMMING

### **STANDARD SOFTWARE PACKAGE 4**

Standard software package 4 contains package 1 and standard software for positioning applications.

### ORDER DATA

Standard software package 4, standard utility programs (comparators, counters, timers, system functions, number conversions, analog I/O module operations, arithmetic programs etc.), Standard software for positioning applications.

35	"	Diskette(	s)	

German	SWSPSPOS01-0
English	SWPLCPOS01-0

Standard software package 4 contains the following components in addition to package 1:

- 20		
- 9D'		POSITIONING (without PNC8)
CNRC	FBK	POSITIONING WITH EXTERNAL ACTUAL POSITION
PNRA	FBK	VARIABLE SPEED POSITIONING FOR PNC1
PNRC	FBK	VARIABLE SPEED POSITIONING FOR PNC3 AND PNC4
PNSA	FBK	POSITIONING PNC1 FOR DUAL SPEED SYSTEMS
PNSC	FBK	POSITIONING PNC3, PNC4 FOR DUAL SPEED SYSTEMS
PSA2	FBK	DRIVER FOR STEPPER MOTOR PSA2
	U.C.	ALC STATES
PAOU	TAB	ACCELERATION PROFILE DEFINITION TABLE
PDRA	TAB	PARAMETER TABLE FOR RAMP POSITIONING PNC3, PNC4
PDSA	TAB	PARAMETER TABLE FOR DUAL SPEED POSITIONING PNC3, PNC4
PSPR	TAB	CONFIG TABLE SET POINTS FOR RAMP POSITIONING
PSPS	TAB	CONFIG TABLE SET POINTS FOR DUAL SPEED POSITIONING
PSTD	TAB	PARAMETER TABLE FOR STEPPER MOTOR (FBK PSA2)
PSTP	TAB	CONFIG TABLE FOR STEPPER MOTOR (FBK PSA2)

Also see Section A8 "Positioning"

	70.	200
	410.	POSITIONING - PNC8 SOFTWARE
PNC8TES	T PRG	TEST PROGRAM WITH ALL PNC8 OPERATING SYSTEM FUNCTIONS
PDLB_SIN	I PRG	SIMULATION OF THE SW ,PNC8-1: DUAL SPEED POSITIONING WITH A PNC8-2 $$
PNC82RM	IP PRG	USE OF SW, PNC8-2: VARIABLE SPEED POSITIONING (RAMP POS.)
PNC82PIL	PRG	USE OF SW, PNC8-2: POSITIONING WITH PI LOOP CONTROLLER
PNC82LIP	PRG	USE OF SW, PNC8-2: POSITIONING WITH PI LOOP CONTROLLER: SIMULTANEOUS MOVEMENT OF TWO AXES IN MANUAL AND AUTOMATIC (LINEAR INTERPOLATION)
	24.00	
DL8A	FBK	DOWNLOAD CPU -> PNC8
DL8B	FBK	DOWNLOAD FPROM -> PNC8
FDLC	FBK	WORKING WITH THE PNC8 DOWNLOAD PROGRAM DLPC
IN8A	FBK	INITIALIZATION OF THE PNC8 MODULES
PNRD	FBK	VARIABLE SPEED POSITIONING FOR PNC8-2
PNSD	FBK	DUAL SPEED POSITIONING FOR PNC8-1
ID8A	TAB	DEFTAB FOR FBK IN8A
PAOD	TAB	DATA TABLE WITH ACCELERATION AND DECELERATION CURVE WITH PNC8-2
PDLA	TAB	DATA TABLE WITH DOWNLOAD PROGRAM OPCODE FOR RAMP POSITIONING WITH PNC8-2
PDLB	TAB	DATA TABLE WITH DOWNLOAD PROGRAM OPCODE FOR DUAL SPEED POSITIONING WITH PNC8-1
PDRD	TAB	DEFTAB FOR FBK PNRD
PDSD	TAB	DEFTAB FOR FBK PNSD
PSRD	TAB	DATA TABLE WITH DESIRED POSITIONS FOR VARIABLE SPEED POSITIONING WITH PNC8-2
PSSD	TAB	DATA TABLE WITH DESIRED POSITIONS FOR DUAL SPEED POSITIONING WITH PNC8-1
PDLA	MSL	DOWNLOAD PROGRAM FOR VARIABLE SPEED POSITIONING WITH PNC8-2 (PC80 MODE)
PDLB	MSL	DOWNLOAD PROGRAM FOR DUAL SPEED POSITIONING WITH PNC8-1 (PC80 MODE)
PAODXXY	Y SPG	B&R SYSTEM FILE CONTAINING THE ACCELERATION AND DECELERATION CURVE FOR VARIABLE SPEED POSITIONING WITH PNC8-2 VERSION XX.YY
PDLAXXY	Y SPG	B&R SYSTEM FILE CONTAINING THE OPCODE OF THE DOWNLOAD PROGRAM FOR VARIABLE SPEED POSITIONING WITH PNC8-2 VERSION XX.YY
PDLBXXY	Y SPG	B&R SYSTEM FILE CONTAINING THE OPCODE OF THE DOWNLOAD PROGRAM FOR DUAL SPEED POSITIONING WITH PNC8-1 VERSION XX.YY

Also see Section A8 "Positioning".

# STANDARD SOFTWARE PACKAGE 5 B&R MININET

PLC SYSTEMS PLC PROGRAMMING





### STANDARD SOFTWARE PACKAGE 5

Standard software package 5 contains the package 1 and additional software for the B&R MININET PLC network.

### ORDER DATA

Standard software package 5, standard utility programs (comparators, counters, timers, system functions, number conversions, analog I/O module operation, arithmetic programs etc.), standard software for the B&R MININET PLC network.

3.5 " Diskette(s)

German	SWSPSCOM01-0	
English	SWPLCCOM01-0	

Standard software package 5 contains the following components in addition to package 1:

		B&R MININET
DFMN	FBK	NETWORK ADAPTER B&R MININET
MCOA	FBK	MODEM CONNECTION FOR B&R MININET TYPE A
мсов	FBK	MODEM CONNECTION FOR B&R MININET TYPE B
MDSA	FBK	B&R MININET/PLC - SLAVE A (PIFA/PIF1/PIF3)
MDSB	FBK	B&R MININET/PLC - SLAVE B (CP32)
MDSC	FBK	B&R MININET/PLC - SLAVE C (CP70/PP60/NTCP6#)
MSSA	FBK	B&R MININET/SPOIO - SLAVE A (PIFA/PIF1/PIF3)
MSSB	FBK	B&R MININET/SPOIO - SLAVE B (CP32)
MSSC	FBK	B&R MININET/SPOIO - SLAVE C (CP70/PP60/NTCP6#)
NDMA	FBK	B&R MININET - MASTER DRIVER A (PIFA/PIF1/PIF3)
NDMB	FBK	B&R MININET - MASTER DRIVER B (CP32)
NDMC	FBK	B&R MININET - MASTER DRIVER C (CP70/PP60/NTCP6#)
NDSA	FBK	B&R MININET - MASTER DRIVER A (PIFA/PIF1/PIF3)
NDSB	FBK	B&R MININET - MASTER DRIVER B (CP32)
NDSC	FBK	B&R MININET - MASTER DRIVER C (CP70/PP60/NTCP6#)
NMCD	FBK	DRIVER FOR BRMEC MASS MEMORY
NPLM	FBK	B&R MININET - MASTER PLC
NPLS	FBK	B&R MININET - SLAVE PLC
NSPO	FBK	B&R MININET - SLAVE SPOIO PLC
TPLC	TAB	CONFIGURATION DATA TABLE FOR FBK NPLM

A detailed description of the B&R MININET PLC network can be found in Section C5 "B&R MININET".



### **CONTENTS**

PLC-SYSTEMS



# **CONTENTS**

PLC-SYSTEMS POSITIONING





A8	POSITIONING	7/6 <sub>7</sub>	/f <sub>0.x</sub>	7/F3.X	
	CONTENTS				190
	GENERAL INFORMATION				
	SHORT DESCRIPTION OF POS				
	REQUIRED SYSTEM COMPON				
	- Cr.	The same of the sa			The
	FEEDBACK SIGNALS (POSITIO	ON DETECTION)			190
		T BARRIERS			
		LUTE ENCODERS			
	INOINE MEININE / IND	LOTE ENGODERO	\D\ <sup>3</sup>	73.7	
	ELECTRICAL MOTORS	-600	-C'	-6%	191
	RELAY CONTROLLED ASY	NCHRONOUS MOTORS		.70	191
		R CONTROLLED ASYNCHRON			
		NOUS SERVO MOTORS			
		ONOUS SERVO MOTORS			
	POSITIONING METHODS				193
	START/STOP POSITIONING	3			193
		G			
	STEPPER MOTOR POSITION	ONING			193
		PEED CONTROL			
		ECEDING SETPOINT GENERA	774		-174
	MAC1 AXIS CONTROLLER	lay			195
	Dan ONO				400
	B&R CNC				
	1,400	TION / DECEL EDATION DAMP			
		FION / DECELERATION RAMP: S IN EXTREME SITUATIONS			
		SIN EXTREME SITUATIONS			
	OTHER B&R CNC CHARAC				





# GENERAL INFORMATION, POSITIONING METHODS, SYSTEM COMPONENTS, POSITION DETECTION

PLC-SYSTEMS POSITIONING

### **GENERAL INFORMATION**

A wide variety of positioning systems is available today in practically every field of technology. Positioning systems in manufacturing are used for tasks such as material processing, handling, transport, assembly and component mounting. This section provides information that will make it easier to select a positioning method and determine the proper configuration. The special characteristics of various systems as well as the basics of control technology are discussed. The solutions offered by B&R are characterized by technical excellence and user friendliness for almost every type of positioning task.

### SHORT DESCRIPTION OF POSITIONING METHODS

### START/STOP POSITIONING

This in an inexpensive positioning method which is only able to travel at constant speeds. Positioning is started and stopped by switching the motor voltage on or off.

### **DUAL SPEED POSITIONING**

A motor with two different speeds is used for this type of positioning. Movements are made at a high working speed and slowed to a search speed just before reaching the target position. The accuracy of this method of positioning is a great improvement over the start/stop method.

### STEPPER MOTOR POSITIONING

The stepper motor rotates by a certain defined angle with every control pulse. By defining an adequate step sequence, the stepper motor can be accelerated and decelerated without losing any steps. B&R offers power units and stepper motor controller modules for all PLC systems.

### POSITION DEPENDENT SPEED CONTROL

The set value for positioning speed is determined from the difference between the set and the actual position. Adjustable stepless drives, especially asynchronous motors with frequency converters are applied in these systems.

### CONTROL LOOP WITH PRECEDING SETPOINT GENERATOR

This method guarantees a precisely defined speed profile and an exact reproducible target position. The B&R MAC1 positioning module calculates the best movement profile and continuously compares the set and actual positions making the necessary corrections along the way. The drive used is a highly dynamic servo motor.

### **REQUIRED SYSTEM COMPONENTS**

		k signals			
Method	Limit Switches Encoders	Signal Processing	Control Output	Motor Control	Drive
Start/Stop Method	End Switch - Encoder	Digital Inp. - Analog Inp. Counter Input	Digital Out.	Relay	DC Motor, Asynchronous Motor
Dual Speed Positioning	End Switch - Encoder	Digital Inp. - Analog Inp. Counter Inp.	Digital Out.	Relay	DC Motor, Asynchronous Motor
Stepper Motor Positioning	Not required	Not required	Digital Out.	Power Electronic	Stepper Motor
Position Dependent Speed Control	Encoder	Analog Inp. Counter Inp. Serial Inp.	Analog Out.	Frequ. Conv. - Servo Amp.	Asynchronous Motor  Async. Servo Motor Sync. Servo Motor DC Servo Motor
Loop Controller with Preceding Setpoint Generator	Encoder	Analog Inp. Counter Inp. Serial Inp.	Analog Out.	Servo Amp.	Async. Servo Motor Sync. Servo Motor DC Servo Motor

### FEEDBACK SIGNALS (POSITION DETECTION)

### **END SWITCHES AND LIGHT BARRIERS**

Ò.	Device	Durability	Reaction Time	Protection (e.g. Dust)	Ext. Supply Required	Characteristics
ı	Mechanical End Switch	Medium	< 10 msec.	Low	No	Contact element activated with tappets, roller switches or swivel levers
	Magnet Switch	High	< 1 msec.	Medium	No	Non-contact activation with permanent magnets
ı	Inductive Proximity Switch	Very High	< 1 msec.	High	Yes	Non-contact activation with conductive material (e.g. Iron, Nonferrous Metal,)
	Capacitive Proximity Switch	Very High	<1 msec.	High	Yes	Non-contact activation with electrically polarizable and conductive materials (Wood, Plastics, Glass, Iron)
	One Way Light Barrier	Very High	< 1 msec.	Low to High	Yes	Light beam between light transmitter and receiver is interrupted
	Reflection Light Barrier	Very High	< 1 msec.	Low to High	Yes	Light is reflected back to a combined transmitter/receiver
	Reflection Light Sensor	Very High	< 1 msec.	Low to High	Yes	Light is reflected from the work piece itself back to the transmitter/receiver


### **INCREMENTAL AND ABSOLUTE ENCODERS**

B&R supports a large variety of devices for length and angle measurement. To follow is a list of common encoders and operational details. The most common devices have proven to be optical rotational, linear and phase encoders.

Device					
(other common names)	Physical Unit	Scanning Method	Signal Processing	Method of Measurement	Characteristics
Rotational Pulse Encoder (Angular step encoder, Incremental encoder, Rotational encoder)	Angle	Optical Capacitive Inductive	Digital	incremental	High accuracy, Medium resolution
Linear Encoder (Lined rule)	Length	Optical Capacitive Inductive	Digital	Incremental	High accuracy, Medium resolution
Angular Encoder (Absolute encoder, Absolute rotational encoder)	Angle	Optical	Digital	Absolute	High accuracy, Medium resolution
Resolver	Angle	Inductive	Analog	Cyclic, Absolute	Robust, Medium accuracy, High resolution
Potentiometer	Angle	Mechanical	Analog	Absolute	Low accuracy
Differential Transformer	Length	Inductive	Analog	Absolute	Short distances
Laser Interferometer	Length	Optical	Digital	Incremental	High resolution
Ultrasonic Transducer	Length	Acoustic	Analog	Absolute	Robust, Medium Accuracy

### Rotational Pulse Encoder and Linear Encoder

Dividing lines which are usually on a glass disk are the essential part of optical scan encoders. On the rotational encoder, these are arranged in a circle and on the linear encoder they are similar to the marks on a ruler. Photo diodes which register emitted light are used to scan the lines. Two scanning marks that are arranged 1/4 of the distance around the circle apart from each another deliver two square wave signals (quadrature signals) which are displaced 90 temporal degrees making it possible to recognize direction.



Position is determined incremental or counter method) by counting encoder pulses with the correct sign. In scanning electronics, the resolution can be double or quadrupled. Measurement systems that count do not indicate an absolute position when activated. The reference point must be determined first, by means of a search home procedure. The search home sets the position


### POSITION DETECTION, ELECTRIC DRIVES

PLC-SYSTEMS POSITIONING






counter to a defined value (Home count) at a defined position (Home Position). Rotational encoders are equipped with an additional trace for this purpose and a reference pulse (marker pulse) is emitted for each revolution. With linear encoders the reference pulse is emitted only once within the possible distance. The reference point can be reproduced in exact increments. If the rotational encoder makes more than one rotation within the



given distance, which is quite common, a reference switch must choose one of the reference points. The exact position of the limit switch is not important.

Output signals can be square waves or sinusoidal. With square wave signals, a differentiation is made between symmetrical and asymmetrical signal generation. In order to increase transmission safety, the symmetrical encoder signals are also sent in inverted for. In addition, some encoders offer an interference signal that warns if the lined disk is dirty or if the scanning lamp is not functioning properly. There is some



discontinuity in supply voltage and it can vary between 5 and 24 V.

#### **Phase Encoders**

Optical scanning systems use coded disks for representing measurements. Gray coded disks can be scanned flawlessly with one sensing unit per track. The gray to binary transformation is made in the encoder itself or is supported by several different B&R positioning modules. Binary coded disks require just about double the number of scanning points for the same accuracy. With phase encoders, the absolute position is available immediately after the unit is activated. The interfaces that are possible should be taken into account: Parallel data transmission is used when each scanning track can also be assigned a transmission line. The

disadvantages of this method are in the amount of wiring and in the susceptibility to disturbance with such a large number of arteries. Serial communication is also available. The most common transmission method is synchronous serial with the so-called SSI protocol. The information is transmitted at 80 to 500 kBaud. The advantage is the high resistance to any interference without having to depend on the word-width of the encoder.

### **ELECTRICAL MOTORS**

#### Overview


Various drive/motor combinations are shown in the following table. Asynchronous motors are usually used for single speed and dual speed systems since they are inexpensive, robust and virtually maintenance free. DC motors, synchronous or asynchronous motors are used for servo motor drives.

70,		×0,	×0,
Span.	SINGLE SPEED DRIVES	VARIABLE SPEED DRIVES	SERVO DRIVES
DC MOTORS	Mains Y Provided Reverse	Set Value X K	Set 2 W
SYNCHRONOUS MOTORS	- while	alient.	Set Value K M ®
ASYNCHRONOUS MOTORS	Mains 3 Forward M	Set Males 3	Sel Value K 3 W 100
SPECIAL MOTORS	Split-pole Motors Capacitor Motors Synchronous Motors	Asynchronous Motors with Dahlander Winding Reluctance Motors Stepper Motors	MAHIGIDA

### RELAY CONTROLLED ASYNCHRONOUS MOTORS

The rotor is made up of aluminium rods which are shorted on the face side and embedded in iron (short circuit rotor, squirrel cage rotor). The stator has a three phase winding. Neither commutator nor slip rings are required for current feed.

The motor can be supplied directly through a three phase system. Synchronous speed is



defined by the pole pair number and supplied power frequency. Reversing the phase sequence of the supply voltage can be used to switch direction.

### FREQUENCY CONVERTER CONTROLLED ASYNCHRONOUS MOTOR

The static frequency converter which is connected to the asynchronous motor causes a smooth change in the supply frequency. The motor RPM changes almost exactly proportional to this. Nevertheless, load changes have direct influences on the speed. Frequency converters with RPM feedback through a tachometer have achieved good results at constant speeds and with little load variation. They are however, not suitable for dynamic positioning tasks.






# DC SERVO MOTORS, ROTATIONAL (A) SYNCHRONOUS SERVO MOTORS

PLC-SYSTEMS POSITIONING

### DC SERVO MOTORS

The rotor is usually composed of a stack of metal sheets with the armature winding situated in grooves. Current supply and forward feed are continuously switched with brushes and commutators which sit on the motor shaft. The stator carries permanent magnets (permanently excited motor) or electromagnets (separately excited motor). The motor speed is changed by variations in the armature voltage. By limiting the current, the torque is also limited.




### Advantages of permanent magnetism

- No additional power required for the exciter winding
- No additional heating through power loss
- Smaller structure

### Advantages of separate excitation

- Possible operation above the rated speed
- No danger of demagnetization if overloaded
- Larger operating range allowed (Commutation limit)


With separately excited motors, the speed can be made to exceed the rated speed by decreasing the exciting current. Operation with low field strength meets the requirements of the main spindle and spool drives. Earlier, the high dynamics required for servo applications were achieved by reducing inertia and later by increasing the torque. This brought about the distinction between highspeed motors and torque motors. Because of the structure of high



speed motors, only low acceleration torque or constant torque can be achieved. The power that is required is gained through high RPM (3000 - 6000 RPM). In order to adjust to load, gears are often required. The torque motor puts out the required power even at low RPM (1000 - 2500 RPM), is not susceptible to load surges due to its high inertia and can be overloaded for a longer period of time due to its capacity for heat.

### THREE-PHASE SYNCHRONOUS SERVO MOTORS

This drive is excited by means of a pole rotor which is fitted with permanent magnets on the servo model, therefore not requiring a current supply. The stator has a three phase winding. No commutators or slip rings are necessary for current induction. The pole rotor induces either sinus or trapezoidal voltage in the stator winding according to the form of the magnetic field and the distribution of stator windings. The stator winding is fed with sine wave in the first case and with a square wave in the second.



### **Advantages of the Sine Commutated Motor**

- Better rotation characteristics
- More robust (No tachometer or quadrature encoder required)
- Less wiring

### **Advantages of the Block Commutated Motor**

- More power for the same size through better use of armature current
- Less work for velocity controllers

With both types of commutation, the position of the rotor must be determined continuously and the stator current must be controlled with the proper electronics. The characteristics of the synchronous servo drive can be summarized as follows:

- Low maintenance since the motor has neither commutators nor slip rings
- High degree of protection
- Cheaper to manufacture than DC motors
- High load capacity through good heat dissipation from the statol winding and no rotor loss
- High torque at all speeds, even when idling
- No commutation limitation curve, i.e., high acceleration torque, even at high RPM
- Short start-up times due to limited rotor inertia and high overload capacity
- Good low field strength operation

### THREE PHASE ASYNCHRONOUS SERVO MOTORS

In order to use the asynchronous machine as a drive for a servo system, very costly servo amplifiers must be used. To obtain a good dynamic response, it is not sufficient to calculate the feed frequency and the feed voltage from the set speed and the measured actual speed. Rotor temperature and saturation effects must also be taken into account and this requires a substantial amount of computing. The three phase asynchronous servo drive has the following characteristics:

- Robust, maintenance free and simple mechanical structure
- High degree of protection
- Low manufacturing cost in comparison to DC and synchronous motors
- Good heat dissipation in phase windings embedded in the stator
- Good dynamics due to high overload capacity and low rotor inertia

# POSITIONING METHODS, PSA2 STEPPER MOTOR CONTROLLER MODULE

### PLC-SYSTEMS POSITIONING





### **POSITIONING METHODS**

ositioning.				oendent ol	Closed Loop Control with Set Value Encoder
Characteristics of Posi- ioning Method	Start/Stop Positioning	Dual Speed Positioning	Step Motor Positioning	Position Dependent Speed Control	Closed Loop Cont Set Value Encoder
Drive	Single speed	Two speed	Stepper motor	Servo motor	Servo motor
B&R Module	Digital I/O module, BRCOMP, PNC3, PNC4, PNC8	Digital I/O module, BRCOMP, PNC3, PNC4, PNC8	PSA2, BRCOMP	PNC3, PNC4, PNC8, BRCOMP	MAC1, PNC8
Positioning Time	Long	Medium	Short	Short	Very shor
Precision	Low	Average	High	High	Very high
Reproducibility	Poor	Average	Very good	Good	Very good
Behaviour under Varied Loads	Average	Average	Very good	Good	Very good
Protection of the Mechanics	Poor	Poor	Good	Good	Very good
Interpolated Multi-axis Operation / CNC	Not possible	Not possible	Not possible	Not possible	Possible

Three phase asynchronous motors are particularly suited to Start/Stop and Dual Speed positioning since they are so cost efficient and require little maintenance as well as having a high degree of protection. The other methods are shown below with some drive characteristics. The most important things to pay attention to in setting up you positioning motor are the power required and the motor torque. Most drive manufacturers are more than happy to provide you with any drive dimensioning information.


Motor Type	Torque	Speed	Power	Remarks
Stepper Motor	0.4 to 1000 Ncm	Max. 1000 min <sup>-1</sup>	0.1 to 500 W	Low efficiency
DC Servo	50 to 15000 Ncm	Max. 6000 min <sup>-1</sup>	150 to 120000 W	Heavy maintenance
Synchronous Servo	100 to 20000 Ncm	Max. 10000 min <sup>-1</sup>	300 to 8000 W	Little maintenance, Good protection
Asynchronous Servo	220 to 40000 Ncm	Max. 10000 min <sup>-1</sup>	500 to 60000 W	Little maintenance, Good protection

### START/STOP METHOD

The end positions are detected by end switches connected digital inputs on the controller. The drive is switched by means of digital outputs and contactors. The position can be determined with an incremental encoder instead of with end switches. The pulse created is registered by a counter card and evaluated by the PLC.


### **DUAL SPEED POSITIONING**

This method aims at increasing positioning accuracy with little time loss in relation to the last method described. A limit switch. located before the target position, switches the drive from high to low speed. The slower speed means shorter reaction times and less fluctuation just before the target position. In order to determine the position, an incremental encoder with counter module can be used. The user can easily define or change positions with a B&R operator interface panel.



#### STEPPER MOTOR POSITIONING

Positioning with stepper motors is done with open control loops. The actual position is not verified. The speed profile is calculated from the actual and the set positions and then is transferred to the power controller. This amplifies the signal and adjusts the motor. The feature that most characterizes the stepper motor is the motor shaft rotates in steps. A full turn of the shaft is made of



a precise number of single steps. The stepper motor has the structure of a synchronous machine whose pole pairs are excited and controlled with DC. The rotor is equipped with permanent magnets. Since no brushes are required, the drive requires very little maintenance. It moves according to the rotational field created on the stator. This makes the frequency directly proportional to the speed of the rotor. Today's widely spread permanent magnet stepper motors

have good static and dynamic characteristics, and self holding torque even with no current. The torque is at its greatest when the motor is idling and decreases drastically at a frequency between 1000 and 5000. At 10 kHz, only half of the maximum torque still exists. When a stepper motor is designed, the drive dimensions are very important. Since the actual position is not taken into account, weaknesses in design or a load which is too large can cause the motor lose track of the given frequency and therefore lose "steps". Many power unit manufacturers offer position monitoring which guarantees that the actual position precisely follows the set position.



### PSA2 - Stepper Motor Controller Module

The PSA2 stepper motor controller module is available for all B&R controller types. The PSA2 module can control two axes simultaneously. The major advantage of integrating a stepper motor controller into the PLC is that all movement parameters can be changed in the CPU through a normal operator interface panel for example. In addition to the different positions, the PLC program developer can make it possible for the end user to enter different speed and acceleration ramps. The module's own processor takes over all calculations for the move. This frees the PLC CPU for other tasks.

Communication with power units made by other manufacturers is made possible through four transistor outputs and a relay output per axis on the module:

- Pulse (Frequency output): Active switch against supply (max. 50 mA) and against 0 Volt (max. 3 mA; 25 Hz to 20 kHz)
- Rotational direction (positive switching, 3 mA)
- Boost (n-switching, 50 mA): Control signal for short term increase of motor dynamics when accelerating or decelerating
- Power unit enable (n-switching, 50 mA): Can be set to 5 24 V for power units of other manufacturers
- Relay output (30 V / 1 A, normally open contact): Used for control of peripheral devices which are in direct contact with the axis, e.g. clamps. Other applications are possible with power units having extended functions such as current shut-off when idling.





# POSITION DEPENDENT SPEED CONTROL

PLC-SYSTEMS POSITIONING

Five digital signals per axis can be wired directly with the module for feedback from the positioning system:

- Axis end limit switch for positive direction (24 V, 6 mA)
- Axis end limit switch for negative direction (24 V, 6 mA)
- Reference switch for search home procedure (24 V, 6 mA)
- Trigger input (24 V, 6 mA / 5 V, 4 mA) e.g. for measuring work pieces or print/press control
- Ready signal from the power unit (any input voltage from 5 to 24 V, 5 mA)

### Types of Positioning

The firmware implemented in the stepper motor controller module allows the user to choose between the following types of positioning:

- Different search home variations
- Absolute positioning (the axis zero point serves as the reference point)
- Relative positioning (the last target position serves as the reference point)
- On-line speed control (speed definitions)
- Positioning with synchronization with a trigger pulse (the position at the time the pulse is registered is available to the user)

### **Operating the Module**

Stepper motor axis parameters can be defined efficiently and easily with a standard function block. The setup time is reduced to a minimum. The user only has to define a few axis specific parameters which are clearly arranged in a data table. A standard parameter configuration is delivered with the software package.




### Interference Resistance and Electrical Isolation

B&R products are characterized by high specifications and high interference resistance. In this module, all inputs and outputs are electrically isolated by optocouplers to prevent any electrical disturbance. All transistor outputs are short circuit and overload protected which ensures the highest possible operational security.

Status LEDs provide fast and dependable optical monitoring of the module. In addition to control functions most inputs can be utilized for diagnosing axis errors.

### POSITION DEPENDENT SPEED CONTROL

This procedure requires the use of servo drives or frequency controlled asynchronous motors. It guarantees a smooth speed profile for independently operated axes. The actual position is compared with the set position by the encoder. The closer that the actual position is to the target position the less set speed adjustment is made.



On the PLC side, the speed profile is precalculated and stored in a data table. Different acceleration ramps can be attained by multiplying the calculated values by a constant before they are written to the analog output. B&R offers high performance function blocks for distance related speed positioning. One speed profile for almost any application is provided in the form of a table that can be connected to the function block. The PLC user only needs to define a few simple parameters. The following overview shows the B&R modules that work according to this principle and the respective technical data:

	Positioning Module	PLC System, Module Rack	Number of Axes	Counting frequency	Counting depth	Supported encoder
	PNC4	MINICONTROL	1	200 kHz	24 Bit	incremental
	PNC3	MULTI, MIDI, M264	1	200 kHz	24 Bit	incremental
	PNC8	MULTI, MIDI, M264	4	100 kHz	32 Bit	incremental and absolute
Ś	BRCOMP	BRCOMP	<u>,</u> 1	20kHz	24 Bit	incremental and absolute

If the PLC CPU is responsible for numerous time critical tasks, it is advisable to use the PNC8 module which processes the positioning function block locally itself. The counting frequency of the module is only relevant for incremental encoders. Maximum positioning speed (v\_max) can be obtained from the encoder resolution ( $\Delta s$ ) with the counting frequency:

$$V_{max} = \Delta S_{Encoder} * f_{max}$$

As an example, the maximum positioning speed of two encoders at a counting frequency of 200 kHz has been calculated.

∆s [μm]	v <sub>max</sub> [m/sec]	v <sub>max</sub> [m/min]
1	0.2	12
10	2	120

# LOOP CONTROLLER WITH SETPOINT GENERATOR, MAC1 AXIS CONTROLLER

PLC-SYSTEMS POSITIONING





In order to travel large distances at high counting frequencies, the positioning module's counter must offer a sufficient counting range.

PNC3, PNC4, BRCOMP ... 
$$s_{max} = 16 * 10^6 * \Delta s$$
  
PNC8 ...  $s_{max} = 4 * 10^9 * \Delta s$ 

The following table shows this correlation

∆s [μm]	PNC8 s <sub>max</sub> [m]	PNC3, PNC4, BRCOMP $s_{max}[m]$	
0.1	400	1.6	
1	4000	16	


On the drive side, it is feasible to operate a closed loop amplifier as well as an open loop speed amplifier. The advantages of the closed loop speed drive are that the actual speed is constantly compared with the set speed and the system reacts very rigidly to load fluctuations.

The open loop speed drive (e.g. DC drive with preceding DC voltage amplifier) is only suitable for positioning applications having moderate demands for repetitive precision.

### LOOP CONTROLLER WITH PRECEDING SETPOINT GENERATOR

If exact reproducible speed profiles are to be achieved regardless of outside interference, this method is to be chosen. B&R has developed the MAC1 axis controller for just such applications. The MAC1 offers a solution for almost any positioning application. Before going into detail about this module, some of the principles and control fundamentals are discussed.

#### Diagram



The setpoint generator calculates the time profile of the desired position before the move. This calculation is done by using the maximum speed and maximum acceleration as limit parameters in order to reach a target in the shortest possible amount of time. The axis controller guarantees that the actual position follows the set position as closely as possible (even during the move). It sends the desired speed to the secondary speed control loop in relation to the difference between the target and the actual position. The speed controller on the drive side offers the extra advantage of precise high speed control. The actual speed follows the set speed more accurately and is less sensitive to loads.

### MAC1 AXIS CONTROLLER


### Precise and Dynamic

The MAC1 axis controller offers shorter machine cycles at the same time as having very low tolerance. To do this, the MAC1 needs:

- Position set value calculation with jolt limitation
- Powerful loop control algorithm
- Short scan times
- High resolution of the speed setpoint
- High counter frequencies

### Jolt Limitation

The system itself is oscillatory since every mechanical system has intertial masses and a limited interference resistance. In order to keep positioning errors to a minimum, the MAC1 calculates a motion profile with no acceleration jumps (jolt limited). Since the move is made with no jumps in acceleration, substantially less vibration is caused. Just moving the encoder from the drive shaft (indirect measurement) to the respective machine segment (direct measurement) does not solve the problem.




A jolt (jerk) is a change acceleration time and can be predefined by the user. Here is a summary of advantages achieved by jolt limitation:

- Higher accuracy during the move (very important for interpolated operation)
- Almost no oscillation (Important for positioning tasks)
- The best possible protection of the mechanics (avoids wear and tear caused by alternating loads, striking of transmission elements because of mechanical play)

The move optimization is performed by the MAC1. Depending on the task, the user can select one of the two following optimization methods for a positioning:

Minimum Positioning Time The axis travels to the target in the shortest amount of time with its move based on the defined limits for speed, acceleration and jolts



The positioning time is calculated and the user knows this time even before the move is started.




# **A8**

### **MAC1 AXIS CONTROLLER**

# PLC-SYSTEMS POSITIONING

Minimum Jolt

If the positioning time has been predefined and should be used, the axis travels as smoothly as possible to its destination. The limits for speed, acceleration and jolt also apply in this case



#### **Electronic Gears**

Every movement of the master axis is copied in a certain defined ratio by the slave axis. This ratio "a" is given as a command parameter and is defined as follows:

The ratio can be defined as less than or more than 1.


Numerator and denominator are defined as 2's compliment numbers which makes negative ratios possible as well.

The gear command can be given with the master axis at a standstill or during a movement. The ratio can also be changed at any time by executing this command.

### **Gear Positioning**


The function can be used to control the "Flying Saw".

The slave axis is linked with the master axis for a certain defined part of the master's entire movement with a certain defined relationship. The acceleration and deceleration procedures are not part of the synchronous path.




### Synchronous Positioning

The slave axis travels a relative positioning path with the master axis for a defined amount of the master's path (synchronous path). The acceleration and deceleration profiles are within the synchronous path.




### **Compensation Gears**

The slave axis should travel from an absolute position of the master axis with the master axis using a certain defined ratio (synchronous phase). The master axis calculates a respective compensation movement, depending on the path that the slave axis must follow back to the start of the synchronous phase and depending on the path of the master axis to the synchronous position.



### Loop Controller

The MAC1 has a loop controller with feed-forward.



### **MAC1 AXIS CONTROLLER**

PLC-SYSTEMS POSITIONING

A8



If no feed-forward was implemented, a constant lag distance would be maintained at constant speed (without any load deviation) according to the following formula.

$$\Delta x = \frac{v}{k_v} \qquad \begin{array}{ccc} \Delta x & ... & \text{Lag Distance} \\ v & ... & \text{Speed} \\ k_v & ... & \text{Speed Amplification} \\ (\text{Proportional part}) \end{array}$$

Since amplification  $k_{\nu}$  depends on the dynamic characteristics of the entire drive, and can therefore not be just any size, the omission of lag errors particularly affects drives with low oscillation frequencies.

The loop controller has P or PI characteristics depending on the defined parameters.

### Scan Time

Digital controllers with constant scan times do not continuously compare the actual and set positions, the set and actual positions are compared at regular timed intervals. This doesn't make any difference as long as the scan time is shorter than the delay of the drive. Formula:

$$T_A \le \frac{1}{f_{oA}}$$
  $T_A$  ... Scan Time  $f_{oA}$  ... Oscillation frequency of drive

Example 
$$\frac{T_A = 2 \text{ msec}}{f_{oA} < \frac{1}{10 T_A}} = 50 \text{ Hz}$$

$$\omega_{oA} = 2 \pi f_{oA} = 314 \text{ s}^{-1}$$

$$k_v = 0.3 \omega_{oA} = 94 \text{ s}^{-1}$$

### Set Value Resolution

The finer that the RPM set values can be output, the less often that the loop controller has to switch between two steps of the digital/analog converter. The speed profile is steadier and the performance in holding control is greatly improved.

Example
$$\frac{16 \text{ bits for } \pm 10 \text{ V}}{\text{V}_{\text{max}} = 0.5 \text{ m/sec}}$$

$$\Delta U = \frac{20 \text{ V}}{65536} = 0.3 \text{ mV}$$

$$\Delta v = \frac{2 \text{ V}_{\text{max}}}{65536} = 15 \text{ µm/sec}$$

### Interference Compensation

In order to transfer the high resolution set values without any errors, sometimes under extreme industrial conditions, the MAC1 has an interference compensation system developed by B&R.

### **Counting Frequency**

The demand for high encoder resolution and high speed at the same time lead to higher counter frequencies with incremental encoders.

Example 
$$v_{max} = 0.5 \text{ m/sec}$$

$$\Delta s = 0.2 \mu\text{m}$$

$$f_{max} = 2.5 \text{ Mio Inc/sec}$$

### Incremental Encoder Filter

The higher the maximum counter frequency is, the weaker that the input filters of conventional counter modules must be. This naturally increases the susceptibility to disturbance as well. B&R has developed a method of filtering for the MAC1 that makes a 100% improvement over conventional circuits.

### **Signal Monitoring**

If variations in the encoder signal are so high that a counter error is to be expected despite the filter, the MAC1 produces an error message, which can be evaluated by the application program.



**A8** 

### THE B&R-CNC

PLC-SYSTEMS POSITIONING


### **B&R CNC**

B&R offers NC machine control software package for the MAC1 axis controller and the B&R MAESTRO coprocessor. Potential integration in the PLC gives this system an wide range of possibilities for special applications unable to be matched by other CNC concepts of this type.

The B&R MAESTRO coprocessor and the OS-9 real-time capable operating system make up the ideal framework for decoding control sets in accordance with DIN 66025, accepting data from CAD systems or visualizing and operating the facility e.g. with B&R industrial terminals. Multiprocessor capabilities and modularity make it possible to simply "plug-in" more computing power. Even the software is modular in structure so that changes or extensions can easily be added. In this way, custom-made solutions can be produced for any application.

### CONFIGURATION

The following diagram shows the different software modules and the methods of communication. The decoder reads and interprets the control data stored as files and sends movement information in sets to the CNC. The CNC calculates the movement profiles from this data and from limit values which were set initially for the axis and then controls the moves accordingly on the MAC1 axis controller. The interrupt service and MAC1 management program "macman" organizes, among other things, the necessary flow of information between the axis controller modules. The "cncman" module completes initializations and sets up an OS-9 data module through which all programs can communicate with one another. The information delivered by the motion controller is decoded into commands in the MAC1 operating system. This is also where the safety functions are implemented. There is a large selection of individual application functions in the CNC library. These were developed to make programming of user tasks as easy as possible. These can also be accessed by standard visualization software.



### THE B&R-CNC

# PLC-SYSTEMS POSITIONING





### MOVEMENT PROFILE

#### **Jolt Limitation**


Every movement profile that the CNC calculates using the information of the decoder, is processed by the MAC1 axis controller in order to minimize any possible jolt according to the defined limit values. Jolt limitation means (as mentioned in section MAC1) that accelerating or decelerating must be done smoothly within a given time period and that the acceleration/deceleration movement profile or speed profile may not have any jumps or discontinuity (kinks).

Advantages of jolt limitation:

- High path precision, since the manipulated variable is able to follow the smoother setpoint values easier
- Protection of mechanics by avoiding wear and tear due to alternating loads
- Mechanical collision caused by play in the works is avoided


Some movement profiles are not possible without a certain jolt however, unless the speed of the movement is brought right down to zero:

### Straight Line to Straight Line Transition



The B&R CNC enable the limitation of speed jumps. Before the actual transition, the movement speed is automatically decreased to a level at which the jolt will remain within the defined limits. The same applies for nontangential transitions such as circle/line and circle/circle.

### **Tangential Circle/Line Transition**



Acceleration jumps can also be limited with the B&R CNC. Before the transition, the speed is automatically reduced to a level that only acceleration jumps within the defined limits occur. The same applies for tangential circle to circle transitions

### ASYMMETRICAL ACCELERATION RAMPS

The acceleration and the deceleration can be defined differently for the path. The limits can be set differently for each axis. The speed profile calculation is done according to all NC sets to enable a time optimal movement profile. This considerable advantage lets the user dispense with programming in NC code entirely for time optimal movements. This also ensures that the movement profile is always made with the highest possible speed (within the axis limitation values). At least one axis is always operated with the maximum acceleration/ speed.

### SPEED CHARACTERISTICS IN EXTREME SITUATIONS

### Information Flow Interrupted

As long as no information is fed to the CNC, the move ends in the last defined state and the speed is dropped to zero using the limit values last defined for the axis.

### **CNC Controller Failure**

If the processor on which the CNC is running fails, the speed will be reduced by the MAC1 axis controller according to the defined axis limit values so that the last moves given to the MAC1 are still completed. This guarantees that the movement is carried out until the last known point and the axis comes to a safe stop.

### **Axis Controller Failure**

A hardware "watchdog" trips a relay which causes 0 V on the analog output if an error occurs. This status is recognized and activates an emergency stop on all participating axis controllers.



# **A8**

### THE B&R-CNC

# PLC-SYSTEMS POSITIONING

### With Heavy Loads on the Processor

If the multiprocessing capabilities are not put to full use, extra complex interpolation procedures could lead to the axis controller not receiving information fast enough. In this case, the axis controller uses the defined deceleration ramps to drop the speed of the movement.

### **Emergency Stop Performance**

An emergency stop decreases the speed of the move to zero using the defined maximum deceleration ramp while holding to the defined profiles.

### **FUNCTIONS OF THE B&R CNC**

#### Linear and Circular Interpolation

Linear interpolation can be used with three axes and circular interpolation with two axes. If a circle in space is to be defined, spline interpolation can be utilized.

### Mirror Imaging the x and y Axes

A mirror image causes the direction of the tool radius correction to change as well.

### **Tool Radius Offset**

Tool radius comes into play in milling applications, for example. The real workpiece size can be programmed and control corrects for the radius of the tool used. Either linear or circular transition can be used on outer corners of the workpiece.



### **Tandem Axes**

Two axes having the same resolution (gear ratio 1:1) can be positioned as an axes pair.

### **C-Like Instruction Sets**

Program branches and loops can be created with control instructions in the NC program. Some of these instructions are shown here:

IF (IF, ELSEIF, ELSE, ENDIF)
SWITCH (SWITCH, CASE, DEFAULT, ENDSWITCH, BREAK)
FOR (FOR, ENDFOR, CONTINUE, BREAK)
WHILE (WHILE, ENDWHILE, CONTINUE, BREAK)
DO (DO, ENDDO, CONTINUE, BREAK)

### **Mathematic Functions**

Mathematic functions can be utilized within instruction sets. These include:

Basic operations (+, -, \*, /, \*\*, MOD)

Numerical functions (ABS, SQR, SQRT, EXP, LN, DEXP, LOG)
Trigonometric functions (SIN, COS, TAN, ASIN, ACOS, ATAN)
Conversions (INT, FRACT, ROUND)

### Communication with the PLC

 $\mbox{\bf M}$  functions can be defined and are used for communicating with the PLC:


MwS M function without synchronization
MbR-SbR M function before record, synchronization before record
MbR-SaR M function before record, synchronization after record
MaR-SaR M function after record, synchronization after record

The purpose of synchronization is to stall the processing of the NC program until the PLC sends a ready message. Different synchronization methods make it possible for the PLC to simultaneously process several tasks which are to be synchronized.


#### Spline Interpolation

Spline interpolation allows the points in a set to be connected with a smooth curve, without having to estimate it with a large number of lines and curves.

### Smooth means:



Curves can be 2 or 3 dimensional.



With the B&R CNC, the spline curve can be made at constant speed or with a time optimal speed profile. Time optimal means a movement executed according to the limits defined for CNC speed, axis speed, axis acceleration and iolt.

### Advantages for the user:

- No feed forward settings are necessary
- Machine mechanics are protected
- Path precision
- Short procedure times

### THE B&R-CNC

PLC-SYSTEMS POSITIONING





### OTHER B&R CNC CHARACTERISTICS

### The B&R CNC System is "PLC Compatible"

Every B&R made MULTICONTROL module can be operated with the CNC hardware configuration. Communication between the CNC software and the PLC CPU module is over the PLC bus.

### The B&R CNC System has Modular Software and Hardware

Computing power can be increased by adding MAESTRO coprocessor modules. Special functions can be integrated into customer specific CNCs

### The B&R MAESTRO Operating System is Multitasking

This makes it possible to complete additional tasks in parallel, such as visualization or networking. It is easy to set up an operator interface using SPECTO\_S and then run it as an additional program in MAESTRO for example.

### The Scan Time of the Position Control Loop is 4 msec.

This guarantees a high degree of stability for the position control loop and high dynamic drives can be used.

### **Additional Axes Possible**

Besides the 2-3 interpolated axes, up to 7 more axes can be run in the CNC combination and operated with NC instructions.

### **Tangential Axis Operation**

A tangential axis can be operated instead of one of the three main axes. A tangential axis can be used to drive a tool such as a cutter for example, in tangent to a 2 dimensional path.



A9

### **CONTENTS**

PLC SYSTEMS

### **CONTENTS**

PLC SYSTEMS PID LOOP CONTROL





### A9 PID LOOP CONTROL

CONTENTS				194
GENERAL INFORMATION	70,0			198
BASIC TERMINOLOGY				198
DYNAMIC PROCESS CONTROL				198
CONTROL LOOP CHARACTERISTICS	4,	49	4,	198
TYPES OF LOOP CONTROLLERS				
ALGORITHM OF A DIGITAL PID LOOP CONTROLLE	R			199
FUNCTIONS OF THE PID LOOP CONTROLLER				
PARAMETERS		3		200
PROPORTIONAL BAND (PB)DEAD BAND (DB)				200
DEAD BAND (DB)			<u> </u>	200
DEVIATION ALARMS (DEV+, TDEV+, DEV-, TDEV-).				201
SETPOINT RAMP (RAMP)				201
WORKING POINT (BIAS)				202
CONTROL SIGNAL LIMITS (MV_HI, MV_LO)	2,		- 2	202
CONTROL SIGNAL RAMP dy/dt (VEL)				202
TIME PROPORTIONAL CONTROL (TP+, TPmin+, TP	P-, TPmin-)			203
STEP SIGNAL (TS, TSmin)		X		204
SYSTEM CONFIGURATIONS				
SOFTWARE COMPONENTS				205





# GENERAL INFORMATION, BASIC TERMINOLOGY, DYNAMIC PROCESS CONTROL

PLC SYSTEMS
PID LOOP CONTROL

### **GENERAL INFORMATION**

B&R offers a complete range of hardware and software components for control applications. Standard software package 3 contains standard software for PID loop control.

### **ORDER DATA**

Standard software package 3, utility programs (comparators, counters, timers, system functions, number conversions', I/O module operation, arithmetic programs etc.), standard software for PID loop control.

3.5 "-Diskette(s)


German	SWSPSPID01-0
English	SWPLCPID01-0
Lingillon	OTTI EOLIDOLO

The following section contains a short introduction into the basics of PID contro and a detailed description of the control algorithms used.

### **BASIC TERMINOLOGY**

Loop control is a procedure in which process value x is continually measured, compared with setpoint w and adjusted depending on the result of the comparison.

### **CONTROL LOOP**



Command Signal w

This is the set value entered into the control loop. This value is not affected by the control process. The value of process variable x is to follow set value w according to predefined conditions.

Output Signal x:

The value that is to remain constant for the movement or is influenced by the set value.

Control Signal y

This is the output of the controller; it transfers the controlling effect

of the controller to the process.

Disturbance z:

The disturbances originating from outside the control loop which

interfere with the output signal.

Deviation  $\mathbf{x}_{\mathbf{w}}$ :


Difference between the output signal and the command signal. This deviation should be kept to an absolute minimum (zero) in the control

control.

The job of a closed loop controller is **to read** the command signals (temperature, pressure, RPM, speed, level, etc.), **compare** them with the command signals and to **produce** a control signal according to the results of the comparison. Control signal y influences output signal x through the controlled process.

### **DYNAMIC PROCESS CONTROL**

For control purposes, the dynamic behavior or most industrial processes can be characterized by a first order lag time with dead time.



T<sub>t</sub> ... Dead time

T<sub>s</sub> ... Lag time

Ks ... System amplification

Dead Time T,:

The dead time is the time that it takes the controlled process to change the actual output signal after a value change. (This is also called the transfer error or transfer lag.)

Lag Time T<sub>s</sub>:

Time constant of the first order lag element. After the time for  $T_{\rm S}$  has run out, the output signal has reached 63.2% of the amplitude  $K_{\rm S}$  in response to an input of control signal y.

After a period of 4  $T_{\rm g}$ , the output signal reaches approximately 95% of  $K_{\rm o}$ .

Control Amplification Ks:

The process is amplified by dividing the percentage that the output signal changes "Dx" by the percentage that the control signal changes "Dy". The amplification created by the device used to do the measuring is also taken into consideration (e.g. Temperature Sensor).

$$K_{s} = \frac{\Delta x \, [\%]}{\Delta y \, [\%]}$$

### **CONTROL LOOP CHARACTERISTICS**

Stability, precision and low correction times are the priorities of any control system.

Stability

Stability means that the control loop uses active compensation (equalization) to prevent any oscillation caused by sudden control changes

(command or control signals).

Precision

**Precision** is determined by the magnitude in control deviation  $(\Delta x_w)$  necessary to initiate a reaction of the loop control system.

Correction Time

**Correction Time** is the time that the loop controller requires to set the output signal to a new value with a command signal or to reset the output signal to its original value after a disturbance.

These three characteristics should be taken into consideration in the construction of any control system. These characteristics seem to be absolutely incompatible. The goal is to achieve an optimal interaction of all three.


# CONTROLLER TYPES, ALGORITHM FOR DIGITAL PID LOOP CONTROLLERS

PLC SYSTEMS
PID LOOP CONTROL





### TYPES OF LOOP CONTROLLERS



y Control Signal

x<sub>w</sub> Deviation

K Proportional Amplification

T<sub>D</sub>

Integral Time
Differential Time

T<sub>N</sub> Integral Action Time
T<sub>V</sub> Derivative Action Time

# $y = K_p \cdot x_{W(n)} + \frac{T_{AB}}{T_i} \sum_{i=0}^{n} x_{W(i)} + \frac{T_{D}}{T_{AB}} \cdot (x_{W(n)} - x_{W(n-1)}) + AP$

Normally the integral action time  $T_{_N}$  and the derivative action time  $T_{_V}$  are given when defining the parameters for PID controllers instead of  $T_{_I}$  and  $T_{_D}$ :

$$T_{N} = K_{P} \cdot T_{I} \qquad T_{V} = \frac{T_{D}}{K_{P}}$$

Thus, the following formula is obtained:

$$y = K_P \cdot [x_{W(n)} + \frac{T_{AB}}{T_N} \sum_{i=0}^{n} x_{W(i)} + \frac{T_V}{T_{AB}} \cdot (x_{W(n)} \cdot x_{W(n-1)})] + AP$$

T<sub>AB</sub> Scan Time(100 msec.) n TIme  $\begin{array}{ll} {\rm T_{_{N}}} & {\rm Integral\ Action\ Time} \\ {\rm T_{_{_{V}}}} & {\rm Derivative\ Action\ Time} \end{array}$ 

All B&R processor loop control systems run in 100 msec cycles.

### **FUNCTIONS OF THE PID LOOP CONTROLLER**

#### MODES OF OPERATION

- MANUAL/AUTOMATIC (M/A)
- LOCAL/EXTERNAL (L/E)
- DESELECT/FEEDBACK (DSEL/FBAK)
- CLOSE/OPEN/FREEZE

### MANUAL/AUTOMATIC (M/A)

MANUAI

The control signal is defined through MV\_MAN in this mode. We recommend that all security functions that relate to the control signal (control signal ramp dy/dt and the upper and lower control signal limit values) are enabled. In order to guarantee a smooth return to the automatic mode of operation, the control signal is made into P and I components which correspond with the parameters PB and TN

AUTOMATIC The control signal is determined with a PID algorithm in automatic model. All functions and security functions are active in this mode.

### ALGORITHM FOR A DIGITAL PID LOOP CONTROLLER

The PIC loop controller consists of a P component, an I component and a D component. The sum of these three components and the momentary working point makes up the algorithm for a PID loop controller:

$$y = P + I + D + AP$$

$$y = K_p \cdot x_w + \frac{1}{T_{1-0}} \int_0^t x_w dt + T_p \cdot \frac{dx_w}{dt} + AP$$

AP Working Point
P Proportional Component

I Integral Component

D Differential Component

These four components AP, P, I and D can sit anywhere between 0 and 64000. This formula applies for analog PID loop controllers and continuous signals. If these considerations are transferred to the digital domain (in which only a finite number of discrete values can occur), differential components have to be replaced by the first order differential components and the integral must be replaced by the sum (rectangular integral):

### LOCAL/EXTERNAL (L/E)

The controller can run with two different set values which can be connected to the L/E input.

LOCAL The set value is taken from the SP\_LOC input in this mode. EXTERNAL The set value is taken from the SP\_EXT input in this mode.

### DESELECT/FEEDBACK (DSEL/FBAK)

Inputs DSEL and FBAK are used for the selector control:

DSEL = 0 The controller is selected, i.e. it runs normally. The control signal is constructed with the PID algorithm.

DSEL = 1 The controller is deselected, i.e. the control signal is not constructed with the algorithm, but is attained from feedback. To guarantee a smooth transfer of the control signal value when selecting the controller again, the feedback is converted into its P and I components to adapt to the controller's parameters (PB





### PARAMETERS, PROPORTIONAL BAND, **DEAD BAND**

**PLC SYSTEMS** PID LOOP CONTROL

### CLOSE/OPEN/FREEZE

These are special control loop functions.

If the CLOSE input is activated in forward mode, control signal y changes from CLOSE the current value to 0 %, in backward mode it changes from the current value

to 100 %

OPEN If the OPEN input is activated in forward mode, control signal y changes from the current value to 100 %, in backward mode it changes from the current value to

0 %

**FREEZE** If the FREEZE input is activated, control signal y is frozen, i.e. it remains at the

current value totally independent of the deviation.

### **PARAMETERS**

The B&R controller uses the following parameters:

РΒ Proportional Band X<sub>n</sub> ΤN Integral Action Time T TV Derivative Action Time T<sub>v</sub> DB Dead Band T<sub>B</sub> Positive Deviation Alarm x<sub>w</sub> DEV+ Positive Alarm Timer t<sub>xw+</sub> Negative Deviation Alarm x<sub>w-</sub> TDEV+ DEV-Negative Alarm Timer t<sub>xw</sub> TDEV-Setpoint Ramp w<sub>RAMP</sub> Working Point AP RAMP BIAS

MV\_HI Upper Control Signal Limit Value y<sub>H</sub> Lower Control Signal Limit Value y<sub>LO</sub> MV\_LO Control Signal Ramp Δy

VEL


Positive Period Time for Clock tp. TP+ Positive Clock Limit t<sub>PMIN+</sub>
Negative Period Time for Clock t<sub>p</sub> TPmin+ TP-Negative Clock Limit t<sub>PMIN</sub> TPmin-

Total Step Time t TS Minimum Step Time t<sub>SMIN</sub> **TSmin** 

### **PROPORTIONAL BAND (PB)**

When deviation x<sub>w</sub> changes, the P components of the controller immediately adjusts the control signal by a proportional amount. The characteristic value for this is proportional amplification K<sub>P</sub>






This ratio applies to the entire control signal range for the P component. Proportional Band X<sub>p</sub> is used to represent this as a percentage:

$$K_{p} = \frac{100}{X_{p}} \Rightarrow X_{p} = \frac{100}{K_{p}}$$


Therefore, a small proportional band causes high amplification and visa versa.

### **DEAD BAND (DB)**

Within this dead band, the deviation  $\mathbf{x}_{\rm w}$  is held at zero, i.e. any deviations that are less than the width of the dead band are suppressed. The dead band applies to positive and negative deviation and is the same size for both.



The width of the dead band can be defined as any value from 0 to 64000.



Dead Band  $T_B = 6400 \dots$ Dead Band  $T_B = 9600 \dots$ Permitted Deviation x<sub>w</sub> = ± 10 % Example Permitted Deviation x<sub>w</sub> = ± 15 %

### DEVIATION ALARMS, SETPOINT RAMP

PLC SYSTEMS
PID LOOP CONTROL






### **DEVIATION ALARMS (DEV+, TDEV+, DEV-, TDEV-)**

Deviation is determined by the difference between the set value and the actual value:


$$x_w = w - x$$

A maximum deviation from the command signal can be set for the positive area  $(x_{w, \cdot})$  and the negative area  $(x_{w, \cdot})$ . If this range is exceeded, a timer is started with the time  $t_{xw, \cdot}$  or  $t_{xw, \cdot}$ . After this time runs out, either the positive alarm  $x_{w, \cdot}$  or the negative alarm  $x_{w, \cdot}$  is set respectively. If the control signal comes back into the allowed range during this time, the timer is reset and the alarm is not activated.



### **SETPOINT RAMP (RAMP)**

A sudden change of the set value causes a large change in the control signal with more control amplification or with a controller with D component. In order to achieve dynamic smooth setpoint change, the setpoint of the controller can be sloped according to a ramp.



The setpoint ramp is based on the scan time  $t_{AB}$  (100 msec). The value entered for the setpoint ramp  $w_{RAMP}$  determines the number of scan cycles that may pass to change the setpoint value by 100% (e.g.  $w_{RAMP}=4$  means that a setpoint can change from 0 to 100% in 400 msec). The slope is therefore:

Example

The setpoint is suddenly changed from 32000 to 48000 ( $\Delta x_{\rm W}=$  16000) in a control loop with a ramp of W\_{\rm RAMP}=100.

$$K_{SWR} = \frac{64000}{W_{RAMB}} = \frac{64000}{100} = 640$$

$$W_{SWR} = \frac{\Delta X_W}{K_{SWR}} = \frac{16000}{640} = 25$$

After 25 scan cycles (2.5 sec), the setpoint has reached 48000 at the controller input.

All specifications refer to a 16 bit value. The maximum value is 64000. The controller is also able to process 10, 12 and 14 bit values however. These values are converted into 16 bit values by the controller internally.






# WORKING POINT. CONTROL SIGNAL LIMITS, CONTROL SIGNAL RAMP

PLC SYSTEMS
PID LOOP CONTROL

### **WORKING POINT (BIAS)**

The working point (AP) represents the dividing line between the positive and negative signals with a time proportional controller. These two signals can be used for heating or cooling a system for example.




Later in this chapter (section Clock Signal), we show that the ON/OFF ratio of the signal and therefore the precision of the controller is partially determined by the position of the working point.

### CONTROL SIGNAL LIMITS (MV\_HI, MV\_LO)


Upper and lower limit values can be set if the control signal y should only be allowed to lie within certain limits.

 $\begin{array}{lll} \mathbf{y}_{_{\text{HI}}} & \dots & \text{Upper Control Signal Limit} \\ \mathbf{y}_{_{\text{LO}}} & \dots & \text{Lower Control Signal Limit} \end{array}$ 



### CONTROL SIGNAL RAMP dy/dt (VEL)

In order to protect the actual controlled path from sudden changes, the control signal can be limited with a ramp. This kind of dynamic slope limit is required in some applications (e.g.: if a pressure valve shouldn't be opened suddenly).



Dy defines the maximum change in control signal per scan (100 msec).

### Example

The controller has calculated a control signal jump from 35000 to 48000. The maximum control signal change per scan cycle is  $\Delta y = 900$ .

$$\frac{50000 - 35000}{\Delta y} = \frac{15000}{900} = 16.67 = 16.75$$

$$\frac{900 \cdot 2}{3} = 600$$

The control signal takes 16 scan cycles to change to the maximum value Dy = 900. During the 17th scan cycle, the control signal changes from 600 to 50000. This means that after 1.7 seconds the calculated control signal is achieved.

### TIME PROPORTIONAL CONTROL

PLC SYSTEMS PID LOOP CONTROL







# TIME PROPORTIONAL CONTROL (TP+, TPmin+, TP-, TPmin-)

The controller creates either a position signal or a negative signal (T+ or T-) depending on the control signal. The positive and negative signals are separated by the working point AP:


0 % - AP ... Negative Signal AP - 100 % ... Positive Signal



The signal is created as a sawtooth signal with periodical times  $t_{_{\rm P+}}$  (positive range) or  $t_{_{\rm P-}}$  (negative range) in either of the two ranges. The slope of the sawtooth determines the ON/OFF ratio of the signal. The slope is defined by the periodic time and the position of the working point. When control signal y remains constant in the positive range, the signal looks like this:




The following two diagrams provide an insight into the generation of the negative sawtooth signal:



The periodic time  $t_{p_*}$  or  $t_{p_*}$  is based on the scan time  $t_{AB}$  (100 msec). The value defines the number of scan cycles after which the signals are restarted (e.g.  $t_{p_*}$  = 100 corresponds to a periodic time of 10 sec).

### RESTRICTING THE SIGNAL

In order to avoid unwanted sharp switching edges in the signal, limit values can be defined  $(t_{p_{\text{MIN}}}, \text{or}\ t_{p_{\text{MIN}}}).$  The switch on and switch off times of the signal which are smaller than the defined limit values are suppressed. This applies to control signals with little deviation from the working point as well as values approaching 0 % or 100 %. The limit value is also based on the scan time  $t_{_{AB}},$  i.e. the defined value corresponds with the multiple of the scan time (e.g.  $t_{p_{\text{MIN}}}$ = 4 corresponds to a limit value in the negative range of 400 msec).



The limit value can be maximum 25 % of the periodic time.






# STEP SIGNAL, SYSTEM CONFIGURATIONS

PLC SYSTEMS
PID LOOP CONTROL

### STEP SIGNAL (TS, TSmin)

Control signal y of the PID controller lies in the range from 0 to 64000, i.e. the total step time  $t_{\rm s}$  is divided into 64000 steps.




$$\Delta t = \frac{t_s}{64000} \cdot \Delta y$$

- ... Time required for the entire step width (total step time)
- $\Delta t$  ... Response time in respect to  $\Delta y$
- $\Delta y \dots$  Control signal change

The step direction is determined by the sign for the control signal change.

Total step time  $t_{_{\rm S}}$  is entered as a multiple of the scan time  $t_{_{\rm AB}}$  (100 msec) (e.g.  $t_{_{\rm S}}$  = 200 corresponds to a total step time of 20 sec). e.g.: The flow through a pipe being regulated by a step controller.



The stepper requires time  $t_{\rm S}$  for the total step width $\Delta x_{\rm MAX}$ . The motor is controlled for time  $\Delta t$  in order to change  $\Delta y$  the control signal by the respective step width  $\Delta x$ .

Any possible flaws in precision which could be caused by play in a bearing for example, are suppressed by single step corrections when reaching the end position or zero coordinate.

### LIMITATION

In order to avoid switching the motor on and off too often, a limit value  $t_{_{SMIN}}$  can be defined. The step controller only starts after the defined time  $t_{_{SMIN}}$  (corresponds with control signal change  $e\Delta y_{_{MIN}}$ ). Limit value  $t_{_{SMIN}}$  is only allowed to be maximum 25 % of the total step time  $t_{_{c}}$ .

### **SYSTEM CONFIGURATIONS**

Two different control systems have been developed because of the requirement of having to operate in different system combinations:

- CP/PLC System
- PP/PLC System

These systems describe the environment (hardware on which the algorithm is running) and the user interface (operation via ladder diagram).

### **CP/PLC SYSTEM**

This system enables the installation of up to 16 PID loop controllers on a CPU with all special functions.

FBK Name	Description	To be installed on
LCCL.MSL LICL.MSL LECL.MSL LPCL.MSL	Configuration Block I/O Block Ext I/O Block Parameter Block	CP CP CP CP
LSCP.MSL	Selector Block for CP System	СР
LPAR.TAB	Parameter table	CP

#### PP/PLC SYSTEM

This system enables the installation of up to 255 PID controllers with all special functions. This requires the respective number of peripheral processors (32 PID control loop per PP), to process the PID algorithms. Operation is via logic.

	FBK Name		Description	To be installed on	'n,
	LCPL.MSL		Configuration Block	CP	
	LIPL.MSL		I/O Block	CP	
	LEPL.MSL		Ext I/O Block	CP	
Я	LPPL.MSL		Parameter Block	CP	
	LSPP.MSL		Selector Block for PP System	CP	
	LPAR.TAB		Parameter Table	CP	
	LPAD.TAB		PP Address Table	CP	
	LAPP_P60.PRG		PID Algorithm	PP60	

### **SOFTWARE COMPONENTS**

PLC SYSTEMS
PID LOOP CONTROL





### **ABBREVIATIONS**

The abbreviations used in the system names have the following meanings:

CP ... The algorithm runs in a CPU PP ... The algorithm runs in a PP


PLC ... Operated with ladder diagram

The PID loop controller software can be run on all peripheral processors and CPUs. We recommend however, that you use a peripheral processor as the controlling processor since the PID software requires its own memory area and cycle time.

### **DESCRIPTION OF SOFTWARE COMPONENTS**

The function blocks above are arranged according to the type of control system used. Each of these function blocks can be identified and assigned by its name:

### LCCL.XXX



### **Exceptions**

LAPP\_P60.PRG PP algorithm (required with a PP/PLC system and runs on a PP)

LPAR.TAB PID parameter table (contains default parameters for a PID controller - is

required with all systems)

LPAD.TAB PP address table (contains default address data - required with a PP/PLC

system)

LSCP.MSL CP selector (required for selector control with a CP/PLC system)

LSPP.MSL PP selector (required for selector control with a PP/PLC system)

### **SOFTWARE COMPONENTS**

Standard software package 3 "PID CONTROLLER" contains the following:

	LAPP_P60	PRG	PID Algorithm for PP60 (32 controllers)	0
	, of 1,		, of 100	
	LCCL	FBK	PID Controller Configuration for CP/PLC	
	LCPC	FBK	PID Controller Configuration for PP/PCS	
2,	LCPL	FBK	PID Controller Configuration for PP/PLC	
	LECL	FBK	PID Controller Extended I/O for CP/PLC	
	LEPC	FBK	PID Controller Extended I/O for PP/PCS	
	LEPL	FBK	PID Controller Extended I/O for PP/PLC (PP60)	
	LICL	FBK	PID Controller Input/Output for CP/PLC	
	LIPC	FBK	PID Controller Input/Output for PP/PCS	
	LIPL	FBK	PID Controller Input/Output for PP/PLC (PP60)	
	LPCL	FBK	PID Controller Configuration for CP/PLC	
4	LPPL	FBK	PID Controller Configuration for PP/PLC (PP60)	
	LSCP	FBK	PID Controller Selector Block for CP	
	LSPP	FBK	PID Controller Selector Block for PP (PP60)	
		2		
	LPAD	TAB	PP Address Table	
	LPAR	TAB	Parameter Table	
		The -		



A9

# PLC SYSTEMS PID LOOP CONTROL

VISUALIZATION

SYSTEM SELECTION

OPERATOR PANEL VISUALIZATION

SEMIGRAPHIC VISUALIZATION



FULL GRAPHIC VISUALIZATION



B

# **CONTENTS**

VISUALIZATION

# **CONTENTS**

### VISUALIZATION





CONTENTS  OPERATOR PANEL OVERVIEW PROVIT TERMINAL OVERVIEW OPERATOR PANEL WITH INTEGRATED INDUSTRIAL COMPUTER PROVIT INDUSTRIAL WORKSTATION OVERVIEW  B2 OPERATOR PANEL VISUALIZATION  CONTENTS GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BROWN TO SEMIGRAPHIC VISUALIZATION  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT INDUSTRIAL TERMINALS PROVIT INDUSTRIAL TERMINALS AT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION  THE SPECTO_S EDITOR THE SPECTO_S EDITOR THE SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  THE SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION	20
PROVIT TERMINAL OVERVIEW.  OPERATOR PANEL WITH INTEGRATED INDUSTRIAL COMPUTER PROVIT INDUSTRIAL WORKSTATION OVERVIEW  CONTENTS  GENERAL INFORMATION.  MINICONTROL OPERATOR PANELS  OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS  BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS  GENERAL INFORMATION.  PROVIT INDUSTRIAL TERMINALS  XT OPERATOR PANELS  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL  BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE  GENERAL INFORMATION  THE SPECTO_S EDITOR  THE SPECTO_S CONFIGURATION  THE SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  THE SPECTO_S CONFIGURATION	21
PROVIT TERMINAL OVERVIEW  OPERATOR PANEL WITH INTEGRATED INDUSTRIAL COMPUTER  PROVIT INDUSTRIAL WORKSTATION OVERVIEW  B2 OPERATOR PANEL VISUALIZATION  CONTENTS  GENERAL INFORMATION  MINICONTROL OPERATOR PANELS  OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS  BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS)  BRRT564 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS  CONTENTS  SEMIGRAPHIC VISUALIZATION  CONTENTS  PROVIT INDUSTRIAL TERMINALS  XT OPERATOR PANELS  PROVIT 100 - SEMIGRAPHIC INDUSTRIAL TERMINAL  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL  BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE  GENERAL INFORMATION  THE SPECTO_S EDITOR  THE SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION  SPECTO_S CONFIGURATION	
OPERATOR PANEL WITH INTEGRATED INDUSTRIAL COMPUTER PROVIT INDUSTRIAL WORKSTATION OVERVIEW  B2 OPERATOR PANEL VISUALIZATION  CONTENTS. GENERAL INFORMATION. MINICONTROL OPERATOR PANELS. OPERATOR PANELS FOR ALL PLC SYSTEMS.  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS. BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS). BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS).  BRATEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS).  CONTENTS. GENERAL INFORMATION. PROVIT INDUSTRIAL TERMINALS. XT OPERATOR PANELS.  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR.  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO. S EDITOR. THE SPECTO. S CONFIGURATION.	
B2 OPERATOR PANEL VISUALIZATION  CONTENTS. GENERAL INFORMATION. MINICONTROL OPERATOR PANELS. OPERATOR PANELS FOR ALL PLC SYSTEMS.  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS. BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS). BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS).  BROWLE SEMIGRAPHIC VISUALIZATION  CONTENTS. GENERAL INFORMATION. PROVIT INDUSTRIAL TERMINALS. XT OPERATOR PANELS.  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR.  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	22
B2 OPERATOR PANEL VISUALIZATION  CONTENTS GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRT1645 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BROWN CONTENTS GENERAL INFORMATION  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO S EDITOR THE SPECTO S EDITOR THE SPECTO S CONFIGURATION	
CONTENTS GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 1000 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	22
CONTENTS GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 1000 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	
CONTENTS GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	"Ac.,
GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRATEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 100 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	Q, ,
GENERAL INFORMATION MINICONTROL OPERATOR PANELS OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRATEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 100 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	22
OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS  BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS  GENERAL INFORMATION  PROVIT INDUSTRIAL TERMINALS  XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS  PROVIT INDUSTRIAL TERMINALS  PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL  BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE  GENERAL INFORMATION  THE SPECTO_S EDITOR  THE SPECTO_S CONFIGURATION	
OPERATOR PANELS FOR ALL PLC SYSTEMS  BRRTM3, BRRTM4 - MINICONTROL OPERATOR PANELS BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT INDUSTRIAL TERMINALS PROVIT O0 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	22
BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  B3 SEMIGRAPHIC VISUALIZATION  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 1000 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S CONFIGURATION	
BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS) BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  B3 SEMIGRAPHIC VISUALIZATION  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 100 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S CONFIGURATION	2:
BRRTEL45 - EL DISPLAY (20 LINES x 80 CHARACTERS)  B3 SEMIGRAPHIC VISUALIZATION  CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	
B3 SEMIGRAPHIC VISUALIZATION  CONTENTS	
CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	
CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	
CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	
CONTENTS GENERAL INFORMATION PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	1900
GENERAL INFORMATION	20,
PROVIT INDUSTRIAL TERMINALS XT OPERATOR PANELS  PROVIT INDUSTRIAL TERMINALS PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	23
XT OPERATOR PANELS	23
PROVIT INDUSTRIAL TERMINALS PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	23
PROVIT INDUSTRIAL TERMINALS PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE GENERAL INFORMATION THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	23
PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL	
PROVIT 600 - SEMIGRAPHIC INDUSTRIAL TERMINAL	
PROVIT 700 - SEMIGRAPHIC INDUSTRIAL TERMINAL WITH EL MONITOR  XT OPERATOR PANEL  BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE  GENERAL INFORMATION  THE SPECTO_S EDITOR  THE SPECTO_S RUNTIME SYSTEM  SPECTO_S CONFIGURATION	
XT OPERATOR PANEL	
BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE	.87
BRXTGR31 / BRXTGR35 - SEMIGRAPHIC OPERATOR PANEL  SPECTO_S VISUALIZATION SOFTWARE	2:
GENERAL INFORMATION  THE SPECTO_S EDITOR  THE SPECTO_S RUNTIME SYSTEM  SPECTO_S CONFIGURATION	
GENERAL INFORMATION  THE SPECTO_S EDITOR  THE SPECTO_S RUNTIME SYSTEM  SPECTO_S CONFIGURATION	25
THE SPECTO_S EDITOR THE SPECTO_S RUNTIME SYSTEM SPECTO_S CONFIGURATION	
THE SPECTO_S RUNTIME SYSTEMSPECTO_S CONFIGURATION	
SPECTO_S CONFIGURATION	
B4 FULL GRAPHIC VISUALIZATION	
B4 FULL GRAPHIC VISUALIZATION	
B4 FULL GRAPHIC VISUALIZATION	
	20,
CONTENTS	24
PROVIT 800 - INDUSTRIAL MONITOR	
MGC1 - FULL GRAPHIC CONTROLLER	
PROVIT 1345 / PROVIT 1800 - INDUSTRIAL WORKSTATIONS	د



**B** 1

### CONTENTS

VISUALIZATION SYSTEM SELECTION

VISUALIZATION SYSTEM SELECTION

**B**1




B1	SYSTEM SELECTION			
	CONTENTS	n,	nn.	216
	OPERATOR PANEL OVERVIEW	A		218
	PROVIT TERMINAL OVERVIEW			220
	OPERATOR PANEL WITH INTEGRATED II	NDUSTRIAL COMPUTER OVE	RVIEW	
	DDOVIT INDUCTDIAL MODIFETATION OV	LD//IL/V		000



#### OPERATOR PANELS, BRRTM3, BRRTM4

VISUALIZATION SYSTEM SELECTION




#### OPERATOR PANELS, BRRT360, BRRTEL45

VISUALIZATION SYSTEM SELECTION










# PROVIT TERMINALS, PROVIT 600

VISUALIZATION SYSTEM SELECTION



### PROVIT TERMINALS, PROVIT 700, PROVIT 800


VISUALIZATION SYSTEM SELECTION












## **PROVIT 800**

		PROVIT700-0			PROVIT800-1	
	. Klorič	Semigraphic Display Electroluminescence, Monochrome 20 x 80 640 x 200 Pixel			Full Graphic Monitor 12" VGA Color CRT, 35 kHz - 800 x 600 Pixel	
		42 30 12			42 30 12	
		RS232			RGB, RS232	
	B&R MAESTR	O Co-Processor (MCO1, MCO3 and Standard Interface Modules	мсозмс),		B&R MAESTRO Graphic Controller (MGC1)	Paritolit.
		SPECTO_S, Standard Function Blocks			SPECTO_S, C-Graphics Library	
		482.6 mm (19 in.) 310.4 mm 150 mm 448 mm 263 mm			482.6 mm (19 in.) 310.4 mm 400 mm 448 mm 263 mm	
		approx. 7 kg			approx. 17 kg	
		IP54			IP54	
	(	allow Installation Depth, Low Weight, High Contrast, Self Lit Display, Connection for External Keyboard, ey Switch, Insertable Legend Strips		7.87 M.S.	High End Visualization in Connection with 3&R MAESTRO Graphics Controller (MGC1), Connection for External Keyboard, Key Switch, Insertable Legend Strips	



### OPERATOR PANEL, BRXTGR31, BRXTGR35

VISUALIZATION SYSTEM SELECTION





## **BRXTGR35**

Model Number	BRXTGR31-0	BRXTGR35-0
Description	Semigraphic Operator Panel with OS-9 Operating System	Semigraphic Operator Panel with OS-9 Operating System
Display Type Lines x Characters	Semigraphic Display LCD, Monochrome 16 x 26	Semigraphic Display LCD, Monochrome 16 x 26
Keys Total with LED without LED	31 19 12	35 23 12
Communication Serial Interfaces Network Connection	2 x RS232 / 2 x TTY / RS485 ARCNET	2 x RS232 / 2 x TTY / RS485 ARCNET
CPU Frequency Math Co-Processor	68000 / 64 KByte SRAM 12.5 MHz -	68000 / 64 KByte SRAM 12.5 MHz -
Main Memory	2 MByte DRAM	2 MByte DRAM
Application Memory	1 MByte Internal FlashPROM	1 MByte Internal FlashPROM
Control Software	SPECTO_S	SPECTO_S
Digital Inputs / Outputs	4 Inputs (24 VDC), 1 Relay Output (24 VDC)	4 Inputs (24 VDC), 1 Relay Outputs (24 VDC)
Measurements Width Height Depth Cutout Width Cutout Height	320 mm 170 mm 58.3 mm 303 mm 143 mm	220 mm 320 mm 71.5 mm 183 mm 300 mm
Weight	approx. 1.8 kg	approx. 1.8 kg
Protection	IP54	IP54
Remarks, Special Features	SPECTO_S Visualization Unit, Integrated Industrial Computer	SPECTO_S Visualization Unit, Integrated Industrial Computer


### PROVITINDUSTRIAL WORKSTATIONS, PROVIT 1345, PROVIT 1830

VISUALIZATION SYSTEM SELECTION









## PROVIT 1345

## **PROVIT 1830**

Model Number	See Section B4 for Sets	See Section B4 for Sets
Description	Industrial Workstation, OS-9 Operating System, Three Processors for Communication, Visualization and Application Software	Industrial Workstation, OS-9 Operating System, Three Processors for Communication, Visualization and Application Software
Display Type Resolution Control	Full Graphic Display, Monochrome with 16 Shades of Grey Electroluminescence 640 x 400 Pixel Internal Visualization Proc. (68000 / 12.5 MHz / 512 KByte DRAM)	Full Graphic Color Display, 256 Colors TFT 640 x 480 Pixel Internal Visualization Proc. (68000 / 12.5 MHz / 512 KByte DRAM)
Keys Total with LED without LED	51 34 17	65 53 12
Communication Serial Interfaces Network Connection	Internal Communication Proc. (68000 / 12.5 MHz / 512 KByte DRAM) 4 x RS232 / TTY / RS485 ARCNET	Internal Communication Proc. (68000 / 12.5 MHz / 512 KByte DRAM 4 x RS232 / TTY / RS485 ARCNET
Other Connections	Keyboard Interface (AT compatible)	Keyboard Interface (AT compatible) Connection for External RGB Monitor
CPU Frequency Math Co-Processor	68000 / 512 KByte SRAM 12.5 MHz 68881	68030 / 0.5 MByte SRAM / with MMU 33 MHz 68882
Main Memory	2 MByte DRAM	10 MByte DRAM
Application Memory	1 Slot for 1 MByte FlashPROM	1 MByte Internal FlashPROM 2 Slots for 1 MByte FlashPROM
PCMCIA Interface		Ethernet LanCard, SRAM Cards or FlashPROM Cards
Hard Disk	4, 4	At Least 120 MByte
Floppy Disk	3.5" / 1.44 MByte	3.5" / 1.44 MByte
Digital Inputs / Outputs	4 Inputs (24 VDC), 2 Relay Outputs ( 220 VAC)	4 Inputs (24 VDC), 2 Relay Outputs (220 VAC)
Measurements Width Height Depth Cutout Width Cutout Height	280 mm 370 mm 120 mm 260 mm 350 mm	482.6 mm (19 in.) 310.4 mm 189 mm 442 mm 282 mm
Weight	approx. 5.5 kg	approx. 10.5 kg
Protection	IP54	IP54
Remarks, Special Features	Excellent Graphics Characteristics, Shallow Installation Depth, Low Weigh, Switch Keyboard from Front	Sharp, High Contrast CRT, Very Good Color Quality, Absolutely Film Free



#### CONTENTS

VISUALIZATION
OPERATOR PANEL VISUALIZATION

VISUALIZATION
OPERATOR PANEL VISUALIZATION

**B2** 



#### **B2 OPERATOR PANEL VISUALIZATION**

CONTENTS	(0)	224
GENERAL INFORMATION	7/2	226
MINICONTROL OPERATOR PANELS	4,	226
OPERATOR PANELS FOR ALL PLC SYSTEMS		226
BRRTM3. BRRTM4 - MINICONTROL OPERATOR PANELS		227
BRRT360 - FLUORESCENT DISPLAY (2 LINES x 16 CHARACTERS	(3)	228
	, 20	



## GENERAL INFORMATION, OVERVIEW

VISUALIZATION
OPERATOR PANEL VISUALIZATION

#### **GENERAL INFORMATION**

Operator friendly control systems with exact diagnosis possibilities are standard requirements today in almost all areas of industrial automation. B&R Operator Panels provide an inexpensive solution for Man/Machine Interface (MMI). B&R Operator panels are the logical addition to the MINICONTROL and MULTICONTROL PLC families.

All B&R Operator Panels are compact, robust and IP54 protected on the front, that means they are protected against dust and sprayed water. Keys with built-in LEDs that are software controlled are available for all B&R Operator Panels.

The displays are available with single line, 16 character displays up to EL displays with 20 lines x 80 characters. All displays are easy to read from almost all angles, also in poor lighting. The control is carried out via serial interfaces (TTY, RS232, RS485). Standard function blocks are used for the software operation (Standard Software Package SWSPSSTD02-0).

Fundamentally, B&R Operator Panels can be separated into two groups:

- MINICONTROL Operator Panels
- Operator Panels for all PLC Systems

#### MINICONTROL OPERATOR PANELS

The following Operator Panels are available for the MINICONTROL system:

	BRRTM3	BRRTM4	
Display	79×	183	
Type	Fluorescent	Fluorescent	
Lines x Characters	1 x 16	1 x 16	
Character Size	5 mm	13 mm	
Keys	24	24	
with LEDs	12	12	
Measurements			
Width	195 mm	249 mm	
Height	175 mm	223 mm	
Depth	35 mm	45 mm	

#### **OPERATOR PANELS FOR ALL PLC SYSTEMS**

The following Operator Panels can be operated with all B&R PLCs:


	BRRT360	BRRTEL45	
Display			
Type	Fluorescent	Electroluminescent	
Lines x Characters	2 x 16	20 x 80	
Character Size	5 mm	"JK0.	
Keys	36	45	
with LEDs	24	31	
Measurements			
Width	170 mm	280 mm	
Height	250 mm	370 mm	
Depth	80 mm	100 mm	

## BRRTM3, BRRTM4, MINICONTROL OPERATOR PANELS

VISUALIZATION OPERATOR PANEL VISUALIZATION







#### BRRTM3, BRRTM4

- Compact Design
- Shallow Installation Depth
- Easy to Read Display
- 24 Keys, 12 of which with Key LEDs

#### ORDER DATA

MINICONTROL Operator Panel, 16 Character Fluorescent Display, 24 Keys, 12 Key LEDS, IP54 Protection, incl. Mylar Front, without Interface Module, without Cable

Character Size 5 mm
Character Size 13 mm

PATA Interface Module for MINICONTROL Operator Panels

MCPATA-0
PATA Connection Cable - Operator Panel

BRKA08-0
BRKA08-0

#### DISPLAY

Self lit fluorescent vacuum display, 16 characters, alphanumeric.




#### **MEASUREMENTS**

Size	BRRTM3	BRRTM4
Width	195 mm	249 mm
Height	175 mm	223 mm
Depth	35 mm	45 mm
Cutout Width	165 mm	208 mm
Cutout Height	160 mm	209 mm
Weight	0.45 kg	0.75 kg

#### **KEYBOARD**

MINICONTROL Operator Panels are equipped with 24 keys (12 function keys, number block).



The 12 function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic strips that can be slid in from the side under the keyboard mylar.

#### INTERFACES / CONTROL

In order to control the MINICONTROL Operator Panels BRRTM3 and BRRTM4, a connection cable, the PATA interface module or the compact control is required (see Order Information).


#### SOFTWARE

Operator panel function blocks are used for the software operation. They are included in the Standard Software Package 2, Model No. SWSPSSTD02-0 (see Section A7 "PLC Programming").



#### BRRT360, FLUORESCENT DISPLAY, 2 LINES x 16 CHARACTERS

VISUALIZATION
OPERATOR PANEL VISUALIZATION



#### BRRT360

- Compact Design
- 2 Line Self Lit Fluorescent Display (2 x 16 characters)
- 36 Keys, 24 with Key LEDs
- Software Operates with Standard Function Blocks

#### ORDER DATA

BRRT360 Operator Panel, 2 Line Self Lit Fluorescent Display
(2 x 16 characters), 36 Keys, IP54 Protection, incl. Mylar Front,
without Cable

without Power Supply
with Power Supply
BRRT360-0
BRRT360-1

#### DISPLAY

2 line self lit fluorescent vacuum display (2 x 16 characters):




#### **MEASUREMENTS**

Size	BRRT360-0	BRRT360-1
Width	170 mm	170 mm
Height	250 mm	250 mm
Depth	80 mm	80 mm
Cutout Width	140 mm	140 mm
Cutout Height	221 mm	221 mm
Weight	approx. 1.2 kg	approx. 1.4 kg
9	(9)	(~)

#### KEYBOARD

The BRRT360 Operator Panel is equipped with 36 Keys (24 function keys, number block).



The 24 function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic strips that can be slid in from the side under the keyboard mylar.

#### INTERFACES / CONTROL

The BRRT360 Operator Panel functions via a serial TTY interface. The control from the PLC is carried out with an interface module or with a peripheral processor:

	Rack / PLC System		
Module(s)	MULTI, MIDI	M264	MINICONTROL
PIF3, PIF1-0		•	
PP60	Tho. •		
PIFA-0, CP32			
NTCP63, NTCP64, PSCP65		•0/	

#### SOFTWARE


Operator panel function blocks are used for the software operation. They are included in the Standard Software Package 2, Model No. SWSPSSTD02-0 (see Section A7 "PLC Programming").

## BRRTEL45, EL DISPLAY, 20 LINES x 80 CHARACTERS

VISUALIZATION OPERATOR PANEL VISUALIZATION








#### ORDER DATA

BRRTEL45 Operator Panel, Self Lit EL Display, 20 Lines x 80 Columns, 45 Keys, IP54 Protection, RS232 Interface, incl. Mylar Front, without Cable

BRRTEL45-0

#### DISPLAY

EL Display, 20 Lines x 80 Columns, Semigraphic:



#### MEASUREMENTS


Size	BRRTEL45	
Width	280 mm	
Height	370 mm	
Depth	100 mm	
Cutout Width	260 mm	
Cutout Height	350 mm	
Weight	approx. 4.4 kg	

#### **BRRTEL45**

- High Contrast EL Display (self lit)
- Good Semigraphic Characteristics with Graphic Elements (e.g. Graph, Bar Diagram etc.)
- 45 Keys, 31 with Key LEDs
- Software operation functions via a B&R MAESTRO Co-Processor with SPECTO\_S visualization software

#### **KEYBOARD**

The BRRTEL45 Operator Panel has 45 keys (33 function keys, number block).



The 31 function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic strips that can be slid in from the side under the keyboard mylar.

#### INTERFACES / CONTROL

The BRRTEL45 Operator Panel functions via a serial RS232 interface. The control from the PLC is carried out with an RS232 interface module or with a B&R MAESTRO Co-Processor (MCO1).

#### SOFTWARE

The BRRTEL45 Operator Panel is conceived as a SPECTO\_S visualizations device. It is software compatible to the PROVIT 700 Industrial Terminal. One of two standard solutions can be selected for the software operation:

SPECTO\_S The BRRTEL45 Operator Panel is controlled by a B&R MAESTRO Co-Processor (see Section B3

"Semigraphic Visualization").

PROVIT FBKs The BRRTEL45 Operator Panel is controlled by a PP60

peripheral processor. PROVIT function blocks are used for the software operation. They are included in the Standard Software Package 2, Model No. SWSPSSTD02-0 (see Section A7 "PLC Programming").



#### CONTENTS

VISUALIZATION SEMIGRAPHIC VISUALIZATION

VISUALIZATION SEMIGRAPHIC VISUALIZATION

**B3** 



Б3	SEIVIIGRAPHIC VISUALIZATION				
	CONTENTS		My	"HAT.	230
	GENERAL INFORMATION			<i>[</i>	232
	PROVIT INDUSTRIAL TERMINALS				232
	XT OPERATOR PANELS				232
	PROVIT INDUSTRIAL TERMINALS	- 10 m	1/22	162	233
	PROVIT 600 - SEMIGRAPHIC INDUS	STRIAL TERMINAL	60	S.	23
	PROVIT 700 - SEMIGRAPHIC INDUS	STRIAL TERMINAL W	/ITH EL MONITOR	70,	234
	XT OPERATOR PANEL		(0)	(O)	23
	BRXTGR31 / BRXTGR35 - SEMIGRA	APHIC OPERATOR P	ANEL	200	23
	SPECTO_S VISUALIZATION SOFTWAR	E			230
	GENERAL INFORMATION	Δ			236
	THE SPECTO S EDITOR				236
	THE SPECTO_S RUNTIME SYSTEM	1	162	Les.	23
	SPECTO_S CONFIGURATION	Δ.	.00		23



## GENERAL INFORMATION, OVERVIEW

VISUALIZATION
SEMIGRAPHIC VISUALIZATION

#### **GENERAL INFORMATION**

A clear designation between semigraphic and full graphic is not possible since e.g. the SPECTO\_S semigraphic visualization software can also be operated on full graphic devices (PROVIT 800 and PROVIT Industrial Workstation). Here is an overview of semigraphic and full graphic visualization devices and software:

 Section B3 Semigraphic Visualization	Section B4 Full Graphic Visualization	S.
 PROVIT Industrial Terminals PROVIT 600 PROVIT 700	PROVIT Industrial Monitor PROVIT 800	
	Graphic Controller	
XT Operator Panels	MGC1	
BRXTGR31		
BRXTGR35	PROVIT Industrial Workstations PROVIT 1345	
ASCII Keyboards for PROVIT Industrial	PROVIT 1830	
Terminals and PROVIT Industrial Monitors		
Software for PROVIT Industrial Terminals SPECTO_S	ALL DE	S. S.

#### **PROVIT INDUSTRIAL TERMINALS**

#### Overview:

	PROVIT 600	PROVIT 700	
CRT / Display	19×	197	
Type	CRT	EL Display	
Lines x Characters	24 x 80	20 x 80	
Color / Monochrome	Color	Monochrome	
Keys	42	42	
with LED	30	30	
Size			
Width	482.6 mm	482.6 mm	
Height	310.4 mm	310.4 mm	
Depth	370 mm	150 mm	
Weight	approx. 19 kg	approx. 7.2 kg	

#### **XT OPERATOR PANELS**

#### Overview:

	BRXTGR31	BRXTGR35	
Display			
Туре	LCD, Monochrome	LCD, Monochrome	
Lines x Characters	16 x 26	16 x 26	
Keys	31	35	
with LED	19	23	
Size			
Width	320 mm	220 mm	
Height	170 mm	320 mm	
Depth	58.3 mm	71.5 mm	
Weight	approx. 1.8 kg	approx. 1.8 kg	

#### PROVIT 600, 19" INDUSTRIAL TERMINAL, IP54

VISUALIZATION SEMIGRAPHIC VISUALIZATION







#### **PROVIT 600**

- Color Monitor
- Robust, Industrial Design
- Dust and Spray Water Protection (IP54)
- 42 Keys, 30 with Key LEDs
- Key Switch
- Connection for External Keyboard
- Software Operates with Standard Function Blocks or SPECTO\_S

#### **ORDER DATA**

Industrial Terminal with 12" Monitor and Built-in Keyboard, 42 Keys,
30 with Keys LED, Semigraphic, 24 Lines x 80 Characters, Front Protection IP54,
Key Switch, 19" Housing, Color CRT

PROVIT600-4

External ASCII Keyboard (shown below), IP40

External ASCII Keyboard (shown below), IP54

BRKEY02-0

#### **MEASUREMENTS**

Size	PROVIT 600	
Width	482.6 mm (19")	
Height	310,4 mm	
Depth	370 mm	
Cutout Width	448 mm	
Cutout Height	263 mm	
Weight	approx. 19 kg	10.7


#### EXTERNAL ASCII KEYBOARD

It makes sense to add an ASCII Keyboard to the PROVIT Industrial Terminals which is offered by B&R. They can also be delivered in IP54 Version (dust and spray water protection):



#### KEYBOARD

The PROVIT 600 has 42 keys (10 softkey function keys under the CRT, 20 function keys, number block).



The 10 softkey function keys and the 20 function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic strips that can be slid in from the side under the keyboard mylar.

#### INTERFACES / CONTROL

PROVIT Industrial Terminals function via an electrically isolated RS232 interface. The control from the PLC is carried out with a RS232 interface module or with a B&R MAESTRO Co-Processor (MCO1).

#### SOFTWARE

One of two standard solutions can be selected for the software operation:

SPECTO\_S The PROVIT Industrial Terminal is controlled by a B&R MAESTRO Co-Processor (see Section "SPECTO\_S").

PROVIT FBKs The PROVIT

The PROVIT Industrial Terminal is controlled by a PP60 peripheral processor. PROVIT function blocks are used for the software operation. They are included in the Standard Software Package 2, Model No. SWSPSSTD02-0 (see Section A7 "PLC Programming").



#### PROVIT 700, 19" INDUSTRIAL TERMINAL WITH EL MONITOR, IP54

VISUALIZATION
SEMIGRAPHIC VISUALIZATION



#### **PROVIT 700**

- Monochrome EL Display (yellow)
- Robust, industrial Design
- Shallow Installation Depth, Low Weight
- Dust and Spray Water Protection (IP54)
- 42 Keys, 30 with Key LEDs
- Key Switch
- Connection for External Keyboard
- Software Operates with Standard Function Blocks or SPECTO\_S

#### ORDER DATA


Industrial Terminal with EL Monitor and Built-in Keyboard, 42 Keys,
30 with Key LED, Semigraphic, 20 Lines x 80 Characters, Front Protection IP54,
Key Switch, 19" Housing

External ASCII Keyboard (shown below), IP40
External ASCII Keyboard (shown below), IP54

BRKEY01-0
BRKEY02-0

### KEYBOARD

The PROVIT 700 has 42 keys (10 softkey function keys under the CRT, 20 function keys, number block).



The 10 softkey function keys and the 20 function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic strips that can be slid in from the side under the keyboard mylar.

#### **MEASUREMENTS**

Size		PROVIT 700	40.
Width Height Depth		482.6 mm (19") 310.4 mm 150 mm	
Cutout Width Cutout Height		448 mm 263 mm	M.
Weight	9	approx. 7.2 kg	

#### EXTERNAL ASCII KEYBOARD

It makes sense to add an ASCII Keyboard to the PROVIT Industrial Terminals which is offered by B&R. They can also be delivered in IP54 Version (dust and spray water protection):



#### INTERFACES / CONTROL

PROVIT Industrial Terminals function via an electrically isolated RS232 interface. The control from the PLC is carried out with a RS232 interface module or with a B&R MAESTRO Co-Processor (MCO1).

#### SOFTWARE

One of two standard solutions can be selected for the software operation:

SPECTO\_S The PROVIT Industrial Terminal is controlled by a B&R MAESTRO Co-Processor (see Section "SPECTO\_S").

PROVIT FBKs

The PROVIT Industrial Terminal is controlled by a PP60 peripheral processor. PROVIT function blocks are used for the software operation. They are included in the Standard Software Package 2, Model No. SWSPSSTD02-0 (see Section A7 "PLC Programming").

#### BRXTGR31, BRXTGR35, SEMIGRAPHIC OPERATOR PANEL, IP54

VISUALIZATION SEMIGRAPHIC VISUALIZATION









BRXTGR35

BRXTGR31

#### **BRXTGR31, BRXTGR35**

- CFL LCD Display
- Compact Design
- Shallow Installation Depth, Low Weight
- Dust and Spray Water Protection (IP54)
- BRXTGR31: 31 Keys, 19 with Key LEDs BRXTGR35: 35 Keys, 23 with Key LEDs
- Software Operates with SPECTO\_S

#### ORDER DATA

Semigraphic Operator Panel, OS-9 Operating System, 68000 Processor, Back Lit CFL LCD Display, 16 Lines x 26 Columns, Protection IP54 (front), TTY, RS232/RS485, RS232/TTY and ARCNET interface (twisted pair and coax connection), includes Stick-on Mylar Front, Labeling Strips and Mounting Stencil, without Interface Cable


31 Keys, 19 with Key LEDs 35 Keys, 23 with Key LEDs	BRXTGR31-0 BRXTGR35-0
oo noyo, zo marnoy LLDo	DICKTOROUT

#### **MEASUREMENTS**

Size	BRXTGR31	BRXTGR35
Width	320 mm	220 mm
Height	170 mm	320 mm
Depth	58.3 mm	71.5 mm
Cutout Width	303 mm 183 mm	
Cutout Height	143 mm	300 mm
Weight	approx. 1.8 kg	approx. 1.8 kg

#### **KEYBOARD**

Keys	BRXTGR31	BRXTGR35	
Total	31	35	
with LED	19	23	
without LED	12	12	
Function Keys	19	23	
Number Block	12	12	



The function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic strips that can be slid under the

TECHNICAL DATA	BRXTGR31 BRXTGR35	
Description	Semigraphic Operator Panel, Multitasking OS-9 Operating System,	
Display Type Design Lines x Characters	Semigraphic Monochrome, 16 Shades of Grey LCD 16 x 26	Semigraphic yMonochrome, 16 Shades of Grey LCD 16 x 26
Keys Total with LED	31 19	35 23
Communication Serial Interfaces Protocol Implemented Network Connection		x TTY / RS485 NEC L1, S3964 (R) ARCNET
Main Processor Frequency Co-Processor Working Memory	68000 12.5 MHz - 64 KByte SRAM	68000 12.5 MHz - 64 KByte SRAM
Main Memory	2 MByte DRAM	2 MByte DRAM
Application Memory	1 MByte Intern	nal FlashPROM
Digital Inputs	4 (24 VDC)	4 (24 VDC)
Digital Outputs	1 (Relay, 24 VDC)	1 (Relay, 24 VDC)
Weight	approx. 1.8 kg	approx. 1.8 kg
Protection	IP54	IP54

#### **INTERFACES**

Interface	Remarks
TTY	not electrically isolated
RS232/RS485	RS232 not electrically isolated / RS485 electrically isolated
RS232/TTY	not electrically isolated
ARCNET	coax connection
ARCNET	twisted pair connection

#### SOFTWARE

The software operation is carried out with the semigraphic visualization package SPECTO\_S (see Section "SPECTO\_S").

#### SETUP TOOL

The Setup Tool (SWMXTP-0) is a user environment for the XT Operator Panels It supports the user in the following ways:

- Installation of SPECTO S
- Creating and Testing the Visualization
- Inserting Optional Files
- Changing the Start-up Parameters
- Managing Files (copying, erasing, ...)
  Possible Entry into the OS-9 Shell



### SPECTO\_S

## VISUALIZATION SEMIGRAPHIC VISUALIZATION

#### **GENERAL INFORMATION**

SPECTO\_S is a user friendly software package for machine and plant visualization. The SPECTO\_S software runs on a B&R MAESTRO Co-Processor (MCO1, MCO3, MCO3MC), a PROVIT Industrial Workstation or an XT Operator Panel

If a B&R MAESTRO Co-Processor is used, the visualization device is controlled via a serial RS232 interface. The following visualization devices can be used:

Device	Туре	Description	70,0
BRRTEL45	Operator Panel	EL Display (monochrome)	
PROVIT 600	Industrial Terminal	12" Color Monitor	
PROVIT 700	Industrial Terminal	EL Display (monochrome)	

A PROVIT Industrial Workstation or an XT Operator Panel is a combination of industrial computer and visualization device. Data acquisition is performed via serial interface(s) and/or network(s).


_	Device	Туре	Description
	PROVIT 1345	Industrial Workstation	Monochrome Graphic Display (EL) without Hard Disk
	PROVIT 1830	Industrial Workstation	Color Graphic Display (TFT) with Hard Disk
	BRXTGR31	XT Operator Panel	CFL LCD Display, 16 Lines x 26 Columns, 31 Keys
	BRXTGR35	XT Operator Panel	CFL LCD Display, 16 Lines x 26 Columns, 35 Keys

The SPECTO\_S software package consists of:

- An editor for the creation of process pictures
- A runtime system for process picture animation

#### THE SPECTO\_S EDITOR

Creation or editing of process pictures can be done simply with mouse or keyboard using windows techniques and "pulldown" menus. A status line and operating references give information for selected operating modes and attributes




Up to 255 fields for input or output of numeric values, text or bar graphs can be defined and selected in a process picture. The size of process pictures can be freely defined. Thus, several process pictures can be displayed at the same time

Also the definition of function keys is menu controlled. Even though SPECTO\_S is designed for semigraphic terminals, customer specific symbols such as valves, switches, motors, company logos etc. can be created simply by redefining unused characters.

For documentation purposes, a hard copy of the actual screen contents can be printed by pressing a key. Processed pictures can be saved to a diskette, hard disk, RAM disk, EPROM or FlashPROM.

#### THE SPECTO S RUNTIME SYSTEM

The pictures (max. 255) which were created with the SPECTO\_S editor, are combined in a module assigned to the process and animated with the SPECTO\_S runtime system.



B&R MAESTRO Co-Processors, PROVIT Industrial Workstations and XT Operator Panels work with the OS-9 multitasking operating system. This enables the execution of different programs (tasks) parallel to SPECTO\_S visualization, e.g. data acquisition via networks.

A strong point of SPECTO\_S is its ability to adapt to the complexity of the application. SPECTO\_S adapts to any application starting with low cost visualization with a PROVIT Industrial Terminal or Operator Panel up to complex multi user systems with PROVIT Industrial Workstations.

### SPECTO\_S

## VISUALIZATION SEMIGRAPHIC VISUALIZATION

# **B3**



#### **SPECTO S CONFIGURATION**

There is a wide variety of possible combinations for SPECTO\_S with B&R MAESTRO and PLC components. Some useful standard configurations for the most current applications are listed in the following section.

- SPECTO\_S in B&R MAESTRO Systems
- SPECTO\_S in PLC Systems with B&R MAESTRO Co-Processor
- SPECTO\_S Combined with Full Graphics
- SPECTO S with PROVIT Industrial Workstation
- SPECTO\_S with XT Operating Panels

If none of these systems are applicable, contact B&R for more information.

#### I. SPECTO\_S IN B&R MAESTRO SYSTEMS

This configuration is useful if your application requires a B&R MAESTRO system. The SPECTO\_S software runs on a B&R MAESTRO Co-Processor. Even though SPECTO\_S software and the process pictures can be stored on the FlashPROM or on a RAM disk, a hard disk is recommended for the development system. The B&R MAESTRO system must be provided with at least 1 MByte RAM (memory expansion module MM8M with 1 MByte RAM is required for MCO1).

The pictures can be created with the keyboard, but a mouse can be used to make creation easier (Microsoft serial mouse or compatible type and RS232 mouse adapter cable, Model No. BRKAMAS-0).

SPECTO\_S is delivered as a set. Please give the model number when ordering (far right column).

	Component	Development Kit (German)	<b>Model Number</b>
S	SWMSPOS-0	SPECTO_S Semigraphic Software (incl. editor)	SWMSPO:SD
S	SWMSPOIMG-0	SPOIMG Process Data Server (incl. library)	
S	SWMDRV-BR	SPOIMG Driver Software (incl. B&R MININET and Net2000)	
N	MASPOIMG-0	SPOIMG - Process Image Manager User's Manual, German	
N	MASPOS-0	SPECTO_S User' Manual, German	

The SPECTO\_S software is delivered on a 3.5" diskette. It is to be installed on the hard disk. Process pictures are also stored on the hard disk. If a hard disk is not available, the SPECTO\_S Software can be stored on a FlashPROM Module and the process pictures remain in the RAM of the B&R MAESTRO Co-Processor.

The following components are required or recommended for a B&R MAESTRO system:

	Designation		Model No.	
9		RO System (rack, RO Co-Processor, Hard Disk)	- 1	
S. J.	if MCO1:	Memory Expansion Module MM8M RAM Expansion 1 MByte	HCMM8M-1 / HCMM8M-3 HCRA1024-0	
	SPECTO_S	Software	SWMSPO:SD	
	PROVIT Indu	strial Terminal or Operator Panel	PROVIT600-4, PROVIT700-0, BRRTEL45-0	
	External ASC	CII Keyboard IP40 / IP54	BRKEY01-0 / BRKEY02-0	
	Connection (	Cable MCOx - PROVIT / Operator Panel	BRKAPC-4	
	Microsoft Ser	rial Mouse or Compatible		
V18	RS232 Mous	e Adapter Cable	BRKAMAS-0	

The B&R MAESTRO Co-Processor provides two serial RS232 interfaces. One of these interfaces is required to control the terminal or operator panel. During picture editing, the second interface is usually used for the mouse. In the runtime operation, the second interface is mostly used to control a report printer or another terminal.

#### II. SPECTO\_S IN PLC SYSTEMS WITH B&R MAESTRO CO-PROCESSOR

An MCO1 Co-Processor is usually used for SPECTO\_S applications (68000 Processor / 12.5 MHz). The MCO1 Co-Processor can be operated in all P slots in the MULTICONTROL PLC System. Slot Overview:

Rack	Model No.	Slot for MCO1
MULTI	ECR165-0 HCR166-0, HCR169-0	\$0 to \$F \$2 to \$F
MIDI	MDR085-1	\$0 to \$7
M264	M2R111-0	\$0 to \$4

A mouse is recommended to create the process pictures (Microsoft serial mouse or compatible type and RS232 mouse adapter cable, Model No. BRKAMAS-0).

SPECTO\_S is delivered as a set (Model No. see "I. SPECTO\_S in B&R MAESTRO Systems").

The following components are required or recommended for a MCO1 system:

	Designation	Model No.
(0)	MULTICONTROL PLC System	. 30,
	SPECTO_S Software	SWMSPO:SD
	PROVIT Industrial Terminal or Operator Panel	PROVIT600-4, PROVIT700-0, BRRTEL45-0
	External ASCII Keyboard IP40 / IP54	BRKEY01-0 / BRKEY02-0
	Connection Cable MCO1 - PROVIT / Operator Panel	BRKAPC-4
	Microsoft serial mouse or compatible	- 20
	RS232 Mouse Adapter Cable	BRKAMAS-0

The MCO1 Co-Processor reads the process visualization data from the PLC CPU or from external devices. It provides two serial RS232 interfaces. One of these interfaces is required to control the terminal or operator panel. During the creation of process pictures, the second interface is mostly used for the mouse. In runtime operation, the second interface is mostly used to control are port printer or another terminal.

#### III. SPECTO\_S COMBINED WITH GRAPHIC ELEMENTS

In some application it may be necessary to combine SPECTO\_S process pictures with full graphic elements. In order to do this, a B&R MAESTRO Graphics Controller (see Section B4 "Full Graphic Visualization" and D2 "Industrial Computer Components") and a PROVIT Industrial Monitor (see Section B4 "Full Graphic Visualization") are required. The size of SPECTO\_S process pictures can be freely defined. The rest of the screen can be loaded with other graphics elements with simple C functions.

If SPECTO\_S is operated in a B&R MAESTRO system, the graphics controller (MCG1) can be operated in a free B&R MAESTRO slot.

In a PLC system without a B&R MAESTRO (SPECTO\_S on B&R MAESTRO Co-Processor), MCO1 has to be able to access graphics controller. This is only the case if:

- A B&R MAESTRO rack is used
- MCO1 and graphics controller are operated on a B&R MAESTRO slot



### SPECTO\_S

## VISUALIZATION SEMIGRAPHIC VISUALIZATION

#### IV. SPECTO\_S IN PROVIT INDUSTRIAL WORKSTATIONS

The PROVIT Industrial Workstations is a combination of an industrial computer and a visualization device in one unit (see Section B4 "Full Graphic Visualization").

Device	Model No.	Description
PROVIT 1345	Sets (see Section B4)	monochrome EL Display, without Hard Disk
PROVIT 1830	Sets (see Section B4)	Color Display (TFT), with Hard Disk

SPECTO\_S software and process pictures are stored on the hard disk of the PROVIT 1830. The PROVIT 1345 is not provided with a hard disk. In this case, a FlashPROM module with the SPECTO\_S software is installed. The process pictures are stored in the RAM or in the FlashPROM.

The advantage of using a PROVIT Industrial Workstations is the large number of communication possibilities. Both devices are equipped with four RS232 interfaces. The following standard protocols can be implemented:

- B&R MININET
- B&R NET2000
- SINEC L1
- S3964 (R) (RK512)

Additionally, the PROVIT Industrial Workstations provide an ARCNET network connection

The interfaces applied are defined in a SPECTO\_S configuration menu. This enables the creation of a process picture with display values using different PLC system data (also other manufacturers). The PROVIT Industrial Workstation can exchange data with B&R MAESTRO systems or other workstations via the ARCNET network.

#### V. SPECTO\_S WITH XT OPERATOR PANEL

An XT Operator Panel is a combination of an industrial computer and a visualization device in one unit (see Section B4 "Semigraphic Visualization").

Model No.	Description	
BRXTGR31-0 BRXTGR35-0	Back Lit CFL LCD Display, 16 Lines 26 Columns, 31 Keys, IP54 Back Lit CFL LCD Display, 16 Lines x 26 Columns, 35 Keys, IP54	

XT Operator Panels are equipped with a 1 MByte FlashPROM. The FlashPROM is divided into four banks. The SPECTO\_S software is stored in one of these banks (256 KByte). Two banks (512 KByte) are provided for the user. The process pictures are stored in these banks.

The advantage of using an XT Operator Panel is the large number of communication possibilities. Both devices are equipped with two serial RS232 interfaces. The following standard protocols can be implemented:

- B&R MININET
- B&R NET2000
- SINEC L1
- S3964 (R) (RK512)

Additionally, the XT Operator Panels provide an ARCNET network connection.


The interfaces applied are defined in a SPECTO\_S configuration menu. This enables the creation of a process picture with display values using different PLC system data (also other manufacturers). XT Operator Panels can exchange data with B&R MAESTRO systems or other XT Operator Panels via the ARCNET network.

VISUALIZATION SEMIGRAPHIC VISUALIZATION

**B3** 



NOTES:





#### CONTENTS

VISUALIZATION FULL GRAPHIC VISUALIZATION

VISUALIZATION FULL GRAPHIC VISUALIZATION **B4** 



#### **B4** FULL GRAPHIC VISUALIZATION


CONTENTS	A	240
PROVIT 800 - INDUSTRIAL MONITOR	a×	242
MGC1 - FULL GRAPHIC CONTROLLER	d <sup>r</sup>	242
PROVIT 1345 / PROVIT 1800 - INDUSTRIAL W	VORKSTATIONS	243





## PROVIT 800 INDUSTRIAL MONITOR, MGC1 GRAPHICS CONTROLLER

VISUALIZATION
FULL GRAPHIC VISUALIZATION





#### ORDER DATA

Graphics Controller for Controlling PROVIT 800 Industrial Monitors,
16 Colors, Resolution 800 x 600 Pixels, Bandwidth 36 MHz, Line Frequency 35 kHz,
Analog RGB Output, 2 Serial Interfaces for Keyboard and Mouse,
Interface for AT Keyboard

HCMGC1-0

#### ORDER DATA

Industrial Monitor with Color Monitor and Built-in Keyboard, Line Frequency max. 35 kHz, Resolution 800 x 600 Pixels, Analog RGB Input, Controlled with B&R MAESTRO Graphics Controller MGC1, 42 Keys, 30 with Key LEDs, Front Protection IP54, Key Switch, 19" Housing

 12" VGA Color CRT, 35 kHz
 PROVIT800-1

 External ASCII Keyboard (not shown), IP40
 BRKEY01-0

 External ASCII Keyboard (not shown), IP54
 BRKEY02-0

#### **MEASUREMENTS**

Size	PROVIT 800	
Width	482.6 mm (19")	24
Height	310.4 mm	
Depth	400 mm	
Cutout Width	448 mm	
Cutout Height	263 mm	
Weight	approx. 17 kg	

#### TECHNICAL DATA

Monitor

Monitor Control	
Output Signal	RGB pos. analog (1 V)
Bandwidth (Pixel Frequency)	36 MHz
Line Frequency	35 kHz
Picture Frequency	56 Hz
Resolution	800 x 600 Pixel
Sync-Signal	pos. TTL
10,0	10
Interfaces	

Keyboard Mouse	1 x serial (RS232), 1 x AT compatible 1 x serial (RS232)	
Speed		
e.g. Line	approx. 330 nsec / Pixel	
e.g. Circle	approx. 875 nsec / Pixel	
Colors	16	

RGB (PGA-Standard)

#### KEYBOARD

The PROVIT Industrial Monitor has 42 keys (10 softkey function keys under the screen, 20 function keys, number block). The 10 softkey function keys and the 20 function keys are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic legend strips that are slid in from the top or side under the keypad mylar.

#### INTERFACES / CONTROL

The PROVIT Industrial Monitor provides a serial RS232 interface for a keyboard in addition to the analog RGB inputs. The control from the PLC is carried out with the B&R MAESTRO Graphics Controller MGC1.

#### SOFTWARE

The visualization software package SPECTO\_S can also be used in connection with the PROVIT 800 Industrial Monitor. In this way, SPECTO\_S process pictures can supplemented with full graphic elements (see Section B3 "Semigraphic Visualization / SPECTO\_S"). The PROVIT 800 is programmed with C functions.

## PROVIT 1345, PROVIT 1830, INDUSTRIAL WORKSTATIONS

## VISUALIZATION FULL GRAPHIC VISUALIZATION

**B4** 





PROVIT 1830



PROVIT 1345

#### **MEASUREMENTS**

Size	PROVIT 1345	PROVIT 1830
Width	280 mm	482.6 mm (19")
Height	370 mm	310.4 mm
Depth	120 mm	189 mm
Cutout Width	260 mm	442 mm
Cutout Height	350 mm	282 mm
Weight	approx. 5.5 kg	approx. 10.5 kg

#### KEYBOARD

The function keys for the PROVIT Industrial Workstation are equipped with LEDs that can be software controlled. Labeling the function keys is done with plastic legend strips that are slid in from the top or side under the keypad mylar.

#### INTERFACES / CONTROL

PROVIT Industrial Workstations are provided with four serial RS232/TTY/RS485 interfaces and an ARCNET network connection (coax / 2.5 MBaud). B&R protocols and protocols from other manufacturers are standardly implemented for the serial interfaces (B&R MININET, SINEC L1 and S 3964). In this way data from other systems can be swapped via the OS-9 driver with a simple Read/Write command.

TECHNICAL DATA	PROVIT 1345	PROVIT 1830
Description	Industrial Workstation, OS-9 Mu Three 680x0 Processors for Applica and Visual	ation Software, Communication
Display Type Design Resolution	Full Graphic Monochrome, 16 shades of grey EL 640 x 400 Pixel	Full Graphic Color TFT 640 x 480 Pixel
Visualization Processor Frequency Working Memory	68000 12.5 MHz 512 KByte DRAM	68000 12.5 MHz 512 KByte DRAM
Keys Total with LED	51 34	65 53
Communication Processor Frequency Working Memory	68000 12.5 MHz 512 KByte DRAM	68000 12.5 MHz 512 KByte DRAM
Communication Serial Interfaces Impl. Protocols Network Connection Keyboard Interface	4 x RS232/TTY/RS485 B&R MININET, B&R NET2000, S ARCNET AT compatible	4 x RS232/TTY/RS485 SINEC L1, S3964 (R) (RK512) ARCNET AT compatible
CPU Frequency Co-Processor Working Memory	68000 12.5 MHz 68881 512 KByte SRAM	68030 33 MHz 68882 512 KByte SRAM
Main Memory	2 MByte DRAM	10 MByte DRAM
Memory Expansion	2 slots for FlashPROM	modules (1 MByte)
Hard Disk	-	at least 120 MByte
Floppy Disk	3.5" / 1.44 MByte	3.5" / 1.44 MByte
PCMCIA Interface	190	YES
Digital Inputs	4 (24 VDC)	4 (24 VDC)
Digital Outputs	2 (Relay, 220 VAC)	2 (Relay, 220 VAC)
Protection	IP54	IP54

#### ORDER DATA

Component

The PROVIT Industrial Workstations are delivered as a set. Three sets are available for each PROVIT Industrial Workstation:

- OEM System
- Development Kit, German

OEM System

- Development Kit, English

Please use the model number when ordering (far right column).

#### **PROVIT Industrial Workstation PROVIT 1345**

MP1345-1A SWMMP00-0	MPROVIT 68000 12.5 MHz, 512 KByte SRAM, FPU 68881 2 MByte DRAM, OS-9 MPROVIT 68000 System Software Diskette (driver and library)	MPROVIT:1345AX
Component	Development Kit (German)	Model Number
MP1345-1A	MPROVIT 68000 12.5 MHz, 512 KByte SRAM, FPU 68881 2 MByte DRAM, OS-9	MPROVIT:1345UD
HCSYSC-TK SWMMP00-0 SWMAN-0	OS-9/Tool Kit, including ANSI C Compiler and Source Debugger MPROVIT 68000 System Software Diskette (driver and library) ARCNET Network Software, OS-9/Net	
SWMCG-0 MAMSYS-0 MAMPRV-0	Graphic Software (driver and library) B&R MAESTRO System Manual, German B&R MAESTRO Workstation Manual, German	
MAMNET-0 MAMGRC-0	B&R MAESTRO Network Manual, German Graphics Controller Manual, German	

Component	Development Kit (English)	Model Number
MP1345-1A	MPROVIT 68000 12.5 MHz, 512 KByte SRAM, FPU 68881 2 MByte DRAM, OS-9	MPROVIT:1345UE
HCSYSC-TK	OS-9/Tool Kit, including ANSI C Compiler and Source Debugger	
SWMMP00-0	MPROVIT 68000 System Software Diskette (driver and library)	
SWMAN-0	ARCNET Network Software, OS-9/Net	
SWMCG-0	Graphic Software (driver and library)	
MAMAESTRO-E	B&R MAESTRO Industrial Computer Manual, English	
MAMPRV-E	B&R MAESTRO Workstation Manual, English	
MAMNET-E	B&R MAESTRO Network Manual, English	
MAMGRC-E	Graphic Controller Manual, English	

Component	Industrial Workstation Memory Expansion	Model Number
HCFP1024-0R	MPROVIT Insertable Memory 1 MByte FlashPROM	HCFP1024-0R
MAMSP-0	Memory Expansion Module User's Manual, German	MAMSP-0
MAMSP-E	Memory Expansion Module User's Manual, English	MAMSP-E

Model Number



# PROVIT 1345, PROVIT 1830, INDUSTRIAL WORKSTATIONS

VISUALIZATION
FULL GRAPHIC VISUALIZATION

#### **PROVIT Industrial Workstation PROVIT 1830**

Component	OEM System	Model Number
MP1830-1A	MPROVIT 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882	MPROVIT:1830AX
	10 MByte DRAM 32 Bit, PCMCIA IF, 1 MByte FPROM, OS-9	
SWMMP30-0	MPROVIT 68030 System Software Diskette (driver and library)	

Component	Development Kit (German)	Mode Number
MP1830-1A	MPROVIT 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882 10 MByte DRAM 32 Bit, PCMCIA IF, 1 MByte FPROM, OS-9	MPROVIT:1830UD
HCSYSC-TK	OS-9/Tool Kit, including ANSI C Compiler and Source Debugger	
SWMMP30-0	MPROVIT 68030 System Software Diskette (driver and library)	
SWMAN-0	ARCNET Network Software, OS-9/Net	
SWMCG-0	Graphic Software (driver and library)	
MAMSYS-0	B&R MAESTRO System Manual, German	
MAMPRV-0	B&R MAESTRO Workstation Manual, German	
MAMNET-0	B&R MAESTRO Network Manual, German	
MAMGRC-0	Graphics Controller Manual, German	

Component	Development Kit (English)	Model Number
MP1830-1A	MPROVIT 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882	MPROVIT:1830UE
	10 MByte DRAM 32 Bit, PCMCIA IF, 1 MByte FPROM, OS-9	
HCSYSC-TK	OS-9/Tool Kit, including ANSI C Compiler and Source Debugger	
SWMMP30-0	MPROVIT 68030 System Software Diskette (driver and library)	
SWMAN-0	ARCNET Network Software, OS-9/Net	
SWMCG-0	Graphic Software (driver and library)	
MAMAESTRO-E	B&R MAESTRO Industrial Computer Manual, English	
MAMPRV-E	B&R MAESTRO Workstation Manual, English	
MAMNET-E	B&R MAESTRO Network Manual, English	
MAMGRC-E	Graphics Controller Manual, English	

Component	Industrial Workstation Memory Expansion	Model Number
HCFP1024-0R	MPROVIT Insertable Memory 1 MByte FlashPROM	HCFP1024-0R
MAMSP-0	Memory Expansion Module User's Manual, German	MAMSP-0
MAMSP-E	Memory Expansion Module User's Manual, English	MAMSP-E

### INDUSTRIAL NETWORKS AND COMMUNICATION





CVCTEAA	SELECTION
SISILIVI	SELECTION

1



ETHERNET

2



ARCNET

3



CAN BUS

4



**B&R MININET** 

5



OTHER PROTOCOLS

6







#### INDUSTRIAL NETWORKS AND COMMUNICATION

C1	SYSTEM SELEC	TION	<sup>7</sup> ,0,	"41.CO.	(4) (O)	
	CONTENTS	N <sub>L</sub>				246
		IATION				
	OLIVLINAL IIVI ONIVI	A11011				200
	LOCAL AREA NETV	VORKS				250
		T AND HISTORY				
		N METHODS				
		IODS				
		N MEDIA				
		EFERENCE MODEL				
		TION				
	FIELD BUS					252
	IEEE 802.3 - CS	MA/CD BUS - ETHERNET .				253
	IEEE 802.4 -TO	KEN-BUS	70,,			253
	IEEE 802.5 -TO	KEN-RING				253
	COMPARISON	AND SELECTION CRITERIA	۹		,	254
		ECTION CRITERIA				
	COMPARISON	OF NETWORKING METHO	DS			255
	FORECAST	·				255
	OVERVIEW OF	B&R NETWORKS				256
	15.	16. J	16.,		15.	160.
C2	ETHERNET					
<u> </u>	.0	*60,	*0{,	* C	Klir.	*O(),
	CONTENTS	- A				258
		IATION				
	CABLE TOPOLOGY	Y AND PROJECT PLANNIN	G			260
		THERNET				
		HERNET (CHEAPERNET)				
		(0)				
	MENC - NETWORK	CONTROLLER	-7 <sub>60</sub>		-74.	261
	ETHERNET / SINEC	C-H1			S	
		PRIORITIES				
		NECTIONS				
	ETHERNET ADI	DRESS	4			
	<b>OPERATION WI</b>	ITH THE SINEC H1 LIBRAR	RY			263
	JOBS					263
	SINGLE JOB DE	ESCRIPTION				264
	MULTICASTING	÷				265
	CONNECTION	OVERVIEW				266
	COMMUNICATI	ON ESTABLISHMENT EXAM	MPLE		<u> </u>	266
		NET				
	FASTNET AND	THE ISO REFERENCE MOD	DEL			267
	FASTNET PROT	TOCOL				267
		)ata				
	FASTNET OPER	RATION				267
	The					
		RNET				
		ACKGROUND				
		E ISO REFERENCE MODE				
		NSFER PROTOCOL				
		<u> </u>				
		T LIBRARY				
	C FUNCTIONS	OF THE SOCKET LIBRARY				269





#### INDUSTRIAL NETWORKS AND COMMUNICATION

	ARCNET				
	Tu, Tu,		74	Tr.	The state of the s
	CONTENTS				
	GENERAL INFORMATION				272
	CABLE, TOPOLOGY AND PLANNIN	10 JAP			07/
	ARCNET WITH COAXIAL CABL				
	ARCNET WITH TWISTED PAIR				212
	MARC - NETWORK CONTROLLER				272
	ARCNET INTERFACE MODULE				
	ARCNET SOFTWARE				
	AUGUET COL TWATE		14		270
C4	CAN BUS	16.	150	. No	
<u> </u>	CAR BOO				
	CONTENTS				274
	GENERAL INFORMATION				
	CAN BUS CHARACTERISTICS				
	B&R AND CAN				
	BUS LENGTH AND CABLE TYPES			- B	276
	B&R PLC SYSTEMS				
	EXS5 - CAN INTERFACE MODULE				277
	<u> </u>	200			200
C5	B&R MININET				
	100	'90,	1900	'95,	190
					278
	CONTENTS				
	GENERAL INFORMATION		72.		280
	GENERAL INFORMATIONCABLE AND TOPOLOGY				280 280
	GENERAL INFORMATION				280 280 280
	GENERAL INFORMATION				
	GENERAL INFORMATION				
	GENERAL INFORMATION				
	GENERAL INFORMATION				
C6	GENERAL INFORMATION				
C6	GENERAL INFORMATION				
C6	GENERAL INFORMATION	, (CS) (CS) (CS) (CS) (CS) (CS) (CS) (CS)			
C6	GENERAL INFORMATION				
C6	GENERAL INFORMATION	MAESTRO SYSTEMS			
C6	OTHER PROTOCOLS  CONTENTS  CONTENTS	MAESTRO SYSTEMS			
C6	CABLE AND TOPOLOGY	MAESTRO SYSTEMS			
C6	CABLE AND TOPOLOGY  CONNECTION TO B&R MININET  B&R MININET-SOFTWARE  ORDER DATA  OTHER PROTOCOLS  CONTENTS  GENERAL INFORMATION  OTHER PROTOCOLS WITH B&R M.  NP02 - COMMUNICATION PROCES  STANDARD SOFTWARE PACKAGI  STANDARD SOFTWARE PACKAGI	MAESTRO SYSTEMS SSOR			280 280 281 282 282 282 284 286 286 287 287
C6	CABLE AND TOPOLOGY  CONNECTION TO B&R MININET  B&R MININET-SOFTWARE  ORDER DATA  OTHER PROTOCOLS  CONTENTS  GENERAL INFORMATION  OTHER PROTOCOLS WITH B&R M.  NP02 - COMMUNICATION PROCES  STANDARD SOFTWARE PACKAGI	MAESTRO SYSTEMS SSORES			
C6	CABLE AND TOPOLOGY  CONNECTION TO B&R MININET  B&R MININET-SOFTWARE  ORDER DATA  OTHER PROTOCOLS  CONTENTS  GENERAL INFORMATION  OTHER PROTOCOLS WITH B&R M.  NP02 - COMMUNICATION PROCES  STANDARD SOFTWARE PACKAGI  STANDARD SOFTWARE PACKAGI	MAESTRO SYSTEMS SSORES			



INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION

# C1



## INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION

CT	SYSTEM SELECTION	No.	W.	No.	
	CONTENITO				244
	CONTENTS				248
	GENERAL INFORMATION				250
	LOCAL AREA NETWORKS				250
	<b>DEVELOPMENT AND HISTORY</b>				25
	TOPOLOGIES		<u> </u>		250
	TRANSMISSION METHODS				25′
	ACCESS METHODS				25
	TRANSMISSION MEDIA	UQ.X	U Ø X		25′
	THE ISO-OSI REFERENCE MOD				
	STANDARDIZATION		~~~		250
	FIELD BUS				
	IEEE 802.3 - CSMA/CD BUS - ET				
	IEEE 802.4 - TOKEN-BUS	ILEKINE I			25.
	IEEE 802.5 - TOKEN-RING		····		23
	FDDI				
	COMPARISON AND SELECTION	I CRITERIA			254
	GENERAL SELECTION CRITERI	A			254
	COMPARISON OF NETWORKIN				
	FORECAST				255
	OVEDVIEW OF DOD METWORK	C			050





## LOCAL AREA NETWORKS, DEVELOPMENT AND HISTORICAL BACKGROUND

INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION

#### **GENERAL INFORMATION**

The networks that are described in this section belong in the category of "Local Area Networks" (abbreviation LAN). To get more acquainted with the ideas behind LAN, here is a short introduction.


#### **LOCAL AREA NETWORKS**

#### **DEVELOPMENT AND HISTORY**

Since the breakthrough into semiconductor technology which enabled the integration of the computing power where it was needed, decentralization has been spreading ever faster through the computing world. The disadvantages of large centralized computers were obvious: A failure in one main central computer can cause a major loss of time (entire complexes or departments ground to a halt) and money. The introduction of backup computers or other similar measures wasn't enough to provide a steady economical answer. After the initial semi-successful decentralization boom, the computer industry was soon hit with a new reality. Previously, nobody had given much thought to peripheral devices such as mass storage facilities, printers, etc. These were simply grouped around the central computer and were available for everybody. Decentralizing meant that every station required its own peripherals. Data transfer was also limited to the physical exchange of diskettes or tapes. Decentralization had produced uneconomical and isolated computer islands. Special offers for linking certain types of computers could not hide the fact that the so called solution was limited to a single manufacturer's products.

This communication deficit inspired the research and development of new concepts of data transfer. It became clear that only a universal concept without reliance on any single manufacturer could satisfy the consumer's needs - a classic task for the standardization committee. Since then, several networking concepts have attained this standard and several more are being developed. At the same time, the future must be considered. Prerequisites concerning long range networks (Metropolitan Area Network - MAN), for instance, are being carefully considered, thereby assuring the orderly development of communication technology.


The possibility of localized data transfer is not entirely new; computers were designed to permit random copying, moving and rearrangement of data. The following illustration indicates the various possible ranges.



A wide variety of buses and I/O interfaces are utilized in the range of less than 100 m. At this level, casual linking of network nodes is impossible because of the restrictions involved; limited number of nodes (often only point-to-point connections), limited communication range, and strict user procedures. These limitations have arisen from the original range of tasks for which networks were designed. Long distance communication is still dominated by the reliance on public networks with their long range and data channeling capabilities. These capabilities make it possible to bridge any distance, but normally only with pointto-point connections and limited data transfer rates. In addition most of these connections must be requested manually by dialling the desired location. Both methods of communication cover the mid-local range but are unable to meet many of the requirements for local data transfer: high speed data transfer, direct access to all connected points (without dialling), or extensions reaching the km range. The missing links in communication have now been filled in by the Local Area Network (LAN). This also makes it clear that the differences between data communication and telecommunication are becoming smaller and smaller

#### **TOPOLOGIES**

The following diagram shows different application structures for LANs.



The bus topology which is known from computer technology belongs to the group of multi-connections, since each participant is directly connected to all others. Each participant can communicate with any other without any rerouting. If a participant crashes, the others can carry on normally as long as the crashed participant doesn't cause a blockade. If this happens, it causes a total collapse of the network. This can be avoided with just a few technical precautions however. The only major disadvantage is that when two participants are communicating, all others have to wait. Blockades can be avoided by setting limits on the transfer times. A disturbance on the bus cable will cause an interruption on the network however, and only sometimes can the remaining part of the network carry on working.

The star is another type of network configuration. The star belongs to the point to point connection group whereas each participant is connected only with the central node. The central node is connected to all others if the network is an active star network where the signal is processed and sent on to its destination. This network uses the same principle as any telephone system. The central node is normally an intelligent participant that has the responsibility of transferring information to the connected stations and sometimes has to amplify signals in the process. All transmissions must be made through the central node which means that if the central node crashes, the entire network goes down. If one of the outer participants crashes, it only means that the central node doesn't communicate with that network branch. Simple central nodes are blocked during communication between two participants while more advanced systems are equipped with more channels and allow a respective amount of simultaneous transmission.

The third configuration is the ring. The ring topology can also be put into the point to point connection class. The main characteristic of the ring is that each participant in the network is connected to the two neighboring nodes. This brings about several different consequences. One is that several data transfers can occur at the same time as long as the transmissions do not cross over each other. Another consequence is that a partner in the network which is not a direct neighbor can be reached through the participants between the two. This basically means that all stations lying between the communicating pair are blocked and must take part in establishing the communication between the two. If one of the participants drops out, the network is interrupted. This can be compensated for however. The separated neighbors can still establish a communication line with the others. Another alternative is that the dead participant can be bridged leaving the rest of the ring intact.

In practice, these topologies are often mixed in order to achieve an advantageous combination. This is different in almost every situation.

## TRANSMISSION MEDIA AND TECHNIQUES ACCESS METHODS


## INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION





#### TRANSMISSION METHODS

The following diagram shows three different methods that are normally seen in networking.



So-called "Manchester Coding" uses a logical 1 for a positive signal change and a logical 0 for a negative signal change. This type of coding has the advantage of having a DC voltage of 0 on the cable during normal operation. Operational disturbances can be detected through any deviation of this DC value. Since every bit causes a signal change, a clock pulse can be generated for the receiver. This coding can be found in ethernet networks for example; it is also called "Base Band Transmission".

Frequency Shift Keying (FSK) normally uses two frequencies for sending logical values, i.e. processing is done by means of frequency shift keys. There are two different types of FSK; "phase coherent" and "phase4 continuous". The difference is mainly that "phase continuous" operates with any frequency ratio and with "phase continuous", any integer can be processed. To guarantee smooth transitions - i.e. no phase jumps - a VCO (Voltage Controlled Oscillator) is used for "phase continuous" FSK. If whole numbers are sufficient for the frequency ratios, then only a simple quartz oscillator and a digital frequency splitter are required. A comparator must then ensure that the frequencies are shifted when 0 is passed. This makes the "phase coherent" method less expensive than the "phase continuous" FSK.

The NRZI technique works according to the principle that a signal always changes if the next character is a 1. If the receiver can also use the signal pulse, a certain number of zeros and ones must be inserted ("Bitstuffing").

#### **ACCESS METHODS**

Carrier Sense, Multiple Access with Collision Detection (CSMA/CD) describes a method of access which is very similar to a round of discussion between several participants with equal rights. Each monitors the network and waits with his contribution until an pause in the conversation occurs (carrier sense). When a pause in the conversation is detected, the participant that wants access may address any other participant directly (multiple access) and then send a message to the respective participant. Naturally, more than one transmission request can be made at the same time and it is possible that more than one also receive permission to send at the same time. This causes a collision which because of the scrambled data is recognized by all participants (collision detection) and therefore doesn't cause any problems.

The fascinating thing about this technique of accessing is that there is no master, each participant has equal rights. If the maximum length of the message is limited and the load quota is not completely exhausted, all traffic is controlled by itself in a way. A small disadvantage is, that with an increasing load the chance of a collision increases. This does not cause a data loss but substantially increases the response times. Generally no response times are guaranteed with this procedure. On the other hand, a high degree of flexibility can be achieved since there is no list of priority participants made and reconfigurations are not required. Anyone connected in the group can immediately take part in data exchange.

With the **Token Passing** technique, a token or access authorization is passed from node to node. Any participant that has the token and wishes to communicate keeps it and contacts the node to which the data should be sent. There is a time limit for this procedure after which the token must be passed on. All other participants in the group monitor the situation, are aware of the time limits and can predetermine when the token will become available again if they know the station number. Response times (collision free even under heavy loads) are predetermined only through a great deal of calculation. If only a few participants are transmitting information they must take the token, check whether they are addressed and pass it on. Every time a station is connected or disconnected, the distributor (scheduler) must be recreated. Token passing can be utilized in bus topologies, where the token is only logically passed on, and in ring topologies, where the token is actually passed from participant to participant around the ring.

With **Polling**, a master and several slaves are implemented. The master determines when the slaves may transmit by addressing them. Different levels of priority can be set. This method is rather risky because a defect in the master renders the entire network inoperable.

Slotted Time Division, Multiple Access (STDMA) requires strict time scheduled linking, because each node is assigned a set time slot in which it has the right to transmit information. During this time it has access to all other nodes. A disadvantage can be strict synchronization. Response times are guaranteed but if there is not a lot of traffic, time is wasted.

#### TRANSMISSION MEDIA

The least expensive form of data transmission is through twisted pair cable. This medium has been tested over kilometers such as with telephone communication. However it has low resistance to interference and where high frequency transmission is required is not reliable. Therefore this medium is only suitable for large networks in some cases, but at short distances with limited transmission rates it is an inexpensive alternative. Much better results can be achieved with coaxial cable. Coaxial cable has a defined surge impedance, is shielded, and has a reasonably good signal-to-noise ratio. Distances of up to several kilometers can be easily bridged. These positive characteristics, however, must be paid for, particularly since special coaxial cable, which is very solid and well shielded, is often used for networks. This also makes it very rigid.

Fiber optic cable is very promising, although not yet widely used. It combines most of the positive characteristics, such as broad bandwidth, high interference resistance, flexibility, and the ability to bridge long distances. This makes it, however, one of the most expensive options. Increased production in the future could bring prices down. At the moment a satisfying solution for optical terminal access points (Taps) is not attainable - in the simplest case a "T"-piece which only picks up a small percentage of the light energy - which makes it impossible to use bus topologies. Optical LANs are usually set up as active or passive star networks for this reason.

To be thorough, the fact that networks can be set up with electromagnetic waves should be mentioned. One type of network which is now widely used owes its existence to experiments with this medium. Work is still being done in this field. Error recognition and correction are especially important here; extremely bad signal-to-noise ratios must often be dealt with.





## THE ISO/OSI REFERENCE MODEL, STANDARDIZATION, FIELD BUS

INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION

#### THE ISO-OSI REFERENCE MODEL

When dealing with LANs, the term OSI reference model (open system interconnection) from the ISO (international organization for standardization) is often mentioned. What is meant is an ISO international standard (ISO IS 7498) which specifies the principal structure of communication devices. Such a station is divided into seven layers (seven layer architecture). While the user calls up the necessary services on the top layer (layer seven), the medium through which information is sent to or from the station is located at the lower end (below layer one).

The table below illustrates the seven layer structure and the tasks assigned to each layer:

	(%)	(%),"
LAYER 7	Application Layer	20
LAYER 6	Presentation Layer	
LAYER 5	Session Layer	3)
LAYER 4	Transport Layer	
LAYER 3	Network Layer	
LAYER 2	Data Link Layer	10,
LAYER 1	Physical Layer	70%


A simple, everyday example can be used to provide a short, precise illustration of how this functions. Two stations will be represented by two separate companies, and the transmission media (network) will be the post office. If a person in one company wants to send a letter to another company, he/she knows that the message must first be written on paper with a pen. This preliminary letter is given to a secretary who puts it in an envelope, writes an address on it and sends it to the post office. From there it reaches its final destination. The paper and pen correspond to level seven of the OSI model and represent the user interface. This is the only level that concerns the user but in order for the letter to reach the final destination many steps must be taken. The other steps are completed in the other OSI levels, completely unobserved by the user. The secretary first puts the letter into the proper form (coding) then seals it in an envelope, the sender and receiver are then indicated and the letter is deposited in the company mail. When the letter is picked up it is transferred to the company mail section where all mail is sorted into internal and external post (routing). In addition, someone might check whether the sender is authorized to use company stamps. Next in the chain the external mail is weighed, stamped and taken to the post office where the real transfer begins. At last the information is on the medium. In this simple example we can ignore the fact that the post office organization is also divided into various levels. When the letter reaches the receiving company this entire procedure is repeated more or less in reverse

No reference is made in this example to the structure of individual layers. Communication set-ups have also been arranged in this unstructured form in the past. As a result, communication between nodes of different companies was not possible. That is where ISO came into the picture with the OSI model and the accomplishments based on it. Not only has the structure been standardized, but a uniform procedure has also been agreed upon. ISO has published guidelines for each layer. Now nodes in different locations can communicate, and, what is more, a package of services (layers 3 and 4, for example) can be easily exchanged since all workers at this level complete the same tasks. This system has cleared the way for truly open communication.

In the layer model, layer 2 is often subdivided into 2a and 2b, or medium access control (MAC) and logical link control (LLC). Today layers 1 and 2a are usually hardware oriented (integrated circuits), while layers 2b to 7 are software. Components for layer 1 are usually called modems or transceivers, and those in layer 2a are controllers.

#### STANDARDIZATION

The following diagram classifies the most important LANs being standardized at the moment.



The largest amount of work is often done by specialized associations, and not by standardizing committees (such as ISO). Once the standard has been extensively developed, it is accepted by the ISO. In order to avoid doubling efforts, it has been agreed that the IEEE (Institution of Electrical and Electronic Engineers) is responsible for LANs in the range from 1 to 20 MBit/sec. The ISO has honored the work done and has accepted the IEEE 802.3ff standards into their own standards as ISO 8802. These IEEE 802.3ff standards regulate the structure of levels 1 and 2a of the ISO/OSI models.

IEEE 802.4 mainly defines a base band network, such as the one designed by three different manufacturers known as Ethernet. Access is achieved through CSMA/CD, and the bit rates are defined as 1 and 10 Mbits/sec. IEEE 802.4 specifies a token bus concept with different data rates and modulation methods, such as is favored for factory automation by an entire group of computer manufacturers at the present in the MAP project. The use of broad band cables is preferred, but the use of carrier band and fiber optic cables is also planned. IEEE 802.5 was developed by the largest computer manufacturer for linking this companies own computers. It regulates token ring data exchange.

The American National Standardization Institute (ANSI) is working on data networks at the upper end of the performance scale. This group is establishing a network with 100 Mbits/sec on the basis of FOL connections and token ring access. It is called "Fiber Distributed Data Interface" (FDDI).

Inexpensive networks are also in great need of standardization. These are summarized under the collective term "field bus".

#### **FIELD BUS**

Field bus is situated at the lower end of the performance scale and represents an economical network. It is mainly used for networking very simple and inexpensive stations, which consist of sensors, simple field equipment and modules. This type of network is used in close relation to processes which is also the reason that it is at the lowest level of the network hierarchy. The following table contains more field bus information.

### CSMA/CD BUS, TOKEN BUS, TOKEN RING

### INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION






#### Field Bus Information

Topology
Transmission Method
Data Rate
Coding
Access Method
Transmission Method
Transmission Method
Transmission Medium
Typical Distance Between Two Stations
Typical Number of Stations
Typical Number of Stations
Secure transmission in unfavorable environments
External Power Supply (Optional)
Has Its Own Data Security

### IEEE 802.3 - CSMA/CD BUS - ETHERNET


Networks which have been standardized according to the Institute of Electrical Electronics Engineers (IEEE), enjoy a certain amount of publicity. In the early 80s, a group of three American businesses got together with the target of developing an open network for office communication. The three firms involved were DEC as the computer manufacturer, Xerox as the office equipment supplier and Intel as the IC designers. The end result was Ethernet, so thoroughly developed that it was accepted as a standard with a couple more modifications from IEEE. The most important Ethernet data is shown below.



This concept has been so successful that Ethernet can be found in offices around the world. ISO has accepted it and given it ISO code ISO 8802.3. The standard has gained additional acceptance because many IC manufacturers have been in competition producing standard ICs for many years now. The number of board and system manufacturers in this market nowadays is almost unfathomable.


### **IEEE 802.4 - TOKEN-BUS**

This standard differs from the CSMA/CD bus mainly in its deterministic accessing. It gained recognition several years ago when General Motors (GM) - tired of manufacturer oriented automation systems that could not communicate with each other - decided to set a standard for automation systems. The project was named "Manufacturing Automation Protocol" (MAP) and applies to the standardization of all OSI layers. IEEE 802.4 applies to the lower layers since a deterministic protocol was deemed necessary due to real time requirements demanded by some tasks. Technical Characteristics:



### **IEEE 802.5 - TOKEN RING**

This type of network combines the token passing technique with the ring topology. The idea was presented by a Swede who even received a patent for it; but it was further developed by IBM and the end product was favored and soon to follow was accepted as standard. The most important points concerning the token ring are shown below.



The ring is set up as a so-called "star-wired ring" which requires a ring distributor which all data runs through. The opinions on the acceptance of this concept are varied and contradictory ("just another LAN?"). One thing is certain however, this type will always have a place in a purely IBM world. Whether it will be any real competition to Ethernet or the token bus methods is still yet to be seen.





### FDDI, COMPARISON AND SELECTION CRITERIA

### INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION

### **FDDI**


Although the large majority of networks today do not operate under maximum loads even if several hundred nodes are connected, the American National Standards Institute (ANSI) is already working on high-power networks. The name of the project is "Fiber Distributed Data Interface" (FDDI). The most important data concerning this project is listed in the table below.

Topology Method of Transmission Ring Structure Base Band Coding NR7I 100 MBit/sec Data Rate Access Technique Transfer Media Fiber Optic Cable Max. Distance Between Two Stations Max. Length of the Network 100 km Max. Number of Stations 500

Part of their work is already contained in a Draft International Standard (DIS) and is being accepted by the ISO. These networks will mainly be used to connect high power nodes that must transmit large amounts of data in short amounts of time, such as workstations, fast peripheral devices, medical equipment, etc. They will also be used as background networks connecting different computing centers because large distances are permissible between the nodes.

### **COMPARISON AND SELECTION CRITERIA**

When you look at all the different standardization work that has been done, it is easy to ask why it was not possible to agree on a single method which could be universally installed. Unfortunately, things are not as easy as one might wish them to be when it comes to LANs. Just as it is impossible to develop one automobile that meets everyone's demands even though developers have a wide range of experience and technology to draw on, it is impossible to meet everyone's requirements with one type of network. The following figure is an example of a mixed operation.



Because of their history, Ethernet or IEEE 802.3 has been established as a standard in the office. In the future token ring or IEEE 802.5 and FDDI in the high power range will join its ranks. Because defined response times must be expected in factories and a large amount of additional information must be sent through the cable, standard IEEE 802.4 broad band was developed for backbone applications and carrier band for the cell range. One day broad band cable may be replaced by modern fiber optics cable as is suggested in FDDI.

All of these solutions however are too expensive when it comes to networking the lowest level of a process where actuators and sensors are situated. New demands for internal safety, current supply from the medium etc. are raised here. These are topics that will have to be addressed by the field bus In the last diagram, separate network types are connected by gateways (GW) These are nothing other than independent computers that translate protocols of different networks.

### **GENERAL SELECTION CRITERIA**

The following table summarizes the criteria that is important when planning the installation of a LAN.

### Speed / Capacity

- Data Rate
- Delays (error, routine, etc.)
- Response Times

### Reliability

- Protection Against Total Failure Data Protection

- Costs
   Installation
- Devices
- Maintenance

- Changes / Extensions Compatibility

The capacity of a network permitted by the cable, expressed as the data rate, is almost always important. The higher the rate, the faster the data transfer - or so it may appear at first glance. Today typical transfer rates range up to approx. 100 MBits/sec. Consider however, that practically no computer can keep up these rates over a long period of time; 100 MBits/sec is equal to approximately 10 MBytes/sec. This means the transmission of 100 MBytes in 10 seconds. I/O channels, however, are rarely equipped with such large, fast memories, and disk access in the millisecond range is called for. On top of that, the fact that it still takes a lot of time to process the complete architecture of the ISO OSI reference model with the microprocessors that are available today decreases the net data rate drastically. This lowers the net data rate to well under 100 kBits/sec. The main strength of a network with this type of data transfer rate is found in the fact the interlocked use of many participants makes it possible to take advantage of these data rates. This is why it makes sense for the network to have a much higher data rate than the quickest node.

Data rates alone, however, do not guarantee short response times. The additional delays which can occur due to transmission errors must also be considered. A package must be retransmitted if the receiver is alerted through an invalid check sum that an error that the receiver itself can not correct has occurred. Collisions with CSMA/CD can also lead to loss of time and capacity. Special attention must be paid to response times if time critical tasks are to be performed on the network. As shown before, not all concepts permit predictable

Reliability is no less important. The first step is determining the methods to be used for error recognition and correction. Reliability of individual components is another consideration; these are often responsible for the total failure of the system. Last but not least, data protection must also be considered with the growth of a network, something which is given very little thought, even today.

The initial set up costs are naturally interesting. Included in these costs are individual end devices, cabling and the medium for data transfer. By no means does this complete the whole picture. Installation and maintenance costs should also be considered. Sometimes initial costs can be kept to a minimum but it can become very expensive to extend a network. This may require amplifiers and transformers which may call for frequent maintenance, or every time a node is added the network might have to be reconfigured.

Flexibility of a network is another question. Network extendability and configuration, as well as the question of stop time if another node is to be added are always a major concern. Hardware and software costs for extension of the network are also decisive factors. Network requirements must be considered in comparison with the limits of technical possibilities.

Last but not least, compliance to networking standards should be considered at all times. A network can not be utilized to its complete capacity unless different brands of computers can communicate with one another. The problem, however, does not normally come from LAN hardware; software support provided by different manufacturers is the usual complicating factor.

### COMPARISON, FORECAST

### INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION





### COMPARISON OF NETWORKING METHODS

In this section, we focus our attention on rival methods of network technology. There are two main pairs of opposing techniques to be discussed: broad band versus base transmission, and CSMA/CD versus token passing.

The primary advantage gained through the use of broad band is multiple transmission capability through one and the same cable. This is made possible through different channels within the cable, sometimes varying in width, which allow not only data but also monitor graphics and voices to be transmitted something of great value in the factory setting where largely varied types of information must constantly be sent. Base band transmission does not offer anything comparable.

Base band is attractive because it is much easier to install. No complicated modems are needed since transmission is always at the same frequency; simple transceivers are sufficient. Amplifiers which must be included with networks of certain lengths are also much less complex. This method is also less expensive. Basic components in an uncomplicated structure help to keep base band network installation costs to a minimum.

Defects in the network represent a problem for both types of data transmission; the results of network failure can be disastrous. The situation is even worse with broad band cable if not only data signals, but monitor signals and other signals are also blocked due to a network defect. Well developed concepts are necessary to minimize the consequences of network failure, especially so with broad band.

When comparing CSMA/CD and token passing, advantages are not restricted to one method or the other. One disadvantage with CSMA/CD is the inability to predict the response time for a message. In fact, it may take extremely long for a response to get through - especially in the event of repeated collisions with other data. It does not matter if such a situation is purely theoretical; it is not even possible to predict an upper response time limit. However, factory control requires the guaranteed availability of certain feedback (such as emergency stop) within a given amount of time (often in the millisecond range). Understandably, this aspect is not quite as crucial in an office setting.

Reference to theoretical load quotas can also be of interest, but their importance is often overrated. If load limits must be relied on, only token passing can guarantee their availability. With CSMA/CD, the probability of collisions increases rapidly with load quotas of approximately 50%. With rapidly increasing response times the quota can almost never be reached. Besides, repeated transmission after collisions speeds the growth of the load on the network. Data rates may have been set too high for planned load quotas such as these.

It is not a problem if one node fails with CSMA/CD since all nodes have equal authorization and access is not coded. Other nodes can no longer communicate with the defect node but all other routes remain open. If a defect causes a node to continuously transmit, a network blockade can be avoided by separating the node from the network after a predetermined amount of time.

More effort is required with the token passing technique because each node is part of a ring - each node must take the token and pass it on. If one node fails, the communication path is interrupted for all nodes. This is compensated for by automatic reconfiguration where the list of token passing nodes is rewritten and the ring is restructured.

A similar situation arises in extending a network. While for CSMA/CD participants are added with equal rights to be accessed by anyone any time, the token passing technique requires a new configuration list of participants in the ring in this case. A new node is only a passive listener before this reconfiguration. The following table provides a clearer picture.

0		0.	.(9)	
		Broadband	Baseband	
Multiple Usag	je	+	-22	
Installation Co	osts	-	+	
Maintenance	Costs		+	
Evaluation of	Defects	-	A +	
		CSMA/CD	Token Passing	
Response Tir	nes	±	+	
Operating at	Theoretical Load Quota	- C/2	+	
Safe Against	Total Failure	+	±	
Possibility of		×50° +	± 30	

### **FORECAST**

Which concepts will now succeed? A question that compares to asking which automobile is the best and has never been answered with 100% certainty. A decision must be made depending on the requests and demands of the individual user. Base band networks with CSMA/CD are swiftly becoming more and more popular in office automation where response times and data rates are not so vital. This trend will probably continue in the future with higher data rates than ever being achieved through technological advancement. In factory automation on the other hand broad band or carrier band solutions with token passing will continue to be the choice if only because of the amount of information to be transmitted. In the low cost range the field bus standard should be developed within the next two or three years.

In general the user will turn to FOL installations more and more often, because in the future the advantages will no longer be outweighed by high price differences. This as well will lead to a substantial increase in data rates.

A purebred solution is not always the way to go; a proper mix of methods and products could be the solution. High performance gateways will be taken advantage of to combine the various types of networks. It will even be possible to combine the advantages of CSMA/CD at low loads and those of token passing at loads of 50% by switching back and forth between the two access methods according to the amount of traffic, or interference free fiber optics cables will be used for main connections and linked to local coaxial cable networks.





### **OVERVIEW**

# INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION

	ETHERNET SINEC H1	ETHERNET FASTNET	ETHERNET INTERNET	
	The same of the sa	17.011121,015	10,200,2	
Trasmission Medium	50 $\Omega$ Coax/Triax cable, Double Shielded	50 $\Omega$ Coax/Triax Cable, Double Shielded	50 $\Omega$ Coax/Triax Cable, Double Shielded	
Connection to the Bus Cable	Transceiver / Transceiver Cable	Transceiver / Transceiver Cable	Transceiver / Transceiver Cable	
Topology	Expanded Bus (tree structure)	Expanded Bus (tree structure)	Expanded Bus (tree structure)	
Transmission Method	Base Band, Wide Band	Base Band, Wide Band	Base Band, Wide Band	
Access Methods	CSMA/CD (IEEE 802.3)	CSMA/CD (IEEE 802.3)	CSMA/CD (IEEE 802.3)	
Coding	Manchester	Manchester	Manchester	
Data Rate gross	10 MBit/sec	10 MBit/sec	10 MBit/sec	
Data Rate net Test A (Writing 1 MByte Data in an OS-9 Pipe over the Network)	70.5 KBit/sec	299.6 KBit/sec	N/A	
Data Rate net Test B (Copying a 500 KByte Data Block from/to a Hard Disk over the Network)	44.3 KBit/sec	139.3 KBit/sec	186.6 KBit/sec	
Max. Distance between Two Stations	2500 m 8500 ft.	2500 m 8500 ft.	2500 m 8500 ft.	
Max. Number of Stations	100 per Segment	100 per Segment	100 per Segment	
B&R-Module(s)	MENC	MENC	MENC	
Application / Remarks	wide use, highly excepted, no response times guaranteed because of CSMA/CD access method, not suited for time critical real time applications, low net data rate	substantially higher net data rates than SINEC H1 by replacing the upper layers with B&R technology, not suited for time critical real time applications because of CSMA/CD access method, fast network for linking B&R MAESTRO industrial computers in applications which are not time critical	for linking B&R MAESTRO industrial computer systems to the UNIX/VMS world, not suited for time critical real time applications because of CSMA/CD access method	


### **OVERVIEW**

# INDUSTRIAL NETWORKS AND COMMUNICATION SYSTEM SELECTION





ARCNET	CAN BUS	B&R MININET	
93 $\Omega$ Coaxial cable (RG62), Fibre optics, Twisted Pair	Four Conductor Twisted Pair Cable 120 $\Omega$	RS485 Twisted pair	
BNC (F) (No Transceiver)	DSUB, Terminal block	DSUB, Terminal block	
Physical Bus, Logical Ring Structure	Bus	Bus	
Carrier Band, Wire Band	Differential Signal	Differential Signal (RS485)	
Token Passing (IEEE 802.4)	CSMA/CA	N/A	
FSK, PSK	NRZ	N/A	
2.5 MBit/sec	Max. 1 MBit/sec	Max. 19.2 KBit/sec	
209.7 KBit/sec	N/A	N/A	
69.6 KBit/sec	N/A	N/A	
6 km (with amplification)	1000 m	1200 m	
255 (8 per Segment)	64	32	
MARC	BRCOMP2, ECEXS5-0	RS485 Interface Module	
good real time characteristics because of token passing access method, high net data rate, ideal network for communication between B&R MAESTRO systems, PROVIT industrial workstations and XT operator panels	Low-cost field bus, high resistance to disturbances because of differential signal, it is an open system for fast data transfer of small data packets (up to 8 bytes)	Low-cost network for B&R PLC and BRMEC Mass Memory, Connecting B&R MAESTRO systems, PROVIT industrial workstations and XT operator panels possible	



C<sub>2</sub>

### **CONTENTS**

INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET

### **CONTENTS**



### INDUSTRIAL NETWORK AND COMMUNICATION **ETHERNET**

C2	ETHERNET	The state of the s	440		Mar.	42,
	CONTENTS					258
	GENERAL INFORMATIO	N				260
	CABLE, TOPOLOGY AN	D PROJECT PLANN	VING			
						260
	THIN WIRE ETHERN	IET (CHEAPERNET	Γ)			26
	MENC - NETWORK CON	ITROLLER		<u></u>		261
	ETHERNET/SINEC-H1					263
	CONNECTION PRIC	RITIES				263
	TYPES OF CONNEC	TIONS				263
	ETHERNET ADDRES	SS	70.,	70.,		
	OPERATION WITH T	HE SINEC H1 LIBR	RARY	90,	<u></u>	
	JOBS		<u></u>			263
	SINGLE JOB DESCR	RIPTION				264
	MULTICASTING			.XCO		265
	CONNECTION OVE	RVIEW		(×)		260
	BLOCKS					266
	<b>COMMUNICATION E</b>	STABLISHMENT EX	XAMPLE		4	266
	FTHERNET/FASTNET					267
						26
	- 170		- 177			26
						267
	DIRECT DATA	1/0	)'	760.	70.	267
	FASTNET OPERATION	ON		1000	7025	267
	7.0					760.
	ETHERNET/INTERNET	· · · · · · · · · · · · · · · · · · ·	- P <sub>2</sub>		12 m	
						268
	TCP/IP AND THE ISO	REFERENCE MO	DEL			268
						268
	- \	,				
						269
			V			





## GENERAL INFORMATION CABLE AND TOPOLOGY

### INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET

### **GENERAL INFORMATION**

ETHERNET is a local area communications network that has achieved a degree of acceptance worldwide. The word "local" indicates that relatively short distances are involved (less than 1.5 km for ETHERNET). In practice, local area networks are used primarily within buildings or building complexes. The lower levels of OSI are explained in this section such as topology, cabling and statements to ETHERNET, which are independent from application oriented levels.

The following three ETHERNET applications are explained in detail:

- ETHERNET / SINEC H1
- ETHERNET / FASTNET
- ETHERNET / INTERNET (TCP/IP)

### **CABLE AND TOPOLOGY**

Two basic ETHERNET networks can be distinguished:

- Thick Wire ETHERNET (yellow bus cable)
- Thin Wire ETHERNET (also CHEAPERNET)

The only differences between these two types are the cable used and the connection to the physical devices. The baudrate or signal is not different.

#### THICK WIRE ETHERNET


With a thick wire ETHERNET, all nodes are connected to the bus with transceivers and transceiver cables. Repeaters or bridges are used for coupling individual ETHERNET bus segments. There are local versions in which two segments are connected to a repeater or bridge with a transceiver cable and remote versions for greater distances.

The basis for a thick wire ETHERNET bus system the a coaxial cable with which the nodes are connected. The transmission rate is 10 MBit/sec. Standard ETHERNET cables are available from numerous manufacturers. The most important cable types are:

- PVC Cable
- Teflon Cable

All cables can be considered equal as far as their electrical properties go. The difference is their sheathing, which is only relevant under extreme heat (e.g. fire). The ETHERNET bus cable is limited to a length of 500 m and must be terminated at both ends with a 50  $\Omega$  resistor. The cable does not have to be cut to connect a node to it. A transceiver is simply clamped onto the bus cable; its small adapter has a prong which penetrates the sheath, making contact with the cable. The transceiver is connected to the ETHERNET network controller with a transceiver cable. The length of this cable is limited to 50 m. The transceiver cable is connected to a D-type connector on the transceiver. All tools needed for installation of transceivers and terminal resistors are available.

### Schematic:



Up to 100 transceivers can be connected to an ETHERNET bus cable segment (max. 500 m). The distance between transceivers must be at least 2.5 m.

A bus cable segment can consist of several sub-segments. In order to avoid reflection at the coupling points, the sub-segments should have a length which is an odd multiple of 23.4 m:

Bus cables are sold in the following lengths:


The bus and transceiver cables must be kept at least 0.5 m from parallel power lines as well as overcurrent protectors and HF antennae. The cable should be run in metal cable duct , especially in areas with high levels of electrical interference. All other components (transceivers, repeaters, ...) should be kept at least 1 m away from sources of interference. The maximum field strength in areas containing industrial bus components must not exceed 2 V/m in the range from 10 kHz to 30 MHz and 5 V/m in the range from 30 MHz to 1 GHz. After the installation of the bus cable segment, a reflectometer ^should be used to make sure that the amplitude of the reflected signal does not exceed 7 % of the amplitude of the introduced test signal.

### Repeaters: Rules for Linking Segments

Multiple bus system segments can be connected with a repeater. A maximum of two repeaters can be positioned between any two nodes on the bus. Repeaters can be used, not only to extend the maximum length of a bus cable, but also to achieve a three dimensional topology (e.g. wiring a building).

Local repeaters and remote repeaters are distinguishable. A local repeater permits the connection of the two segments via point-to-point coupling with two transceiver cables, each with a maximum of 50 m. This type of coupling is used within buildings. With two repeaters, the connection can also be constructed redundantly. A remote repeater permits the connection of two segments via point-to-point coupling with up to 1000 m of fiber optics cable. This type of coupling is employed for greater distances within a building or to connect segments in different buildings.

### Schematic:



# MENC ETHERNET-NETWORK CONTROLLER

INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET






The fiber optics cable connection between more than two segments should not exceed the maximum length of 1000 m. Both local and remote repeaters are connected to the bus with transceivers. Since the principle of the CSMA/CD access method depends on the time that a signal requires to transverse the length of the cable and back, the maximum length of a linked bus is limited, even if it consists of multiple segments. The maximum length of the bus cable, measured between the two most remote transceivers, is 1500 m. This results in 2500 m as the maximum separation between two stations (1000 m fiber optics cable and 1500 m coaxial cable).

Point-to-point separation of two repeaters is also limited for the same reason. The distance between the transceivers of any two stations must not exceed the maximum length of 1000 m.


### Interface Multiplier

Interface multipliers can be used to connect multiple stations (up to 8) to a single transceiver note. The sum of the cable lengths from the transceiver to the interface multiplier and from the interface multiplier to the station cannot exceed 50 m.




### THIN WIRE ETHERNET (CHEAPERNET)

The Thin Wire ETHERNET (CHEAPERNET) is distinguished from Thick Wire ETHERNET only by it's cable and connectors. Instead of thick wire coaxial cables, thinner cables are used. Contrary to the Thick Wire ETHERNET, the transceiver is coupled with a T-connector.



### **MENC - NETWORK CONTROLLER**

The MENC network controller is used to connect a B&R PLC (MULTICONTROL or MIDICONTROL) to an ETHERNET network.



Although the MENC network controller follows the design of the B&R MAESTRO system (gray front with blue stripes), it can be used in systems without a B&R MAESTRO co-processor. In this case, it is operated by the PLC CPU.

Another possibility for network coupling is the MCIF2 PLC bus interface module and the B&R MAESTRO MCO3MC co-processor. Both are equipped with a type II PCMCIA interface.

An ETHERNET LAN card BRKAETL-2 can be inserted in the PCMCIA interface. The LAN card is connected to a ETHERNET Thin Wire network with a BNC adapter. A power supply is required for the operation of the BNC adapter.





and an ETHERNET PCMCIA LAN Card

More exact differences are first seen in the higher, application oriented layers. Four types of ETHERNET are available for the B&R MAESTRO system:

- SINEC H1
- FASTNET
- INTERNET
- NOVELL





### MENC, **ETHERNET NETWORK CONTROLLER**

INDUSTRIAL NETWORK AND COMMUNICATION

### ORDER DATA

### MENC ETHERNET Network Controller

The MENC ETHERNET network controller is delivered as a set. The sets are in divided into three areas:

- OEM System Development Kit (German) Development Kit (English)

Please give the model number (far right column) when ordering.

	Component	OEM System	Model Number
	HCMENC-0 SWMEN-0	ETHERNET Controller, 10 MBaud, 50 $\Omega$ ETHERNET Network Software, SINEC-H1	HCMENC:0SX
	HCMENC-0 SWMTN-0	ETHERNET Controller, 10 MBaud, 50 Ω INTERNET TCP/IP Network Software	HCMENC:0TX
	HCMENC-0 SWMFN-0	ETHERNET Controller, 10 MBaud, 50 $\Omega$ ETHERNET Network Software, FASTNET	HCMENC:0FX
65	HCMENC-0 SWMIPX-CD	ETHERNET Controller, 10 MBaud, 50 $\Omega$ ETHERNET NOVELL OS-9/Client	HCMENC:0NX

Component	Development Kit (German)	Model Number
HCMENC-0 SWMEN-0 MAMNET-0	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, SINEC-H1 B&R MAESTRO Network Manual, German	HCMENC:0SD
HCMENC-0 SWMTN-0 MAMNET-0	ETHERNET Controller, 10 MBaud, 50 $\Omega$ INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, German	HCMENC:0TD
HCMENC-0 SWMFN-0 MAMNET-0	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, FASTNET B&R MAESTRO Network Manual, German	HCMENC:0FD
HCMENC-0 SWMIPX-SD SWMIPX-CD	ETHERNET Controller, 10 MBaud, 50 $\Omega$ ETHERNET NOVELL Server ETHERNET NOVELL OS-9/Client	HCMENC:0ND

	Components	Development Kit (English)	Model Number
.8	HCMENC-0 SWMEN-0 MAMNET-E	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, SINEC-H1 B&R MAESTRO Network Manual, English	HCMENC:0SE
	HCMENC-0 SWMTN-0 MAMNET-E	ETHERNET Controller, 10 MBaud, 50 Ω INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, English	HCMENC:0TE
	HCMENC-0 SWMFN-0 MAMNET-E	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, FASTNET B&R MAESTRO Network Manual, English	HCMENC:0FE

Component	Accessories	Model Number
HCMTRAN2-0	ETHERNET Transceiver, BNC	HCMTRAN2-0
BRKAETX-0	Cheapernet T-Connector, BNC	BRKAETX-0

### **ETHERNET PCMCIA LAN Card**

Two sets are available for the ETHERNET PCMCIA LAN Card:

- **OEM System**
- Development Kit German

Please give the model number (far right column) when ordering.

750	Component	OEM System	Model Number
	BRKAETL-2 SWMIPX-CD	ETHERNET PCMCIA LAN Card ETHERNET NOVELL OS-9/Client	HCMENC:LNX
	Component	Development Kit (German)	Model Number
	BRKAETL-2 SWMIPX-SD SWMIPX-CD	ETHERNET PCMCIA LAN Card ETHERNET NOVELL Server ETHERNET NOVELL OS-9/Client	HCMENC:LND
_			

# ETHERNET / SINEC H1, CONNECTION TYPES, APPLICATIONS

INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET





### **ETHERNET / SINEC-H1**

The SINEC-H1 library is a user interface for ETHERNET networks. It belongs to the application oriented layers (5 to 7) of the ISO reference model. Using the MENC network controller assures complete compatibility with the SINEC-H1 bus. The following is a summery of the specifications and standards:

Physical Layer and Media Access Control Bit Coding Access Method Logical Link Control Network Layer

according to IEEE 802.3 Manchester Code CSMA/CD According to IEEE 802.2 Not provided According to ISO 8073 Clas

Transport Layer According to ISO 8073 Class 4 and ISO 8602
Session Layer Partial functions for SINEC H1 and DEC

Various services are provided for ETHERNET data communication:

- Normal Service
- Priority Service
- Datagram Service
- Multicast Service
- Broadcast Service

Link management takes in the transport layer level. Links are established and terminated through a request made by superordinate layers. They require information for the description of the communication partner and the local link data is passed on as parameters. These parameters are, e.g., the Etherne address of the partner node, the name of the partner TSAP ID and the transmitters own TSAP ID. In addition to the names, the priorities and types of the partners need to be specified. Only SINEC L1 specific functions are activated. Any other tasks are handled directly from the transport layer.

Established links are constantly monitored. Multicast, broadcast and datagram work without specific links. The TSAPs (Transport Service Access Points) are entered, but there is no end-to-end monitoring.

### LINK PRIORITIES

Link priority determines the priority of data records transmitted within the MENC network controller, the type of links established/terminated and the format of the transport head.

Priority 0 and 1

Highest Priority. High priority data service, links with priorities 0 and 1 are established immediately upon recognizing the link request. The established link in the network is not time-monitored, i.e., even if the partner node does not answer the link request, the attempt to establish the link continues for the life of the link request. The data is transmitted in a special format via the network and can "overtake" data with lower priorities..

Priority 2

Normal Priority. The establishment of the link is handled as with priority 0 but the data is transmitted with lower priority and in normal format.

**Priority 3** 

SINEC-H1 Specific. This involves the implicit establishment of a link and its explicit termination. The establishment of the link is made to the connection after a transmission request. The link establishment phase is time monitored. If the link establishment request is not confirmed by the communications partner within 60 seconds, the search is interrupted. An established connection remains until its explicit termination occurs. The data is transmitted in normal format.

**Priority 4** 

SINEC-H1 Specific. This involves the implicit establishment of a link and its explicit termination. The establishment of the link is made the same as with priority 3. The only difference is that the links are automatically established after a successful transmission.

#### CONNECTION TYPES

The type of connection determines whether a real link must be established and terminated or whether the transmission can be made without making a link.

Normal Virtual Connection

The connections are established and terminated as de-

scribed in section "Link Priorities".

Datagram Service

Only with Priority 0. The connection parameters are defined through a connection request but whether the transmission or reception is performed correctly is not checked.

Multicast Service

Only with Priority 0. The connection is managed the same as with a datagram. A telegram goes to all partners which are

defined for the respective multicast circuit.

**Broadcast Service** 

Only with Priority 0. The connection is managed the same as a datagram service. The message is sent to all stations of

the network.

#### **ETHERNET ADDRESS**

The Ethernet address is used for identifying stations. This address consists of 6 optional characters. The lowest value byte must be 0. The following standard has been established:

- The first three characters contain the company initials of the network manufacturer
- The next two bytes contain the node number
- The last character is a constant end character

### **B&R Standard**

B & R x x <Space> \$42 \$26 \$52 \$20

A nodes own Ethernet address is designated as "ownid" in the C function. The Ethernet addresses of the partner station is designated as "destid". "ownid" and "destid" are pointers to the 6 character string (char \*destid).

### SINEC H1 LIBRARY OPERATION

Operating SINEC L1 with application programs is done with a C library. Communication with the Siemens COM 535 network module is also possible in this operation mode. The "n\_send" module establishes and active connection with another station and sends data to a destination station. The "n\_rec" module receives this data and displays the status of the job.

### JOBS

Accessing the network occurs via jobs sent to the MENC network controller. When using the SINEC H1 library, the user distributes jobs to the network controller in order to perform initialization, for the connection establishment and termination as well as for sending and receiving data. A C function exists for each of these jobs. Every job is converted to a job control block (JCB), which means a sequence of parameters for the MENC network controller. For jobs that require additional parameters or data, the JCB contains a pointer to this data.

As an alternative to the C functions, the user can assemble the JCB him/herself and pass it on to the MENC network controller with the "n\_akb()" function. The following section explains the individual jobs and the respective C functions.





### ETHERNET / SINEC H1, JOBS

### INDUSTRIAL NETWORK AND COMMUNICATION

### SINEC H1 JOB CONTROL BLOCK (JCB)

BYTE 1	BYTE 0	Offset
Reserved	Job Type	\$00
Q/Z Type	Connection Number	\$02
Reserved	Data Block Number	\$04
Q/Z Address	1 1/20	\$06
Display Word		\$08
Data Length - User	19/10	\$0A
Data Pointer (Long Word Pointer)	1/101	\$0C
Data Length - MENC	10	\$10
Address Event Service Routine (Long Word Pointer)		\$12
Address of Next JCB (Long Word Pointer)		\$16
Reserved	Board Status	\$1A
Address of Current JCB (Long Word Pointer)		\$1C

The job code indicates the type of job.

Job 10	Reset MENC (N_RESET)
Job 12	Init (N_INIT)
Job 11	Connection Request (N_CONNECT)
Job 13	Data Send (N_SEND)
Job 14	Data Receive (N_RECEIVE)
Job 16	Connection Termination (N_DISCON)
Job 98	Error LED Clear (N_CLRERR)
Job 99	Error LED Set (N_SETERR)
Job 113	Send High Priority Data (N_HSEND)
Job 114	Receive High Priority Data (N_HRECEIVE)
Job 201	Read System Identification (N_IDENT)
Job 54	Read System Identification over Network (N_NIDEN

Q/Z-Type Currently not used but will be employed later for addressing S5

addresses direct

Connection Number Holds the number of the connection which is assigned to this task. When a connection is requested by the user, this is set by the MENC. This is to be set by the user for all jobs to follow. Connection numbers greater than 27 are reserved internally in the system. This means that a maximum of 27 static connections are possible.

Data Block number Currently not used but will be employed later for addressing S5

addresses directly.

Q/Z Address

Currently not used but will be employed later for addressing S5

ddresses directly.

Display Word

Used for monitoring the respective job.

AW 4	Job Ended Successfully.
AW 5	Active Connection: The partner

AW 5 Active Connection: The partner station is on the network. It is not ready to establish a connection however.

No Active Connection: The connection is established.

W 6 N\_HSEND or N\_HRECEIVE: The connection is not established ye Otherwise: Error in the parameter list. A second command has been sent, although the first was not yet acknowledged. E.g. a second RECEIVE is sent to the same connection

although a RECEIVE is waiting.

N HSEND: The data could not be sent within 4 seconds

war i will write in the war

Bit 15 is used as a block recognition. The meaning is explained with jobs N\_SEND and N\_RECEIVE.

Data Length (User)

Length of the data area set by the user in bytes.

**Data Pointer** The data pointer is used by the C library and points to the job data.

MENC Data Length Length of actual data transferred in bytes

Address Event Service Routine Can be entered by the user. It holds the address of the routine that is started after the job is finished. If address 0000.0000 is entered,

 $no\ routine\ is\ started.$ 

Addr. of Next JCB When blocking over several RECeive jobs, the address of the job block which points to the next data block can be shown here.

**Board Status**Bit patterns indicating the respective MENC error.

Bit	Status	Error
0	1	MENC RAM Error
1	1	MENC PROM Error
2	1 🔉	Internal Loop Error (LANCE)
3	1	External Loop Error (LANCE)
4	1	Fatal Error (LANCE)
7	0	MENC Not Initialized
7	√°1	MENC Initialized

Address of Start address of the current job control block. This can be defined by the user Current JCB for getting a response.

### INDIVIDUAL JOB DESCRIPTIONS

The individual SINEC H1 jobs are described in more detail in the following section:

10	RESET	Reset MENC
12	INIT	Initialization MENC
11	CON	Connection Establishment Request
13	SEND	Send Data
14	REC	Receive Data
16	DCON	Disconnect
98	CLRERR	Clear Error LED
99	SETERR	Set Error LED
113	HSEND	Send High Priority Data
114	HREC	Receive High Priority Data
201	IDENT	Read System Identification
254	NIDENT	Read System ID over the Network

### 10 - RESET MENC

The MENC bus is reset completely and the a new INIT call is made. All connections must be rebuilt and redefined. The reset takes approximately 1.5 seconds.

### 12 - N\_INIT - INITIALIZE NETWORK CONTROLLER

The INIT request causes the MENC network controller to initialize the bus. The respective Ethernet address and the defined multicast loop is defined in the MENC. After every RESET, the network controller is initialized.

### 11 - N\_CONNECT - CONNECTION ESTABLISHMENT REQUEST

A connection is defined in the MENC with N\_CONNECT. This must be done before a send, receive or connection request is made. Whether a connection is really established on the network depends on the type of connection. The MENC defines the respective connection number in the job control block (JCB) and returns it to the user as the function result. The connection number is to be defined by the user for all further jobs for this connection.

### 13 - N\_SEND - SEND DATA

Sending data. The parameters for data transmission are implicitly determined in the establishment of the connection. Bit 15 of the status word of the JCB (the variable ""akb\_send.akb\_status") allows the user to specify whether another data block is to succeed the current one or not. The bit is transferred to the partner station and is displayed, if the N\_RECEIVE command is executed (also bit 15 in the status word). A single block is allowed to be a maximum of 400 bytes.

### 14 - N\_RECEIVE - RECEIVE DATA

The user must provide a buffer for receiving data. When MENC has received the jobs data, it is stored according to the parameters in the JCB. Testing bit 15 of the status word in the JCB (global variable "akb\_status") allows the user to determine whether other blocks will follow.

### ETHERNET / SINEC H1, JOBS, MULTICASTING

### INDUSTRIAL NETWORK AND COMMUNICATION **ETHERNET**





### 16 - N\_DISCON - DISCONNECT

The connections of the network which are defined with the connection number are disconnected and deleted from the MENC network controller.

### 201 - N IDENT - READ SYSTEM IDENTIFICATION

MENC specific information is read with this job. This includes the version number of the MENC software, the MENC status, the defined Ethernet address and the status of the station number switch.

### 99 - N\_SETERR - ERROR LED ON

The error LED can be switched on from the application program with the n\_seterr() function.

### 98 - N\_CLRERR - ERROR LED OFF

The error LED can be switched off from the application program with the

### 113 - N\_HSEND - SEND HIGH PRIORITY DATA

Used to send high priority data. The parameters are defined implicitly with the establishment of a connection. The user can define whether another data block should succeed the current one with bit 15 in the display word of the JCB (reads the structure variables "akb\_send.akb\_status"). A single data block is allowed to be Max. 16 Bytes long.

### 114 - N\_HRECEIVE - RECEIVE HIGH PRIORITY DATA

The user must create a receive buffer. If the MENC network controller has received the data for the job, then the job control block (JCB) is stored according to the defined parameters. By checking bit 15 of the display word in the JCB (global variable "akb\_status"), the user can determine whether a data block should follow or not.

### 254 - N\_NIDENT - READ SYSTEM IDENTIFICATION OVER NETWORK

MENC specific information of another station can be read over the network by using this job. This includes the version number of the MENC software, the MENC status, the defined Ethernet address and the status of the station number

### N\_AKB - USING JOB CONTROL BLOCKS

 $With \ C \ functions \ n\_reset()", "n\_init()", "n\_connect()", "n\_send()", "n\_receive()", "n\_receive()", "n\_send()", "n\_receive()", "n\_send()", "n\_se$ "n\_discon()" and "n\_ident()", the job control block is automatically supplied with the required parameters. The user has the choice of either setting up the job control block him/herself or letting the "n\_akb()" function of the MENC network controller handle it

### **N\_READY - CHECK STATUS OF A JCB**

The user can determine whether a block exists or not with this function.

### N HASH - CALCULATION OF CP 535 MULTICAST NUMBER

The user can calculate the multicast number of a Siemens CP 535 with this function.

### MULTICASTING

 $Multicasting \, allows \, you \, to \, send \, data \, from \, a \, group \, of \, stations \, that \, are \, participants$ in a multicast loop. To avoid complicating the network, it is a good idea to build all connections in the same direction.

### **Example for Multicast Addressing**

#### a. B&R <-> B&R

Receiver Station (stations of multicast loop): The multicast number must be defined for the INIT. The following parameters are required for the connection request:

The Ethernet address of the station from which data should be received

The priority (0 or 1)

The type (multicast service)

The number of the multicast loop


Send Station (Stations sending to a multicast loop): The following parameters are required for the connection request:

The priority (0 or 1)

The type (Multicast service)

The number of the multicast loop

After the connection has been established, the data is sent to all stations which are participants of the multicast loop with a SEND instruction.



### b. Siemens -> B&R

Receive Station (B&R): Before the MENC is initialized, the multicast number must be calculated with the "n\_hash" C function. The transferal value for the "n\_hash" function is the Ethernet address of the partner station. The result is the multicast number which is to be defined with the INIT. The following parameters are required for the connection request:

> The Ethernet address of the station from which data should be received The priority (0 or 1)

The type (Datagram Service)

### c. B&R -> Siemens

Send Station (B&R): The following parameters are required for the connection request:

The Ethernet address of the partner station

The priority (0 or 1)

The type (Datagram Service





# ETHERNET / SINEC H1, CONNECTION OVERVIEW, BLOCKS

### INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET

#### CONNECTION OVERVIEW

The following table is an overview of connections depending on their priority and type:

	<	2		Priority	9		
Туре	1	2	4	5	8	9	16
1	×	Х	NA	HNA	IEA	IEHA	IIA
2 (	DTA	DTA	Х	Х	Х	Х	Х
4	Mcast	Mcast	X	Х	Х	Х	×
8	Bcast	Bcast	Х	х	Х	х	×
129	Х	Х	NP	HNP	IEP	IEHP	IIP
HNA IEA IEHA IIA DTA MCast BCast NP	Priority 3, Priority 3 Priority 4, Datagram Multicast of Broadcas Normal vii	with processing Active connection connection to connection to connection conn	ng priority, Ac	ctive	ko:j,		
HNP	Priority 3,	Normal virtual connection with processing priority, Passive Priority 3, Passive					
IEHP	Priority 3 v	with processing	na priority. Pa	assive			

BLOCKS

Priority 4, Passive

In order to transfer large amounts of data, the data must be split into several small data blocks. The receiver must be informed that the segment is a blocked segment. There are two different ways of splitting data into data blocks:

### a. By the User

The user can use bit 15 of the display word to divide a data segment into data blocks. The bit is sent over the network to the target station and can then be evaluated by the user with functions N\_RECEIVE and N\_HRECEIVE. By setting bit 15, the user is informed that another data block must be received.

### b. Automatic

**Example:** 400 bytes are sent from station 1 to station 2. Receiving station (station 2) only has a receive buffer of 10 bytes however. The N\_RECEIVE function sends a response that a 10 bytes long data block has been received and bit 15 in the display word is set. This means that more than 10 bytes has been sent. If another N\_RECEIVE instruction for 10 bytes is given to the MENC, the next 10 bytes of the data segment are received and bit 15 remains set. Bit 15 is only cleared after the last byte has been received.

### COMMUNICATION ESTABLISHMENT EXAMPLE

Communication should be established between two stations in both directions. The stations are initialized and are not participants in a multicast loop. The connection should allow normal and high priority data transmission.

Priority: Bit 0 ... With priority
Bit 2 ... Normal Priority

Value 5 must be defined with the N\_CONNECT call for the priority. In this example, station 1 is active and station 2 is passive. In order to achieve a proper connection, one station must always have a passive N\_CONNECT call and the other an active N\_CONNECT call. If both stations try to establish an active connection, they both think that the other is using the network but is not ready to make a connection. The result is that a connection number is delivered but all other instructions to this connection are responded to with value 5 or 6.

If both stations try to establish passive communication, then the stations wait infinitely since neither station starts any activity.

Station 1 attempts to establish active communication with the instructions

```
destid = "stat_2"
owntsap = "ABCD"
desttsap = "FFGH"
connum = n_connect(path,5,1,destid,0,owntsap,desttsap,1)

Active
Priority 0 and Priority 2
Station 1
```

This call causes an active connection request with priority 0 and 2. Data having priority (N\_HSEND and N\_HRECEIVE) can also be sent or received with this connection. The variable "connum" contains the connection number. The display word of the N\_CONNECT instruction is stored in the global variable "akb status" and has value 5.

If an N\_SEND instruction is executed for this connection, the MENC network controller transfers the command to a new connection request. The N\_SEND instruction puts value 5 in the display word since the receive station is not ready to establish a connection. The N\_HSEND instruction puts the value 6 in the display word, since the connection is not yet established.

Station 2 attempts to establish a passive connection with the instructions

```
destid = "stat_1"
owntsap = "EFGH"
desttsap = "ABCD"
connum = n_connect(path,5,129,destid,0,owntsap,desttsap,1)

Passive
Priority 0 and Priority 2

Station 1
```

This call causes a passive connection request with priorities 0 and 2. Data having priority (N\_HSEND and N\_HRECEIVE) can also be sent or received with this connection. The connection establishment request only sends the connection number back (waits until), if the other station (station 1) sends again. An N\_SEND instruction from station 1 is only sent if station 2 is ready to receive data. An N\_HSEND instruction from station 1 send the value 8 to the display word after a timeout of approximately 4 seconds. If a station is switched off from the network, all instructions deliver a value of 5 to the display word after a timeout.

### ETHERNET / FASTNET, GENERAL

### INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET





### **ETHERNET / FASTNET**

FASTNET is a communication software package that enables data exchange between OS-9 systems by means of an NFM (Network File Manager). Since the complexity of the standard to be implemented causes a speed reduction for SINEC-H1, FASTNET was especially developed for the MENC network controller. It enables rapid data transfer because of optimal software adjustment and noncompliance to existing standards. The protocol applied respects to no standard except the Ethernet specification for transmission and frame establishment. It is suitable for fast MAESTRO couplings.

The Network File Manager (NFM) requires a driver for the data transmission, which takes over these tasks. The tasks of this driver are to transmit the, limited length, NFM messages to a certain station. This procedure should be performed securely, and in case of an error or transmission interference the NFM should be informed. With the help of a simple communication confirmation, the data transfer between 2 stations is observed. With an optimal adjustment of hardware and the NFM tasks of OS-9 a higher data rate is achieved.

### **FASTNET AND THE ISO REFERENCE MODEL**

7	Application Layer	OS-9	application process, that uses the utilities of the NFM (e.g. COPY. DIR,)
6	Presentation Layer	OS-9	This layer cannot be described precisely. Corresponding transformations can be performed for different devices.
5	Session Layer	OS-9/NFM	Combines two processors for data exchange. This is performed with a path qualification. Any number of data connections can exist between two nodes. With an individual connection, a cycle is realized. This contains different services and applications.
4	Transport Layer	MENC SW	Secure transport of the NFM messages to the opposite nodes and control of transmission confirmation. Confirmation of received NFM message and transmission to the NFM.
	7	OS-9/NFM	The second part of this layer is executed by OS-9 / NFM. The NFM only produces an individual numbering of the packages (NFM-message). Addressing of opposite nodes is done by individual node numbers. This protocol also performs a flow control. MENC software is responsible for "node-to-node error protection".
3	Network Layer	MENC SW	FASTNET is only possible within a network, thus no routing is required. Here, however, the conversion of an OS-9 model number to the respective ETHERNET address is found.
2	Data Link Layer	MENC SW	Transmission of packages to one or all nodes. Check of received packages to validity and preparation for further processing. Recognition and processing of different package types.
1 ,	Physical Layer	MENC SW	Generation or evaluation of ETHERNET frames, as well as transmission and reception of these frames on the ETHERNET bus.

### FASTNET PROTOCOL

The FASTNET protocol has two different method of data transfer:

- Broadcast Data
- Direct Data

### **BROADCAST DATA**

Broadcast-data comes in packages (NFM) which are sent to and received from all nodes connected. They serve for the establishment of a network, in order to determine which nodes are available. This is possible, since each node (or its NFM) reacts with an additional data transmission to this broadcast package. Transmission or reception of these packages at the usually unknown destination nodes is not checked for interference-free reception. Thus no repetition of data is performed. If a node receives repeated data several times, must be considered as intended.

### **DIRECT DATA**

Direct data also comes in packages (NFM messages), but can only be sent to a specific node. Since the destination node is known, a data confirmation from this node is expected within a certain period of time. If this does not occur within a predefined time, a transmission of the same data is repeated. Because of the additional information that is transmitted to the destination node, it can determine whether the data is new or if the data was already confirmed and the confirmation to the source station got lost. Thus data cannot be duplicated and appear several times. After a certain number of repetitions the transmission attempt to the opposite node is interrupted and an error is displayed to the NFM.

Since the NFM distributes numbers (node ID) for a characterization of nodes, the conversion of the node ID to the respective Ethernet address (6 Bytes) must be performed in the MENC software. This node ID and Ethernet address consists of 2 Bytes. Since the allocation between node ID and Ethernet address should be free and this assignment is supported by the NFM, the following procedure is applied:

To start the procedure, the NFM sends a message to all nodes. Active nodes answer this with an NFM message to this node. The HCMENC software memorizes the allocation of the Ethernet address and the node ID, which is stored in this message. Since the NFM addresses nodes only via node ID, the MENC software can now specify the pertinent Ethernet address in order to send the frame, according to the Ethernet standard, to the destination node. Thus the Ethernet address is independent of the node ID, which is managed by OS-9. This allocation can also be displayed with a utility program. These procedures enable a new node to be connected. The node ID does not have to be known by any other nodes (dynamic response - the network can be expanded or reduced during normal operation).

### **FASTNET OPERATION**

The MENC network controller is set as a standard for the SINEC H1 operation. With a download function, it can be reprogrammed to different protocols such as FASTNET.

OS-9/NET further enables logging into any node in the network. This is designated as "REMOTE login". Thus it is possible to work as a user via the network without restrictions, just like a connected terminal. Not only the file system and the device are accessible, but also the CPU and its memory are now used by this station. This individual system is then available via the OS-9/NET (path). For this operation two programs are required. In one node "CHP" (for starting the remote shell) and in the other a special timesharing monitor adapted to the OS-9/NET for logging, which replaces the existing TSMON and the pipe with the name /pipe/.sh, are necessary. This MTSMON monitor is normally loaded in the start-up file.





# ETHERNET / INTERNET, GENERAL INFORMATION, FTP, TELNET

INDUSTRIAL NETWORK AND COMMUNICATION

### **ETHERNET / INTERNET**

INTERNET is a communication software package which enables data exchange between OS-9 systems and other INTERNET systems with TCP/IP protocol (TCP/IP = Transmission Control Protocol /Internet Protocol). With the INTERNET C-library, a function collection is available which is almost identical with the UNIX BSD INTERNET functions.

### HISTORIC BACKGROUND

The protocol combination TCP/IP was initially developed for ARPANET, which is a computer network created in USA in the early 70s. It was established in 1980 by the department of defence and should guarantee reliable data transport between different host computers and partial networks. Since the protocol was approved in practice and represented a standard independent of any one manufacturer, it was also very common in networks other than ARPANET.

### TCP/IP AND THE ISO REFERENCE MODEL

Even though the TCP/IP is not standardized by the ISO, it is easy to establish into the ISO reference model:

	7	Application Layer		19'S
	6	Presentation Layer	, i	e.g. FTP or TELNET
Š	5	Session Layer	NITON.	
3	4	Transport Layer	7192	тср
	3	Network Layer		IP
	2	Data Link Layer		e.g. IEEE 802.3
	1	Physical Layer		10°S.

TCP/IP is mainly applied as an addition to ETHERNET in layers 3 and 4. The biggest success of TCP/IP is not only because of the installation in the UNIX 4.2 BSD kernel in 1982. The combination ETHERNET - TCP/IP - UNIX soon became obligatory for many work station manufacturers. In previous years many manufacturers developed TCP/IP products for different systems, thus encouraging its distribution.

IP (INTERNET protocol) attaches directly to layer 2 of ETHERNET (ISO 802.2/ ISO 802.3). It is a protocol without connections and resembles almost layer 3 in the ISO reference model, at which the limits to layer 4 (transport layer) are not precisely defined. IP is responsible for addressing in the network, distribution of data packages and routing in multi network systems.

TCP (Transport Control Protocol) is similar to the ISO transport protocol (level 4) and guarantees control of end-to-end connections. It is based on the IP and makes a number of services available for the user process:

- connection establishment and disconnection
- sequence guarantee and protection against loss
- time control of connections
- multiplexing and transparent data transport

In higher layers different protocols are used based on TCP/IP, which were also defined by the US department of defence: FTP (File Transfer Protocol) for data transmission, TELNET for Terminal Emulation and SMTP (Simple Mail Transfer Protocol) for electronic mail.

TCP/IP allows the user to interconnect different networks. Some advantages are long-term experience, wide distribution and low costs. A continuous increase of this product is to be expected in the following years considering the long life span of communication software.

#### FTP - FILE TRANSFER PROTOCOL

FTP is 100% a file transfer program. Only transfer services like deleting files are defined. Read and write accesses to external system files are not provided. The protocol does not specify a standard for the corresponding file system. The user must be acquainted with the structure of the external file system and the position of the file. No utility tools are offered except the list of directories and the change of the current directory.

FTP communication represents communication according to the "client server" model. FTP builds a virtual terminal connection to the partner system. The access of files (only for transfer purposes) is performed after successful identification by user name and password. The user needs access rights for the external system. Files are transmitted via a separately established data connection, which is operated parallel to the virtual terminal connection.

The transfer service is comfortable and takes into account the difficulties of a correct data transfer between systems of different manufacturers. The initiator of a FTP connection can select the transmission mode and the representation of a file.

### FTP - B&R MAESTRO Example

### TELNET

TELNET offers a standardized possibility to interconnect different type terminals and terminal-oriented processes. The entire TELNET is to be assigned to ISO-levels 5-7 (session, presentation and application level). A connection represents the bidirectional, 8 bit oriented communication possibility, which is based on TCP/IP protocols between two "Network Virtual Terminals" (NVT). The basis of the virtual terminal is the model of the scrollable terminal (line oriented) with ASCII character record.

### **Example TELNET - B&R MAESTRO**

```
> telnet hpunix
Trying 127.51.50.1...
HP-UX otto 6.5 B 9000/360
login: tcp
Password: tcp123
TERM = (hp2392) vt100

Terminal set to: vt100

guest: 11
total 4
-rw-rw-rw- 1 tcp guest 52 May 2 15:35 test
drwxrwxrwx 2 tcp guest 1024 May 2 14:50 tmp
guest: exit
logout
Connected to hpunix .
Escape character is '^]'.
capture closed.
Connection closed by foreign host.
```

# ETHERNET / INTERNET, TCP/IP SOCKET LIBRARY

### INDUSTRIAL NETWORK AND COMMUNICATION ETHERNET





The subdirectory NETCONFIG contains among others the "hosts" file, which describes the correlation between station name and INTERNET address. An additional program converts this ASCII file to a loadable data module ("idbgen"). Included on diskette are several utilities which make working more comfortable:

lestat displays information to a TCP/IP device

mstat network data traffic is displayed clearly on screen; current

data is displayed every second

ispstart starts the TCP/IP software package and initializes the MENC

controller

ispload loads the program necessary for operation in MENC memory

ispdown terminates all network processes and interrupts activity

### TCP/IP SOCKET LIBRARY

The programs "ftp" and "telnet" provide an available access to the network on a TCP/IP base. If user specific data blocks should be sent via the network, accessing functions of the transport layer is possible with the C-library.

All functions can be accessed with the help of a "socket". If an "open" is executed in a file or device, an integer value is usually sent back, which can be referred to in the user process. The big difference between an "open" in a file or device and an "open" in a socket is that a file or device name must be defined. No name must be specified for an "open" in a socket, i.e. the destination can also be defined at a different time. A socket can also be accessed with "read" or "write".

### C FUNCTIONS OF THE SOCKET LIBRARY

A socket is opened with the "socket()" function. After the call a socket is given, but no destination address is specified. With the "bind ()" function specific data from the node is given to the socket.

After this step, either a connection to a different station can be started (active, connect) or a different station gives an establishment request (passive, list and accept). The call "connect ()" is used for the generation of an active establishment demand. The passive partner station can intercept eventual connection requests of other stations with the call "listen ()".

The "bind" function only assigns a port number, not a destination address, thus the socket functions as a "wild card". If a connection should actually be established, then the "accept" function is to be used. The old socket still remains opened and operates as a "wild card". If it is no longer required, it can be terminated again with the call "close".

The data can be sent and received now via the existing connection



**C**3

### **CONTENTS**

INDUSTRIAL NETWORKS AND COMMUNICATION

**INDUSTRIAL NETWORKS AND COMMUNICATION** 



C3	ARCNET	_45T	-91AL	-4;G/L	
	CONTENTS	10 <sup>(1)</sup>	TO LL	10 <sup>1</sup> 1.	270
	GENERAL INFORMATION				
	CABLE, TOPOLOGY AND PLANNING				27
	ARCNET WITH COAXIAL CABLE	47,	2),	4,	272
	ARCNET WITH TWISTED PAIR				27
	MARC - NETWORK CONTROLLER				273
	ARCNET INTERFACE MODULE	1000			
	ARCNET SOFTWARE	ACC	Z.c.		273





# GENERAL INFORMATION / CABLE, TOPOLOGIES AND PLANNING

INDUSTRIAL NETWORKS AND COMMUNICATION ARCNET

### **GENERAL INFORMATION**

ARCNET is a fast network and is used for linking B&R MAESTRO systems or for communication with other systems (e.g. Personal Computers). ARCNET offers an inexpensive alternative to ETHERNET. The MARC network controller is the interface between the B&R MAESTRO system and the ARCNET network. ARCNET performs all accessing by means of a modified token passing technique (ISO 8.4). This makes ARCNET better for time critical tasks than a bus system with CAMA/CD access. The gross ARCNET baudrate is 2.5 MBits/sec. Changes in the network configuration (stations switched on or off) are recognized immediately.


### **CABLE, TOPOLOGY AND PLANNING**

The transfer medium used by ARCNET is either 93  $\Omega$  coaxial cable or a two conductor twisted pair line.

### ARCNET WITH COAXIAL CABLE

The network consists of segments of up to 8 stations and a maximum of 300 meters in length. By linking segments by means of so-called HUBs, the network can be expanded to up to 255 stations. The longest permissible distance between two stations is 6 km (approx. 3.5 miles) when using special amplifiers.

#### Diagram




The MARC network controller has two identical BNC connectors on the from. These are for connecting to the bus cable or to the termination resistor. The difference to other network systems (e.g. ETHERNET) is that no transceiver is required for connecting to a station.

### ARCNET WITH TWISTED PAIR

The twisted pair network consists of segments of up to 10 stations and a maximum length of 120 meters). This method can also be extended to 255 stations with amplifiers.

### Diagram



The line has to be terminated with a 120 W resistance on either end. The twisted pair line must meet the following requirements:

Line Type	22, 24 or 26 AWG	
Number of Twists per Meter	Min. 7	
DC Resistance	Max. 28.6 Ω / 300 m	
Typical Impedance	105 Ω ±20% at 1 MHz	
Maximum Attenuation	16 dB / 300 m at 5 MHz	

### MARC - ARCNET-NETWORK CONTROLLER, **ARCNET INTERFACE MODULE**

INDUSTRIAL NETWORKS AND COMMUNICATION





### **MARC - NETWORK CONTROLLER**

The MARC network controller is used for connecting a B&R PLC (System MULTICONTROL; MULTI or MIDI racks) to an ARCNET network.

Even though the MARC network controller has the design of the B&R MAESTRO system (grey front with blue stripes), it can also be used in systems without the B&R MAESTRO. In this case, the management is completely taken over by the

Another way of connecting to ARCNET is through the MCIF2 PLC bus interface





#### ORDER DATA

The ARCNET network controller MARC is delivered in sets. These sets are divided into three categories:

- **OEM System**
- Development Kit (German)
  Development Kit (English)

Please include the model number (right-hand column) when placing your order.

Component	OEM System	Model Number
Component	OLINOyatem	Modernaniber
HCMARC-0CT SWMAN-0	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair ARCNET Network Software, OS-9/NET	HCMARC:CAX
HCMARC-0CT SWMTN-0	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair INTERNET TCP/IP Network Software	HCMARC:CIX

H	Components	Development Kit (German)	Model Number
50.1	HCMARC-0CT SWMAN-0 MAMNET-0	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair ARCNET Network Software, OS-9/NET B&R MAESTRO Network Manual, German	HCMARC:CAD
	HCMARC-0CT SWMTN-0 MAMNET-0	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, German	HCMARC:CID

	Components	Development Kit (English)	Model Number
N.	HCMARC-0CT SWMAN-0 MAMNET-E	ARCNET Controller, 2.5 MBaud, 93 Ω, Coax/Twisted Pair ARCNET Network Software, OS-9/NET B&R MAESTRO Network Manual, English	HCMARC:CAE
	HCMARC-0CT SWMTN-0 MAMNET-E	ARCNET Controller, 2.5 MBaud, 93 Ω, Coax/Twisted Pair INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, English	HCMARC:CIE

Components	Miscellaneous	Model Number
BRKAARC-0 BRKAARW-0 BRKAARH-0	ARCNET Bus Cable, 10 m, 93 $\Omega$ ARCNET Bus Terminator, BNC, 93 $\Omega$ ARCNET HUB, 8 Coax	BRKAARC-0 BRKAARW-0 BRKAARH-0

### **ARCNET INTERFACE MODULE**

The ARCNET interface module is a combination of application memory module and ARCNET interface. It fits in MINICONTROL CPUs CP30 and CP32 as well as in MULTICONTROL CPU CPU40.

The connection to an ARCNET twisted pair network is either made through a 5 pin terminal block or a 9 pin D-type (F) connection.

The application memory can be write protected with a switch.



### ORDER DATA

ARCNET Interface Module; combination of application memory module and ARCNET interface, to be used in CP30, CP32 and CP40,

Application Program Memory ARCNET Interface:

16 KByte EEPROM, 16 KByte RAM for 4.7 K instructions Linking to a twisted pair network with a 5 pin terminal block or a 9 pin

BRARCIF-0T

### **ARCNET SOFTWARE**

The software for using the MARC network controller and the ARCNET interface module can be ordered as standard software.

The software package contains the PLC to PLC communication, OS-9 Net Server, SPOIO Server (SPECTO\_S) and PC ARCNET driver (TSR Program for

3.5 " Diskette(s)

XL9	AL 9	
German	SWSPSARC01-0	
English	SWPLCARC01-0	



### **CONTENTS**

INDUSTRIAL NETWORKS AND COMMUNICATION



### INDUSTRIAL NETWORKS AND COMMUNICATION CAN BUS

C4	CAN BUS	<i>8</i> 2	20 <sup>01</sup>	Day 70/21
	CONTENTS	247	P. P	274
	GENERAL INFORMATION	4,	4.	276
	CAN BUS CHARACTERISTICS			
	B&R AND CAN			276
	BUS LENGTH AND CABLETYPES	X		276
	B&R PLC SYSTEMS			276
	EXS5 - CAN INTERFACE MODULE			277





# GENERAL INFORMATION, BUS LENGTHS, CABLE TYPES, B&R PLC SYSTEMS

INDUSTRIAL NETWORKS AND COMMUNICATION CAN BUS

### **GENERAL INFORMATION**

### **CAN BUS CHARACTERISTICS**

- Field bus
- Low cost
- Differential signals increase resistance to interference
- Bus structure
- Open system
- Fast data transfer for small data packages (up to 8 bytes)
- Error recognition with CRC (Cyclic Redundancy Check) and frame check
   -> hamming distance 6
- Predictable transfer times for high priority messages (Real-Time behavior)
- Easy use

### **B&R AND CAN**

The controller provided by B&R conforms to the CAN Bus specification 2.0B, therefore, the standard and extended CAN protocols can run on one bus.

B&R software supports the Standard CAN identifier (11 Bit).

### **BUS LENGTH AND CABLE TYPES**


The type of cable to be used depends on the length of the bus and the number of nodes. The bus length is mainly dependent on the bit rate.

The following table contains a few values for the maximum bus length depending on the transmission speed and the synchronization jump width (SJW). The fourth column shows the permitted oscillator tolerance.

The synchronization jump width (SJW) is the factor that determines how close the controller can be synchronized. The larger the synchronization jump width is, the smaller the bus length is.

Bit rate [kBit/sec]	Synchronization Jump Width (SJW)	Bus Length [m]	Permitted Osc. Tolerance [%]
500	0	67	0.121
	1	56	0.242
	2	33	0.363
	3	10	0.485
250	0	215	0.121
	1	192	0.242
	2	147	0.363
	3	101	0.485
125	0	510	0.121
	1	465	0.242
	2	374	0.363
	3	283	0.485
100	0	658	0.121
	1	601	0.242
	2	488	0.363
	3	374	0.485
50	0 1 2 3	1397 <sup>1)</sup> 1284 <sup>1)</sup> 1056 <sup>1)</sup> 829	0.121 0.242 0.363 0.485
20	0	3613 <sup>1)</sup>	0.121
	1	3329 <sup>1)</sup>	0.242
	2	2761 <sup>1)</sup>	0.363
	3	2193 <sup>1)</sup>	0.485
10	0 1 2 3	7306 <sup>1)</sup> 6738 <sup>1)</sup> 5602 <sup>1)</sup> 4456 <sup>1)</sup>	0.121 0.242 0.363 0.485

Number of nodes, length of the bus and what they have in common with certain types of cable:



### **B&R PLC SYSTEMS**

The following control systems have CAN interfaces:

- BRCOMP2 Compact Control
- PLC System MULTICONTROL (CAN Interface Module EXS5)

The compact controller is described in detail in section A2.

The CAN interface module EXS5 is described on the next page.

The maximum bus length is 1000 m (CAN in Automation).

### EX\$5, CAN INTERFACE MODULE

### INDUSTRIAL NETWORKS AND COMMUNICATION CAN BUS





### **EXS5 - CAN INTERFACE MODULE**



### SLOTS

The CAN interface module EXS5 can be operated in MULTI, MIDI and M264 racks in the following slots.

The CAN interface module can be operated in the slot for the EXS2 expansion transmission module in a MULTI base rack (between power supply and CPU).

	Rack	Slot		0	1	2	3	4	5	6	7	8	9	Α	В	CI	0	E	F
Š	MULTI Base Rack	or in	10	an	d in		sle	ot f	or t	he	EX	S2	ехр	ans	sior				• odule
	MULTI Expansion Rack MIDI M264			ò	0		•	Ö •	•	0	0	O	0	0		<b>o</b>	) (	<b>)</b> (	Э
	<ul> <li>The module can be operated</li> <li>The module cannot be operated</li> </ul>						14	120											

### ORDER DATA

ECEXS5-0	CAN interface module with controller to 2.0B specifications
	Of it intortace medale with controller to 2.05 openingations

### TECHNICAL DATA

#### EXS5

Controller	Corresponds with the 2.0B specifications for CAN bus				
Interface IF1		CAN Bus			
Node Number Switch	Two 16	position rotary switches	(0 - F)		
Power Consumption at +8 V		4.8 W			
Resistance to Disturbance		3 kV Burst			
Operating Temperature	'9 <u>0</u> ,	0 - 60 °C	,89°		
Relative Humidity	0	to 95 %, non-condensing			

### IF3 - CAN BUS

The EXS5 CAN interface module is equipped with a CAN bus interface which conforms to ISO\_DIS 11898. The connections to it are made according to CiA DS 102-1.

PIN-OUTS	Pin	Assignment		
O nin D tuno	1		21/2	
9 pin D-type	2	CAN L		
(M)	3	GND		
~1	4			
6	5			
1.34	6	GND		
	7	CAN H		
9	8			
×0 5	9			

### **USING THE CAN BUS**

The CAN bus operates with the CNEX function block. This function block can be obtained as standard software.

	3.5 " Diskette(s)	
German	SWSPSCAN01-0	
English	SWPLCCAN01-0	
ASV		

### CNEX - CAN Client/Server

The function block enables communication over a standard CAN net (11 bit ID) with CAL/CMS services for transmitting object data. No layer or network management services and no identifier distribution services are supported. That means that CAL is an LMT/NMT/DBT slave of class 0 with static CAN ID distribution. Communication is performed with the CMS protocol for variables and for "Uncontrolled Events".

The Client/Server services for "Read-Only Access, Basic Variable" are not implemented. Of the CMS data types, only integers are supported as byte multiples.

Transfer data (max. 8 Bytes) is transferred on the bus in sequence from low to high bytes (LSB to MSB) (Little Endian).

### Abbreviations

CAL	CAN Application Layer	
CMS	CAN based Message Specification	
LMT	Layer Management	
NMT	Network Management	
DBT	Communication Object Distributor	



**C**5

### **CONTENTS**

INDUSTRIAL NETWORKS AND COMMUNICATION

# C5 M



### INDUSTRIAL NETWORKS AND COMMUNICATION

C5	<b>B&amp;R MININET</b>				
	CONTENTS	22,	2/2/2	Nay.	278
	GENERAL INFORMATIO				280
	CABLE AND TOPOLOGY	<i>(</i>			
	CONNECTION TO B&R I	MININET	X	?.×	280
	B&R MININET-SOFTWAR	RE	2. 2.	1,000	281
	ODDED DATA				202





# GENERAL INFORMATION, CABLE AND TOPOLOGY, CONNECTIONS

INDUSTRIAL NETWORKS AND COMMUNICATION B&R MININET

### **GENERAL INFORMATION**

B&R MININET is a universal Master/Slave network for fast and secure transfer of small to medium amounts of data. The Master/Slave structure has the following advantages and disadvantages in comparison to a bus system with token passing:

Advantages: Reaction times are short and can be calculated Valuable connection to existing base systems

Disadvantages: If the master crashes, the entire net goes down

The following devices can be run on a B&R MININET Network:

- B&R PLC Systems (Compact Controller, MINICONTROL, MULTICONTROL)
- BRMEC Mass Memory
- B&R MAESTRO Co-Processors
- PROVIT Industrial Workstations
- XT Operator Panels


Up to 32 stations can be run in a B&R MININET Network. Within the 32 stations, up to 31 PLCs or respectively 7 BRMEC mass memory units are possible. Software operation is handled with standard function blocks. Individual station parameters are defined by filling out simple tables.

### **CABLE AND TOPOLOGY**

RS485 twisted pair cable is used as the transfer medium. This cable must meet these requirements:

 $\begin{array}{lll} \mbox{Type} & \mbox{Two conductor, shielded twisted pair} \\ \mbox{Cross Section} & \mbox{Min. } 0.5 \mbox{ mm}^2 \\ \mbox{Line Resistance} & 120 \ \Omega \\ \mbox{Termination Resistance} & 120 \ \Omega \mbox{ on each end} \\ \mbox{Length} & \mbox{Max. } 1200 \mbox{ m} \\ \mbox{Max. Line Resistance} & 50 \ \Omega \mbox{ per branch} \\ \end{array}$ 

The cable shielding on the bus cable is to be grounded for every station (e.g. with a grounding clamp to the ground rail under the PLC). D-type connectors are to have metal housings with direct shield contact. Wiring the RS485 network is only permitted in the bus structure. The bus connection can be made either direct or over a maximum 2.5 m branch line.



RS232, RS422 or TTY interfaces can also be used for point to point connections. These types decrease the communication distance respectively.

### **CONNECTING TO B&R MININET**

All B&R devices can be connected directly to a B&R MININET network with an RS485 interface. RS232 interface modules require the use of a RS232/RS485 interface converter (INT1). TTY and RS422 interface modules cannot be connected. Overview:

SYSTEM/Rack	MODULE	INTERFACE	CONNECTION
Compact Control		RS485	Direct
MULTI	PIF1	RS232	Through INT1
MIDI	PIF3	RS232	Through INT1
M264	PP60	RS485	Direct
	CP70	RS485	Direct
M264	NTCP6#	RS485	Direct
MINICONTROL	CP32	RS485	Direct
	PIFA-2	RS232	Through INT1
B&R MAESTRO	MCO1, MCO3, MCO3MC	RS485	Direct
	MCIF2	RS485	Direct
	MSIO	RS485	Direct
PROVIT Industrial Workstation	PROVIT 1345, 1830	RS485	Direct
XT Operator Panels	BRXTGR31, BRXTGR35	RS485	Direct
Mass Memory	BRMEC	RS485	Direct

#### PLC SYSTEMS

PLC systems can be connected directly to a B&R MININET network if a module with an RS485 interface is used. The only exception is the PIFA-3 MINICONTROL interface module. This module may not be connected to B&R MININET. The connection of a MINICONTROL system is usually made through a CP32 CPU which is standardly equipped with a B&R MININET capable RS485 interface.

B&R MININET software either runs on a CPU or a peripheral processor. The package contains driver function blocks for all interfaces. The station number is defined in an initialization table with software

### **B&R MAESTRO SYSTEM**

B&R MAESTRO Co-Processors (MCO1, MCO3, MCO3MC), PLC bus interface module MCIF2 and the B&R MAESTRO interface module MSIO, all have RS485 ports. They can all be connected directly into the B&R MININET network.

A B&R MININET driver is required for B&R MAESTRO systems. This driver is a component of the driver software package SWMDRV-BR. The driver software package is also included in the SPECTO\_S visualization system.

### PROVIT INDUSTRIAL WORKSTATIONS

PROVIT Industrial Workstations PROVIT 1345 and PROVIT 1830 are both equipped with four serial interfaces, some of which are RS485 interfaces. These can be linked directly to a B&R MININET network.

A B&R MININET driver is required for connecting a PROVIT Industrial Workstation to a B&R MININET network. This is a component of driver software package SWMDRV-BR. The driver software package is also included in the SPECTO\_S visualization system.

# CONNECTION, B&R MININET-SOFTWARE

### INDUSTRIAL NETWORKS AND COMMUNICATION B&R MININET





### **BRMEC MASS MEMORY**

The BRMEC mass memory unit can be linked directly into the B&R MININET network. The B&R MININET software is already implemented into the BRMEC. The station number is set with a switch. For controlling the BRMEC over the network, special drivers and operation function blocks are required.

### XT OPERATOR INTERFACE PANELS

The XT operator interface panels BRXTGR31 and BRXTGR35 both have RS485 interfaces. They can be connected directly to a B&R MININET network.

For connecting an XT operator interface panel into a B&R MININET network, a B&R MININET driver is needed. This is a component of the SWMDRV-BR driver software package. The driver software package is also included with the SPECTO\_S visualization system.

### **B&R MININET SOFTWARE**

Connecting B&R MAESTRO industrial computer systems, PROVIT industrial workstations or XT operator interface panels to a B&R MININET network is normally done with an OS-9 driver. The following section refers exclusively to the use of B&R MININET with PLC systems.

B&R MININET network control is all done with function blocks. The parameters for some of these function blocks are defined with preprogrammed tables. The B&R MININET software is divided into driver function blocks and operation function blocks:

**Driver** - Driver for interface operation

Data transmission and receiveError recognition and reporting


\_\_\_\_\_\_

Operation - Operation function blocks for PLC and BRMEC mass memory

- Error recognition and reporting

### DRIVER FUNCTION BLOCKS IN THE MASTER PLC

A driver function block is required for every device that is to run in a B&R MININET network. This driver initializes the serial interface, sends the unit's data onto the network and receives incoming data.




The driver function block that is used depends on the interface of the device to be connected:

Module / Interface	Function Block	
PIFA, PIF1, PIF3	NDMA	
CP32	NDMB	
CP70, PP60, NTCP6#	NDMC	

#### **OPERATING A SLAVE PLC**


Operating one or more slave PLCs is done with the NPLM function block. The commands that a master can give to a slave are defined in the TPLC table.



The right to transmit is sent from one function block to another. Operation function block NPLM can only send a command to the slave PLC if it has the right to transmit. Contact is made via a driver function block.

### **OPERATING BRMEC MASS MEMORY**

Processing with one or more BRMEC mass memory units is done with the NMCD function block. The commands that the master can give to the BRMEC are defined in the TMCD table. Selecting the BRMEC is done with the station number in the TMCD table.



The right to transmit is sent from one operation function block to another. The NMCD operation function block can only send its command to the BRMEC if it has the right to transmit. Contact is made through the driver function block.

NAME	FBK/TABLE	FUNCTION
NMCD	BRMEC Driver	For operating BRMEC mass memory
TMCD	BRMEC Configuration table	Defines the possible commands, that the MASTER PLC can send to the BRMEC






### B&R MININET SOFTWARE, ORDER DATA

INDUSTRIAL NETWORKS AND COMMUNICATION B&R MININET

### DRIVER FUNCTION BLOCK FOR SLAVE PLC


A driver function block is required for every device that is to run on a B&R MININET network. This driver function block initializes the serial interface, sends the units data to the network and receives incoming data.



The driver function block that is used depends on the interface of the respective device:

Module / Interface	Function Block	
PIFA, PIF1, PIF3	NDSA	
CP32	NDSB	
CP70, PP60, NTCP6#	NDSC	

### SLAVE PLC OPERATION FUNCTION BLOCK



The NPLS function block executes the master's commands and informs the user of its actions.

### **ORDER DATA**

B&R MININET is based on standard interface modules and devices with standard interface modules. Software and user's manual are included in the B&R MININET package.


Standard software package 5, Software for the PLC network B&R MININET, including User's Manual

### **INDUSTRIAL NETWORKS AND COMMUNICATION B&R MININET**





NOTES:





**C6** 

### **CONTENTS**

INDUSTRIAL NETWORKS AND COMMUNICATION OTHER PROTOCOLS

**INDUSTRIAL NETWORKS AND COMMUNICATION** 





C6	ΟI	HER	PRO	IOCOL:	5

CONTENTS			284
GENERAL INFORMATION		x2	286
OTHER PROTOCOLS WITH B&R MAESTRO SYSTEMS	22	<u> </u>	286
NP02 - COMMUNICATION PROCESSOR			286
STANDARD SOFTWARE PACKAGES	4	42	287
STANDARD SOFTWARE PACKAGE 6			287
STANDARD SOFTWARE PACKAGE 7			287
STANDARD SOFTWARE PACKAGE 8			287
STANDARD SOFTWARE PACKAGE 9		-197	287
SPECIAL PROTOCOLS			287





# GENERAL INFORMATION, OTHER PROTOCOLS FOR B&R MAESTRO, NP02 COMS. PROCESSOR

INDUSTRIAL NETWORKS AND COMMUNICATION OTHER PROTOCOLS

### **GENERAL INFORMATION**

Individual PLCs or groups of PLCs must be integrated into existing automation structures for many different application circumstances. This is practically always connected with the requirement for communication between different systems. Almost all PLC manufacturers develop and provide communication protocols between systems of their own design. The problem only comes into effect if systems of different manufacturers must be combined for the best results.

While the more powerful networks, e.g. ETHERNET applications SINEC H1 and INTERNET (TCP/IP) are established worldwide and are appreciated as standards, almost every manufacturer also produces their own network in the field bus range. There are now so many different field bus networks that it creates a area of confusion for the user and unfortunately it also leads to many network incompatibilities.

Since standardization hasn't taken an easy course to follow in making a definite worldwide fieldbus system standard, B&R has taken the strategy of the "Open System", i.e.:

- Hardware and software for communication with other systems is offered
- The components used in the interface modules are almost unlimitedly accessible to the user, which also enables the creation of new or application specific interface protocols.

### OTHER PROTOCOLS B&R MAESTRO SYSTEMS

The OS-9 driver is used in B&R MAESTRO industrial computer systems, PROVIT industrial workstations and XT operator interface panels for enabling communication with other systems. Currently, the following protocols are available:

- S3964 (R) (RK512)
- Ľ

Other drivers upon request.

### **NP02 - COMMUNICATION PROCESSOR**

An NPO2 communication processor can be obtained through B&R for communication through other protocols. The protocol is delivered on EPROM and inserted on the NPO2.

A standard software diskette is also required. The software packages are listed on the following page.



Der NP02 Communication processor can also be operated in an M264 rack (slot 0). Currently, the following protocols are available for the NP02 communication processor:

- MODBUS
- S3964 (R) (RK512)
- Honeywell CIM620
- A+B Data Highway
- L
- B&R MININET

### ORDER DATA

NP02 Communication processor, without EPROM memory	ECNP02-0
EPROM Memory with MODBUS Protocol	SWNP02DP01-0
EPROM Memory with S3964(R) Protocol (RK512)	SWNP02DP02-0
EPROM Memory with Honeywell CIM620 Protocol	SWNP02DP03-0
EPROM Memory with A+B Data Highway Protocol	SWNP02DP04-0
EPROM Memory with L1 Protocol	SWNP02DP05-0
EPROM Memory with B&R MININET Protocol	SWNP02DPMN-0
LETION METHOLY WITH DATA MININET FIOLOGOI	SVVINFUZDFIVIIV-U

The order numbers for the standard software packages are listed on the next page.

### STANDARD SOFTWARE PACKAGE, SPECIAL PROTOCOLS

### INDUSTRIAL NETWORKS AND COMMUNICATION OTHER PROTOCOLS





### STANDARD SOFTWARE PACKAGES

Parameter definition software is also required for communication using different protocols. The standard software package must correspond to the protocol that will be used.

### STANDARD SOFTWARE PACKAGE 6

Standard Software Package 6 includes package 1 and additional communication software for linking into a MODBUS system.

#### **Order Data**

Standard software package 6, general utilities (comparators, counters, timer functions, system functions, number conversions, analog I/O module operation, arithmetic programs etc.), standard software for connection to MODBUS systems.

	-7 <sub>f0</sub> ,	3.5 " Diskette(s)	$-2i_0$ .
German English	20,0	SWSPSDRV01-0 SWPLCDRV01-0	1900

### STANDARD SOFTWARE PACKAGE 7

Standard software package 7 includes package 1 and additional communication software for connecting to S3964 (R) (RK512) systems.

#### Order Data

Standard software package 7, general utilities (comparators, counters, timer functions, system functions, number conversions, analog I/O module operation, arithmetic programs etc.), standard software for connecting to Siemens S3964 (R) (RK512) systems.

20	3.5 " Diskette(s)	26,
German	SWSPSDRV02-0	"Afr
English	SWPLCDRV02-0	

### STANDARD SOFTWARE PACKAGE 8

Standard software package 8 includes package 1 and additional communication software for connecting to Honeywell CIM620 Systems.

### Order Data

Standard Software Package 8, general utilities (comparators, counters, timer functions, system functions, number conversions, analog I/O module operation, arithmetic programs etc.), standard software for connection to Honeywell CIM620 systems.

The state of the s	3.5 " Diskette(s)	
German English	SWSPSDRV03-0 SWPLCDRV03-0	

### **STANDARD SOFTWARE PACKAGE 9**

 $Standard\,software\,package\,9\,includes\,package\,1\,and\,additional\,communication\,software\,for\,connecting\,to\,Allen\,Bradley\,Data\,Highway\,systems.$ 

### Order Data

German English

Standard software package 9, general utilities (comparators, counters, timer functions, system functions, number conversions, analog I/O module operation, arithmetic programs etc.), standard software for connection to Allen Bradley Data Highway systems.

40,	3.5 " Diskette(s)	160,
1000	SWSPSDRV04-0	'92 <sub>00</sub>

### **SPECIAL PROTOCOLS**

An exact knowledge of the interface IC is absolutely necessary for developing new application specific protocols. Two interface ICs are used in B&R modules:

- 6551
- 68681

The exact functions of these components can be found in the data sheets provided by the manufacturer. The following table shows which B&R modules and devices are equipped with which IC:

	Module / Device	Description	SYSTEM/Rack	IC
	PIFA CP32	Interface Module CPU	MINICONTROL MINICONTROL	6551 6551
	PIF1 PIF3 PP60 CP70	Interface Module Interface Module Peripheral Processor CPU	MULTI, MIDI, M264 MULTI, MIDI, M264 MULTI, MIDI MULTI, MIDI	6551 6551 68681 68681
	NTCP6#	CPU	M264	68681
S	MCO1, MCO3 MCIF2 MSIO	Co-Processor PLC Bus Interface Module Interface Module	B&R MAESTRO B&R MAESTRO B&R MAESTRO	68681 68681 68681


If you need support or are not certain whether a certain protocol is available at B&R for the development of a special protocol, please contact the B&R representative responsible for your area.





### INDUSTRIAL NETWORKS AND COMMUNICATION OTHER PROTOCOLS

NOTES:



## INDUSTRIAL COMPUTER

D



**B&R MAESTRO SYSTEM** 

1



**B&R MAESTRO COMPONENTS** 

2



INDUSTRIAL COMPUTER SOFTWARE

3







#### INDUSTRIAL COMPUTER

וע	SYSTEM B&R MAESTRO	147.	- A.	- 12h.	
	n,				27,2
	CONTENTS				
	SYSTEM B&R MAESTRO				
	GENERAL INFORMATION				8
	THE OS-9 OPERATING SYSTEM				
	MICROWARE - THE "CREATOR" OF	OS-9			8
	OS-9, A MODULAR REAL-TIME OPE				
	MODULE STRUCTURE				
	MEMORY MANAGEMENT				
	MODULE DIRECTORY				9
	RE-ENTRANT CODE				
	POSITION INDEPENDENT CODE				
	MODULES IN EPROM				
	GHOST MODULES				
	FILE MANAGERS			······	10
	DEVICE DRIVERS				
	DEVICE DESCRIPTORS				
	I/O MANAGEMENT				
	PROCESS MANAGEMENT				
	REAL-TIME FUNCTIONALITY				
	COMMUNICATION BETWEEN THE F				
	DATA MODULES				
	PIPES				
	EVENTS				
	SIGNALS				
	INTERRUPTS				13
		The same		Ty.	2.
)2	<b>B&amp;R MAESTRO COMPONENTS</b>				
	CONTENTS				
	SYSTEM CONFIGURATION		<u></u>	<u>,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,</u>	16
	MODULE RACKS				
	HCR166-0				
	HCR169-0				16
	B&R MAESTRO COPROCESSORS				
	AS A SINGLE PROCESSOR IN THE I				
	MCO AS MAIN PROCESSOR IN A BE				
	MULTIPROCESSOR SYSTEMS				
	ORDER DATA		<u></u>		18
	76,				3,
	PLC-BUS INTERFACE MODULE MCIF2 .				
	MEMORY EXPANSION MODULE MM8M				
	MCO HARD DISK				21
	EL ODDIV DIOV OTITIONO				
	FLOPPY DISK STATIONS				
	FLOPPY DISK STATION MFDD700				
	FLOPPY DISK STATION MFDD70S				23
	NETWORKS				0
	NETWORKS				
	ETHERNET				
	ARCNET				25
	DOD MATCTOO INTEREACT CONTROL	LED WITH			00
	B&R MAESTRO INTERFACE CONTROLL				
	GRAPHIC CONTROLLER				
	PROVIT INDUSTRIAL MONITOR				
	MAC1 AXIS CONTROLLER				
	DUMMY FRONTS				
	DOCUMENTATION				





## INDUSTRIAL COMPUTER

<b>D</b> 3	INDUSTRIAL COMPUTER SOFTWARE					
	CONTENTS	Ma	No.		Ma	3
	GENERAL INFORMATION	`	. 6			34
	GRAPHIC USER INTERFACE		- 12/10.	77/2.,		3
	SPECTO_S VISUALIZATION SOFTWARE		C.,	10/10		3
	SPOIMG - PROCESS DATA MANAGEMENT			- 12 p		3
	OS-9/TOOL KIT					3
	DRIVERS FOR REMOTE CONNECTIONS					3





INDUSTRIAL COMPUTER B&R MAESTRO SYSTEM

INDUSTRIAL COMPUTER
B&R MAESTRO SYSTEM





#### D1 B&R MAESTRO SYSTEM


CONTENTS				292
	EM			
<b>GENERAL INFORMAT</b>	ION	A		296
THE OS-9 OPERATING	G SYSTEM	<i>X</i>	<i></i>	296
MICROWARE - TH	IE "CREATOR" OF OS-9			296
OS-9, A MODULAI	R REAL-TIME SYSTEM	<u>*O``</u>		296
MODULE STRUCT	ΓURE			297
MEMORY MANAG	SEMENT			297
MODULE DIRECT	ORY			297
RE-ENTRANT CO	DE			297
POSITION INDEP	ENDENT CODE			297
MODULES IN EPP	ROM	·····		297
GHOST MODULES	S	<u> </u>	<u>. C</u>	298
FILE MANAGERS			<i>Y</i>	298
DEVICE DRIVERS	S			298
DEVICE DESCRIP	PTORS			298
I/O MANAGEMEN	Т			298
PROCESS-MANA	GEMENT			299
REAL-TIME FUNC	TIONALITY			299
COMMUNICATION	BETWEEN THE PROCESSE	S		300
DATA MODUL	ES			300
PIPES		<b></b>		300
EVENTS		<u> </u>	<u></u>	301
SIGNALS	× X2		<i>Y</i>	301
INTERRUPTS				301







## **B&R MAESTRO SYSTEM**


INDUSTRIAL COMPUTER
B&R MAESTRO SYSTEM



















## **B&R MAESTRO SYSTEM**

## INDUSTRIAL COMPUTER B&R MAESTRO SYSTEM


D1










## B&R MAESTRO S Y S T E M













#### GENERAL INFORMATION, THE OS-9 OPERATING SYSTEM

INDUSTRIAL COMPUTER B&R MAESTRO SYSTEM

#### **GENERAL INFORMATION**

B&R offers an unbeatable combination of PLC and powerful Real-Time Multitasking computer in the form of the MAESTRO industrial computer. The computing power is not installed where you can somehow fit it in. It is integrated where it is needed - in the PLC. The advantages of this system are overwhelming. The industrial computer no longer communicates with the PLC through slow serial interfaces. The computer is in the PLC and can access all PLC peripherals directly and without any lost time. Combined with the strength of the multitasking OS-9 operating system, the B&R MAESTRO provides you with optimal real-time data processing. The areas in which the B&R MAESTRO can be put to use are just as diverse as the PLC's application range. Whether in the automobile industry, the petrochemical, mechanical engineering, in the food stuff industry, the steel, aluminium or synthetic industry, the B&R MAESTRO harmonizes with the requirements of the job and with the environment. The following section explains the OS-9 operating system in a bit more detail.

#### THE OS-9 OPERATING SYSTEM

In the last few years, the OS-9 operating system has become more popular in the industrial field. Besides the flexibility and the simplicity of the system, this development also includes features like multi-user and multitasking capabilities, real-time processing, 100% ROM capability and modular structure to name a few. Increasingly complex industrial applications are demanding systems that can handle today's requirements and at the same time can satisfy the developments of tomorrow.

#### MICROWARE - THE "CREATOR" OF OS-9

To be a successful software business you have to do a lot more now days than just bring an innovative product onto the market. Success in this area is based on fulfilling customer desires and staying with the requirements of the market in that respect. This produces a steady climb in the evolution of hardware and software. Microware Systems was founded in 1977 by a group of programmers. Right from the very start, the group insisted that advancement would not continue along the line of large and general use computers. They picked the route of an increasing market of small ROM based industrial computers and midsized multitasking systems. Microware's first product, the RT/68, was the first real-time system ever found on a single ROM chip. Microware followed the philosophy of the independent module. This "memory module" concept managed all data and programs in memory. Memory modules are linked dynamically by the kernel during processing. This revolutionary concept allowed Microware to grow along with microprocessor technology. In the same aspect, this modular concept enabled the integration of the operating system in just about any hardware environment. The result brought OS-9 to a real-time operating system with a complete software development environment. Today the products of Microware are grouped around the OS-9 operating system, the modular realtime multitasking operating system for Motorola 680x0 processors.


OS-9 has now reached a high level of acceptance in research and in industrial applications. The acceptance is based on its efficiency and on compact and economical real-time applications. OS-9 can now be found in almost all areas of the computer industry. It has been integrated into many different systems in many different areas such as process computing engineering, visualization, data management, machine control etc. OS-9 is the only operating system that can be used throughout the entire range of the 68000 family from small ROM oriented systems up to large multi-user systems. OS-9 combines the advantages of new operating system concepts and real-time possibilities with the global structure of the UNIX operating systems. Today, OS-9 requires less memory than UNIX and therefore much more efficient.

#### OS-9, A MODULAR REAL-TIME OPERATING SYSTEM

The main job of an operating system is to manage the resources and functions of a computer. This naturally includes the interface between the user and the computer, the entire I/O system, file system management for the data and program storage, application memory management and much more as well.

OS-9 is a real-time operating system. That means that OS-9 not only supports a real-time kernel and the respective system modules but all file manager and device driver are also real-time capable. OS-9 uses time sharing and multitasking for managing I/O requirements. The user's working environment has a desktop similar to the UNIX shell, hierarchical directory and file architecture and over 70 utility programs provide user access to the functionality of the operating system.

The modular design of OS-9 every user to construct OS-9 to suit his/her individual requirements. Every modular component of OS-9 with the exception of the kernel can be used or ignored depending on the requirements of the application. This makes the system very easy to expand. The heart of the operating system is the kernel. It supports system routines, memory, I/O and process management. The simplest version of OS-9 is the kernel together with the init module. The next modules to be integrated are the file manager and the respective I/O systems. Microware has created the right file manager for any type of I/O device. All hardware specific sections are taken care of by the device driver. Every program, whether utility or application, can now be integrated in the exact same way. When calling a program, it is loaded to memory and can be used from there. Programs that are used more often can be loaded with a system boot automatically in order to avoid wasting time in the future since the loading procedure is no longer required.



Memory modules are the basis of OS-9. This modularity provides the user with the ability to set up a system with various optional modules according to the application requirements. Here is a short example: A small single board computer based on an EPROM needs the modules that are required for operating mass memory, but not very often. This modularity also guarantees that OS-9 can be adapted to suit the most varied of hardware conditions. An adaptation does not mean making changes to a complex operating system in this case, it simply means modifying a single module which is responsible for the respective task. In addition, the changes and adaptations can be made while the operating system is running and it is not necessary to reboot the system every time. It is thanks to OS-9 that the modularity is being used in the application range from single board computers right up to large industrial multi-user systems.

Another major advantage is the full ROM capabilities of OS-9 modules. This affects operating system segments as well as the application programs. OS-9 recognizes different sorts of modules whereas the different types of modules have different tasks and functions. Modules don't always have to be complete programs and they do not have to be programmed in an assembler language. The only requirement that these modules must fulfil is that they do not modify themselves and that they must remain in a certain position in memory. This enables OS-9 modules to be loaded into the area reserved for them. OS-9 organizes the modules in a so-called module directory. The module directory is generated automatically and contains data concerning all modules, such as the name, start address, size access rights, etc.

#### MODULE STRUCTURE, MEMORY MANAGEMENT, MODULE DIRECTORY

INDUSTRIAL COMPUTER **B&R MAESTRO SYSTEM** 








#### MODULE STRUCTURE

Every module has a certain structure which is exactly the same whether the module is the kernel, a file manager, a data module or an application program. An OS-9 module consists of three different parts:



Module Header:

The module header contains information which is used by the kernel or by other programs. The header contains information such as the module name, module type, size, access rights, revision, memory requirements and program offset. The module header is secured by means of a parity

Module Body:

The module body contains the actual program or the functions of the

CRC Check Value: The last three bytes of the module contains the CRC Check Value (Cyclic Redundancy Count Value), to check the validity of the module. CRC is an algorithm for recognizing errors in data blocks whereas the recognition is much more accurate than simple parity checks. The CRC value is checked if the module is loaded to the module. If an error is found, OS-9 doesn't load the module to memory and reports the respective error message

#### **MEMORY MANAGEMENT**

RAM can be obtained in large capacities which makes creating long and complex programs easier. The kernel dynamically allocates memory as system memory for application programs.

Organizing the modules is simple and logical. Programs and tables are organized from the highest RAM address and data arrays and variables are organized from the lowest RAM address. This guarantees that the most possible memory is available in one block and that the remaining memory is not split into segments.

#### MODULE DIRECTORY

OS-9 has a memory map which manages all memory. The processes share a common memory area. OS-9 manages all modules that are found in memory. If a process wants to start a program, the kernel checks whether the desired program module is in the module directory. If the program module is in the memory, it is then started. If the program module is not in the memory, the program must be loaded from mass memory, the integrity of the module must be checked and then it must be entered to the module directory before the program can be started. In order to recognize when a module is no longer required and therefore able to be removed from memory, every module is provided with a so-called link count.


Before a program is started, the link count must be increased by the kernel, i.e. the number of processes that is being used by this module is increased. After ending the program the link count is decreased by one, i.e., the number of processes used by this module is decreased. If the link count reaches zero, this is the signal for the kernel that this module is no longer needed and can be deleted from memory. The module is then automatically deleted from memory and therefore doesn't block any main memory.

If a module should always remain in memory, the module must be loaded. When the module is loaded, its link count is set to one. This means that the value zero can no longer be reached in the normal run of the program which in turn means that this module can also no longer be deleted from memory.

#### **RE-ENTRANT CODE**

To minimize memory requirements, OS-9 uses re-entrant programming techniques. Modules that do not modify themselves are called re-entrant. Re-entrant code means a strict division between program and data ranges. This enables the same module to be used by different processes at the same time. In this case, only the respective data area is double occupied. The entire OS-9 family is re-entrant.

Here is an example. The Microware text editor uMACS uses 43 Kbyte memory. A request to start the editor is made to the operating system even though it is already being used by another process. OS-9 allows both processes to use the same program. This saves 43 Kbytes whenever the editor is called again.



#### POSITION INDEPENDENT CODE

Since OS-9 modules are managed within a common memory range, they are position independent and can therefore be located anywhere in the OS-9 memory range. This places one of the most substantial loads on a modular system so that the modules can be used in the least amount of space independent of a certain memory address.

#### **MODULES IN EPROM**

After starting OS-9 the kernel searches the memory for modules. The modules are recognized by the header sync-code (\$4AFC). If this bit pattern is found, the header parity is checked. If this is successful, the kernel reads the size of the module from the header and does a CRC check throughout the entire module. The module is only put into the module directory if this test is successful. This makes it possible to have a partial or complete EPROM oriented system.





## GHOST MODULES, FILE MANAGER, DEVICE DESCRIPTORS, I/O MANAGEMENT

INDUSTRIAL COMPUTER B&R MAESTRO SYSTEM

All valid modules in EPROM (Application programs as well) are put into the module directory. Since OS-9 modules are re-entrant and do not modify themselves, it is not necessary to load or copy modules that are on EPROM again into the main memory. Modules found in EPROM are executed directly from the EPROM. This saves a considerable amount of RAM space.

#### **GHOST MODULES**

OS-9 supports so-called "Ghost Modules". Programs are not deleted from the module directory after they are ended even if the link count reaches zero. If the program is called again after a while, the module is still in memory and does not have to loaded again. OS-9 Ghost Modules remain in memory until they are deleted from the module directory or until the memory is required for other processes. Modules are only regarded as Ghost-Modules if the link count is zero and only then can they be deleted from memory. The function of the ghost modules is a very important instrument in optimizing memory capacity utilization

#### **FILE MANAGERS**

File managers support I/O processing for different types of I/O devices. OS-9 file managers are re-entrant which means that one file manager can be used by several different device drivers. This way, an RBF can be used, for example, to use a hard disk and a floppy disk at the same time. Several file manager are shown below:

	NAME	ABBREVIATION	UTILIZATION
	Sequential Character File Manager	SCF	for sequential oriented I/O devices (e.g. serial or parallel interfaces)
	Random Block File Manager	RBF	for block oriented mass memory (e.g. Hard Disk, Floppy Disk, Memory Disk)
110	Pipe File Manager	PIPEMAN	for communication between processes through memory buffers (pipes)
	Sequential Block File Manager	SBF	for sequential block oriented devices (e.g. Streamer Tapes)
	Network File Manager	NFM	connects OS-9 systems with one another independent of the type of network

#### **DEVICE DRIVERS**


Device Drivers make up the physical interface between the file manager and the device. Device drivers are naturally re-entrant as well so that several devices can be operated with one module. Device drivers are a collection of seven subprograms:

- 1. Initialize device
- 2. Read a standard unit
- 3. Write a standard unit
- 4. Request a specific device status
- 5. Set a specific device status
- 6. Deinitialize the device
- 7. Routine for error handling

Device drivers contain no organizational functions, these are done completely by the file managers.

#### **DEVICE DESCRIPTORS**

Device descriptors are small non-runnable modules in the form of tables containing device specific data. Among other things, the device descriptor contains the names of the respective file manager and the device driver. Device descriptors are assigned to one single device. If more devices of the same type exist, they are identical for the user (more than one serial interface) but they have different internal addresses which means that each of the devices must have its own device descriptor.



#### I/O MANAGEMENT


OS-9 uses a modular and hardware independent I/O system that can be expanded or made smaller to suit the application needs. The I/O system uses paths similar to UNIX paths for addressing the devices used.

Here are some examples:

Floppy Disk: /f0/<directory>/.../sfile name>
Hard Disk : /h0/sdirectory>/.../sfile name>
Memory Disk: /m0/<directory>/.../sfile name>
Streamer Tape: /mt0
Serial interfaces: /t1, /t2, /t3, /t4, ...
Network: /n0/<station\_name>/<device>/<directory>/.../sfile\_name>

OS-9 is different from UNIX in that a large amount of I/O tasks from the kernel are put into the file manager. The entire I/O system is interrupt controlled and therefore real-time capable.

Now, lets take a look at accessing a device:



The access is made through the device descriptor e.g. "dir /h0". The kernel will pass these tasks on. The kernel reads the responsible file manager from the descriptor and passes the majority of the work to the file manager. The kernel works under ideal conditions. It doesn't have to worry about which type of device is in question, how that device is controlled or which logic functions are to be processed in which order. The advantage is that the kernel only knows one access to one path which means that the programmer only has to access one path. The path can now be a file, an interface, a network station or another device independent of the file manager. This enables the integration of completely new

## PROCESS MANAGEMENT, REAL-TIME FUNCTIONALITY

INDUSTRIAL COMPUTER
B&R MAESTRO SYSTEM





devices in an existing system, since the kernel doesn't change. Only the respective file manager, the device driver and device descriptor must be defined for the system. This allows programs to be simply expanded to other system devices, e.g. connecting another visualization device, another printer etc., even if the devices operate from the same processor or if they are linked via network.

#### PROCESS MANAGEMENT


The OS-9 multitasking kernel allows more processors to work at the same time. This is done through task switching and by communication between the processors. The operating system supports this with automatic distribution of CPU computing time with the help of a technique called "Time Slicing". "Time Slicing" allows one process to share its CPU time with other active processes. OS-9 uses an task model similar to UNIX with a priority controlled distributer which distributes the CPU time to the processes. The CPU time is split up with a real-time clock into certain time intervals (ticks). OS-9 can interrupt a process with each of these ticks and assign the computing power to a different task. Starting and stopping is done so that the run of the program is not influenced. The priority is determined by the number of ticks in the process. A process can have up to three different states independent of this:

STATUS	MEANING
ACTIVE	The process is active and ready to work.
WAITING	The process is inactive until a sub-process is ended or until it gets a signal. In this state, the process doesn't need any computing power.
SLEEPING	The process is inactive for a certain time or until it gets a signal.  In this status, the process doesn't need any computing power.

Lists containing all processes exist. The current status of the process is also shown in these lists. All active processes are entered in the active list and are sorted according to a process "Age". The process age is a count of how many process switches have been made since the process entered the list, plus the process' initial priority.

# tick Priority → Process Age tick +1 tick +1 tick +1 tick +1 tick +1 tick Priority → Process Age tick +1

This count is incremented by one with every tick (possible task switch). Since the list is sorted according to the process age, the "oldest" process is at the top of the list and gets the computing power with the next task switch. After distributing the computing power, every process is put back into the list with its new priority. The following diagram shows the distribution of the computing power by means of an example. It is quite easy to see that the difference between the individual priorities roughly corresponds to the relationship to the assigned computing power. The more processes that exist, the less precise a forecast can be given. However, you can see that even small changes in the priority cause relatively large changes in the distribution of computing power. Therefore priorities should be handled carefully so that processes that are not so important do not get the same amount of computing power as important processes.



Sooner or later the conclusion is made, that a multitasking system doesn't mean assigning the most possible computing power for every single process. This only leads to a slow down of the whole system. Being a bit careful in the distribution of the computing power often improves the efficiency more that increasing the power of the computer itself.

#### **REAL-TIME FUNCTIONALITY**

IEEE defines a real-time operating system as a system "that makes its functions available because of external event in a predictable amount of time". This means that the following characteristics should observed:


- Priority controlled, advanced task switching to assure that the tasks with the highest priority are processed first, if they are ready
- Direct control of the scheduler with application processes to guarantee that the respective tasks are processed
- Interrupt handling ability in order to react to an asynchronous external event within a defined amount of time
- Real-time process synchronization that guarantees the data exchange between processes

#### **Pre-emptive Task Switching**

During critical real-time applications, fast interrupt response times are necessary. OS-9 provides this by pre-empting the currently executing process when a process with a higher priority becomes active. The lower priority task loses the remainder of its time slice and is re-inserted into the active queue.

#### Process Run Control

A special OS-9 system call (F\$SetSys) is used for control of the process activity. This call can be used to change global variables "D\_MinPty" (Minimum Priority) and "D\_MaxAge" (Maximum Age). "D\_MinPty" defines the lowest priority value under which processes are neither aged nor considered candidates for execution or task switching.



"D\_MaxAge" is the maximum age that processes are allowed to have. When this variable is activated, it essentially divides tasks into two classes: low and high priority. Low priority tasks stop processing at the "D\_MaxAge" cutoff. Therefore, all high priority processes have all of the computing power that they require since they are always above the lower priority processes in the table. Only if the higher priority processes voluntarily submit their CPU time-slice, i.e. become inactive (e.g. because of an event, signal, sleep, ...), can the lower priority processes obtain CPU time. Processes with a priority above "D\_MaxAge" do not age. This means that the priority is identical to the process age and is to be considered as






## COMMUNICATION BETWEEN THE PROCESSES, DATA MODULES, PIPES

INDUSTRIAL COMPUTER B&R MAESTRO SYSTEM

constant. Since this deals with real-time operation, the processes above "D\_MaxAge" are not interrupted by a task switch again. Every process remains with its set priority until a higher priority becomes active or until the current process resigns its time-slice.




#### COMMUNICATION BETWEEN THE PROCESSES

OS-9 offers four possibilities of synchronizing processes or communicate between them


- Data module
- Pipes
- Events
- Signals

These four mechanisms are a very efficient set of tools for solving almost any problem.




#### **Data Modules**

The data module is an OS-9 memory module with module header, module body and CRC check. This enables the data module to be positioned independently and allows it to be accessed by every process that has the corresponding access rights. Processes can have access to data modules in any sequence or time period. All information can be read and/or written at any time. Once a data module is created it can be kept in the memory and used for an optional period of time.




A good example of an application would be a data module function using the structure of a data point handler such as in a process control system. The task of a data handler is to keep a copy of the process in memory in order to guarantee coordinated access to the process data. A data module is used for storing and managing process data. An interface task exists for supplying the data module with process data. This interface task only has the job of keeping the process copy updated and current. A second task, the server, provides all connected processes e.g. visualization, alarm management, trend etc. with the data from the process copy. Diagram:



This is a relatively easy way to solve all access rights and data consistency problems. Now another simple method is required to enable both the interface and the server processes to communicate with each other. This is done with pipes.

#### Pipes

Pipes enable data exchange for simultaneously executing processes through a "first in first out" (FIFO) buffer. Output from one process is read as an input by the other process. This method of communicating replaces the necessity of a global memory range used as a mail box. A pipe is constructed as a 90 byte FIFO buffer. Typically, two pipes share the pipe path: one writing and one reading. However, multiple processes can also access a pipe simultaneously. A process can even send data to itself via a pipe.



The major difference between data modules and pipes is the strict, sequential data transfer. The data stream through a pipe cannot be changed and information which is read once cannot be read again. Pipes have some distinct advantages, such as:

- Longer (than 16 bits) messages
- Queued messages
- Easy process independent coordination

The connection between the process interface and the server was excluded in the previous data module example. This connection can be arranged relatively easy by means of pipes. Urgent data point requirements etc. can be best performed through pipes. Connecting the visualization process through pipes has a substantial advantage. Pipes are organized by OS-9 somewhat like files. This means that pipes are also network capable and as a result, the visualization process is completely independent of the server and can therefore be operated from other computers. A simulation program can be used instead of the server for supplying the visualization. Process communication enables the creation of modular software which in turn permits process distribution without changes to the program. This is performed mainly by time critical processors. If a multiprocessor system is used, such as MAESTRO for example, which allows fast communication via a memory network, processes can be distributed among sub-processors without having to change any of the program. In this case, only the destination path has to be changed.

## EVENTS, SIGNALS, INTERRUPTS


INDUSTRIAL COMPUTER
B&R MAESTRO SYSTEM





#### Events


In many real-time applications, certain areas (data modules, serial interfaces, ...) must be safeguarded from the access of more than one process at a time. Events and semaphores are used to synchronize access so that one process communicates with one device at any given time. The OS-9 Event System is completely different than data modules or pipes. Events do not exchange any data. Only control information is transferred between processes with events. Here is a simple example for the use of events: Process A and process B both want access to device C. Device C is e.g. a printer or a terminal. Diagram:



It is not hard to understand that there are command sequences (cursor positioning and text output, ..) that are not to be interrupted since if they were the end result would be different than the desired result. Process A and process B must have some kind of communication in order to avoid disturbing one another. This is done through events. If process A wants to access device C then process A requests an event. If the event is not busy, then process A occupies the event and begins its transfer to device C. Now, process B wants to access device C and sends its request for the event. Since the event is busy, process B gets put into wait-status. That means that process B wait without putting any load on the system until the event is free and process B can access device C. If process A has ended its access with device C now, the event is cleared. This automatically activates process B (active status) so that it can access device C.

#### Signals

An OS-9 signal is smaller than an event. It can be sent between two processes at any time. The OS-9 signal is a 16 bit value which is sent to a process. It can differentiate between 65536 different signals. A process can send several signals and can also receive several process signals.



A process that receives a signal has to make a so-called intercept routine available for the processing. This intercept routine is processed similar to an interrupt and should therefore be as short as possible. If a process receives a signal without offering an intercept routine the process is stopped. While the process waits for a signal it is in wait status and therefore requires no CPU power. Because of the restricted informational content, signals represent quicker communication between processes.

#### **INTERRUPTS**

OS-9 supports all possibilities that the extensive 680x0 family interrupt system offers. The OS-9 I/O system is for example one task that is handled by this interrupt system. Polling is not required here since all I/O functions are controlled with interrupts. If OS-9 receives an interrupt, it searches through a polling table for the device that sent the interrupt. The search is performed according to priority so that devices with higher priorities have their interrupts put through before those with lower priorities. If OS-9 has found the originator of the interrupt, it refers to the respective interrupt service routine. If another interrupt with a higher priority occurs during the processing of this routine, this routine is temporarily stopped and the higher priority routine is run. The routine that was running before is continued when the higher priority routine has finished.



D2

#### CONTENTS

INDUSTRIAL COMPUTER

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS





MODULE RACKS			30-
HCR166-0	······································		30
HCR166-0	N <sub>s</sub>	W.	30
B&R MAESTRO COPROCESSORS			30
AS A SINGLE PROCESSOR IN THE PLC	AX		30
MCO AS MAIN PROCESSOR IN A B&R MAES	TRO SYSTEM		30
MULTIPROCESSOR SYSTEMS	-CO	Z. (2)	30
ORDER DATA		70.	30
PLC BUS INTERFACE MODULE MCIF2			100
PLC BUS INTERFACE MODULE MCIF2			30
MM8M MEMORY EXPANSION MODULE			308
MCO HARD DISK			30
FLOPPY DISK STATIONS		\\.	31
MFDD700 FLOPPY DISK STATION	75,	5	310
MFDD70S FLOPPY DISK STATION			31
NETWORKS			311

MAC1 AXES CONTROLLER .....

303

DOCUMENTATION.....

DUMMY FRONTS .....

**B&R MAESTRO COMPONENTS** 

CONTENTS .....

SYSTEM CONFIGURATION .....

D2



**D2** 

## SYSTEM CONFIGURATION, MODULE RACKS

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS

#### SYSTEM CONFIGURATION

Unlike the black PLC modules, all components of the B&R MAESTRO system have a light grey front with blue vertical stripes.

The PLC modules and B&R MAESTRO modules are operated from the same rack. The B&R MAESTRO coprocessor has direct access to the PLC bus through the MCIF2 PLC bus interface module. That means to all PLC modules including the CPU module.

#### **MODULE RACKS**


The following module racks can be utilized for B&R MAESTRO system operation:

	Model No.	B&R MAESTRO Slots	PLC Module Slots	System Module Slots	Color	Width
_	HCR166-0	6	10	PS, EXS, CP	Black	19 inch
	HCR169-0	11.0	5	PS, EXS, CP	Black	19 inch
Π	DG G	System slot for nower	cupply modulo	77,		

PS ... System slot for power supply module EXS ... System slot for expansion module CP ... System slot for PLC CPU


#### HCR166-0

HCR166-0 is a 19 inch MULTICONTROL rack with 3 slots for system modules and 16 module slots, 6 of which are suited for B&R MAESTRO module operation. Diagram:



#### HCR169-0

HCR169-0 is a 19 inch MULTICONTROL rack with 3 slots for system modules and 16 module slots, 11 of which are suited for B&R MAESTRO module operation. Diagram:



#### **B&R MAESTRO COPROCESSORS**

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS





#### **B&R MAESTRO COPROCESSORS**

B&R MAESTRO Coprocessors are industrial computers that can be applied universally. By using several coprocessors in one rack (multiprocessor system), the power and efficiency of a B&R MAESTRO system is increased considerably.



TECHNICAL DATA	MCO1	MCO3	MCO3MC
Processor	68000	68030	68030
Clock frequency	12.5 MHz	33 MHz	33 MHz
Memory Management Unit	10,	YES	YES
Arithmetic processor	68881	68882	68882
Operating system	OS-9/68000	OS-9/68030	OS-9/68030
Memory	0.5 MByte SRAM 1 MByte FPROM optional	0.5 MByte SRAM 2 MByte DRAM 1 MByte FPROM	0.5 MByte SRAM 10 MByte DRAM 1 MByte FPROM
Interfaces	RS232/TTY RS232/RS485	RS232/TTY RS232/RS485	RS232/TTY RS232/RS485
PCMCIA Interface	-		YES

B&R MAESTRO coprocessors offer all kinds of different configurations. Here are just a few examples:

- as single processors in PLC systems
- as main processors of industrial computer systems
- for multiprocessor systems

#### AS A SINGLE PROCESSOR IN THE PLC

B&R MAESTRO coprocessors do not have to be components of a B&R MAESTRO system. They can be operated in all P slots of PLC racks without a B&R MAESTRO bus board.

RACK	SLOTS	SUITABLE FOR MCO	
ECR165-0 (MULTICONTROL)	16 (\$0 to \$F)	\$0 to \$F	
MDR085-0 (MIDI)	8 (\$0 to \$7)	\$0 to \$7	
M2R111 (M264)	11 (\$0 to \$A)	\$0 to \$4	

The B&R MAESTRO coprocessor communicates with the CPU through the PLC bus or with other devices through its serial interface. A typical example of an MCO in the PLC is SPECTO\_S (see section B3 "Semigraphic Visualization").

#### MCO AS MAIN PROCESSOR IN A B&R MAESTRO SYSTEM

The B&R MAESTRO coprocessor can be operated in the slots that have been prepared especially for B&R MAESTRO components. They cannot be operated in slot 0 however, this slot is reserved for the PLC bus interface module MCIF2. If no MCIF2 is in the slot, a PLC module can be operated in slot 0.

RACK	SLOTS	SUITABLE FOR MCO
HCR166-0 (PLC/B&R MAESTRO)	16	\$2 to \$6
HCR169-0 (PLC/B&R MAESTRO)	16	\$2 to \$B

#### MFDD700 Floppy Disk Station

The MFDD700 is connected to the MCO hard disk. The file manager, the driver and several device descriptors are already programmed on the module PROM of the MCO hard disk.

#### MFDD70S Floppy Disk Station

If no MCO hard disk is used or if the floppy disk station must be mounted more than 2.5 meters (approx. 8 ft.) away, the serial disk station MFDD70S can be used. The only difference that can be noticed is that the data transfer is slower with the serial connection.

#### **PLC Access**

B&R MAESTRO coprocessors can access PLC peripherals in two different ways:

1. Software: This requires a function block in the PLC CPU for MCO

communication.

If no MCIF2 is in the slot or if data must be transferred consistently, data exchanged must be performed by means of

software.

2. MCIF2: For time critical applications, the MCO can be accessed

directly by running the MCIF2 PLC bus interface module in slot

0.

#### **MULTIPROCESSOR SYSTEMS**

If a single MCO is no longer sufficient for the application, you can set up a multiprocessor system. This consists of multiple MCOs. Since more processors can be accessed on a common bus, the technical aspects of the multiprocessor system hardware, such as bus accessing procedures, memory allocation and interrupt handling must be considered carefully during program development and organization.

#### Interrupt Master and MCO Master

If a system is equipped with one or more (max. 8), then an MCO must be assigned to take over the interrupt handling and the memory allocation as well as the functions of the MCO master. In this system, the interrupt master and the MCO master are the same unit. This master is automatically assigned by the boot program.

#### **Bus Priority**

When access to a common bus occurs simultaneously, collisions can happen. In order to organize the access on the bus, every MCO is assigned with a bus priority. The bus priority (0 to 7; 0 = highest priority) is automatically assigned by the boot program and displayed on the console terminal. The MCO and interrupt master always have the highest priority (0). The slots in the rack are arranged from left to right with increasing priority. The left-most MCO is always the MCO master and the right-most MCO always has the lowest priority.



## **D2**

## **B&R MAESTRO COPROCESSORS**

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

#### Interrupt Distribution

Interrupts which are generated by B&R MAESTRO components (e.g. graphic or network controller), can only be acknowledged by the interrupt master (MCO Master). Because of this, every device driver must be loaded and initialized on the MCO master and on the respective MCO. Both drivers communicate during the initialization phase. The driver on the interrupt master knows which driver should actually process this interrupt. The device driver on the interrupt master transmits the interrupt from the periphery to the executing driver, which distributes the arriving interrupts to the individual MCOs.

#### **Local and Global Addresses**

There are local and global address areas in every MCO. The local address areas are situated in the memory of the respective MCO. Access to these address areas is very fast since only the local bus is required. The global address ranges are situated outside of the MCO and can be accessed by all MCOs. Access must therefore be controlled with bus access logic. Since this requires time, "wait states" are used.

All B&R MAESTRO Peripherals (e.g. graphic, networks) can be reached through the global bus. This supplies the user with all kinds of different possibilities but some discretion should be used. A worst case scenario could be that MCO A executes a program that is sitting in the application memory of MCO B or the other way around. That would mean that the MCOs were reading the instruction code of their programs via the global bus which considerably delays program execution. For this reason, programs should only be executed on the local bus of the MCO (local RAM, local ROM). Nevertheless, it is possible to transfer data between the MCOs and/or MAESTRO via global communication areas (data commons) or to load programs through the global bus into the memory without any noticeable delays.

#### MODEL NUMBERS AND DESCRIPTIONS

B&R MAESTRO coprocessors are delivered in sets. Three sets are available for every MCO:

- OEM System
- Development Kit, German
- Development Kit, English

Please ensure that the proper indicator code is entered with the model number (outer left-hand column).

#### **B&R MAESTRO Coprocessor MCO1**

Components	OEM System	Model Number
HCMCO1-A SWMCO1-0	MCO1 OS-9/68000 12.5 MHz, 512 KByte SRAM 16 Bit, FPU MCO1 System Software Diskette (driver and library)	HCMCO:10AX

Comp	onents	Development Kit (German)	Model Number
HCMC HCFP HCSYS SWMC MAMS MAMC SWMT	1024-0 SC-TK CO1-0 YS-0	MCO1 OS-9/68000 12.5 MHz, 512 KByte SRAM 16 Bit, FPU Memory Expansion, 1 MByte Flash-PROM OS-9/Tool Kit, including ANSI C Compiler and Source Debugger MCO1 System Software Diskette (driver and library) B&R MAESTRO System Manual, German B&R MAESTRO Coprocessor Manual, German B&R PC PROVIT 700 Emulation	HCMCO:10UD

	Components	Development Kit (English)	Model Number
, S	HCMCO1-A HCFP1024-0 HCSYSC-TK SWMCO1-0 MAMAESTRO-E MAMCO-E SWMTERM-0	MCO1 OS-9/68000 12.5 MHz, 512 KByte SRAM 16 Bit, FPU Memory Expansion, 1 MByte Flash-PROM OS-9/Tool Kit, including ANSI C Compiler and Source Debugger MCO1 System Software Diskette (driver and library) B&R MAESTRO User's Manual, English B&R MAESTRO Coprocessor Manual, English B&R PC PROVIT 700 Emulation	HCMCO:10UE

Components	MCO1 Memory Expansion	Model Numbers
HCFP1024-0	MCO1 Plug-in Module 1,0 MByte Flash-PROM	HCFP1024-0
MAMSP-0	Memory Expansion Module User's Manual, German	MAMSP-0
MAMSP-E	Memory Expansion Module User's Manual, English	MAMSP-E

#### **B&R MAESTRO Coprocessor MCO3**

**OEM System** 

HCMCO3-1A	MCO3 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882 2 MByte DRAM 32 Bit, 1 MByte FPROM, incl. OS-9 License	HCMCO:31AX
SWMCO3-0	MCO3 System Software Diskette (driver and library)	
	'76., 'Ye	
Components	Development Kit (German)	Model Number
HCMCO3-1A	MCO3 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882 2 MByte DRAM 32 Bit, 1 MByte FPROM, incl. OS-9 License	HCMCO:31UD
HCSYSC-TK	OS-9/Tool Kit, Including ANSI C Compiler and Source Debugger	
SWMCO3-0	MCO3 System Software Diskette (driver and library)	
MAMSYS-0	B&R MAESTRO System Manual, German	
MAMCO-0	B&R MAESTRO Coprocessor Manual, German	
SWMTERM-0	B&R PC PROVIT 700 Emulation	

Model Number

Components	Development Kit (English)	Model Number	
HCMCO3-1A	MCO3 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882	HCMCO:31UE	
	2 MByte DRAM 32 Bit, 1 MByte FPROM, incl. OS-9 License		
HCSYSC-TK	OS-9/Tool Kit, Including ANSI C Compiler and Source Debugger		
SWMCO3-0	MCO3 System Software Diskette (driver and library)		
MAMAESTRO-E	B&R MAESTRO User's Manual, English		
MAMCO-E	B&R MAESTRO Coprocessor Manual, English		
SWMTERM-0	B&R PC PROVIT 700 Emulation		

#### **B&R MAESTRO Coprocessor MCO3MC**

Components	OEM System	Model Number
HCMCO3MC-1A	MCO3 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882	HCMCO:32AX
	10 MByte D RAM 32 Bit, PCMCIA IF, 1 MByte FPROM, OS-9	
SWMCO3-0	MCO3 System Software Diskette (driver and library)	
- 30	7	

Components	Development Kit (German)	Model Number
HCMCO3MC-1A	MCO3 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882	HCMCO:32UD
	10 MByte D RAM 32 Bit, PCMCIA IF, 1 MByte FPROM, OS-9	
HCSYSC-TK	OS-9/Tool Kit, Including ANSI C Compiler and Source Debugger	
SWMCO3-0	MCO3 System Software Diskette (driver and library)	
MAMSYS-0	B&R MAESTRO System Manual, German	
MAMCO-0	B&R MAESTRO Coprocessor Manual, German	
SWMTERM-0	B&R PC PROVIT 700 Emulation	

Components	Development Kit (English)	Model Number
HCMCO3MC-1A	MCO3 68030 MMU 33 MHz, 512 KByte SRAM, FPU 68882	HCMCO:32UE
	10 MByte D RAM 32 Bit, PCMCIA IF, 1 MByte FPROM, OS-9	
HCSYSC-TK	OS-9/Tool Kit, Including ANSI C Compiler and Source Debugger	
SWMCO3-0	MCO3 System Software Diskette (driver and library)	
MAMAESTRO-E	B&R MAESTRO User's Manual, English	
MAMCO-E	B&R MAESTRO Coprocessor Manual, English	
SWMTERM-0	B&R PC PROVIT 700 Emulation	

## PLC BUS INTERFACE MODULE

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS





#### PLC BUS INTERFACE MODULE MCIF2

The B&R MAESTRO coprocessor cannot read data directly from a CP60/70. By using the MCIF2 PLC bus interface module, the B&R MAESTRO coprocessor can read PLC data directly from a CP60/70. The MCIF2 is operated in slot 0.

Additional module features are:

- Two serial ports
- PCMCIA Interface
- ARCNET Connection (BNC)



#### **SERIAL PORTS**

INTERFACE		TYPE
IF1	all le	RS232 and 20 mA TTY
IF2	70,	RS232 and RS485 - Galvanically Isolated

INTERFACE	BAUDRATE	
RS232, RS485 20 mA TTY	300 Baud up to115.2 kBaud 300 Baud up to19.2 kBaud	

#### **PCMCIA INTERFACE**

The MCIF2 PLC bus interface module is equipped with a PCMCIA interface. The slot is compatible with JEIDA-ICMC Vers. 4.1 or PCMCIA Standard Release 2.0.

Attribute memory is absolutely necessary on the IC memory card which is approximately the same size as an ordinary credit card. This memory must hold the device ID Tuple / JEDEC Device ID Tuple.

Exchanging the cards can be done under power. However, you should be careful that the card is not being accessed while it is removed!

SRAM and Flash-PROM cards are supported by B&R.

MEMORY CARD	CAPACITY
SRAM Flash-PROM	16 KByte - 64 MByte 16 KByte - 64 MByte

#### **ARCNET**

The MCIF2 can be hooked up to an ARCNET network through a BNC connector. The transfer medium is a 93 W coaxial cable in this case.

A branch to another station is made with a T-connector. The cable can only be connected directly to the first or last station.

#### ORDER DATA

The PLC bus interface module MCIF2 is delivered as a set. The ARCNET software is available for OS-9/Net and for Internet TCP/IP. There are three different sets of software available for each version:

- OEM System
- Development Kit German
- Development Kit English

Please include the proper code in the model number (right-most column).

#### MCIF2 with OS-9/Net

Components	OEM System	Model Number
HCMCIF2-0 SWMAN-0	MCIF PLC Controller IF, 2*RS232, ARCNET, PCMCIA For Applications Using ARCNET, OS-9/Net Software	HCMCIF:2AX

Components	Development Kit (German)	Model Number
HCMCIF2-0	MCIF PLC Controller IF, 2*RS232, ARCNET, PCMCIA	HCMCIF:2AD
SWMAN-0	For Applications Using ARCNET, OS-9/Net Software	
MAMCIF-0	MCIF User's Manual, German	
MAMNET-0	B&R MAESTRO Network User's Manual, German	

Components	Development Kit (English)	Model Number
HCMCIF2-0	MCIF PLC Controller IF, 2*RS232, ARCNET, PCMCIA	HCMCIF:2AE
SWMAN-0	For Applications Using ARCNET, OS-9/Net Software	
MAMCIF-E	MCIF User's Manual, English	
MAMNET-E	B&R MAESTRO Network User's Manual, English	

#### MCIF2 with TCP/IP

Components	OEM System	Model Number
HCMCIF2-0 SWMTN-0	MCIF PLC Controller IF, 2*RS232, ARCNET, PCMCIA For Applications Using ARCNET, ISP Software (TCP/IP)	HCMCIF:2IX

Components	Development Kit (German)	Model Number
HCMCIF2-0 SWMTN-0	MCIF PLC Controller IF, 2*RS232, ARCNET, PCMCIA For Applications Using ARCNET, ISP Software (TCP/IP)	HCMCIF:2ID
MAMCIF-0	MCIF User's Manual, German	
MAMNET-0	B&R MAESTRO Network User's Manual, German	

Components	Development Kit (English)	Model Number
HCMCIF2-0	MCIF PLC Controller IF, 2*RS232, ARCNET, PCMCIA	HCMCIF:2IE
SWMTN-0	For Applications Using ARCNET, ISP Software (TCP/IP)	
MAMCIF-E	MCIF User's Manual, English	
MAMNET-E	B&R MAESTRO Network User's Manual, English	



# **D2**

## **MEMORY EXPANSION MODULE**

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

#### MM8M MEMORY EXPANSION MODULE

The RAM or the PROM memory of the B&R MAESTRO system can be expanded with the MM8M memory expansion module.



#### TECHNICAL DATA

TECHNICA	LDAIA		MINISIM	
LEDs		760		77,00
CA		Indic	F	PROM Flash-PROM SRAM
VP		Flas	sh-PROM Programmi	
.5N			rith a 0.5 MByte RAM	
1 M			with a 1 MByte RAM	
Working N			ight.	
DR			4 MByte	
SR	AM		MByte optional plug-in	n module
Applicatio	n Memory		1 or 3 MByte Flash-F	PROM
	er Consumption Maximum Expansion			
At 8			3.2 W	
At 1	12 V		0 W	
At -	-30 V		0 W	
Flash-PR0	OM Programming Operation	on		
At 8	8 V		4.4 W	
	12 V		0.48 W	
At -	-30 V	70%	0 W	70%
Buffer Bat	tery	10317	50 mAh	102/2
Operating	Temperature		0 to 60 °C	
Relative H	lumidity		0 - 95 % non-conde	nsing

#### MEMORY TYPES

The MM8M can be equipped with up to four different memory types

- Module PROM
- Flash-PROM
- DRAM
- SRAM (optional)

#### Module PROM

Every MM8M memory expansion module is equipped with a module PROM. With revisions of MM8M xx.10 and above the PROM disk file manager as well as the respective descriptors and utilities are programmed on the module PROM.

- The module PROM cannot be programmed by the user.
- The module PROM takes up 1 MByte of the addressing area.

#### Flash PROM

The MM8M memory expansion module can be ordered with either a 1 MByte or 3 MByte Flash PROM.

By using Flash PROM memory modules, the system can be set up to be completely nonvolatile. If OS-9 modules are programmed on an EPROM, they are automatically recognized and included in the module directory when starting the MAESTRO system.

A PROM disk can also be installed. A PROM disk can be set up with the same type of directory structure as a normal hard disk.

#### DRAM


Every MM8M memory expansion module is equipped with 4 MByte of dynamic RAM. This is managed by the OS-9 operating system on the B&R MAESTRO system.

MCO: Revision xx.42 Operating System and above

The addressing area of a 680x0 systems is 16 MBytes is size. Of this 16 MBytes, the user has 12.5 MBytes. If the sum of the RAM and PROM memory exceeds this value, the user can deactivate the dynamic RAM with the S1 and S2 DIL switches (see User's Manual).

#### SRAM

An option RAM memory module can be attached to the MM8M memory expansion module. This consists of 1 MBvte of static RAM.



A jumper can be found on the RAM memory module. This jumper can be used to set the way in which the RAM memory should be used. If the jumper is not in place (default upon delivery), the additional memory is managed by the OS-9 operating system of the MCO master.

If the jumper is in place, all memory on the module is treated as a protected RAM disk. That means that the OS-9 operating system does not use this memory, it is addressed with a device driver.

#### ORDER DATA

MM8M memory expansion modules are delivered as sets. These sets are divided into three categories:

- OEM System
- Development Kit German
- Development Kit English

Please ensure that the proper indicator code is entered with the model number (outer left-hand column).

Components	OEM System	Model Number
HCMM8M-1	MM8M with 4 MByte DRAM and 1 MByte Flash-PROM	HCMM8M-1
HCMM8M-3	MM8M with 4 MByte DRAM and 3 MByte Flash-PROM	HCMM8M-3
HCRA1024-0	1 MByte SRAM Plug-in Module	HCRA1024-0

Components	Development Kit (German)	Model Number
HCMM8M-1 HCRA1024-0 MAMSP-0	MM8M with 4 MByte DRAM and 1 MByte Flash-PROM 1 MByte SRAM Plug-in Module Memory Expansion Module User's Manual, German	HCMMEM:811D
HCMM8M-3 HCRA1024-0 MAMSP-0	MM8M with 4 MByte DRAM and 3 MByte Flash-PROM 1 MByte SRAM Plug-in Module Memory Expansion Module User's Manual, German	HCMMEM:831D
	HCMM8M-1 HCRA1024-0 MAMSP-0 HCMM8M-3 HCRA1024-0	HCMM8M-1 MM8M with 4 MByte DRAM and 1 MByte Flash-PROM 1 MByte SRAM Plug-in Module MAMSP-0 Memory Expansion Module User's Manual, German  HCMM8M-3 MM8M with 4 MByte DRAM and 3 MByte Flash-PROM 1 MByte SRAM Plug-in Module

Components	Development Kit (English)	Model Number
HCMM8M-1 HCRA1024-0 MAMSP-E	MM8M with 4 MByte DRAM and 1 MByte Flash-PROM 1 MByte SRAM Plug-in Module Memory Expansion Module User's Manual, English	HCMMEM:811E
HCMM8M-3 HCRA1024-0 MAMSP-E	MM8M with 4 MByte DRAM and 3 MByte Flash-PROM 1 MByte SRAM Plug-in Module Memory Expansion Module User's Manual, English	HCMMEM:831E

## MCO HARD DISK

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

**D2** 



#### MCO HARD DISK

MCO hard disks are meant to be rack mounted. Two MCO hard disks can be inserted in a rack. These MCOHDD hard disks operate on the B&R MAESTRO bus.

Installation or system and application data can be stored, by connecting the MFD700 diskette station connector provided on the front of the unit.

The MCO hard disk is either 2 or 3 slots in width. The 3 slot MCOHDD is equipped with an extra 4 MByte of DRAM and a module PROM in which all required drivers and descriptors are preprogrammed. This saves the time and effort of loading drivers etc. with floppy or hard disk in the future.



	CHNICAL DATA	MCOHDD
	Memory Capacity	>120 MBytes
	Access Time	<12 msec.
	LED: HD FD	Hard Disk Access Diskette Station Access
	Number of Slots Required	2/3
Max. Shock Resistance (11 msec.) In Operation  Not In Operation		6 g (no read errors) 10 g (with one read error per block) 60 g
	Max. Vibration In Operation Not In Operation	0.5 g 2 g
	Diskette Station	MFDD700 Connection
	Working Memory	4 MBytes DRAM
	Power Consumption 8 V 15 V In Operation Power-on -30 V	7 W 7 W 15 W for 1 sec. 0 W
	Operating Temperature	4 to 50 °C
	Max. Temperature Variation in Operation	10 °C/h
	Relative Humidity	8 - 85 % non-condensing

The MCOHDD with 3 slots is also equipped with 4 MBytes DRAM and a module PROM

#### ORDER DATA

The MCO hard disk is delivered as a set. Sets are divided into two categories:

- OEM System
- Development Kit German

Please ensure that the proper indicator code is entered with the model number (outer left-hand column).

	Components	OLINOyatem	Woderwariber
Ö	HCMCOHDD-2 HCMCOHDD-2S	MCO Hard Disk >120 MByte, Rack Mount, 4 MByte DRAM MCO Hard Disk >120 MByte, Rack Mount, 2 Slots	HCMHDD:CO2X HCMHDD:CS2X
		50,	2,

 Components	Development Kit (German)	Model Number
HCMCOHDD-2 MAMMSP-0	MCO Hard Disk >120 MByte, Rack Mount, 4 MByte DRAM Mass Memory User's Manual, German	HCMHDD:CO2D
HCMCOHDD-2S MAMMSP-0	MCO Hard Disk >120 MByte, Rack Mount, 2 Slots Mass Memory User's Manual, German	HCMHDD:CS2D





#### FLOPPY DISK STATIONS, MFDD700, MFDD70S

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS

#### **FLOPPY DISK STATIONS**

Two floppy disk stations are available for the B&R MAESTRO system. Both external diskette stations are equipped with dust and spray resistant housings (IP54 or NEMA12).

Parallel Floppy Disk Station
 Serial Floppy Disk Station
 MFDD700
 MFDD70S



Both stations have two 3.5" drives. The following formats are supported:

FORMAT	DISKETTE TYPE	CAPACITY
B&R MAESTRO	DD	640 KByte
B&R MAESTRO	HD	1.44 MByte
MS-DOS	DD	720 KByte
MS-DOS	HD	1.44 MByte
Universal OS-9	DD	640 KByte

#### INSTALLATION

These floppy disk stations are enclosed within housings which conform to DIN 43700.

Cutout dimensions in mm: 138+1 \* 138+

#### MFDD700 FLOPPY DISK STATION

Te	chnical Data	MFDD700	
	Number of Drives	2	
9	Drive	3.5"	
	Access Time Track to Track Average	3 msec. 79 msec.	
	Controller	WD 37 C 65	
	Connection	With the delivered cable (BRKA30-0) to the FDD interface on the MCOHDD	
	Power Supply	Through the MCO Hard Disk	
9	Max. Power Consumption 8 V 15 V -30 V	3.2 W 6.9 W 0 W	
	Housing	DIN 43700 Switchboard Housing	
	Front	Dust and Spray Resistant (IP54 / NEMA12)	
	Operating Temperature	10 to 45 °C	
	Relative Humidity	20 - 80 % non-condensing	200

#### Connection

Connecting the floppy disk station to the MCO hard disk is done with the standard BRKA30-0 cable. The cable is 2.5 meters long. Longer distances are not possible.

If the floppy station must be mounted further than 2.5 meters away, a branch can be made to the serial floppy disk station MFDD70S. Note here however, that data transmission is slower because of the serial connection.

#### Order Data

The MFDD700 is delivered as a set. Sets are split into two categories:

- OEM System
- Development Kit (German)

Please enter the proper indication code when ordering (outermost right-hand column).

Model Number

_	•	•	
À	HCMFDD700-0 BRKA30-0	MFDD700 Floppy Disk Station, 2 * 3.5" Floppy Station Cable (Length: 2.5 m)	HCMFDD:PX
×		10,3	18.3
	Componento	Development (# (Compan)	Madel Number

Components	Development Kit (German)	- CO	Model Number
HCMFDD700-0 BRKA30-0 MAMMSP-0	MFDD700 Floppy Disk Station, 2 * 3.5" Floppy Station Cable (Length: 2.5 m) Mass Memory User's Manual, German		HCMFDD:PD

#### FLOPPY DISK STATIONS, MFDD700, MFDD70S

INDUSTRIAL COMPUTER **B&R MAESTRO COMPONENTS** 






#### MFDD70S FLOPPY DISK STATION

Technica	al Data	MFDD70S
Numbe	er of Drives	2
Drive		3.5"
Contro	ller	WD 37 C 65
Input \	/oltage	24 V AC/DC ±20 %
	Consumption Not in Operation In Operation	4 W 9 W
Fuse	The state of the s	T 1.6 A / 250 V
	ces IF1 IF2	RS232/RS485 - Galvanically Isolated RS232/20 mA TTY - Galvanically Isolated
	um Distance RS232 RS485 TTY	Max. 10 meters with Shielded Cable max. 1200 meters with Shielded Twisted Pair Max. 200 meters with shielded cable
	ate TTY RS232, RS485	300 Baud to 19.2 kBaud 300 Baud to 115.2 kBaud
Housir	ng	DIN 43700 Switching Cabinet Housing
Front		Dust and Spray Resistant (IP54 / NEMA12)
Opera	ting Temperature	10 to 45 °C
Relativ	re Humidity	20 - 80 % non-condensing

#### **Power Supply**

An external power supply (24 V AC/DC) is required for the MFDD70S.



The IF1 interface can be used as an RS232 or RS485 interface. The port is a 9 pin D-type (F) and is electrically isolated.

The serial floppy station is connected with the MCO through the IF1 interface. B&R delivers the standard BRKAPC-6 cable with the unit (RS232).

This combination can communicate a speeds from 50 Baud to 115.2 kBaud.

INTERFACES	MAX. REACH
RS232	Max. 10 meters with shielded cable
RS485	Max. 1200 meters with Shielded Twisted Pair

PIN-OUTS	Pin	RS232	RS485
9 pin D-type (F)	1 2 3 4	GND2 RTS TXD RXD	GND2
9 000	5	(45)	DATA Enable *
6	8 9	стѕ	DATA

<sup>\*</sup> Pin 6 (Enable) must be connected with GND2 in RS485 operation

#### IF2 Interface

The IF2 interface can be used as an RS232 or TTY interface. The port is a 9 pin

D-type (F) and is electrically isolated.
The IF2 interface can be used for connecting e.g. a terminal or a printer. It cannot be connected to any device which requires a protocol driver however.

INTERFACE	TRANSFER RATE	
RS232	50 Baud to 115.2 kBaud	
TTY	50 Baud to 19.2 kBaud	

INTERFACE	MAX.REACH
RS232	Max. 10 meters with Shielded Cable
TTY	max. 1200 meters with Shielded Twisted Pair

PIN-OUTS	Pin	RS232	TTY
9 pin D-type	1	GND	
	2	RTS	
(F)	3	TXD	
o5	4	RXD	
7/60	5		TXD
	6		TXD Ret
اا ٥ ما	7		RXD
6	8		RXD Ret
	9	CTS	

#### **Order Data**

The MFDD70S is delivered as a set. Sets are split into two different categories:

- **OEM System**
- Development Kit (German)

Please enter the proper indication code when ordering (outermost right-hand

Components	OEM System	Model Number
HCMFDD70S-0 BRKAPC-6	Serial Floppy Disk Station, 2 * 3.5", RS232/RS485 Cable Coprocessor - Coprocessor (Length: 2.5 m)	HCMFDD70S:X

	Components	Development Kit (German)	Model Number
-	HCMFDD70S-0	Serial Floppy Disk Station, 2 * 3.5", RS232/RS485	HCMFDD70S:D
	SWMFDD70S-0	Software for Serial Floppy Disk Station	
	BRKAPC-6	Cable Coprocessor - Coprocessor (Length: 2.5 m)	
	MAMMSP-0	Mass Memory User's Manual, German	





#### NETWORKS, ETHERNET

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

#### **NETWORKS**

The following networks are available for the B&R MAESTRO system:

- ETHERNET (SINEC H1, FASTNET, INTERNET and NOVELL)
- ARCNET
- SERIAL-NET
- B&R MININET Driver

These networks are all described in detail in section C - "Industrial Networks and Communication".

#### **ETHERNET**

The term ETHERNET describes the lower layers of the OSI model, which means the medium and bus access procedures. Connection to an ETHERNET network is made with the MENC - Network controller.



The PLC bus interface module and the B&R MAESTRO coprocessor MCO3MC can also be used for a network connection. Both are equipped with a PCMCIA interface Type II.

An ETHERNET LAN card BRKAETL-2 can be installed in the PCMCIA interface. The LAN card is connected to the ETHERNET Thin Wire Net with a BNC adapter. A power supply is required for operating the BNC adapter.





And ETHERNET PCMCIA LAN Card

A clearer differentiation is only seen in the upper application oriented layers. Four different ETHERNET combinations are available for the B&R MAESTRO system:

- SINEC H1
- FASTNET
- INTERNET
- NOVELL

The ETHERNET network is described in detail in section C2 "ETHERNET" .

#### ORDER DATA

#### **ETHERNET Network Controller MENC**

The ETHERNET Network Controller MENC is delivered as a set. These sets are split into three categories:

- OEM System
- Development Kit (German)
- Development Kit (English)

Please enter the proper indication code with the model number when ordering (outer right-hand column).

Components	OEM System	Model Number	
HCMENC-0 SWMEN-0	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, SINEC-H1	HCMENC:0SX	
HCMENC-0 SWMTN-0	ETHERNET Controller, 10 MBaud, 50 Ω INTERNET TCP/IP Network Software	HCMENC:0TX	
HCMENC-0 SWMFN-0	ETHERNET Controller, 10 MBaud, 50 $\Omega$ ETHERNET Network Software, FASTNET	HCMENC:0FX	
HCMENC-0 SWMIPX-CD	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET NOVELL OS-9/Client	HCMENC:0NX	

	Components	Development Kit (German)	Model Number
9	HCMENC-0 SWMEN-0 MAMNET-0	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, SINEC-H1 B&R MAESTRO Network Manual, German	HCMENC:0SD
	HCMENC-0 SWMTN-0 MAMNET-0	ETHERNET Controller, 10 MBaud, 50 $\Omega$ INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, German	HCMENC:0TD
	HCMENC-0 SWMFN-0 MAMNET-0	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, FASTNET B&R MAESTRO Network Manual, German	HCMENC:0FD
2	HCMENC-0 SWMIPX-SD SWMIPX-CD	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET NOVELL Server ETHERNET NOVELL OS-9/Client	HCMENC:0ND

	Components	Development Kit (English)	Model Number
	HCMENC-0 SWMEN-0 MAMNET-E	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, SINEC-H1 B&R MAESTRO Network Manual, English	HCMENC:0SE
	HCMENC-0 SWMTN-0 MAMNET-E	ETHERNET Controller, 10 MBaud, 50 Ω INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, English	HCMENC:0TE
Ŝ	HCMENC-0 SWMFN-0 MAMNET-E	ETHERNET Controller, 10 MBaud, 50 Ω ETHERNET Network Software, FASTNET B&R MAESTRO Network Manual, English	HCMENC:0FE

Components	Accessories	Model Number
HCMTRAN2-0 BRKAETX-0	ETHERNET Transceiver, BNC Cheapernet T piece, BNC	HCMTRAN2-0 BRKAETX-0

#### ETHERNET PCMCIA LAN Card

Two sets are available for the ETHERNET PCMCIA LAN card:

- OEM System
- Development Kit (German)

Please enter the proper indication code with the model number when ordering (outer right-hand column).

	Components	OEM System	Model Number
7	BRKAETL-2 SWMIPX-CD	ETHERNET PCMCIA LAN Card ETHERNET NOVELL OS-9/Client	HCMENC:LNX
>>		740.X	"Morx
	Components	Development Kit (German)	Model Number
	BRKAETL-2	ETHERNET PCMCIA LAN Card	HCMENC:LND

#### NETWORKS, ARCNET

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS





#### ARCNET

ARCNET is a fast network for linking B&R MAESTRO systems or for the communication with remote systems of systems of other manufacturers (e.g. personal computers). ARCNET is an inexpensive alternative to ETHERNET.

The MARC Network Controller is the interface between a B&R MAESTRO system and the ARCNET network. Coaxial cable and twisted pair cable are used for ARCNET network controller connections.

The MCIF2 PLC bus interface module can also be used for ARCNET network connections.





As media access, a modified token passing method (ISO 802.4) is used. For this reason ARCNET is better suited for time critical real-time applications than networks with CSMA/CD accessing. The maximum baudrate of ARCNET is 2.5 MBit/sec. Changes in the network configuration (Stations being switched on or off) are recognized automatically.

The transmission medium for ARCNET is optional, either a  $93\,\Omega$  Coaxial cable or a twisted pair cable.

ARCNET is described in detail in section C3 "ARCNET".

#### ORDER DATA

The ARCNET Network Controller MARC is delivered as a set. These sets are split into three categories:

- OEM System
- Development Kit (German)
- Development Kit (English)

Please enter the proper indication code with the model number when ordering (outer right-hand column).

80	Components	OEM System	Model Number
	HCMARC-0CT SWMAN-0	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair ARCNET Network Software, OS-9/NET	HCMARC:CAX
	HCMARC-0CT SWMTN-0	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair INTERNET TCP/IP Network Software	HCMARC:CIX

	Components	Development Kit (German)	Model Number
.6	HCMARC-0CT SWMAN-0 MAMNET-0	ARCNET Controller, 2.5 MBaud, 93 Ω, Coax/Twisted Pair ARCNET Network Software, OS-9/NET B&R MAESTRO Network Manual, German	HCMARC:CAD
	HCMARC-0CT SWMTN-0 MAMNET-0	ARCNET Controller, 2.5 MBaud, 93 Ω, Coax/Twisted Pair INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, German	HCMARC:CID

Components	Development Kit (English)	Model Number
HCMARC-0CT SWMAN-0 MAMNET-E	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair ARCNET Network Software, OS-9/NET B&R MAESTRO Network Manual, English	HCMARC:CAE
HCMARC-0CT SWMTN-0 MAMNET-E	ARCNET Controller, 2.5 MBaud, 93 $\Omega$ , Coax/Twisted Pair INTERNET TCP/IP Network Software B&R MAESTRO Network Manual, English	HCMARC:CIE

_	Components	Accessories	Model Number
	BRKAARC-0 BRKAARW-0 BRKAARH-0	ARCNET Bus Cable, 10 m, 93 $\Omega$ ARCNET Bus Terminator, BNC, 93 $\Omega$ ARCNET HUB, 8 Coax	BRKAARC-0 BRKAARW-0 BRKAARH-0



# D2

## **INTERFACE MODULE MSIO**

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

#### **B&R MAESTRO INTERFACE CONTROLLER**

The interface controller MSIO has four serial interfaces. The MSIO interface controller does not handle the data to be sent or received bytewise as is the case with MCO. It handles all data blockwise. This greatly relieves the B&R MAESTRO coprocessor.




#### INTERFACES

The following four serial interfaces are available:

INTERFACE	TYPE	
IF1	RS232 and RS485	
IF2	RS232 and 20 mA TTY	
IF3	RS232 and RS422	
IF4	RS232 and 20 mA TTY	

#### **BLOCK DIAGRAM**

The four interfaces are electrically isolated from the PLC. Each pair of interfaces is galvanically connected together and galvanically isolated from the others.



#### **DATA TRANSFER**

Contrary to the MCO which send single characters to the terminal driver (tx) or retrieves single character from the terminal driver, the MSIO driver (tsx) can work with entire data blocks. This greatly relieves the MCO since by using an MSIO interface only one interrupt per data block is required whereas the MCO interface needs one per data byte. There are a few different ways of transmitting data with the MSIO interface controller. Depending on the type of application, the following can be selected:

- Non-optimized data transfer (with acknowledgement)
- Optimized data transfer (without acknowledgement)
- Protected data transfer (with B&R MININET Protocol)

#### NON-OPTIMIZED DATA TRANSFER

The device driver of the MSIO interface controller (tsx) is initialized so that a write task is only acknowledged or given back to the application program when all of the data is sent. For some applications this can be too slow. In this case the device driver parameters can be modified.

#### **OPTIMIZED DATA TRANSFER**

#### a. Modified Acknowledgement

For time-critical applications, a special mode of write command without acknowledgment is available. In this mode, the driver only puts the data that is supposed to be sent into a buffer on the MSIO interface controller. It then immediately returns to the application program. The MSIO interface controller then transmits the data down the line independently and without any communication with the driver. This type of write call are extremely fast and completely out of the user's sight. Any possible transmission error is indicated to the MCO master by the MSIO interface controller with the next write call.

#### b. Variable Data Transfer

Two buffers exist per transmitting interface on the MSIO interface controller:

- MSIO/MCO buffer: The MCO master puts the data to be sent into this buffer

MSIO send buffer: The data is sent down the line with interrupt

control from here

The data is read from the MSIO/MCO buffer by a "Data Manager". The data is converted to line code if necessary and then put into the MSIO send buffer. Since the MSIO interface controller has four different interfaces to take care of and they can all transmit simultaneously, the "Data Manager" can only transmit a certain amount of characters from the MSIO/MCO buffer to the MSIO send buffer at any given time before it switches to the next interface. This "Transfer Count" can be defined.

#### PROTECTED DATA TRANSFER

In order to transfer data between two stations with a higher degree of safety, the B&R MININET protocol has been implemented on the MSIO interface controller. The user can choose between point to point operation and network operation.

#### ORDER DATA

HCMSIO-0

SWMSIO-0

MAMSIO-E

The B&R MAESTRO interface controller MSIO is delivered as a set. There are three different set available:

- OEM System
- Development Kit (German)
- Development Kit (English)

Please enter the proper indicator code with the model number when ordering (outermost right-hand column).

100	Components	OEW System	Wodel Number
8,	HCMSIO-0	Interface Controller, 4xRS232, RS485, RS422, TTY	HCMSIO-0
	Components	Development Kit (German)	Model Number
	HCMSIO-0 SWMSIO-0 MAMSIO-0	Interface Controller, 4xRS232, RS485, RS422, TTY Interface Controller Software Serial Interface Controller User's Manual, German	HCMSIO:0D
	Componente	Davalanmant Kit (English)	Madal Number

Interface Controller, 4xRS232, RS485, RS422, TTY

Serial Interface Controller User's Manual, English

Interface Controller Softwa

HCMSIO:0E

## GRAPHIC CONTROLLER MGC1, PROVIT INDUSTRIAL MONITOR

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS





#### **GRAPHIC CONTROLLER**

A graphic controller is also available for the B&R MAESTRO coprocessor:



The MGC1 graphic controller has a standard RGB output to which any monitor can be attached. Timing values are found in the "Technical Data" section.

#### TECHNICAL DATA MGC1

		M. moo.
Mon	itor Control Output Signal Band Width (pixel frequency) Line Frequency Picture Frequency Resolution Sync-Signals	RGB pos. analog (1 V) 36 MHz 35 kHz 56 Hz 800 x 600 Pixel pos. TTL
Inter	rfaces Monitor Keyboard Mouse	RGB (PGA-Standard) 1 x serial (RS232), 1 x AT compatible 1 x serial (RS232)
Spe	ed e.g. Line e.g. circle	ca. 330 nsec. / Pixel ca. 875 nsec. / Pixel
Colo	ors16	6 <sub>2</sub> /6 <sub>2</sub>

#### ORDER DATA

The MGC1 graphic controller is delivered as a set. The sets are divided into three categories:

- OEM System
- Development Kit (German)
- Development Kit (English)

Please enter the proper indicator code with the model number when ordering (outermost right-hand column).

 Components	OEM System	Model Number
HCMGC1-0	Graphic Controller RGB 800 x 600, 16 Colors	HCMGC1-0
35'	L. The state of th	

	Components	Development Kit (German)	Model Number
	HCMGC1-0	Graphic Controller RGB 800 x 600, 16 Colors	HCMGC:1LD
	SWMCG-0	Graphic Software (Driver and library)	
	BRKAMAS-0	Adapter Cable MGC - Microsoft Mouse, 0.2 m	
	BRKARGB-0	Cable MGC - RGB Monitor	
	MAMGRC-0	Graphic Controller Manual, German	
_			

Components	Development Kit (English)	Model Number
HCMGC1-0 SWMCG-0	Graphic Controller RGB 800 x 600, 16 Colors Graphic Software (Driver and library)	HCMGC:1LE
BRKAMAS-0	Adapter Cable MGC - Microsoft Mouse, 0.2 m	
BRKARGB-0	Cable MGC - RGB Monitor	
MAMGRC-E	Graphic Controller Manual, English	

Components	Accessories	Model Number
BRKAMAS-0	Adapter Cable MGC - Microsoft Mouse, 0.2 m	BRKAMAS-0
BRKARGB-0	Cable MGC - RGB Monitor	BRKARGB-0

#### **PROVIT INDUSTRIAL MONITOR**

B&R offers an industrial monitor which goes under the name of PROVIT 800 which can be connected directly to the MGC2 graphic controller.



The PROVIT industrial monitor provides 42 keys (10 softkeys below the screen, 20 function keys and a numerical key block). The 10 softkeys and the 20 function keys are provided with LEDs which can be controlled through the software. The function keys are labelled with insertable plastic legend strips. The PROVIT industrial monitor is equipped with a serial RS232 interface for an external keyboard as well as an analog RGB input.

	DIMENSIONS	PROVIT 800	1021
1	Width Height Depth	482.6 mm (19") 310.4 mm 400 mm	
	Installation Depth Installation Height	448 mm 263 mm	
	Weight	ca. 17 kg	

#### ORDER DATA

Industrial Monitor with built keyboard, line frequency maximum 35 kHz, resolution 800 x 600 pixels, analog RGB input, controlled with B&R MAESTRO Graphic Controller MGC1, 42 keys, of which 30 have key LEDs, Front IP54 / NEMA12, Key Switch, 19" Housing

With 12" VGA Color Monitor, 35 kHz

PROVIT800-1

External ASCII Keyboard (see section B3), IP40 External ASCII Keyboard (see section B3), IP54 BRKEY01-0



# D2

## MAC1 AXIS CONTROLLER

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

#### **MAC1 AXIS CONTROLLER**

The MAC1 axis controller is a high performance dynamic positioning module.




#### **Precision and Dynamics**

The MAC1 axis controller has what it takes to offer shorter machine cycles and smaller production tolerances. This needs:

- Set-point generation with jolt limitation
- efficient position control algorithms
- short scan time
- high resolution of the speed set-point
- high counter frequencies

#### Jolt Limitation

The system itself is oscillatory, since every mechanical system has inertial masses and is susceptible to interference above a certain level. In order to keep the positioning errors which are caused by these deviations to a minimum, the MAC1 regulates its movement profiles so that no jumps in acceleration are possible (jolt limited positioning). The absence of acceleration jumps creates a smooth movement profile with much less vibration. Encoder measurements made on the drive shaft (indirect measurement) or even straight from the respective machine part (direct measurement) could not solve the problem.




Jolt is the change in acceleration in respect to time and can be defined by the user. Here is an overview of advantages that exist because of jolt limitation:

- Increased precision during the movement (important for interpolated operations)
- Almost no oscillation (important for positioning tasks)
- Protection of mechanics (avoidance of wear and tear due to alternating loads, avoids striking of transmission elements due to mechanical play)

Move optimization is performed by the MAC1. The user can choose between the two following optimization methods to suit the positioning application:

## Minimum Positioning Time


The axis moves according to the defined speed, acceleration and jolt limitations in the shortest possible amount of time .



The user knows the calculated positioning time before the movement is even started.


#### Minimum Jolt:

If the positioning time had been defined for this method, and it should be used, the axis moves as smoothly as possible to the target position. The limit values for speed, acceleration and jolt are also in effect with this method.



#### **Loop Controller**

The MAC1 uses a loop controller with feed-forward functionality (distance between axis and target determines speed).



Without feed forward, a permanent control deviation (lag distance) would occur at a constant speed (without any load as well) according to the formula shown below.

$$\Delta x = \frac{v}{k_v} \qquad \begin{array}{ccc} \Delta x & ... & \text{Lag distance} \\ v & ... & \text{Speed} \\ k_v & ... & \text{Speed amplification} \\ & (Proportional part) \end{array}$$

## **MAC1 AXIS CONTROLLER**

## INDUSTRIAL COMPUTER B&R MAESTRO COMPONENTS

D2



The loop controller has P or PI characteristics depending on the defined parameters.

#### Scan Time

Digital controllers with constant scan times do not continuously compare the actual and set positions but use time periods (scan time). This is not relevant as long as the scan time is short in comparison with the delays of the drive. Basic Formula:

$$T_{A} \leq \ \, \frac{1}{f_{_{OA}}} \qquad \qquad \qquad T_{_{A}} \ ... \ \ Scan time \\ f_{_{OA}} \ ... \ \ Oscillating frequency of the drive$$

If the drive is faster, the speed amplification  $k_{\rm v}$  can be increased but not higher than would be done for a continuous controller. The potential accuracy of the drive cannot be fully utilized.

Example: 
$$T_A = 2 \text{ msec}$$

$$f_{oA} < \frac{1}{10 T_A} = 50 \text{ Hz}$$

$$w_{oA} = 2 \pi f_{oA} = 314 \text{ s}^{-1}$$

$$k_v = 0.3 w_{oA} = 94 \text{ s}^{-1}$$

#### Set Value Resolution

The more distinct the steps of the analog output are, the less often the position controller has to switch between the digital/analog converter steps. The speed profile is steadier and the performance in holding control is much better.

Example: 
$$16 \text{ Bit for } \pm 10 \text{ V} \\ \frac{v_{\text{max}} = 0.5 \text{ m/sec}}{20 \text{ V}} \\ \Delta U = \frac{20 \text{ V}}{65536} = 0.3 \text{ mV}$$

$$\Delta V = \frac{2 \text{ v}_{\text{max}}}{65536} = 15 \text{ µm/sec}$$

#### Interference Compensation

In order to transmit the high resolved setpoint values under industrial conditions (adjoining interference sources) to the servo amplifier without errors, MAC1 provides a system, developed by B&R, for disturbance pulse compensation.

#### **Counter Frequency**

The simultaneous requirements for high encoder resolution and high speed lead to higher counting frequencies with incremental encoders.

Example: 
$$v_{max} = 0.5 \text{ m/sec}$$

$$\Delta s = 0.2 \mu m$$

$$f_{max} = 2.5 \text{ Mio Inc/sec}$$

#### Incremental Encoder Filter

The higher the maximum counting frequency is, the smaller the input filters of conventional counter modules must be. This also means that the susceptibility to disturbance is greater. B&R has put a damper on the problem for the MAC1 with which interference has one hundred percent less chance of causing problems in comparison with conventional circuitry.

#### **Signal Monitoring**

If encoder signal deviations are so strong that errors might be expected in spite of the filter, the MAC1 sends an error message that can be recognized through the application program.

#### ORDER DATA

MAC1 Axis Controller, highly dynamic positioning module, incremental encoder connection up to 700 kHz input frequency, integrated digital filter for incremental encoder input, maximum counter frequency 2.8 MHz at quadruple evaluation, connection of serial absolute encoders, encoder supply 5.24 VDC adjustable, analog output to the motor controller ( $\pm 10$  V, 16 Bit) with interference compensation, 6 digital inputs, one of which is a quick trigger input, three digital outputs, all inputs and outputs electrically isolated

HCMAC1-0






#### DUMMY FRONTS, CABLE

INDUSTRIAL COMPUTER
B&R MAESTRO COMPONENTS

#### **DUMMY FRONTS**

Slots that are not occupied by any module should be covered with dummy fronts. The same applies to the PLC systems as well as to the B&R MAESTRO modules. The MAESTRO system has grey dummy modules.



#### ORDER DATA

B&R MAESTRO System Dummy Fronts	
Single slot Double slot	HCBL01-0 HCBL02-0

#### **CABLE**

The following standard cables are available for the B&R MAESTRO system:

FROM	то	LENGTH	MODEL No.
B&R MAESTRO (FDD Interface) MCOHDD (FDD Interface)	Floppy Disk Station MFDD700	2.5 m	BRKA30-0
SCSI-Controller (MSCSI) Rack Mount Hard Disk (MDISC40R)	External Hard Disk (MDISC40) Streamer Tape Drive (MSTR20) Optical Disk Drive (MOD800)	2 m	BRKA40-0
B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	PROVIT-Industrial Terminal	2.5 m	BRKAPC-4
B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	VT100 Compatible Terminals	2.5 m	BRKAPC-5
B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	2.5 m	BRKAPC-6
MCO1/MCO3 (RS232)	Floppy Disk Station MFDD70S	2.5 m	BRKAPC-61
B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	PC (9 pin D-type F)	2.5 m	BRKAPC-7
MGC1 (RGB Output)	RGB Monitor (e.g. PROVIT 800)	2 m	BRKARGB-0
MGC1 (RS232 Mouse Int.)	Microsoft Mouse or Compatible	0.2 m	BRKAMAS-0
MGC1 (Keyboard Int.)	PROVIT 800 (Keyboard Int.)	2.5 m	BRKAPC-43

Order Data for ETHERNET and ARCNET bus cables as well as the respective accessories can be found in section "Networks".

## **DOCUMENTATION**

INDUSTRIAL COMPUTER





#### **DOCUMENTATION**

The following manuals are available for the B&R MAESTRO System:

#### ORDER DATA

ORDER DATA	13.5	1.0°
B&R MAESTRO Syste German	m Manual	MAMSYS-0
B&R MAESTRO User's English	s Manual	MAMAESTRO-E
B&R MAESTRO Copro German English	cessor User's Manual	MAMCO-0 MAMCO-E
PROVIT Industrial Wor German English	kstation User's Manual	MAMPRV-0 MAMPRV-E
Graphic Controller Use German English	r's Manual	MAMGRC-0 MAMGRC-E
Network User's Manual German English	ı 3	MAMNET-0 MAMNET-E
Mass Memory User's N German	Manual	MAMMSP-0
PLC Bus Interface Mod German English	fule User's Manual	MAMCIF-0 MAMCIF-E
Memory Expansion Usi German English	er's Manual	MAMSP-0 MAMSP-E
SPOIMG - Process Ima German	age Manager User's Manual	MAMSPOIMG-0
MSIO - Serial Interface German English	Module User's Manual	MAMSIO-0 MAMSIO-E



D3

#### CONTENTS

INDUSTRIAL COMPUTER

INDUSTRIAL COMPUTER
INDUSTRIAL COMPUTER SOFTWARE

D3



D3	INDUSTRIAL COMPUTER SOFTW	/ARE			
Thou	CONTENTO	Mo.,	Tho.	"No.,	
	CONTENTSGENERAL INFORMATION				320 322
	GRAPHIC USER INTERFACE				
	SPECTO_S VISUALIZATION SOFTWA	RE		Way .	322
	SPOIMG - PROCESS DATA MANAGEN	//ENT			323
	OS-9/TOOL KIT		7.0	3	324





## GRAPHIC USER INTERFACE, SPECTO S VISUALIZATION SOFTWARE

INDUSTRIAL COMPUTER
INDUSTRIAL COMPUTER SOFTWARE

#### **GENERAL INFORMATION**

An entire range of powerful software packages are available for the B&R MAESTRO system. Most of these software packages have been developed by well known software companies and are being used worldwide. B&R holds licenses for these software packages that are passed on the user as individual user licenses. These software packages are received on disks which are packed inside sealed safety envelopes on which the license agreement has been printed. By opening the envelope the user accepts all of the conditions of use defined by the manufacturer. Please be sure to read the license agreement in full before opening the envelope. After the envelope has been opened, the software cannot be returned. The following four points are of special importance:

- Upon purchase, the user is entitled to user the software for an unlimited time. The ownership and all software rights belong to the manufacturer
- The rights of use are limited to one computer at any given time.
- The manufacturer of the software does not guarantee that the software will fill all requirements of the application. Since it is also impossible to write error free software and keep up with the technological advances of today, the manufacturer only guarantees that the software covers the functionality described in the documentation.
- If other applications (e.g. C programs which have been compiled with a C compiler) are created by using the respective software package, the user attains all rights to the applications. This also applies if the respective application program contains e.g. part of a library.

#### **GRAPHIC USER INTERFACE (DESKTOP)**

The graphic user interface is an interesting alternative to working with SHELL commands. The functions of the OS-9 operating system can all be called through easy to handle pull-down menus. Optimal operating comfort is achieved by utilizing the logically structured window techniques. The following hardware components are required for operation with the graphic user interface:

- Graphic controller (MGC1) with RGB Monitor (e.g. PROVIT 800)
   or PROVIT Industrial Workstation
- Serial Mouse

#### **Order Data**

The graphic user interface is delivered as a set. These have been split into two categories:

- OEM System
- Development Kit (German)

Please remember to fill in the entire model number when ordering (outer right-hand column below).

Components	OEM System	Model Number
SWMGDTOP-0	G-WINDOWS Full Graphic Visualization (Run-time)	SWMSPO:GX
	3	
Components	Development Kit (German)	Model Number
SWMGVIEW-0 SWMSPOIMG-0 SWMDRV-BR MASPOIMG-0	G-WINDOWS Graphic User Interface, including Editor SPOIMG Process Data Server (including Library) SPOIMG Driver Software (including B&R MININET) SPOIMG - Process Image Manager User's Manual (German)	SWMSPO:VD

#### SPECTO S VISUALIZATION SOFTWARE


SPECTO\_S is a software package for comfortable machine and process visualization. The SPECTO\_S software runs on a B&R MAESTRO Coprocessor (MCO1, MCO3) or a PROVIT Industrial Workstation.

The SPECTO\_S software package consists of:

- Editor for creating process pictures
- Run-time System for animating process pictures

#### THE SPECTO\_S EDITOR

Process pictures are easily created or edited using the mouse and the keyboard. Commands are called from pull-down menus. A status line and notes for operation are displayed giving information about the type of operation and the attributes are being used at all times.



Up to 255 fields can be defined in one process picture. These fields can be for the input and output of numerical values, text or bar charts. The size of the process picture can be defined to suit the application. This means that your pictures can be created so as to enable as many process pictures as you want as one time.

Defining the function keys is also done through menus. Although SPECTO\_S was designed for semigraphic terminals, application specific symbols can also be easily made e.g. valves, switches, motors, company logos etc.

A hardcopy of the screen can be made at any time just by pressing a key. In addition, complete process pictures can be stored on floppy disk, hard disk, RAM disk, EPROM or FlashPROM.

#### SPECTO\_S VISUALIZATION SOFTWARE, SPOIMG - PROCESS DATA MANAGEMENT


INDUSTRIAL COMPUTER INDUSTRIAL COMPUTER SOFTWARE





#### THE SPECTO\_S RUN-TIME SYSTEM

The process pictures created with SPECTO\_S (Max. 255) can be assembled and combined in a process module and then animated with the SPECTO\_S Run-Time system.



B&R MAESTRO Coprocessors and the PROVIT Industrial Workstations work with the OS-9 multitasking operating system. This enables other programs (tasks) to run in parallel to SPECTO\_S visualizations e.g. data capture over a network.

Another benefit of SPECTO\_S is the ability to adapt to the complexities of the application. From low-cost visualizations with a PROVIT industrial terminal or operator interface panel up to complex decentralized systems with PROVIT industrial workstations, SPECTO\_S is the tool for every application.

A detailed description of SPECTO\_S software can be found in section B3 "Semi-graphic Visualization".

#### ORDER DATA

SPECTO\_S is delivered in sets. Please enter the entire model number when ordering (outer right-hand column below).

PO:SD	
	Number SPO:SD

#### **SPOIMG - PROCESS DATA MANAGEMENT**

The introduction of a B&R MAESTRO system in a visualization application needs a transparent modular data base for local and decentral management of process variables. These requirements are fulfilled with the process data management of SPOIMG.

Transparent
This means that independent of the visualization or application (semigraphic or full graphic) being used, a standard interface to process variable management should exist. This interface must be able to be used by several applications simultaneously

(multitasking) without any collisions.

The names of process variables have symbolic characters and are separated from the absolute addresses of the PLC by

automatic address calculation.

Modular The modular process variable management structure allows

you to switch PLC types by exchanging the respective PLC driver and the respective address management system.

Local process variable management means that the data areas

for process variables are situated on the same CPU that the

application is running.

Decentral Decentral process variable management means that the process variable management takes over all process variable

handling that is not on the local CPU but must be retrieved from other PLC systems over network cards or serial interfaces.

#### ORDER DATA

Local

SPOIMG is delivered in sets. Please enter the entire model number when ordering (outer right-hand column below).

Components	Development Kit (German)	Model Number
SWMSPOIMG-0 SWMDRV-BR MASPOIMG-0	SPOIMG Process Data Server (including Library) SPOIMG Driver Software (including B&R MININET) SPOIMG - Process Image Manager User's Manual (German)	SWMSPO:IMGD





#### OS-9/TOOL KIT, **DRIVERS FOR REMOTE LINKS**

**INDUSTRIAL COMPUTER** INDUSTRIAL COMPUTER SOFTWARE

#### **OS-9/TOOL KIT**

The tools required for program development can be ordered with the OS-9/Tool Kit. The OS-9/Tool Kit is a component of the Development Kit (English/German) for B&R MAESTRO Coprocessors and the PROVIT Industrial Workstations.

#### The following prerequisites apply

- Operating System OS-9 V 2.4 or higher 2 MByte Main Memory
- 10 MByte Free Space on the Hard Disk for the Installation

#### The OS-9/Tool Kit Consists of

- uMACS Editor
- Ultra C ANSI C-Compiler
- OS-9/680x0 Macro Assembler and Linker
- C Source Level Debugger

#### **Documentation Included**

- Using Ultra C Manual
- OS-9 Assembler/Linker Manual
- Using C Source Level Debugger Manual
- Using uMACS Manual

#### **DRIVERS FOR REMOTE LINKS**

For connecting to PLC systems made by manufacturers other than B&R, the following drivers are available:


- S3964 (R) (RK512)
- B&R-MININET (SWMDRV-BR)
- B&R NET2000 (SWMDRV-BR Rev. 02.00 and higher)


Other drivers are available upon request.

INDUSTRIAL COMPUTER INDUSTRIAL COMPUTER SOFTWARE

D3







## **CONTENTS**

**ACCESSORIES** 

# **CONTENTS**

### ACCESSORIES



E	ACCESSORIES				
	CONTENTS	N. S.	No.		326
	CABLE OVERVIEW				328
	PLC - OPERATOR PANEL				329
	PLC - PLC AND PLC - PROVIT				330
	B&R MAESTRO SYSTEM				330
	PC / PANELWARE - PLC / PROVIT / BR	MEC			331
	ONLINE CABLE	<u> </u>	50	ZO.	332
	OTHER			-)	332
	DUMMY FRONTS				333
	TERMINAL BLOCKS				333
	CABLE GUIDE FOR 19" RACK INSTALL	_ATION			334
	BATTERIES				
	ONLINE ADAPTER				334
	TEST EQUIPMENT				335





### **ACCESSORIES**

### **CABLE OVERVIEW**

The following table overview of B&R standard cables. Most of these cables are described in detail on the following pages. If a module has several interfaces (e.g. the PIF3), the type of interface is written in parentheses. Many interface connectors can be used with more than one type of interface. For example, the PP60 can use either a RS485, RS232 or TTY interface. In this case, a reference to the type of interface is also written in parenthesis. e.g.:

PIF3 (IF3/RS232) RS232 interface on the IF3 connector of a PIF3 module

PP60 (TTY) TTY interface of a PP60 parallel processor

The FROM and TO columns in the table show the possible connection. Devices in the FROM column can be used with the devices in the TO column. e.g.:

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	PIF3 (IF2/RS232) PROVIT Industrial Terminal	1.5 m	BRKA09-0

### i.e.: The BRKA09-0 cable can be used for the following connections:

PIF3 (IF3/RS232)	to	PIF3(IF2/RS232)
PP60 (RS232)	to	PIF3(IF2/RS232)
NTCP6# (RS232)	to	PIF3(IF2/RS232)
PIF3 (IF3/RS232)	to	PROVIT Industrial Terminal
PP60 (RS232)	to	PROVIT Industrial Terminal
NTCP6# (RS232)	to	PROVIT Industrial Terminal

### I. PLC - OPERATOR PANEL

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/TTY) PP60 (TTY) NTCP6# (TTY)	Operator Panel (BRRT360,)	1.5 m	BRKA01-0
PIF3 (IF2/TTY)	Operator Panel (BRRT360,)	1.5 m	BRKA02-0
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	BRMEC Mass Memory (RS232)	1.5 m	BRKA04-0
PATA Compact Control (PATA)	MINICONTROL Operator Panel Compact Control Relay Card	1.5 m	BRKA08-0
PC (male 9 pin D-type connector) Compact Control (IF1/RS232)	COMPACT MMI	2.5 m	0G0003.00-090
Compact Control (IF1/RS232)	COMPACT MMI	1.5 m	BRKACOMP1-0

### II. PLC - PLC AND PLC - PROVIT

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	PIF3 (IF2/RS232) PROVIT Industrial Terminal	1.5 m	BRKA09-0
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	1.5 m	BRKA09-1
PIF3 (IF2/RS232)	PIF3 (IF2/RS232)	1.5 m	BRKA09-1 <sup>1)</sup>
<sup>1)</sup> Same function as PIF3 (IF3/R	S232) - PIF3 (IF3/RS232)	A .	

### III. B&R MAESTRO SYSTEM

FRC	M	то		LENGTH	MODEL NO.
B&R	MAESTRO (FDD interface)	Diskette Station MCOHDD (FDI		2.5 m	BRKA30-0
	il Controller (MSCSI) rtable Hard Disk (MDISC40R)		Disk (MDISC40) Drive (MSTR20) ive (MOD800)	2 m	BRKA40-0
	MAESTRO (RS232) D1/MC03 (RS232)	PROVIT Indust	rial Terminal	2.5 m	BRKAPC-4
	MAESTRO (RS232) D1/MCO3 (RS232)	VT100 Compat	ible Terminal	2.5 m	BRKAPC-5
	MAESTRO (RS232) D1/MC03 (RS232)	B&R MAESTRO MCO1/MCO3 (		2.5 m	BRKAPC-6
мсс	01/MC03 (RS232)	Diskette Station	MFDD70S	2.5 m	BRKAPC-6 <sup>1)</sup>
	MAESTRO (RS232) D1/MC03 (RS232)	PC (male 9 pin	D-type connector)	2.5 m	BRKAPC-7
MG	C1 (RGB output)	RGB Monitor (e	e.g. PROVIT 800)	2 m	BRKARGB-0
MG	C1 (RS232 mouse interface)	Microsoft Mous	e or Compatible	0.2 m	BRKAMAS-0
MGC	C1 (keyboard interface)	PROVIT 800 (k	eyboard interface)	2.5 m	BRKAPC-4 <sup>2)</sup>

<sup>9</sup> Same function as B&R MAESTRO - B&R MAESTRO or MCO1/MCO3 - MCO1/MCO 2 Same function as B&R MAESTRO - PROVIT or MCO1/MCO3 - PROVIT

### IV. PC / PANELWARE - PLC / PROVIT / BRMEC / MODEM APM

FROM	TO	LENGTH	MODEL NO.	
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232) BRMEC	PC (male 9 pin D-type connector) PANELWARE (RS232)	2.5 m	BRKAPC-0	
Male 25 Pin D-Type Connector	Male 9 Pin D-Type Connector	0.2 m	BRKAPC-2	
PC (male 9 pin D-type connector)	PROVIT (keyboard interface)	2.5 m	BRKAPC-3	
Modem Application Program Memory	PC (male 9 pin D-type connector)	2.5 m	BRKAPC-8	

### V. ONLINE CABLE

FROM	то	LENGTH	MODEL NO.
Online Interface BRIFPC-0	all CPUs all Parallel Processors	2.5 m	BRKAOL-0
Modem Application Program Memory	all CPUs all Parallel Processors	0.2 m	BRKAOL-1

### VI. OTHER

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/RS232)	INT1 Interface Converter	1.5 m	BRKA05-0
Expansion Sender Module (EXS2)	Expansion Receiver Module (EXE3)	0.5 m	ECEXKA-1
Modem Application Program Memory	Modem	1.5 m	BRKAMO-0
PIF1 (RS422)	BRMEC Mass Memory (RS422)	1.5 m	BRKA11-0

### VII. ETHERNET AND ARCNET BUS CABLE AND ACCESSORIES

See Section C "Industrial Networks and Communication".

### **ACCESSORIES**






### **PLC - OPERATOR PANEL**

### I. [PIF3/IF3, PP60 NTCP6#] - [Operator Panel (e.g. BRRT360)]

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/TTY) PP60 (TTY) NTCP6# (TTY)	Operator Panel (BRRT360,)	1.5 m	BRKA01-0




### II. [PIF3/IF2] - [Operator Panel (e.g. BRRT360)]

PIF3 (IF2/TTY)	Operator Panel (BRRT36	60,) 1.5	m <b>BRKA02-0</b>
25 Pin D-Type Connector (M)	BRKA02-0		9 Pin D-Type Connector (F)
	GND 7 <b>◇</b>		
	TXD 9 0	0 7 RXD 0 6 RXD RET 0 4 +8 V	
	RXD RET 12 0	→ 3 TXD RET → 2 TXD → 5 -30 V	
PIF3/IF2	DSR 6 0		Operator Panel

### III. [PIF3/IF3, PP60, NTCP6#] - [BRMEC]

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	BRMEC Mass Mem	ory (RS232) 1.5 m	BRKA04-0



# IV. [PATA, Compact Control] - [MINICONTROL Operator Panel, Compact Control Relay Card]

PATA Compact Control (PATA)		MINICONTROL Operator Compact Control Relay C		1.5 m	BRKA08-0
	25	BRKA08-0	<u></u>	8"	
9 Pin D-Type Connector (M)		DKKA00-0		9 Pin Conne	D-Type ctor (M)
				SET 🎇	8
0		<del></del>			-0
~~ <del>_</del> _	+24V 5 o	<del></del>	O 1 +2	4 V	-0.5
		<del></del>			160
DA DA		<del>-27)</del>			(III)
IJ		<del></del>			
PATA.	CLK 9 O-			K MINICO	ONTROL
Compact Control (PATA)				Operate Compac	or Panel t Control Card

MODEL NO.

### V. [PC, Compact Control] - [COMPACT MMI]

	FROM TO		LENGTH	MODEL NO.
	PC (male 9 pin D-type connect Compact Control (IF1/RS232)	or) COMPACT MMI	2.5 m	0G0003.00-090
_	- 6		9	
	9 Pin D-Type Connector (F)	0G0003.00-090	9 Pin Connec	D-Type ctor (F)
2	COMPACT MMI	RXD 2 0 TXD 3 0 GND 5 0 45 V 6 0 45 V 9 0	0 2 RXD 0 5 GND 0 4 DTR 0 6 DSR 7 RTS	
	9 Pin D-Type Connector (M)	A.	Log cts [	PC
	Connector (M)	GND 5 0 45 V 6 0 45 V 9 0		
7	to BRKACOMP1-0			

### VI. [Compact Control] - [COMPACT MMI]


FR	OM	то		LENGTH	MODEL NO.
Cor	mpact Control (IF1/RS232)	COMPACT MMI	U.	1.5 m	BRKACOMP1-0
	300				~110
(90)	9 Pin D-Type Connector (F)	BRKACON	P1-0	9 Pin Conn	D-Type ector (F)
12		RXD 2 0			
		+5 V 6 0		v	
	12.8.	, 0	10.2		
	COMPACT MMI			Compa (IF1)	nct Control /RS232)

### **ACCESSORIES**

### **PLC - PLC AND PLCS - PROVIT**


### I. [PIF3/IF3, PP60, NTCP6#] - [PIF3/IF2, PROVIT Terminal]

FROM	то	LENGTH	MODEL NO.
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232)	PIF3 (IF2/RS232) PROVIT Industrial Terminal	1.5 m	BRKA09-0



### II.a [PIF3/IF3, PP60, NTCP6#] - [PIF3/IF3, PP60, NTCP6#]

FROM PIF3 (IF3/RS232)		то	LENGTH	MODEL NO.
Ī	PIF3 (IF3/RS232) PP60 (RS232)	PIF3 (IF3/RS232) PP60 (RS232)	1.5 m	BRKA09-1
	NTCP6# (RS232)	NTCP6# (RS232)		




### II.b [PIF3/IF2] - [PIF3/IF2]

PIF3 (IF2/RS232)	PIF3 (IF2/RS232)	1.5 n	BRKA09-1 <sup>1)</sup>
1) Identical to II.a [PIF3/IF3	, PP60, NTCP6#] - [PIF3/IF3, PP60, NTCP6#]		
25 Pin D-Type Connector (M)	BRKA09-1	3.9	25 Pin D-Type Connector (M)
	TXD 2 0———————————————————————————————————	— 0 3 RXD — 0 2 TXD — 0 20 DTR	
	GND 7 0	── 7 GND ── 6 DSR	
PIF3/IF2			PIF3/IF2

### **B&R MAESTRO SYSTEM**


### I. [B&R MAESTRO, MCO1/MCO3] - [PROVIT Terminals]

À	FROM	то	LENGTH	MODEL NO.
×	B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	PROVIT Industrial Terminal	2.5 m	BRKAPC-4
	S.	2.,	75.	
	9 Pin D-Type Connector (M)	BRKAPC-4	25 F Con	Pin D-Type nector (M)



### II. [B&R MAESTRO, MCO1/MCO3] - [VT100 Terminals]

FROM	то	LENGTH	MODEL NO.
B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	VT100 Compatible Terminals	2.5 m	BRKAPC-5



### III. [B&R MAESTRO, MCO1/MCO3] - [B&R MAESTRO, MCO1/MCO3]

ROM TO		17.	LENGTH	
B&R MAESTRO (RS232) MCO1/MCO3 (RS232)	B&R MAESTRO (R MCO1/MCO3 (RS2		2.5 m	BRKAPC-6
The.		$T_{M_1}$		
9 Pin D-Type Connector (M)	GND 1 0	0 1 GI	Conne ND SR (D	D-Type ctor (M)
B&R MAESTRO, MCO1/MCO3				AESTRO, 1/MCO3

### IV. [B&R MAESTRO, MCO1/MCO3] - [MFDD70S]

	FROM	TO	0	L	ENGTH	MODEL NO.
	MCO1/MCO3 (RS232)	FI	oppy Disk Station MFDD	'0S	2.5 m	BRKAPC-6 <sup>1)</sup>
	1) Identical to III. [B&R MAES	STRO, MCO1/MCO3	B] - [B&R MAESTRO, MC	O1/MCO3]		
		7,		-37,		
	9 Pin D-Type		BRKAPC-6		9 Pin	D-Type
	Connector (M)				Connec	ctor (M)
	C MOHAD A	GND 1 0	70,	O 1 GND		
	<b>]</b> 8 8	DTR 2 0				8
	<b>—</b>	TXD 3 o		— 0 4 RXD — 0 3 TXD	_ <u>_</u>	<b>-</b>
8,		DSR 9 0	,3		N2	8.
	B&R MAESTRO, MCO1/MCO3				MFD	D70S

### **ACCESSORIES**





### V. [B&R MAESTRO, MCO1/MCO3] - [PC]

FROM	20	10	200	LENGIH	MODEL NO.
B&R MAESTR MCO1/MCO3 (		PC (male 9 pi	n D-type connector)	2.5 m	BRKAPC-7
9		- 2	h		- 6
9 Pin D Connecto	or (M)		APC-7	Conne	D-Type ctor (F)
- A	D T. R.	ND 1 0		DSR RXD	
	MALOD	SR 9 0			
B&R MAE MCO1/N				ı	PC

### VI. [MGC1 (RGB Output)] - [RGB Monitor (e.g. PROVIT 800)]

FROM	то		LENGTH	MODEL NO.
MGC1 (RGB output)	RGB	Monitor (e.g. PROVIT 800)	2 m	BRKARGB-0
Mr.		34	7	



### VII. MOUSE CABLE ADAPTER


MGC1 (RS232 mouse interface)	Microsoft Mouse or Compatible	0.2 m BRKAMAS-0
	Mr.	700
9 Pin D-Type Connector (M)	BRKAMAS-0	9 Pin D-Type Connector (M)
GND DTR TXD RXD	2 o	05 GND 04 DSR 03 RXD 02 TXD
	9	or crs
MGC1		Serial Microsoft

MODEL NO.

### PC / PANELWARE - PLC / PROVIT / BRMEC

### I. [PIF3/IF3, PP60, NTCP6#, BRMEC] - [PC, PANELWARE]

FROM	TO	LENGTH	MODEL NO.
PIF3 (IF3/RS232) PP60 (RS232) NTCP6# (RS232) BRMEC (RS232)	PC (male 9 pin D-type connector) PANELWARE (RS232)	2.5 m	BRKAPC-0



### II. 9 TO 25 PIN CONVERTER FOR MALE D-TYPE PC CONNECTOR

FROM	то	LENGT	H MODEL NO.
Male 25 Pin D-Type Connector	Male 9 Pin D-Type Connector	0.2 m	BRKAPC-2
~35.		8.	
25 Pin D-Type Connector (F)	TXD 2 0 DTR 20 0 GND 7 0	2 RXD 3 TXD 4 DTR 5 GND 6 DSR	9 Pin D-Type Connector (M)
PC with 25 Pin D-Type Connector (M)			to BRKAPC-0

### III. [PC] - [PROVIT (Keyboard Interface)]

FROM	то 💥	LENGTH	MODEL NO.
PC (male 9 pin D-type connector)	PROVIT (keyboard interface)	2.5 m	BRKAPC-3
	727	12.	
9 Pin D-Type Connector (F)	BRKAPC-3		Pin DIN nector (M)
رن حصام			
	XD 2 0	-0 1 TXD -0 2 RXD	
	TR 40	-0 7 DSR	
	ND 5 0	→ 4 GND	
(A)	SR 60	→ 6 DTR	
PC PC		PROV	LJ /IT Keyboard nterface
			nienace

### IV. [Application Program Memory with Modem Interface] - [PC]

FROM	то	- The	LENGTH	MODEL NO.
Modem Application Program M	emory PC (male 9 pin	D-type connector)	2.5 m	BRKAPC-8
10,		50,		0.5
9 Pin D-Type Connector (M)	GND 1 0	· 5	GND RXD	D-Type ctor (M)
Application Program Memory with Modem Interface			ı	PC






### **ACCESSORIES**

### **ONLINE CABLE**


### I. FOR BRIFPC

FROM	то	LENGTH	MODEL NO.
Online Interface BRIFPC-0	all CPUs all Parallel Processors	2.5 m	BRKAOL-0




### II. FOR APPLICATION PROGRAM MEMORY WITH MODEM INTERFACE

FROM	то	LENGTH	MODEL NO.
Modem Application Program Memory	all CPUs all Parallel Processors	0.2 m	BRKAOL-1
		\	



### **OTHER**

### I. [PIF3/IF3] - [INT1 Interface Converter]



### II. [Application Program Memory with Modem Interface] - [Modem]

FROM		TO	. 1/1	LENGTH	MODEL NO.
Modem Application F	Program Memory	Modem	May.	1.5 m	BRKAMO-0
9 Pin D-Type Connector (M	· )	BRK	AMO-0	25 Con	Pin D-Type
	GND 1 o	143.x		GND (102) RXD (103)	84
	RXD 4 o-		o 3	TXD (104) (109)	
U			-04	CTS (106) DTR (108)	
Application Progr Memory with Modem	ram Interface				Modem
27,0					

### III. [PIF1/RS422] - [BRMEC]

	FROM	т	)	LENG	STH	MODEL NO.
	PIF1 (RS422)	BF	RMEC Mass Memory (RS422)	1.5	m	BRKA11-0
	×	\$ <sup>7</sup>	×2	(B)		
	9 Pin D-Type Connector (F)		BRKA11-0		9 Pin D-1 Connector	Type (M)
_		RXD 2 0		-0 5 TXD -0 6 TXD -0 7 RXD -0 8 RXD		
,2		120 / 024	3	-0 8 RAD -0 1 GND -0 9 DSR	ye.	
	PIF1/RS422,				BRME	С

# **DUMMY FRONTS, TERMINAL BLOCKS**








### **DUMMY FRONTS**

All rack slots that are not required are to be covered with dummy fronts. Black or grey dummy fronts are used according to the system.




### ORDER DATA

Dummy front for MULTICONTR	OL PLC system
Black	Grey
One Slot ECBL01-0	HCBL01-0
Two Slots ECBL02-0	HCBL02-0
Four Slots	ECBL04-0 -
Dummy front for MULTICONTR	OL PLC system (not shown)
One Slot, Black	MCBL01-0

### **TERMINAL BLOCKS**

Standard D-type connectors and PHOENIX terminal blocks are used to wire the modules. The terminal blocks can be obtained with 2, 4, 5, 8, 9 or 10 terminals.



The following table is an overview of all module that use one or more terminal blocks:

ILTICONTROL	PLC SYSTEM	BL2	BL4	BL5	BL8	BL9	BL10
NT43	Power Supply Module 24 VDC, 100 W		1	1			
NT44	Power Supply Module 220 VAC, 100 W		1	1			
PS45	Power Supply Module 120 VAC, 100 W		1	1			
NTCP33	Power Supply / CPU Module 24 VDC		1	1			
NTCP63	Power Supply / CPU Module 24 VDC		1	1			
NTCP64	Power Supply / CPU Module 220 VAC		1	1			
PSCP65	Power Supply / CPU Module 120 VAC		1	1			
EE32MP	Application Program Memory with Modem Interface			1			
FP128MP	Application Program Memory with Modem Interface			1			
					-		

M	ULTICONTROL PI	LC SYSTEM (cont.)	95.	BL2	BL4	BL5	BL8	BL9	BL10
	E161	Digital Input Module, 16 x 24 VD	C/AC						2
	E162	Digital Input Module, 16 x 220 V	AC						2
	E163	Digital Input Module, 16 x 24 VD	C						2
	I164	Digital Input Module, 16 x 120 V	AC						2
	E243	Digital Input Module, 24 x 24 VD	C				2		1
	A161	Digital Output Module, 16 x Rela	ıy						2
	A162	Digital Output Module, 16 x Tran	nsistor						2
	A163	Digital Output Module, 16 x Rela	ıy						2
	A115	Digital Output Module, 16 x Tran	nsistor						2
	A244	Digital Output Module, 16 x Rela	ıy				2		1 8
	A121	Digital Output Module, 12 x Tria	c, 220 VAC						2
	0125	Digital Output Module, 12 x Tria	c, 120 VAC						2 2 2
	PE82	Analog Input Module, 8 x U/I, 10	Bit, 12 Bit						2
	PE42	Analog Input Module, 4 x U/I, 10	Bit, 12 Bit						2
	PE84	Analog Input Module, 8 x U/I, 16	6/15 Bit				4		
	PE16	Analog Input Module, 16 x /U/I/I	emp., 16 Bit				4		
	PTE8	Analog Input Module, 8 x Temp.	, 10 Bit						2
	PT81	Analog Input Module, 8 x PT100					4		
	PA81	Analog Output Module, 8 x U/I,							2
	PA42	Analog Output Module, 4 x U/I,							2
	PNC3	Counter Module for Positioning				1			
	MARC	ARCNET Controller, Twisted Pa				1			
	PMV4	Proportional Solenoid Module			1		1		
		75.75							

N	MINICONTROL PL	C SYSTEM	BL2	BL4	BL5	BL8	BL9	BL10
	NT33	Power Supply Module			1			
	CP30	CPU		1				
	CP32	CPU		1				
	EE32MP	Application Program Memory with Modem Interface			1			
	FP128MP	Application Program Memory with Modem Interface			1			
	E16A	Digital Input Module, 16 x 24 VDC				1	1	
	A12A	Digital Output Module, 16 x Relay				1	1	
	A12B	Digital Output Module, 16 x Transistor				1	1	
	A12C	Digital Output Module, 16 x Transistor				1	1	
	MAEA	Digital Input / Output Module, 8 E / 6 A				1	1	
	MAEB	Digital Input / Output Module, 16 E / 16 A	1					
	PEA4	Analog Input Module, 4 E, 10 Bit				1	1	
	PEA8	Analog Input / Output Module, 4 E 10 Bit / 4 A 8 Bit				1	1	
	PT41	Analog Input Module, 4 x PT100				1	1	
	PTA2	Analog Input / Output Module, 4 x PT100, 2 x A 8 Bit				1	1	
	PTE6	Analog Input Module, 6 x Thermoelement, 16 Bit				1	1	
	PTE8	Analog Input Module, 8 x KTY10, 16 Bit				1	1	
	PRTA	Analog Input Module with Real Time Clock, 10 Bit			1			
	PNC4	Counter Module for Positioning Applications		1				
	PZL2	Counter Module for Event Counting				1.0	1	
	MZEA	Input / Timer Module					1	
	MZEB	Input / Timer Module				1	1	
	BRARCIF	ARCNET Interface Module			1			

### ORDER DATA

Standard terminal block for orange, accessible from fro	MINICONTROL and MULTICONTROL sys nt	tems,
2 Terminals 4 Terminals		C0112039 C0112010
5 Terminals		C0112011
8 Terminals		C0112012
9 Terminals		C0112013
10 Terminals		C0112014



# CABLE GUIDE FOR 19" RACK INSTALLATION, BATTERY, ONLINE ADAPTER


**ACCESSORIES** 

### **CABLE GUIDE FOR 19" RACK INSTALLATION**

Systems that are installed in a 19" rack can be optionally equipped with a 19" cable guide.



The cable guide is installed under the PLC rack. The cutouts make it easy to properly route the cables.



### ORDER DATA

Cable Guide for 19" Rack Installation

ECMB01-0

### **BATTERY**

A lithium battery in the power supply module buffers the memory of all modules in the PLC rack. The contents of the memory remain even when the power is turned off. All power supply modules use the same lithium battery.




Lithium batteries fall into the category of harmful waste. Please pay attention to the legal provisions for disposal in your area.

### ORDER DATA

Lithium Battery for all Power Supply Modules BRLITB-0

### **ONLINE ADAPTER**

A female 25 pin D-type connector links the online interface to the user interface for M264 CPU modules NTCP63, NTCP64 and PSCP65 as well as for all parallel processors. These modules require an online adapter.




### ORDER DATA

Online Adapter for Parallel Processors and NTCP6# CPUs **ECPAD1-0** 

# **TEST EQUIPMENT**





### **TEST EQUIPMENT**

It is often necessary to simulate input states when testing and debugging programs. This can be accomplished with the following input simulator.



The input simulator is inserted on the module in place of the terminal block. It requires a 24 VDC supply voltage. Input simulators can be obtained for all digital input modules with 24 V input voltage:

### ORDER DATA


Input Simulator for Digital Inputs	
E161 (MULTICONTROL, 16 x 24 VDC/AC) E163 (MULTICONTROL, 16 x 24 VDC)	ES-E161 ES-E163
E243 (MULTICONTROL, 24 x 24 VDC/AC)	ES-E243
E16A (MINICONTROL, 16 x 24 VDC)	ES-E16A

Further test equipment for analog input and output modules as well as for positioning applications can be obtained from B&R on request. Please contact B&R if you have any questions.






### **ACCESSORIES**



ACCESSORIES

E







# **CONTENTS**

### **DOCUMENTATION**





CONTENTS			33	8
USER'S MANUALS				0
			34	0
B&R MAESTRO SYSTEM	7/22	77/2	34	0
SHORT DESCRIPTIONS	£00	70	34	1





### USER'S MANUALS, ORDER DATA

### **DOCUMENTATION**

### **USER'S MANUALS**

All B&R product user's manuals can be obtained either in German or English. Some documentation is also available in other languages (French, Spanish, Italian). User's manuals are delivered with a ring binder and a binder box. The user's manuals for B&R standard software are only delivered together with the software package and cannot be obtained separately.

### PLC SYSTEM

### ORDER DATA

ORD	ER DATA	-47	- 6
	B&R Compact Control Use	r's Manual	
	German and English		MABRCOMP1-0E
	Hardware Manual MINICO	NTROL	
	German		MAHWMINI-0
	English French		MAHWMINI-E MAHWMINI-F
	MULTICONTROL / MIDICO	ONTROL / M264 Hardware Ma	anual
	German		MAHWMULTI-0
	English		MAHWMULTI-E
	French Italian		MAHWMULTI-F
	Spanish		MAHWMULTI-I MAHWMULTI-S
		m Haarla Manual	
	B&R PROgramming SYSte German	m User's Manual	MAPROSYS-0
	English		MAPROSYS-E
	French		MAPROSYS-F
	Spanish		MAPROSYS-S
	Standard Software User's I	Manual (2 Bands)	
	German		only with software package
	English		only with software package
	Positioning User's Manual	27,	24,
	German		MAPOSI-0
	English		MAPOSI-E
	Operator Interface Panel P	rogramming System User's M	lanual
	German		MAITGR-0
	English		MAITGR-E
	Operator Terminals User's	Manual	797
	German		MATERM2-0
	English		MATERMINAL-E

### **B&R MAESTRO SYSTEM**

### ORDER DATA

ORD	ER DATA	The same	20
	B&R MAESTRO System User's Manual		
	German		MAMSYS-0
4	B&R MAESTRO Industrial Computer		
	English		MAMAESTRO-E
	B&R MAESTRO Co-Processor User's Mar	nual	
	German English		MAMCO-0 MAMCO-E
	PROVIT Industrial Workstation User's Man	nual	
	German English		MAMPRV-0 MAMPRV-E
	Memory Expansion Modules		
	German		MAMSP-0
	English		MAMSP-E
	Mass Memory User's Manual		
	German		MAMMSP-0
	SPECTO_S Process Visualization User's I	Manual	
	German		MASPOS-0 MASPOS-E
	English		WASPUS-E
	SPOIMG - Process Image Manager		X
Ś.	German		MASPOIMG-0
	PLC Bus Interface Module		
	German English		MAMCIF-0 MAMCIF-E
	B&R MAESTRO Industrial Computer Grap	hics Controller	
	German		MAMGRC-0
	English	The same	MAMGRC-E
	B&R MAESTRO Industrial Computer Netw	rorking	
	German English		MAMNET-0 MAMNET-E
	100		INDIVINE I'E
	MSIO - Serial Interface Module		MANGO
	German English		MAMSIO-0 MAMSIO-E

### SHORT DESCRIPTIONS, ORDER DATA





### SHORT DESCRIPTIONS

Short descriptions offer an introduction to a product or product group.


### ORDER DATA

ORDER DATA		
Allen Bradley Data Highway German	y for SPECTO_S	MAABDRVKB-0
SINEC L1 for SPECTO_S German English		MAL1DRVKB-0 MAL1DRVKB-E
3964R SPECTO_S Driver German		MA39DRVKB-0
STL Programming Short De German English	scription	MAAWLKB-0 MAAWLKB-E
CP32 MINICONTROL CPU German English		MACP32KB-0 MACP32KB-E
MULTICONTROL CP70 German English		MACP70KB-0 MACP70KB-E
PSA2 Stepper Motor Contro German English	oller Module	MAPSA2KB-0 MAPSA2KB-E
PWP4 Ultrasonic Transduce German English	er Module	MAPWP4KB-0 MAPWP4KB-E
BRMEC Mass Storage Devi German English	ice Short Description	MABRMECKB-0 MABRMECKB-E
BRADOL Online / Modem C German English	Converter Short Description	MABRADOL-0 MABRADOL-E
BRKEY01/BRKEY02 Indust German English	rial Keyboard Short Description	MABRKEYKB-0 MABRKEYKB-E
BRRTEL45 Panel Short Des English	scription	MABRRT45KB-E
BRXTGR31 Operator Panel English	Short Description	MAXTGR31KB-E
RS232/RS485 Interface Cor German English	nverter Short Description	MAINT1-0 MAINT1-E






### **DOCUMENTATION**



### DOCUMENTATION









Symbol	
3964 (R) (RK512) 286, 324	
Flags Compact Control 28 MINICONTROL 52	
MULTICONTROL CPU 92 Registers	
Compact Control 28 MINICONTROL 52	
MULTICONTROL CPU 92	
A NOT	
A115 128 A121 130	
A12A 60 A12B 61	
A12C 61 A161 125	
A162 127	
A163 126 A244 129	
Absolute Encoder 190 Acceleration Jumps 199	
Access Methods 251 Actualization Time	
Analog I/O Modules MINICONTROL 62	
MULTICONTROL 132 Additional User EEPROM	
Compact Controller 37 CP32 - MINICONTROL CPU 51	
Addresses and Telephone Numbers 346 Algorithms for Digital PID Loop Controllers	205
	200
Allen Bradley Data Highway 287 Analog I/O Modules Comparisons 16, 20, 21 MINICONTROL 44, 50, 62	
PEA4 63	
PEA8 64 PRTA 69	
PT41 65 PTA2 66	
PTE6 67 PTE8 68	
MULTICONTROL 84 PA42/PA81 141	
PE16 136 PE42/PE82 133	
PE84 134 PT81 138	
PTE8 137	
Analog Inputs Compact Control 32	
MINICONTROL 62 MULTICONTROL 132	
Analog Outputs Compact Control 33	
MINICONTROL 62 MULTICONTROL 140	
Angle Code 190, 191 Angular Encoder 190	
Application 346 Application Layer 252	
Application Program Checksum Test 15 Application Program Memory Module	
MINICONTROL 54 MULTICONTROL 110	
EE32 111 EE96 112	
EP128 113 EP128 114	
FP384 114 Application Program Test	
Compact Control 28 MINICONTROL 52	
MULTICONTROL 93	
ARCNET 272, 307, 312 Coaxial Cable 272	
Interface Module 273 Overview 256	
Software 273 Twisted Pair Cable 272	
Automation Systems 14 Automation Tasks 14	
Axes Controller MAC1 316	
B NO.	
B&R MAESTRO Industrial Computer 296 B&R Multiprocessor Technology 82	
B&R PLC Philosophy 14	
B&R PROgramming SYStem 175 Base Rack 84, 161	
Base Unit MINICONTROL 51	
MULTICONTROL 90 Battery 334	
Compact Control 37 MINICONTROL 54	
MULTICONTROL 102 Break Point 177	
BRMEC 165 Standard Software 181, 184	
BRRT360 228 BRRTEL45 229	
BRRTM3 227 BRRTM4 227	
BRXTGR31 235	
BRXTGR35 235 Bus Board MINICONTROL 53	
Bus Monitoring 15	

200	
C 7/2	
C0112010 333	
C0112011 333 C0112012 333	
C0112013 333	
C0112014 333 C0112039 333	
Cabinet Back Plane	
Compact Controller 25 MULTICONTROL 86	
Relay Card 39 Cabinet Grounding	
Compact Controller 27	
MINICONTROL 46 MULTICONTROL 86	
Cabinets	
Compact Controller 27 MINICONTROL 46	
MULTICONTROL 86	
Cable 328 MAESTRO	
BRKAMAS-0 331	
BRKAPC-4 330 BRKAPC-5 330	
BRKAPC-6 330	
BRKAPC-7 331 BRKARGB-0 331	
Overview 328 On-line Cable	
BRKAOL-0 332	
BRKAOL-1 332 Overview 328	
Other Cables	
BRKA05-0 332 BRKA11-0 332	
BRKAMO-0 332	
Overview 328 PC/PANELWARE-PLC/PROVIT/BRMEC	
BRKAPC-0 331	
BRKAPC-2 331 BRKAPC-3 331	
BRKAPC-8 331	
Overview 328 PLC-Operator Panels	
0G0003.00-090 329	
BRKA01-0 329 BRKA02-0 329	
BRKA04-0 329 BRKA08-0 329	
BRKACOMP1-0 329	
Overview 328 PLC-PLC and PLC-PROVIT	
BRKA09-0 330	
BRKA09-1 330 Overview 328	
Cable Duct	
Compact Control 26 MINICONTROL 46	
MULTICONTROL 85, 86 Cable Guide 334	
Cable Shield	
Compact Control 27 MINICONTROL 46	
MULTICONTROL 87	
Cable Shield Grounding Compact Control 27	
MINICONTROL 46	
MULTICONTROL 86, 87 Cable Types	
Compact Control 26 MINICONTROL 45	
MULTICONTROL 85	
Cabling Compact Controller 26	
MINICONTROL 45	
MULTICONTROL 85 Callback Protected Modem Remote Diagnosis 173	
CAN Bus 36, 276	
B&R and CAN 276 Bus Length 276	
Cable Type 276	
Compact Control 36 Interface Module EXS5 277	
Overview 256 Carrier Sense, Multiple Access	
With Collision Detection (CSMA/CD) 251	
CENTRONICS / On-line Converter 171 CHEAPERNET 261	
CHEAPERNET T Connector 262, 312	
Checksum for Application Program 15 CIM620 287	
Circle Interpolation 200	
Circle to Circle Transition 199 Circle to Line Transition 199	
Closed Loop Speed Drive 195	
CNC 198 Command Signal 204	
Communication Processor 162 Communication Processor NP02 286	
Communication Software 287	
Compact Control 24 Additional Application EEPROM 37	
Analog Inputs 32	
Analog Outputs 33 CAN Bus 36	
Compact MMI P120 and MMI P121 34	
Counter Inputs 30 CPU 28	
Digital Inputs 29	
Digital Outputs 31 Fuses 37	
Hardware Counter 0 30 IF1 - RS232 Interface 34	
Notae interface of	

IF2 - RS232/RS485 Interface 35	
IF3 - PATA/SSI Interface 36	
IF4 - On-line Interface 28	
IF5 - CAN Bus 36 Interrupt Input 30	
Lithium-Battery 37	
On-line Interface 28	
Reference Input 30	
Relay Expansion Card 24, 38	
Supply Voltage 37	
System Selection 16 Two Channel Counter 30	
Compensation Gears 196	
Contact Washers MULTICONTROL 86	
Control Amplification 204	
Control Deviation 204, 207	
Control Deviation Alarm 207	
Control Loop 195	
Control Loop 204 Control Loop Application 204	
Standard Software 185	
Control Loop Values 204	
Control Path 204	
Control Signal 208	
Control Signal Ramp 208	
Control Types 205 Conversion Time	
Analog I/O Modules	
MINICONTROL 62	
MULTICONTROL 132	
Analog Inputs - Compact Controller 32	
CoProcessor	
B&R MAESTRO System (MCO) 305	
PLC System (PP) 148 Correction Time Loop Control 204	
Counter Compact Controller 30	
Counter Module	
MINICONTROL	
PNC4 75	
PZL2 76	
MULTICONTROL 152	
PNC3 153	
PNC8 156 PZL1 155	
Counting Frequency 195	
CP30 51	
CP32 51	
CP40 94	
CP60 95	
CP70 96 CPU	
Comparisons 16 17 18	
Compact Controller 28	
MINICONTROL 44, 50, 51	
MULTICONTROL 83, 91	
CP40 94	
CP60 95	
CP70 96	
CP70 96 NTCP33 97	
CP70 96 NTCP33 97 NTCP63 98	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177	
CPT0 96 NTCP33 97 NTCP63 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251,253	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PC50265 98 Cross Reference List 177 CSMA/CD 251,253	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252	
CPT0 96 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52	
CP70 96 NTCP33 97 NTCP63 98 NTCP64 98 PC50P65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Ink Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL C91 MULTICONTROL C92 MULTICONTROL C92 MULTICONTROL C91	
CP70 96 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL P 92	
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 22 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL CPU 92 Data Modules 300	
CP70 96 NTCP33 97 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL P192 MULTICONTROL P29 MULTICONTROL P20 Data Modules 300 Data Modules 300 Date	
CP70 96 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28	
CP70 96 NTCP33 97 NTCP33 97 NTCP63 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL P192 MULTICONTROL P29 MULTICONTROL P20 Data Modules 300 Data Modules 300 Date	
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL P33 MULTICONTROL 52 MULTICONTROL P30 MULTICONTROL P31	
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL CPU 92 MULTICONTROL Pu 93 MINICONTROL CPU 93 MINICONTROL CPU 93 MINICONTROL Pu 93 MINICONTROL Pu 93 MULTICONTROL Pu 94 MULTICONTROL Purer Supply Module	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP34 98 NTCP64 98 NTCP64 98 PSCP5595 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL 52 MULTICONTROL Devalel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL Devalel Processor 149 DC LED MINICONTROL Parallel Processor 149 DC LED MINICONTROL Parallel Processor 149 DC LED MINICONTROL Power Supply Module Dead Band 206	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Date Modules 300 Date MiniControl 28 MINICONTROL CPU 92 MULTICONTROL CPU 93 MULTICONTROL POWER SUPPly Module Dead Band 206 Dead Time 204	5-
CP70 96 NTCP33 97 NTCP33 97 NTCP64 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Data MINICONTROL Parallel Processor 149 DCLED MINICONTROL Parallel Processor 149 DCLED MINICONTROL Power Supply Module Dead Band 206 Dead Time 204 Debugging 177	5-
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP505 98 Cross Reference List 177 CSMA/CD 251,253  Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL PU 93 MULTICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Power Supply Module 1 Dead Band 206 Dead Time 204 Debugging 177 Delay Time 204	5-6
CPT0 96 NTCP33 97 NTCP33 97 NTCP34 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL DP 192 MULTICONTROL DP 192 MULTICONTROL DP 192 MULTICONTROL POP 193 MULTICONTROL POP 194 MULTICONTROL POP 194 MULTICONTROL POP 195 MULTICONTROL POP 195 MULTICONTROL POP 194 MULTICONTROL POP 195 MULTICONTROL POP 195 MULTICONTROL PARIBLE Processor 149 DE LED MINICONTROL Parallel Processor 149 DE LED MINICONTROL Parallel Processor 149 DE LED MINICONTROL Parallel Processor 149 DE LED MINICONTROL POP 197 DE	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL CPU 93 MULTICONTROL Power Supply Module 1 Dead Band 206 Dead Time 204 Debugging 177 Delay Time 204 Derivative Action Time 205 Device Driver 298	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 PSCP5595 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 28 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Data Ima 204 Determine 205 Dead Time 204 Debugging 177 Delay Time 205 Device Descriptors 298 Device Driver 298 Device Driver 298 Device Diagnosis Functions 14	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 92 MULTICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTROL PU 93 MULTICONTROL Power Supply Module Dead Band 206 Dead Time 204 Debugging 177 Delay Time 204 Derivalive Action Time 205 Device Descriptors 298 Diagnosis Functions 14 Compact Control 28	5-
CPT0 96 NTCP33 97 NTCP33 97 NTCP34 98 NTCP64 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL DP 192 MULTICONTROL DP 192 MULTICONTROL DP 192 MULTICONTROL PAIRIEI Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL 29 MULTICONTROL PAIRIEI Processor 149 DE LED MINICONTROL Parallel Processor 149 DE LED MINICONTROL 52 MULTICONTROL DE 198 Debug Direc 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 52	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 27 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Dever Supply Module Dead Band 26 Dead Time 204 Dead Band 26 Dead Time 204 Derwigite Action Time 205 Device Descriptors 298 MINICONTROL 52 MINICONTROL 103	5-
CPT0 96 NTCP33 97 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Pu 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Power Supply Module Dead Time 204 Debugging 177 Delay Time 204 Debraitive Action Time 205 Device Descriptors 298 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 52 MULTICONTROL 103	5-
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 93 MULTICONTROL Power Supply Module Dead Band 206 Dead Time 204 Debugging 177 Debay Time 204 Derivative Action Time 205 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL D SERVICE PROVED PROVED PROVED Prover 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTRO	5-
CPT0 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 PSCP5595 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL DP 192 MULTICONTROL DP 192 MULTICONTROL P3 20 MULTICONTROL P40 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL P3 MULTICONTROL P40 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL P40 Data MODULTONTROL P40 Data MODULTONTROL P50 Data MULTICONTROL P50 Device Descriptors 298 Device Driver 298 Device Driver 298 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 25 MULTICONTROL 103 MULTICONTROL 205 MULTICONTROL 103 MULTICONTROL 103 MULTICONTROL 205 MULTICO	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Parallel Processor 149 Data Minicontrol 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTROL PU 92 MULTICONTROL PU 93 MULTICONTROL PU 93 MULTICONTROL PU 93 MULTICONTROL PU 93 MULTICONTROL POWER Supply Module 1 Dead Band 206 Dead Time 204 Debugging 177 Delay Time 204 Derivalive Action Time 205 Device Descriptors 298 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 Differential Time 205	5-6
CPT0 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP44 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Pu 94 Data Modules 300 Date Compact Control 28 MINICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Parallel Processor 149 DC LED MINICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 93 MULTICONTROL Parallel Processor 149 Debugging 177 Delay Time 204 Debugging 177 Delay Time 204 Debugging 170 Delay Time 204 Debugging 170 Delay Time 204 Debugging 171 Delay Time 204 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL CPU 93 Dialog Language Programming System 175 Differential Component 205 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21	5-6
CP70 96 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 NTCP64 98 NTCP656 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 29 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Date MULTICONTROL Pul 93 MULTICONTROL Parallel Processor 149 Dead Band 206 Dead Time 204 Debugging 177 Delay Time 204 Derivative Action Time 205 Device Descriptors 298 Device Descriptors 298 Device Descriptors 298 Device Descriptors 298 Device Descriptors 198 Device Descriptors 298 Device Descriptors 298 Device Descriptors 298 Device Descriptors 198 Diagnosis Functions 14 Compact Control 28 MINICONTROL PU 93 MINICONTROL CPU 93 Dialog Language Programming System 175 Differential Component 205 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 44, 50, 56	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL CPU 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 92 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 93 MULTICONTROL DE 93 Device Driver 298 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 52 MULTICONTROL CPU 93 Dialog Language Programming System 175 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 14, 50, 56 A 12A 60	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP34 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 28 MINICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Data MODURTOL Parallel Processor 149 Data MODURTOL Parallel Processor 149 Data MODURTOL Parallel Processor 149 Data Data 206 Dead Time 204 Dead Jime 204 Dead Jime 204 Dead Service Descriptors 298 Device Descriptors 298 Device Diver 298 MINICONTROL CPU 93 MULTICONTROL DE MINICONTROL 25 MULTICONTROL CPU 93 Diagnosis Functions 14 Compact Control 28 MINICONTROL 25 MULTICONTROL CPU 93 Dialog Language Programming System 175 Differential Component 205 Differential Component 205 Differential Component 205 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 44, 50, 56 A12A 60 A12B 61	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL CPU 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 92 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Pu 93 MULTICONTROL DE 93 Device Driver 298 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 52 MULTICONTROL CPU 93 Dialog Language Programming System 175 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 14, 50, 56 A 12A 60	5-
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP54 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149 Data Modules 300 Data MINICONTROL CPU 93 MULTICONTROL CPU 93 Devide Driver 298 Dead Time 204 Devide Driver 298 Diagnost Functions 14 Compact Control 28 MINICONTROL 28 MULTICONTROL D3 MULTICONTROL CPU 93 Dialog Language Programming System 175 Differential Time 205 Differential Time 2	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP44 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251,253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 92 MULTICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Pu 94 Data Modules 300 Date Compact Control 28 MINICONTROL Pu 93 MULTICONTROL Pu 93 MULTICONTROL Parallel Processor 149 DC LED MINICONTROL Power Supply Module 10ead Time 204 Debugging 177 Delay Time 204 Debugging 177 Delay Time 204 Debugging 170 Delay Time 205 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL CPU 93 Dialog Language Programming System 175 Differential Component 205 Differential Component 205 Differential Time 205 Di	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP64 98 NTCP64 98 NTCP64 98 PSCP5595 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Data Minicontrol Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL Parallel Processor 149 Data Modules 300 Date Data Minicontrol Power Supply Module 10- Dead Band 206 Dead Time 204 Dead Time 204 Device Descriptors 298 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 29 MULTICONTROL D193 Dialog Language Programming System 175 Differential Component 205 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 44, 50, 56 A12A 60 A12B 61 A12C 61 E16A 57 MAEA 58 MAEB 59 MULTICONTROL 84, 124, 116	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP54 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 Data Band 206 Dead Time 204 Debugging 177 Delay Time 204 Derivative Action Time 205 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTROL Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 29 MULTICONTROL CPU 93 Dialog Language Programming System 175 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 44, 50, 56 A12A 60 A12B 61 A12C 61 E16A 57 MAEA 58 MAEB 59 MULTICONTROL 84, 124, 116 A115 128	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP64 98 NTCP64 98 NTCP64 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL DP 192 MULTICONTROL DP 192 MULTICONTROL P3 20 MULTICONTROL P40 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL P3 MULTICONTROL P40 Data Modules 300 Date Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Data MODULE MINICONTROL Parallel Processor 149 Date Descriptor 193 MULTICONTROL Parallel Processor 149 Determine 204 Dead Time 204 Dead Time 204 Device Driver 298 Device Driver 298 Device Driver 298 Device Driver 298 MINICONTROL 52 MULTICONTROL 103 MULTICONTROL 20 MINICONTROL 44, 50, 56 A12A 60 A12B 61 A12C 61 E16A 57 MAEA 58 MAEB 59 MULTICONTROL 84, 124, 116 A115 128 A121/10125 130	5-6
CP70 96 NTCP33 97 NTCP33 97 NTCP33 98 NTCP54 98 PSCP65 98 Cross Reference List 177 CSMA/CD 251, 253  D Data Bits Serial Interfaces MINICONTROL 71 MULTICONTROL 142 Data Link Layer 252 Data Memory Compact Control 28 MINICONTROL 52 MULTICONTROL Parallel Processor 149 Data Modules 300 Date Compact Control 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 Data Band 206 Dead Time 204 Debugging 177 Delay Time 204 Derivative Action Time 205 Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL CPU 93 MULTICONTROL CPU 93 MULTICONTROL Device Driver 298 Diagnosis Functions 14 Compact Control 28 MINICONTROL 29 MULTICONTROL CPU 93 Dialog Language Programming System 175 Differential Time 205 Digital I/O Modules Comparisons 16, 20, 21 MINICONTROL 44, 50, 56 A12A 60 A12B 61 A12C 61 E16A 57 MAEA 58 MAEB 59 MULTICONTROL 84, 124, 116 A115 128	5-6





A244 129	Flying Saw 196	K . (3)
E161 117	FP128 114	1, 47
E162 118	FP384 114	Kernel 296
E163 120	Framing Error	Keyboard 233, 234
E243 122 I164 121	Serial Interfaces	
Digital Inputs 29	MINICONTROL 71 MULTICONTROL 143	L
Digital Outputs Compact Control 31	Frequency Shift Keying 251	_
Diodes/Z-Diode Combinations	Front Cover MINICONTROL 50, 53	LAD 175
Compact Control 27	FSK 251	Debugger 175, 177
MINICONTROL 47, 56	FTP 268	Ladder Diagram 175
MULTICONTROL 87, 124	Function Blocks 175, 178	LAN 250
Disturbance 204	Function Extensions 14	Laser Interferometer 190
Documentation 340	Functionality 14	Licence Agreement 322
Dual Speed Positioning 193	"Dr.	Life Span 14
Dummy Front 333	G	Linear Encoders 190
B&R MAESTRO 318, 333	, CP C	Linear Interpolation 200
MINICONTROL 53, 333	G WINDOWS Full Graphic Visualization 322	Lithium Battery 334
MULTICONTROL 333	Gateway 254	Compact Control 37
Dynamic Contour Controller 198	Gear Positioning 196	MINICONTROL 54
Dynamic Process Control PID Loop Controller 204	Ghost Modules 298	MULTICONTROL 102
	Graphic User Interface B&R MAESTRO 322	LLC 252 Local Area Networks 250
E	Graphics Controller MGC1 242, 315	Logic Block 176
	Ground Connection MULTICONTROL 86	Logic Control MULTICONTROL 82
E161 117	Grounding	Logic Plan 175
E162 118	Compact Controller 27	Logic Plan Programming 176
E163 120	MINICONTROL 46	Logical Link Control 252
E16A 57	MULTICONTROL 86	LP 175, 176
E243 122	Grounding Rail	
Early Failure 14	MINICONTROL 46	M S
EE32	MULTICONTROL 86, 87	IVI N
MINICONTROL 54		MAC - Medium Access Control 252
MULTICONTROL 111	(A) H	MAC1 Axis Controller 316
EE96 112	Th. Th.	MAEA 58
Electromagnetic Disturbances	Handshake	MAEB 59
Compact Control 27	MINICONTROL 70	MAESTRO CoProcessors 305
MINICONTROL 46 MULTICONTROL 86	MULTICONTROL 142	MAESTRO Corridcessors 303
MULTICONTROL 86 Electromechanical Switching Elements	Hard Disk for B&R MAESTRO CoProcessor 309	MAESTRO Rack 304 MAESTRO System 304
Compact Control 27	Hardware Handshake	Main Processor in B&R MAESTRO System (MCO) 30
MINICONTROL 46	MINICONTROL 70	Manchester Coding 251
MULTICONTROL 86	MULTICONTROL 142	MARC Network Controller 273, 313
Electronic Gears 196	Hardware Reset 15	Mass Memory (BRMEC) 165
Electrostatic	Hardware Watchdog 15	Mathematics Instructions
Compact Control 27	Compact Control 28	Compact Controller 28
MINICONTROL 47	MINICONTROL 52	MINICONTROL 52
MULTICONTROL 87	Honeywell CIM620 287	MULTICONTROL CPU 92
Elementary Diagnosis Functions MULTICONTROL 103	Housing MINICONTROL 53	MULTICONTROL Parallel Processor 149
Emulation PROVIT 700 306		MCIF2 PLC Bus Interface Module 307
EP128 113	77.	MCO Hard Disk 309
Error Free Operation 14		MCO1 B&R MAESTRO CoProcessor 305
Error Location 177	1164 121	MCO3 B&R MAESTRO CoProcessor 305
ETHERNET 253, 260, 312	IEEE 252	MCO3MC B&R MAESTRO CoProcessor 305
FASTNET 267	IEEE 802.3 253	Meantime-Between-Failure 14
INTERNET 268	IEEE 802.4 253	Measurement 190
Overview 256	IEEE 802.5 253	Compact Control 25
SINEC-H1 263	Incremental Encoder 190	Comparisons 16, 17, 18
ETHERNET Address 263	Input / Timing Module	MINICONTROL 44, 53
ETHERNET PCMCIA LAN Card 262, 312	MINICONTROL	Module Rack MULTICONTROL 101
ETHERNET Transceiver 262, 312	MZEA 78	Medium Access Control 252
Event Counting	MZEB 78	Memory Expansion 1 MByte Flash PROM 243, 244, 306
Compact Control 30	Input Filter	1 MByte SRAM 308
MINICONTROL 74	Analog Input Modules	Memory Expansion Module MM8M 308
MULTICONTROL 152	MINICONTROL 62	Memory Module 296
Events 300	MULTICONTROL 132	MENC Network Controller 261, 312
EXE3 84, 161	Compact Control 32	MFDD700 Parallel Disk Drive Station 310
Expanded Diagnostics Functions MULTICONTROL 103 Expansion Cable 84, 161	Input Simulator 335	MFDD70S Serial Disk Drive Station 311
Expansion Rack 84, 100, 161	Inputs / Outputs	MGC1 Graphic Controller 242, 315
Expansion Receiver Module 84, 161	Comparisons 16, 17, 18 Compact Control 24	Microware 296
Expansion Test 15	MINICONTROL 44	MINICONTROL 44,50
Expansion Transmitter 84	MULTICONTROL 83	MINICONTROL CPU 52
Expansion Transmitter Module 84, 161	Installation Guidelines	MINICONTROL Housing 53
Expansion Unit 84, 161	Compact Control 25	MINICONTROL Operator Interface Panels 226, 227
Expansions 84	MINICONTROL 45	Interface Module PATA 73
EXS2 84, 161	MULTICONTROL 85	MININET 280, 324
EXS5 277	Instruction Set	EPROM with Protocol 286
	Compact Control 28	Overview 256
F N	MINICONTROL 52	Standard Software 187
· ~~~	MULTICONTROL CPU 92	MM8M Memory Expansion Module 308
Failure Rate 14	MULTICONTROL Parallel Processor 148	Mnemonics 175 MODBUS 287
Fan	INT1 146	
Compact Control 25	Integral Component 205	Modem 172, 173 Modem Interface 172
MINICONTROL 45	Integral Action Time 205	Modular Concept 14
MULTICONTROL 85	Interface Controllers	Module Fronts MINICONTROL 53
Relay Expansion Card 39	Compact Controller 26 MINICONTROL 45	Module Grounding
FASTNET 261, 267, 312	MULTICONTROL 85	Compact Controller 27
Overview 256		MINICONTROL 46
FBK 175	Interface Controller 143, 146 RS232/RS485 (INT1) 146	MULTICONTROL 86
FBK Editor 175, 176		Module Installation / Removal
FDDI 254	Interface Controller MSIO 314 Interface Module	MINICONTROL 45
Feedback 205	ARCNET 273	MULTICONTROL 85
Fiber Distributed Data Interface 254	MINICONTROL	Module Overview I/O Modules
Fiber Optics Cable 251	PATA 73	Comparisons 20, 21
Field Bus 252	PIFA 72	MINICONTROL 44, 50
File Manager 298	MULTICONTROL	MULTICONTROL 84, 90
First Scan Flag	PIF1 144	Mounting
Compact Control 28	PIF3 145	Compact Controller 25
MINICONTROL 52 MULTICONTROL CPU 92	Interface Modules	Relay Piggyback 39
MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149	MINICONTROL 70	Movement Profile 198
Flags	MULTICONTROL 142	MSIO Interface Controller 314
Compact Controller 28	Interfaces Compact Controller 28, 34	MTBF-Rate 14
MINICONTROL 52	INTERNET 261, 268, 312	MULTICONTROL 82
MULTICONTROL CPU 92	Overview 256	MULTICONTROL Rack
Floating Point Mathematics Instructions	Interpolation 200	Installation Guidelines 85
Compact Control 28	Interpolation Tasks 198	Multiprocessor Architecture 82 Multiprocessor Systems (MCO) 305
MINICONTROL 52	Interrupts 301	Multiprocessor Systems (MCO) 305 Multiprocessor Technology 82
MULTICONTROL Parallel Processor 149	ISO 802.4 272	MZEA 78
MULTICONTROL CPU 92	ISO-OSI Reference Model 252	MZER 78
Floppy Disk Stations for B&R MAESTRO 310	Jolt Limitation MAC1 Axis Controller 199	





N	
NC Machines 198	
NC Program 200 Network / Communication	
Compact Controller 24	
Comparisons 16, 17, 18, 19 MINICONTROL 44	
MULTICONTROL 83	
Network Controller MARC (ARCNET) 273, 313	
MENC (ETHERNET) 261, 312	
Network Layer 252 Network Overview 252	
Networks 250	
B&R MAESTRO System 312 NFM 298	
NOVELL 261, 312	
NP02 162, 286	
NRZI 251 NT33 54	
NT43 104	
NT44 105 NTCP33 91, 97, 102, 107	
NTCP63 91, 98, 102, 107 NTCP64 91, 98, 102, 108	
0	
0125 130	
On-line Adapter 174, 334	
On-line Cable Compact Controller 8	
MINICONTROL 51	
MULTICONTROL CPU 92 MULTICONTROL Parallel Processor	148
On-line Interface Modules 171	
Compact Controller 28 MINICONTROL 51	
MULTICONTROL CPU 92	
MULTICONTROL Parallel Processor On-line Networks 172, 173	148
Open Loop Speed Drive 195	
Operating Security 14 Operating Temperature	
Compact Control 24	
MINICONTROL 50 MULTICONTROL 90	
Operator Panels 226	
BRRT360 228 BRRTEL45 229	
BRRTM3 227	
BRRTM4 227 BRXTGR31 235	
BRXTGR35 235	
Standard Software 181 OS-9 296	
OS-9 I/O Management 298	
OS-9 Memory Management 297 OS-9 Module Construction 297	
OS-9 Module Directory 297	
OS-9 Process Management 299 OS-9/Tool Kit 324	
Other Protocols 286, 324	
Overrun Error Serial Interfaces	
MINICONTROL 71	
MULTICONTROL 143	
P	
B.O	
P Component 206 PA42 141	
PA81 141 Parallel Diskette Station MFDD700 310	
Parallel Interfaces	
MINICONTROL 70	
MULTICONTROL 142 Parity Bit	
Serial Interfaces	
MINICONTROL 71 MULTICONTROL 142	
Parity Error	
Serial Interfaces MINICONTROL 71	
MULTICONTROL 143	470
Password Protected Modem Remote Diagr PATA 73, 227	nosis 173
Path Dependent Speed Control 194	
PC 170 PCMCIA Interface	
MCIF2 307	
MCO3MC 305 PROVIT 1830 243	
PCMCIA LAN Card ETHERNET 262, 312	
PE16 136 PE42 133	
PE82 133	
PE84 134 PEA4 63	
PEA8 64	
Performance Compact Control 24	
MINICONTROL 44	
MULTICONTROL 83 Peripheral Processors 82, 148	
PP60 150	
PP60 MEM 151 Personal Computer 170, 175	
PG 170	
Physical Layer 252 PID Loop Controller 205	
PIF1 144	

PIF3 145	
PIFA 72	
PIPEMAN 298	
Pipes 300 PLC Bus Interface Module MCIF2 307	
PLC Network Standard Software 187	
PMV4 163 PNC3 153	
PNC4 75	
PNC8 156	
Polling 251 Position Control Loop 201	
Positioning 190, 194	
Compact Controller 30	
MINICONTROL 74 MULTICONTROL 152	
Standard Software 186	
Positioning Methods 193 Positioning Module 316	
Positioning Module 316 MINICONTROL	
PSA2 77	
MULTICONTROL PNC8 156	
PSA2 154	
Positioning Modules 194	
MINICONTROL 74 MULTICONTROL 152	
Positioning Systems 190	
Potential Shifts	
Compact Controller 27 MINICONTROL 46	
MULTICONTROL 87	
Potentiometer 190	
Power Requirements 103 Power Supply for BRKAOL5 171	
Power Supply for BRKAULS 1/1 Power Supply Modules	
M264	
NTCP33 107 NTCP63 107	
NTCP64 108	
PSCP65 109	
MINICONTROL 50, 54 MULTI, MIDI	
NT43 104	
NT44 105	
PS45 106 MULTICONTROL 102	
Power-On Behavior	
Compact Control 29	
EE32 111 EE96 112	
EP128 113	
FP128/FP384 114 MINICONTROL 52 54	
MINICONTROL 52, 54 PP60 150	
PP60 MEM 151	
Precision Control Loop 204 Presentation Layer 252	
Presentation Layer 252 Printer Standard Software 181, 182	
Process Data Management SPOIMG 323	
Processors	
Compact Controller 28	
MINICONTROL 51	
MINICONTROL 51	40
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 14	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Time 15	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 14 Production Defects 14 Program Cycle Time 15 Program Documentation 177	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Time 15 Program Initialization 177	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Time 15 Program Initialization 177 Program Initialization	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Inme 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 1891 Programming 1951 Programming System 175	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printbut 177 Programming 170 Programming 170 Programming System 175 Project Planning 346	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming Languages 175 Programming Languages 175 Programming System 175 Project Planning 346 Proportonal Amplification 205, 206	48
MMINCONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 175 Programming System 175 Project Planning 346 Proportional Amplification 205, 206 Proportional Band 206	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Cycle Ime 15 Pogram Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Pogramming 170 Pogramming Languages 175 Programming System 175 Project Planning 346 Proportional Applification 205, 206 Proportional Band 206 Proportional Component 205 Proportional Component 205 Proportional Component 205 Proportional Component 205	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 14 Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Indigitation Compact Controller 28 MINCONTROL 52 Program Initiation 20 Programming 170 Programming 175 Programming 175 Programming System 175 Programming 346 Proportional Amplification 205, 206 Proportional Band 206 Proportional Component 205 Proportional Solenoid Module PMV4 163 Protective Circuia	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 14 Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MMICONTROL 52 Program Initialization Typergramming 170 Programming 170 Programming 170 Programming System 175 Programming System 175 Project Planning 346 Proportional Applification 205, 206 Proportional Applification 205, 206 Proportional Positional Component 205 Proportional Solenoid Module PMV4 163	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Incide 172 Program Incide 172 Program Indialization Compact Controller 28 MIMICONTROL 52 Program Printiout 177 Programming 170 Programming 170 Programming Languages 175 Programming System 175 Project Planning 346 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MIMICONTROL 47, 66 MULTICONTROL 47, 64	48
MMICONTROL 51 MULTICONTROL Parallel Processor 1 MULTICONTROL Parallel Processor 1 Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MMICONTROL 52 Program Printout 177 Programming 170 Programming Languages 175 Programming System 175 Programming System 175 Programming 346 Proportional Aspulfication 205, 206 Proportional Pandification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MMICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 87, 124 Protective Measures	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Incide 172 Program Incide 172 Program Indialization Compact Controller 28 MIMICONTROL 52 Program Printiout 177 Programming 170 Programming 170 Programming Languages 175 Programming System 175 Project Planning 346 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MIMICONTROL 47, 66 MULTICONTROL 47, 64	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 14 Program Cycle Iime 15 Program Cycle Iime 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 175 Programming 181 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Component 205 Proportional Component 205 Proportional Component 205 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 67 MINICONTROL 47 MINICONTROL 47 MINICONTROL 67 MINICONTROL 67 MINICONTROL 67 MINICONTROL 68 MULTICONTROL 66 MULTICONTROL 66	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Incide 172 Program Incide 172 Program Incide 172 Program Indiazation Compact Controller 28 MIMICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 187 Programming 187 Programming 187 Programming 187 Programming 187 Programming 188 Programming 205 Programming 188 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MIMICONTROL 47, 56 MULTICONTROL 87 PROVITION 188 MULTICONTROL 86 MULTICONTROL 86 PROVITI	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 14 Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Incilization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 175 Programming 181 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Band 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47 MINICONTROL 47 Protective Green Compact Controller 27 MINICONTROL 47 MINICONTROL 46 MULTICONTROL 66	48
MINICONTROL 51 MULTICONTROL Parallel Processor 1 MULTICONTROL Parallel Processor 1 Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 170 Programming 180 Programming 346 Proportional Amplification 205, 206 Proportional Band 206 Proportional Band 206 Proportional Bongification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 54 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Terminals 232	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Incident 28 MINICONTROL 52 Program Indiazation Compact Controller 28 MINICONTROL 52 Programming 170 Programming 177 Programming 177 Programming 175 Programming 175 Programming 346 Proportional Amplification 205, 206 Proportional Component 205 Proportional Component 205 Proportional Solenoid Module PMV4 163 Proportional Component 205 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47, 124 Protective Circuit Compact Controller 27 MINICONTROL 47, 124 Protective Measures Compact Controller 27 MINICONTROL 46 MULTICONTROL 66 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Imminals 232 PROVIT 600 233	48
MINICONTROL 51 MULTICONTROL Parallel Processor 1 MULTICONTROL Parallel Processor 1 Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 170 Programming 180 Programming 346 Proportional Amplification 205, 206 Proportional Band 206 Proportional Band 206 Proportional Bongification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 54 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Terminals 232	448
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Documentation 177 Program Initialization Compact Controller 28 MMICONTROL 52 Program Initialization 177 Programming 170 Programming 170 Programming 177 Programming 177 Programming 175 Programming 181 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Genopenent 205 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MMICONTROL 47, 56 MULTICONTROL 87, 124 Protective Measures Compact Controller 27 MMICONTROL 46 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Imminals 232 PROVIT 600 233 PROVIT 700 234 Industrial Workstations PROVIT 700 234 Industrial Workstations	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1/2 Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Initialization Compact Controller 28 MMINICONTROL 52 Program Printout 177 Programming 170 Programming Languages 175 Programming Languages 175 Programming Languages 175 Programming System 175 Programming 346 Proportional Amplification 205, 206 Proportional Band 206 Proportional Band 206 Proportional Bonghication 205, 206 Proportional Solenoid Module PMV4 163 Proportional Component 205 Proportional Solenoid Module PMV4 163 Proportional Component 205 Proportional Component 205 Proportional Component 205 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Monitor PROVIT 800 242, 315 Industrial Workstations PROVIT 700 234 Industrial Workstations PROVIT 1745 243 PROVIT 1830 243	48
MMICONTROL 51 MULTCONTROL CPU 92 MULTCONTROL CPU 92 MULTCONTROL Parallel Processor 1. Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Incide 128 MINICONTROL 52 Program Indiazation Compact Controller 28 MINICONTROL 52 Programming 170 Programming 170 Programming 175 Programming Languages 175 Programming Janguages 175 Programming 346 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Sonopment 205 Proportional Solenoid Module PMV4 163 Proportional Component 205 Proportional Solenoid Module PMV4 163 Proportional Component 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47, 124 Protective Measures Compact Controller 27 MINICONTROL 46 MULTICONTROL 66 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Workstations PROVIT 700 234 Industrial Workstations PROVIT 1345 243 PROVIT 1345 243 PROVIT 1345 243 PROVIT 1345 243 Standard Software 181	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Incident 177 Program Incident 177 Program Indigization MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 175 Programming Languages 175 Programming 176 Proportional Component 205 Proportional Amplification 205, 206 Proportional Component 205 Proportional Component 205 Proportional Component 205 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47, 124 Protective Circuit Compact Controller 27 MINICONTROL 47, 124 Protective Measures Compact Controller 27 MINICONTROL 46 MULTICONTROL 66 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Workstations PROVIT 700 234 Industrial Workstations PROVIT 1345 243	48
MINICONTROL 51 MULTCONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Initialization 177 Programming 170 Programming 170 Programming 177 Programming 177 Programming Languages 175 Programming Languages 175 Project Planning 346 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Solenoid Module PMV4 163 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 48 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 PROVIT 700 224 Industrial Terminals 232 PROVIT 600 233 PROVIT 1345 243 PROVIT 6mulation SWMTERM-0 306	448
MINICONTROL 51 MULTICONTROL Parallel Processor 1 Production Defects 14 Program Cycle Time 15 Program Cycle Time 15 Program Toyle Time 15 Program Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming Languages 175 Programming System 175 Proportional Band 206 Proportional Band 206 Proportional Band 206 Proportional Solenoid Module PMV4 163 Proportional S	448
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Initialization Compact Controller 28 MMINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 170 Programming 170 Programming Languages 175 Programming Languages 175 Programming 180 Proportional Amplification 205, 206 Proportional Band 206 Proportional Band 206 Proportional Bonghication 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47 MINICONTROL 46 MULTICONTROL 47 Industrial Monitor PROVIT 800 242, 315 Industrial Ierminals 232 PROVIT 100 PROVIT 100 PROVIT 101 Salandard Software 181 PROVIT 1145 243 PROVIT 11450 243 PROVIT 11450 243 PROVIT 1140 Emulation SWMTERM-0 306 PRTAL 69 PSAS 706 PRTAL 69 PSAS 77, 154, 193	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Cycle Time 15 Program Documentation 177 Program Incidence 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 175 Programming Languages 175 Programming 181 Proportional Amplification 205, 206 Proportional Genopment 205 Proportional Genopment 205 Proportional Solenoid Module PMV4 163 Proportional Component 205 Proportional Component 205 MINICONTROL 47, 56 MULTICONTROL 47, 124 Protective Circuit Compact Controller 27 MINICONTROL 47, 124 Protective Measures Compact Controller 27 MINICONTROL 46 MULTICONTROL 66 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Terminals 232 PROVIT 1800 243 PROVIT 1800 243 Standard Software 181 PROVIT 1345 243 PROVIT 1300 243 PROVIT 1300 243 PROVIT 1300 243 PROVIT 169 39 PSOLP 57, 154, 193 PSOLP 59, 198, 102, 109	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1/2 Production Defects 14 Program Cycle time 15 Program Documentation 177 Program Documentation 177 Program Initialization Compact Controller 28 MMICONTROL 52 Program Printbut 177 Programming 170 Programming 170 Programming 170 Programming 170 Programming 180 Programming 180 Programming 180 Programming 180 Programming 180 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MMICONTROL 47, 56 MULTICONTROL 87, 124 Protective Measures Compact Controller 27 MINICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Terminals 232 PROVIT 600 233 PROVIT 1800 243 Industrial Workstations PROVIT 1800 243 Industrial Workstations PROVIT 1830 243 PROVIT 1845 243 PROVIT 1850 245 PROVIT 1950 Emulation SWMTERM-0 306 PSA2 77, 154, 193 PSCP65 91, 98, 102, 109 PT41 65	48
MMICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Documentation 177 Program Documentation 177 Program Initialization Compact Controller 28 MMINICONTROL 52 Program Printbut 177 Programming 170 Programming 170 Programming 170 Programming Languages 175 Programming Languages 175 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Genopenent 205 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 47, 56 MULTICONTROL 48 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 MULTICONTROL 46 PROVIT 800 242, 315 Industrial Imminals 232 PROVIT 800 PROVIT 800 242, 315 Industrial Imminals 232 PROVIT 700 234 Industrial Workstations PROVIT 1800 243 Standards Software 181 PROVIT 1830 243 PROVIT 1800 Emulation SWMTERM-0 306 PSA2 77, 154, 193 PSCP65 91, 98, 102, 109 PT44 65 PT81 138 PT42 66	48
MINICONTROL 51 MULTICONTROL Parallel Processor 1. Production Defects 14 Program Cycle Time 15 Program Cycle Time 15 Program To Cycle Time 15 Program Documentation 177 Program Initialization Compact Controller 28 MINICONTROL 52 Program Initialization 205 Programming 170 Programming 170 Programming 177 Programming Languages 175 Programming Languages 175 Programming 180 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Band 206 Proportional Component 205 Proportional Component 205 Proportional Solenoid Module PMV4 163 PROVIT 100 Emulation Solenoid Module PMV4 163 PSOVIT 1345 243 PROVIT 1350 243 PROVIT 1360 243 PROVIT 1361 243 PROVIT 1	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Oyel Time 15 Program Decide Time 15 Program Decide Time 15 Program Initialization Compact Controller 28 MINICONTROL 52 Program Printout 177 Programming 170 Programming 170 Programming 170 Programming 346 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Component 205 Proportional Component 207 Proportional Component 207 Proportional Component 207 MINICONTROL 47, 56 MULTICONTROL 87, 124 Protective Measures Compact Controller 27 MINICONTROL 46 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Monitor PROVIT 800 242, 315 Industrial Terminals 232 PROVIT 100 234 Industrial Workstations PROVIT 1345 243 PROVIT 1345	448
MINICONTROL 51 MULTICONTROL PU 92 MULTICONTROL PU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Opcle Time 15 Program Decumentation 177 Program Individual Program Opcle Time 15 Program Individual Program Individual Program Individual Proportional Proportio	48
MINICONTROL 51 MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Oyel Time 15 Program Dec Time 15 Program Dec Time 15 Program Individual State 17 Programming 170 Programming 170 Programming 170 Programming System 175 Project Planning 346 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Amplification 205, 206 Proportional Component 205 Proportional Component 205 Proportional Solenoid Module PMV4 163 Protective Circuit Compact Controller 27 MINICONTROL 47, 56 MULTICONTROL 87, 124 Protective Measures Compact Controller 27 MINICONTROL 48 MULTICONTROL 86 PROVIT Industrial Monitor PROVIT 800 242, 315 Industrial Terminals 232 PROVIT 1800 233 PROVIT 1800 233 PROVIT 1700 234 Industrial Workstations PROVIT 1345 243 PROVIT 1345 243 PROVIT 1343 243 Standard Software 181 PROVIT 1345 243 PROVIT 135 243 PROVIT 135 243 PROVIT 1360 244 PROVIT 1360 245 PROVIT 1860 245 PROVIT 1	48
MINICONTROL 51 MULTICONTROL PU 92 MULTICONTROL PU 92 MULTICONTROL Parallel Processor 1- Production Defects 14 Program Opcle Time 15 Program Decumentation 177 Program Individual Program Opcle Time 15 Program Individual Program Individual Program Individual Proportional Proportio	48

. 1000
Q NOTE OF
Quality Criteria 14
R
Rack B&R MAESTRO System 304
R166 304 R169 304
M264 R111 100
MIDI R085 100
MULTI R165 100
R166 100 R169 100
MULTICONTROL 100 Rack Unit MINICONTROL 53
Random Failures 14 RBF 298
RC Combinations Compact Controller 27 MINICONTROL 47, 56
MULTICONTROL 87, 124 Ready Relay 15, 103
Real Time Applications 296 Real Time Clock
Compact Control 28 MINICONTROL 52, 69
MULTICONTROL CPU 93 Real Time Clock Multitasking Computer 296
Real Time Functionality 299 Register
Compact Controller 28 MINICONTROL 52
MULTICONTROL CPU 92 MULTICONTROL Parallel Processor 149
Registers Compact Control 28
MINICONTROL 52 MULTICONTROL CPU 92
Relative Humidity Compact Control 24
MINICONTROL 50 MULTICONTROL 90
Relay Card Description 38
Model Number 24 Relay Output Module
MINICONTROL Overview 50 MULTICONTROL Overview 124
Protective Circuit Compact Controller 27
MINICONTROL 47, 56 MULTICONTROL 87 Reliability 14
Remnant Memory Location Compact Controller 28
MINICONTROL 52 MULTICONTROL CPU 92
MULTICONTROL Parallel Processor 149 Remote Diagnosis 172, 173
Reserve Efficiency 14 Resolution
Analog I/O Modules MINICONTROL 62
MULTICONTROL 140, 132 Cam Disk Encoder 194
Compact Control Analog Input 32
Analog Output 33 Resolver 190
Resources 14 Rights 322
Rotational Pulse Encoder 190 RS232 Interface
Compact Controller 34, 35 MINICONTROL 70
MULTICONTROL 142 RS422 Interface MINICONTROL 70
MULTICONTROL 142 RS485 Interface
Compact Controller 35 MINICONTROL 70
MULTICONTROL 142 RUN - MINICONTROL 54
Runtime Error 15 Runtime Monitor 15
Compact Controller 28 MINICONTROL 52
MULTICONTROL 93
S
S3964 (R) (RK512) 286, 324 Sales and Support 346
SBF 298 SCF 298
Security and Diagnosis Functions 14 Compact Controller 28
MINICONTROL 52 MULTICONTROL 93
Security Functionality Compact Controller 28
MINICONTROL 52 Modem Remote Diagnosis 173
MULTICONTROL CPU 93 Security Layer 252
Seminars 346 Serial Diskette Station MFDD70S 311





Serial Interfaces	System Slots
Compact Controller 34	MINICONTROL 50
MINICONTROL 70	MULTICONTROL 100
MULTICONTROL 142	Systems
SERIAL-NET Overview 256	MINICONTROL 44
Service 346	MULTICONTROL 82
Session Layer 252	moznoonnoz oz
Set Point Ramp 207	_
	T 💍
Set Value (Command Signals) 204	
Set Value Change (Command Signal Adjustment) 204, 208	Table Editor 176
Set Value Limit 208	Table of Contents
Setup Tool for XT Operator Interface Panels 235	Chapter A PLC System
Seven Layer Architecture 252	
Shielding	Section A1 System Selection 13
Compact Controller 27	Section A2 B&R 23
MINICONTROL 46	Section A3 System MINICONTROL 43
MULTICONTROL 86	Section A4 MINICONTROL Components 49
	Section A5 System MULTICONTROL 81
Short Descriptions 341	Section A6 MULTICONTROL Components 88
Signals 300	Section A7 PLC Programming 169
SINEC H1 261, 263, 312	Section A8 Positioning 189
Overview 256	Section A9 Loop Control 203
SINEC L1 286, 324	
Single Processor in the PLC (MCO) 305	Chapter B V isualization
Single Step Operation 177	Section B1 System Selection 217
Slot Number	Section B2 Visualization with Operator Panels 225
Digital Input Module	Section B3 Semigraphic Visualization 231
MULTICONTROL 116	Section B4 Full Graphic Visualization 241
	Chapter C Industrial Networks and Communication
Digital Output Module	Section C1 System Selection 249
MULTICONTROL 124	Section C2 ETHERNET 259
MINICONTROL 56	Section C3 ARCNET 271
MULTICONTROL 100	Section C4 CAN Bus 275
Slots	
MINICONTROL 44, 50	Section C5 B&R MININET 279
MULTICONTROL 83	Section C6 Other Protocol 285
Slotted Time Division, Multiple Access 251	Chapter D Industrial Computer
SMTP 268	Section D1 System B&R MAESTRO 293
Software Clock	Section D2 B&R MAESTRO Components 303
MINICONTROL 52	Section D3 Industrial Computer Software 321
	Chapter E Accessories 327
MULTICONTROL CPU 93	Chapter F Documentation 339
MULTICONTROL Parallel Processor 149	Chapter G Sales and Support 345
Software Handshake	Tables 176
MINICONTROL 70	
MULTICONTROL 142	Tandem Axes 200
Software Package B&R MAESTRO 322	TCP/IP 268
Software Timing	Telephone Number and Addresses 346
	TELNET 268
Compact Controller 8	Temperature Measurement
MINICONTROL 52	Compact Controller 32
MULTICONTROL CPU 92	MINICONTROL 62, 65, 66, 67, 68
Software Watchdog 15	MULTICONTROL 132, 137, 138
Compact Controller 28	
MINICONTROL 52	Terminal Blocks 24, 333
MULTICONTROL CPU 93	Test Equipment 335
MULTICONTROL Parallel Processor 149	Test Operation 14
Special Protocols 287	Thick Wire ETHERNET 260
SPECTO_S 236	Thin Wire ETHERNET 261
	Three Phase Synchronous Servo Motors 192
Configurations 237	Time
With B&R MAESTRO CoProcessor 237	Compact Controller 28
With B&R MAESTRO System 237	MINICONTROL 52
With Full Graphic Elements 237	
With PROVIT Industrial Workstation 238	MULTICONTROL CPU 93
With XT Operator Interface Panels 238	MULTICONTROL Parallel Processor 149
Editor 236, 322	Time Proportional Control 209
Runtime System 236, 323	Timer Modules
	MINICONTROL
Speed Control 194	MZEA 78
Speed Jumps 199	MZEB 78
Spline Interpolation 200	Timing
SPOIMG - Process Data Management 323	Analog I/O Modules
Stability - Loop Control 204	MINICONTROL 62
Stack Pointer Test 15	
Standard Software Package 1 179	MULTICONTROL 132
Standard Software Package 12 273	Compact Controller 28
Standard Software Package 15 37,277	Digital I/O Modules
Standard Software Package 2 181	MINICONTROL 56
	MULTICONTROL 124, 116
Standard Software Package 3 185, 204	MINICONTROL 52
Standard Software Package 4 186	MULTICONTROL CPU 92
Standard Software Package 5 187	MULTICONTROL Parallel Processor 149
Standard Software Package 6 287	
Standard Software Package 7 287	Timing Pulses Compact Controller 28
Standard Software Package 8 287	
Standard Software Package 9 287	MINICONTROL 52
Standard Software Package Overview 178	MULTICONTROL CPU 92
Standards 252	MULTICONTROL Parallel Processor 149
Start Bit	Token Bus 253
	Token Passing 251, 272
Serial Interfaces	Token Ring 253
MINICONTROL 71	Tool Radius Correction 200
MULTICONTROL 142	Trace Function 177
Start/Stop Positioning 193	Transient Current
Statement List 175	
Status Test 177	Compact Control 27
STDMA 251	MINICONTROL 46
Step Signal Control 210	MULTICONTROL 87
Stepper Motor	Transistor Output Modules
MINICONTROL 77	MINICONTROL Overview 50
	MULTICONTROL Overview 124
MULTICONTROL 154	Protective Circuits
Stepper Motor Controller Module 193	Compact Controller 27
Stepper Motor Positioning 193	MINICONTROL 47,56
Stepper Motors 193	MULTICONTROL 87
STL 175	Transmission Media 251
STL Debugger 177	
Stop Bit	Transmission Methods 251
Serial Interfaces	Transport Layer 252
MINICONTROL 71	Trap Error 15
MULTICONTROL 143	Triac Output Module
	MULTICONTROL Overview 124
Storage Temperature	Protective Circuit
Compact Control 27	MULTICONTROL 87
MINICONTROL 47	TTY Interface
MULTICONTROL 87	MINICONTROL 70
Straight Line to Straight Line Transition 199	
SYMB 176	MULTICONTROL 142
Symbol Assignments 176	
Symbol Table 177	U(O)
Synchronous Positioning 196	200
	Ultraconic Transducer Medule 100
System Selection PLC Systems 15	Ultrasonic Transducer Module 190
	Update Time

```
Analog I/O Modules
MINICONTROL 62
MULTICONTROL 132
User Interface
MINICONTROL 52
MULTICONTROL 52
MULTICONTROL 92
MULTICONTROL 92
MULTICONTROL 92
MULTICONTROL 93
MULTICONTROL 94
User's Manuals 340

V

V24 Interface
MINICONTROL 70
MULTICONTROL 142
Varistor
Compact Controller 27
MINICONTROL 47,56
MULTICONTROL 87,124
Voltage Supply
BRKAOL5 171
Compact Controller 37
Relay Card 40

W

Wearout Failures 14
Wire Cross Section
Compact Control 26
MINICONTROL 45
MULTICONTROL 45
MULTICONTROL 55
MULTICONTROL 55
MULTICONTROL 55
MULTICONTROL 165
MULTICONTROL 170
MULTICONTROL 170
MULTICONTROL 142
XFER
MINICONTROL 54
MULTICONTROL 142
XFER
MINICONTROL 54
MULTICONTROL 54
MULTICONTROL 54
MULTICONTROL 54
MULTICONTROL 54
MULTICONTROL 54
MULTICONTROL 54
```



# B&R<sup>EL</sup> NUMBER INDEX

# **PRODUCT RANGE**

ı	٩	ı	
l	ı	•	

0G0003.00-090 328, 329

### В

BRADOL-0 174 BRADPNC8E-0 156 BRADPNC8E-0 18 BRADREL1-0 24 BRARCIF-0T 273 BRCOMP1-0 24 BRCOMP2-0 24 BRIFPC-0 171 BRKA01-0 328, 329 BRKA01-0 328, 329 BRKA02-0 328, 329 BRKA04-0 328, 329 BRKA05-0 146, 328, 332 BRKA05-0 73, 227, 328, 329 BRKA09-0 328, 330 BRKA09-1 328, 330 BRKA09-1 328, 330 BRKA11-0 328, 332 BRKA30-0 310, 318, 328 BRKAA0-0 273, 313 BRKAARC-0 273, 313 BRKAARH-0 273, 313 BRKAARH-0 273, 313 BRKAARH-0 273, 313 BRKAACOMP1-0 328, 329 BRKA1-1 262, 312 BRKAETL-2 526, 312

BRKAETL-3 526, 312

BRKAMS-3 18, 328, 331

BRKAMO-0 328, 332

BRKAOL-0 28, 51, 92, 148, 172, 328, 332

BRKAOL-1 772, 328, 332

BRKAOL-1 772, 328, 332

BRKAOL-1 378, 333 BRKADL5-1 171
BRKAPC-0 328, 331
BRKAPC-2 328, 331
BRKAPC-3 328, 331
BRKAPC-3 318, 328, 330
BRKAPC-5 318, 328, 330
BRKAPC-5 318, 328, 330
BRKAPC-6 318, 328, 331
BRKAPC-7 318, 328, 331
BRKAPC-8 328, 331 BRKAPC-8 328, 331
BRKAPGH-0 315, 318, 328, 331
BRKEY01-0 233, 234
BRKEY02-0 233, 234
BRLITB-0 334
BRMCER008-0 165
BRMCR032-0 165
BRMCR128-0 165
BRMCR128-0 165 BRMEC-0 165 BRPS220904-0 171 BRRT360-0 228 BRRT360-1 228 BRRTEL45-0 229 BRRTM3-0 227 BRRTM4-0 227 BRTB0218-0 24 BRXTGR31-0 235 BRXTGR35-0 235

ECA121-0 130 ECA161-01 125 ECA162-01 127 ECA162-01 12: ECA244-0 129 ECBL01-0 333 ECBL02-0 333 ECBL04-0 333 ECCP40-01 94 ECCP60-01 95 ECCP70-01 96 ECCP70-01 96 ECE161-0 117 ECE161-1 117 ECE162-3 118 ECE243-0 122 ECE243-1 122 ECEE32-0 111 ECEE32MP-0 111, 172 FCFF96-0 112 ECEE96-0 112 ECEP128-0 113 ECEXE3-0 161 ECEXKA-1 161, 328 ECEXS2-1 161 ECEXS5-0 277 ECFP128-0 114 ECFP128-U 114 ECFP128MP-0 114, 172 ECFP384-0 114 ECI164-0 121 ECINT1-1 146 ECINT1-11 146 ECINT1-11 146 ECMB01-0 334 ECNP02-0 162, 286 ECNT43-0 104 ECNT43-1 104 ECNT44-0 105 ECNT44-1 105 ECO125-0 130 ECPD442-0 141 ECPA42-0 141 ECPA42-01 141 ECPA42-01 141 ECPA42-2 141 ECPA42-21 141 ECPA81-0 141 ECPA81-01 141 ECPA81-2 141 ECPA81-2 141 ECPA81-21 141 ECPA01-0 174, 334 ECPE16-0 136 ECPE42-1 133 ECPE42-11 133 ECPE42-2 133 ECPE42-2 133 ECPE82-1 133

ECPE82-2 133 ECPE82-21 133 ECPE84-0 134 ECPE84-0 134 ECPE84-2 134 ECPIF3-0 145 ECPNC3-0 153 ECPNC3-1 153 ECPNC8-13 156 ECPNC8-23 156 ECPNC8-23 156 ECPP60-01 150 ECPP60MEM-01 151 ECPS45-0 106 ECPSA2-0 154 ECPT81-0 138 ECPT81-1 138 ECPTE8-0 137 FCPTF8-1 137 ECPTE8-1 13/ ECPTE8-2 137 ECPTE8-3 137 ECPWP4-0 158 ECPWP4-2 158 ECPWP4-4 158 ECPZL1-0 155 ECR165-0 100 ES-E161 335 ES-E163 335 ES-E16A 335 ES-E243 335

HCMARC-0CT 273, 313 HCMARC:CAD 273, 313 HCMARC:CAD 2/3, 313 HCMARC:CAE 273, 313 HCMARC:CAI 273, 313 HCMARC:CIE 273, 313 HCMARC:CIE 273, 313 HCMARC:CIX 273, 313 HCMCIE:2AD 307 HCMCIF:2AE 307 HCMCIE:2AX 307 HCMCIF:2ID 307 HCMCIF:2IE 307 HCMCIF:2IX 307 HCMCIF:2-0 307 HCMCO:10AX 306 HCMCO:10UD 306 HCMCO:10UE 306 HCMCO:31AX 306 HCMCO:31UD 306 HCMCO:31UE 306 HCMCO:32AX 306 HCMCO:32UD 306 HCMCO:32UE 306 HCMCO1-A 306 HCMCO1-A 306 HCMCO3-IA 306 HCMCO3MC-IA 306 HCMCOHDD-2 309 HCMCOHDD-2S 309 HCMENC-0 262, 312 HCMENC:0FD 262, 312 HCMENC:0FD 262, 312 HCMENC:0FE 262, 312 HCMENC:0FX 262, 312 HCMENC:0ND 262, 312 HCMENC:0NX 262, 312 HCMENC:0SD 262, 312 HCMENC:0SD 262, 312 HCMENC:0SX 262, 312 HCMENC:0TD 262, 312 HCMENC:0TE 262, 312 HCMENC:0TE 262, 312 HCMENC:0TX 262, 312 HCMENC:LND 262, 312 HCMENC:LNX 262, 312 HCMFDD:PD 310 HCMFDD:PX 310 HCMFDD700-0 310 HCMFDD70S-0 311 HCMFDD70S:D 311 HCMFDD70S:X 311 HCMGC:1LD 315 HCMGC:1LE 315 HCMGC1-0 242, 315 HCMHDD:CO2D 309 HCMHDD:COZD 309 HCMHDD:COZX 309 HCMHDD:CSZD 309 HCMHDD:CSZX 309 HCMM8M-1 308 HCMM8M-3 308 HCMMEM:811D 308 HCMMEM:811E 308 HCMMEM:831D 308 HCMMEM:831E 308 HCMSIO-0 314 HCMSIO:0D 314 HCMSIO:0E 314 HCMTRAN2-0 262, 312 HCR166-0 100 HCR169-0 100 HCRA1024-0 308 HCSYSC-TK 243, 306

M2NTCP33-0 97, 107 M2NTCP63-0 98, 107 M2NTCP64-0 98, 108 M2PSCP65-0 98, 109

### н

HCBL01-0 318, 333 HCBL02-0 318, 333 HCFP1024-0 306 HCFP1024-0R 243, 244 HCMAC1-0 317

MAABDRVKB-0 341 MAAWLKB-0 341 MAAWI KR-F 341 MABRADOL-0 341 MABRADOL-E 341 MABRCOMP1-0E 340 MABRKEYKB-0 341 MABRKEYKB-E 341 MABRMECKB-0 341 MABRMECKB-0 341 MABRMECKB-E 341 MABRRT45KB-E 341 MACP32KB-0 341 MACP32KB-E 341 MACP70KB-0 341 MACP70KB-E 341 MAHWMINI-0 340 MAHWMINI-F 340 MAHWMINI-E 340 MAHWMINI-F 340 MAHWMULTI-D 340 MAHWMULTI-E 340 MAHWMULTI-I 340 MAHWMULTI-S 340 MAINT1-0 341 MAINT1-B 341 MAINT1-E 341 MAITGR-O 340 MAITGR-E 340 MALIDRVKB-O 341 MALIDRVKB-B 341 MAMAESTRO-E 340 MAMCIF-0 340 MAMCIF-F 340 MAMCO-0 340 MAMCO-E 340 MAMGRC-0 340 MAMGRC-E 340 MAMMSP-0 340 MAMNET-0 340 MAMNET-F 340 MAMNET-E 340 MAMPRV-0 340 MAMPRV-E 340 MAMSIO-0 340 MAMSIO-E 340 MAMSP-0 340 MAMSP-E 340 MAMSYS-0 340 MAMSYS-0 340 MAPOSI-0 340 MAPOSI-E 340 MAPROSYS-0 340 MAPROSYS-E 340 MAPROSYS-S 340 MAPROSYS-S 340 MAPSA2KB-0 341 MAPSA2KB-U 341 MAPSA2KB-E 341 MAPWP4KB-O 341 MAPWP4KB-E 341 MASPOIMG-O 340 MASPOS-C 340 MASPOS-E 340 MATERM2-0 340 MATERMINAL-F 340 MATERMINAL-E 340 MAXTGR31KB-E 341 MCA12A-0 60 MCA12B-0 61 MCA12C-0 61 MCBL01-0 53, 333 MCE16A-0 57 MCE16A-1 57 MCF16A-1 57 MCGE232-022 51 MCGE232-022M 51 MCGE31-0 51 MCMAEA-0 58 MCMAEB-0 59 MCMAEB-1 59 MCMZEA-0 78 MCMZEB-0 78 MCMZEB-0 78 MCPATA-0 73, 227 MCPEA4-1 63 MCPEA4-2 63 MCPEA8-1 64 MCPEA8-2 64 MCPIFA-2 72 MCPIFA-2 /2 MCPNC4-1 75 MCPRTA-0 69 MCPSA2-0 77 MCPT41-0 65 MCPT41-1 65 MCPTA2-21 66 MCPTA2-21 66 MCPTE6-0 67 MCPTE8-0 68 MCPZL2-0 76 MDA115-0 128 MDA163-0 120 MDE163-0 120 MDE163-1 120 MDPIF1-0 144 MDPIF1-1 144 MDR085-1 100 MP1345-1A 243 MP1830-1A 244 MPROVIT:1345ALD 243 MPROVIT:1345UD 243 MPROVIT:1345UE 243 MPROVIT:1830AX 244

M2R111-0 100 MA39DRVKB-0 341

PROVIT600-4 233 PROVIT800-1 242, 315

# MODEL NUMBER INBER R AUTOMATION SYSTEM





### S

SWMAN-0 243, 273, 307, 313
SWMCG-0 243, 315
SWMCO1-0 306
SWMCO3-0 306
SWMCO3-0 306
SWMCO3-0 306
SWMEN-0 262, 312
SWMEN-0 262, 312
SWMEN-0 262, 312
SWMSPN-CD 262, 312
SWMIPN-CD 262, 312
SWMIPN-SD 262, 312
SWMIPN-SD 262, 312
SWMIPN-SD 262, 312
SWMSP-SD 262, 312
SWMSP-SD 323
SWMSP-SD 323
SWMSP-SD 323
SWMSP-O 314
SWMSP-O 314
SWMSP-O 302
SWMSP-O 322
SWMSP-O 322
SWMSP-O 323
SWMSP-O 323
SWMSP-O 323
SWMSP-O 323
SWMSP-O 323
SWMSP-O 325
SWMSP-O 326
SWSP-O 3





# **RELEVANT CONVERSIONS**

AUTOMATION SYSTEM PRODUCT RANGE

### **RELEVANT CONVERSIONS**

### METRIC AND ENGLISH EQUIVALENTS

Units of measurement have been confusing people for centuries. In the last 25 years a lot of us have felt the effects of a major switch over from the imperial measurement system to the metric system. Some of the values in this catalog and in other documentation that you may have has only been written in metric. Follow the formulas and charts on this page to help with any conversion problems that you may have:

### TEMPERATURE

Below are two formulas to help in the conversion from Fahrenheit to Centigrade and visa versa:

$$\frac{5}{9}$$
 X (°F - 32) = °C

$$(\frac{9}{5} \text{ X }^{\circ}\text{C}) + 32 = {}^{\circ}\text{F}$$

Fahrenhei °F	t Metric
-40 -20 -10 -5 0 5 10 15 20 25 30 35 40 45 50 60 65	-40 -28.89 -23.33 -20.56 -17.78 -15.00 -12.22 -9.44 -6.67 -3.89 -1.11 1.67 4.44 7.22 10.00 12.78 15.56 18.33
70 75 80 85 90 95 100 105 110 115 120 125 130 135 140 145 150	21.11 23.89 26.67 29.44 32.22 35.00 37.78 40.56 43.33 46.11 48.89 51.67 54.44 57.22 60.00 62.78 65.56

Metric °C	Fahren °F
-40 -35 -30 -25 -20 -15 -10 -5 0 5 10 15 20 25 30 35 40 45 50 65 70 75 80 85 90	-40.00 -31.00 -22.00 -13.00 -4.00 5.00 14.00 32.00 41.00 59.00 68.00 77.00 86.00 95.00 113.00 122.00 131.00 149.00 158.00 167.00 185.00 176.00 185.00

### LINEAR MEASURE

s ters
ters
ers
nete ters
er
r
er
er

All B&R documentation includes the dimensions of all products, distances for cabling and cutout sizes in metric. To calculate the-se measurements into the equi-valent English units, use the conversions on the left:

### INDUSTRY STANDARDS

Quality standards play a large role in the development of B&R products. Standards that the products in this catalog and other B&R documentation conform to are always listed in the technical data sections. Over the years several different authorities have defined standards concerning the safety and reliability of electrical products and enclosures. B&R customers are mainly affected by the IEC and NEMA stan-dards. The standards used in manufacture and in our descrip-tions are usually IEC standards. IEC enclosure classification designations cannot be exactly equated with NEMA enclosure type numbers. The main areas of concern are listed below:

IEC	NEMA	Description
IP54	NEMA 12 1)	This standard means that the enclosure of the device protects the from dust and that it protects the contents from splashing water.
IP65	NEMA 4 1)	This standard means that the enclosure of the device is sealed to keep any dust out and that it protects the contents from jets of water from any direction.

<sup>&</sup>lt;sup>1)</sup> The descriptions in the table above refer to the IEC standards. The NEMA type numbers either meet or exceed these specifications.